



THE CITY OF SAN DIEGO PUBLIC UTILITIES DEPARTMENT
METROPOLITAN WASTEWATER BRANCH
FOOD ESTABLISHMENT WASTEWATER DISCHARGE (FEWD) PERMIT PROGRAM




FEWD PLAN CHECK POLICIES

FEWD Plan Checks require:

- * Fixture/Equipment List
- * Facility Floor Plan (should correspond with Fixture/Equipment List)
- * Proposed underground Plumbing Plan (showing fixtures routed to GRE)
- * Details of Grease Removal Equipment and sizing calculations

1. FEWD Plan Check identifies fixtures requiring grease removal equipment (GRE) and the required minimum size of GRE ONLY.
2. All installation/plumbing must be inspected/approved by the Development Services Department. The FEWD Plan Check List must be available on site during the plumbing inspection.
3. You must re-submit your plans to the FEWD Permit Program if any plumbing changes are made to the plans after the plan review date.
4. A sample box is required on all gravity grease interceptors.
5. Three (3) manholes are required on gravity grease interceptors 1500 gallons and over. Four (4) total with the sample box.
6. A minimum five (5) foot clearance to open manholes is required on all above ground gravity grease interceptors.
7. Hydromechanical Grease Interceptor (formerly grease trap) installation location to be determined by DEPARTMENT OF ENVIRONMENTAL HEALTH.
8. NO suspended Hydromechanical Grease Interceptors will be allowed.
9. If corrections are needed, ALL CADD drawings must be corrected and re-submitted. NO hand drawn corrections will be permitted.
10. Size of Grease Removal Equipment (GRE) installed should match or exceed size on Plan Check List.
11. Hydromechanical Grease Interceptor calculations should always be rounded up.
12. It is recommended to connect Vegetable Prep sinks to GRE if sink is located in a grease sensitive area.
13. For Retrofit/Requirement installations—Please call 858-654-4188 to schedule inspection with FEWD inspector prior to backfilling plumbing connections of the grease waste line.



Grease Trap



EFFECTIVE FEBRUARY 1, 2012

- GREASE REMOVAL EQUIPMENT WILL BE SIZED USING THE 2010 CA PLUMBING CODE.
- USE 1 MINUTE DRAIN PERIOD FOR HYDRO-MECHANICAL GREASE INTERCEPTORS

