

Deferred Capital Needs identified in 2009 Parsons Assessment (Council District 2)

Recommended-3-10 Yrs – Projects in this category include items that represent a sensible improvement to existing conditions. These items are not required for the most basic function of a facility. Maintenance needs in this category are not included in the proposed list of projects.

Rank	System Ranking	Facility_Type	FCI%	Facility_Name	System	Maint	District	Material	Distress	Correction	Estimated Repair Cost
1	1	Police Department	35.95%	Police Clubhouse Pistol Range	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Lighting/Branch Wiring	Damaged	Clean and Preventive Maintenance to Light Fixture	\$2,291
1	1	Police Department	35.95%	Police Clubhouse Pistol Range	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$1,988
1	1	Police Department	35.95%	Police Clubhouse Pistol Range	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,808
1	1	Police Department	35.95%	Police Clubhouse Pistol Range	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$30,013
1	1	Police Department	35.95%	Police Clubhouse Pistol Range	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$65,760
1	2	Police Department	35.95%	Police Clubhouse Pistol Range	Roof Construction	Critical / Immediate Need	District 4	Roof Construction	Damaged	Replace roof construction assembly	\$47,146
1	2	Police Department	35.95%	Police Clubhouse Pistol Range	Roof Construction	Critical / Immediate Need	District 4	Roof Construction	Damaged	Prepare Paint Wood Fascia and Eaves (SF)	\$9,875
1	3	Police Department	35.95%	Police Clubhouse Pistol Range	Exhaust Fans	Potentially Critical-12 months	District 4	Exhaust Ventilation System	Beyond Expected Life	Install or replace kitchen range exhaust hood syst	\$68,983
1	3	Police Department	35.95%	Police Clubhouse Pistol Range	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$5,677
1	4	Police Department	35.95%	Police Clubhouse Pistol Range	Rain Water Drainage	Critical / Immediate Need	District 4	Rain Water Drainage	Damaged	Replace Gutter; Aluminum up to 6" x LF	\$9,942
1	5	Police Department	35.95%	Police Clubhouse Pistol Range	Roof Coverings	Critical / Immediate Need	District 4	Roof Covering	Damaged	Replace Asphalt Shingle	\$50,332
1	6	Police Department	35.95%	Police Clubhouse Pistol Range	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$12,749
1	6	Police Department	35.95%	Police Clubhouse Pistol Range	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Expected Life	Replace Water Heater; Electric; up to 30 Gallons	\$4,177
1	7	Police Department	35.95%	Police Clubhouse Pistol Range	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$6,069
1	7	Police Department	35.95%	Police Clubhouse Pistol Range	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Wall Panelling	\$19,871
1	8	Police Department	35.95%	Police Clubhouse Pistol Range	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$48,467
1	8	Police Department	35.95%	Police Clubhouse Pistol Range	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$17,120
1	9	Police Department	35.95%	Police Clubhouse Pistol Range	Exterior Doors	Potentially Critical-12 months	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$27,252
1	10	Police Department	35.95%	Police Clubhouse Pistol Range	Exterior Windows	Potentially Critical-12 months	District 4	Exterior Windows	Damaged	Replace Wood Windows	\$43,974
1	11	Police Department	35.95%	Police Clubhouse Pistol Range	Water Supply	Potentially Critical-12 months	District 4	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$8,615
1	12	Police Department	35.95%	Police Clubhouse Pistol Range	Site Development	Necessary- 2-5 Yrs	District 4	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,831
1	13	Police Department	35.95%	Police Clubhouse Pistol Range	Exterior Walls	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$4,348
1	14	Police Department	35.95%	Police Clubhouse Pistol Range	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Int. Door; Solid; Painted; up to 3/0 x 7/0	\$5,302
1	15	Police Department	35.95%	Police Clubhouse Pistol Range	Electrical Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$9,491
1	16	Police Department	35.95%	Police Clubhouse Pistol Range	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$9,902
1	17	Police Department	35.95%	Police Clubhouse Pistol Range	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Inadequate	Replace Intercom/Paging System-50 stations	\$14,473
1	18	Police Department	35.95%	Police Clubhouse Pistol Range	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$15,913
1	19	Police Department	35.95%	Police Clubhouse Pistol Range	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Prepare and Paint Interior Ceiling	\$20,710
1	20	Police Department	35.95%	Police Clubhouse Pistol Range	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$48,159
1	21	Police Department	35.95%	Police Clubhouse Pistol Range	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$70,749
1	22	Police Department	35.95%	Police Clubhouse Pistol Range	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Inadequate	Install New Pkg. System; DX Cool; Gas Heat to 5T	\$71,477
1	23	Police Department	35.95%	Police Clubhouse Pistol Range	Parking Lots	Necessary- 2-5 Yrs	District 4	Roadways	Damaged	Replace Asphalt Road Surfaces	\$75,574
2	24	Fire Stations	27.68%	Fire Department Training Tower	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$19,097
2	24	Fire Stations	27.68%	Fire Department Training Tower	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,980
2	24	Fire Stations	27.68%	Fire Department Training Tower	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Receptacle, 20A 120V ASSY/Ea.	\$36,805
2	24	Fire Stations	27.68%	Fire Department Training Tower	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Incandescent Light Fixtures	\$28,766
2	24	Fire Stations	27.68%	Fire Department Training Tower	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Install or replace exterior lighting	\$935
2	25	Fire Stations	27.68%	Fire Department Training Tower	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Re-Attach Steel Balcony to Exterior Wall	\$5,974
2	25	Fire Stations	27.68%	Fire Department Training Tower	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Wall Sign; Painted Letters and Background	\$45,159
2	26	Fire Stations	27.68%	Fire Department Training Tower	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Missing	Install Circuit Breaker Knock-Out Blank; Plastic	\$299
2	27	Fire Stations	27.68%	Fire Department Training Tower	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
2	28	Fire Stations	27.68%	Fire Department Training Tower	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$9,177

2	29	Fire Stations	27.68%	Fire Department Training Tower	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Metal Door/Metal Frame	\$9,851
2	30	Fire Stations	27.68%	Fire Department Training Tower	Standpipes	Potentially Critical-12 months	District 6	Fire Supression	Damaged	Replace Stand Pipe System - 5 Outlets	\$12,069
2	31	Fire Stations	27.68%	Fire Department Training Tower	Roof Openings	Potentially Critical-12 months	District 6	Roof Openings	Damaged	Replace Roof Hatch; Metal; up to 12 SF	\$12,746
2	32	Fire Stations	27.68%	Fire Department Training Tower	Stair Construction	Potentially Critical-12 months	District 6	Stairs	Damaged	Repaint Handrails	\$14,051
2	33	Fire Stations	27.68%	Fire Department Training Tower	Communications and Security	Potentially Critical-12 months	District 6	Communications/Security	Damaged	Replace Intercom/Paging System-50 stations	\$27,919
2	34	Fire Stations	27.68%	Fire Department Training Tower	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Steel Windows	\$76,164
2	35	Fire Stations	27.68%	Fire Department Training Tower	Sprinklers	Potentially Critical-12 months	District 6	Fire Supression	Damaged	Install or replace wet fire suppression system	\$99,367
3	36	Life Guard Stations	20.62%	Garage - Northern	Exterior Walls	Critical / Immediate Need	District 1	Exterior Walls	Damaged	Replace Ext. Wall; Wood Fram; 1-Story	\$15,888
3	36	Life Guard Stations	20.62%	Garage - Northern	Exterior Walls	Critical / Immediate Need	District 1	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$6,719
3	36	Life Guard Stations	20.62%	Garage - Northern	Exterior Walls	Critical / Immediate Need	District 1	Exterior Walls	Damaged	Termite Inspection of Structure	\$13,136
3	36	Life Guard Stations	20.62%	Garage - Northern	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
3	37	Life Guard Stations	20.62%	Garage - Northern	Roof Construction	Critical / Immediate Need	District 1	Roof Construction	Damaged	Replace roof construction assembly	\$20,161
3	37	Life Guard Stations	20.62%	Garage - Northern	Roof Construction	Critical / Immediate Need	District 1	Roof Construction	Damaged	Prepare Paint Wood Fascia and Eaves (SF)	\$4,467
3	38	Life Guard Stations	20.62%	Garage - Northern	Exterior Doors	Critical / Immediate Need	District 1	Exterior Doors	Failing	Repair/Replace Overhead Door Safety Switch	\$2,592
3	38	Life Guard Stations	20.62%	Garage - Northern	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$3,321
3	38	Life Guard Stations	20.62%	Garage - Northern	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Wood Doors	\$5,094
3	39	Life Guard Stations	20.62%	Garage - Northern	Roof Coverings	Critical / Immediate Need	District 1	Roof Covering	Damaged	Replace Asphalt Shingle	\$10,037
3	40	Life Guard Stations	20.62%	Garage - Northern	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,651
3	41	Life Guard Stations	20.62%	Garage - Northern	Parking Lots	Necessary- 2-5 Yrs	District 1	Roadways	Damaged	Replace Asphalt Road Surfaces	\$15,134
4	42	Block House	18.69%	Blockhouse - Point Loma	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install Junction Box and Cover; 4' x 4" Steel	\$159
4	42	Block House	18.69%	Blockhouse - Point Loma	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,005
4	42	Block House	18.69%	Blockhouse - Point Loma	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Flourescent Fixture S.F.	\$13,348
4	43	Block House	18.69%	Blockhouse - Point Loma	Landscaping	Critical / Immediate Need	District 2	Landscaping	Failing	Re-grade Site	\$8,651
4	44	Block House	18.69%	Blockhouse - Point Loma	Site Development	Necessary- 2-5 Yrs	District 2	Site Development	Damaged	Prepare and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$676
4	45	Block House	18.69%	Blockhouse - Point Loma	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
4	46	Block House	18.69%	Blockhouse - Point Loma	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 2	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
4	47	Block House	18.69%	Blockhouse - Point Loma	Exterior Walls	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
4	48	Block House	18.69%	Blockhouse - Point Loma	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$4,247
4	49	Block House	18.69%	Blockhouse - Point Loma	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Failing	Prepare Paint Wood Fascia and Eaves (SF)	\$5,331
4	50	Block House	18.69%	Blockhouse - Point Loma	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
4	51	Block House	18.69%	Blockhouse - Point Loma	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$23,126
5	52	Fire Stations	16.70%	Fire Station #26	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Replace Carpet	\$29,402
5	52	Fire Stations	16.70%	Fire Station #26	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Epoxy floor	\$6,627
5	52	Fire Stations	16.70%	Fire Station #26	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$8,351
5	52	Fire Stations	16.70%	Fire Station #26	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Seal stone floor	\$18,250
5	53	Fire Stations	16.70%	Fire Station #26	Wall Finishes	Critical / Immediate Need	District 4	Wall Finishes	Damaged	Replace Plaster / Lath Interior Wall	\$4,930
5	53	Fire Stations	16.70%	Fire Station #26	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Ceramic Tile	\$1,055
5	53	Fire Stations	16.70%	Fire Station #26	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$13,512
5	54	Fire Stations	16.70%	Fire Station #26	Site Development	Necessary- 2-5 Yrs	District 4	Site Development	Damaged	Replace Pipe Bolalard; Steel; Painted	\$1,027
5	54	Fire Stations	16.70%	Fire Station #26	Site Development	Necessary- 2-5 Yrs	District 4	Site Development	Damaged	Prepare and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$676
5	54	Fire Stations	16.70%	Fire Station #26	Site Development	Necessary- 2-5 Yrs	District 4	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$877
5	55	Fire Stations	16.70%	Fire Station #26	Exterior Walls	Necessary- 2-5 Yrs	District 4	Stairs	Damaged	Repaint Handrails	\$10,117
5	55	Fire Stations	16.70%	Fire Station #26	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Clean and Re-Point Masonry Wall Joints	\$1,505
5	55	Fire Stations	16.70%	Fire Station #26	Exterior Walls	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
5	56	Fire Stations	16.70%	Fire Station #26	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$24,994
5	56	Fire Stations	16.70%	Fire Station #26	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,866
5	56	Fire Stations	16.70%	Fire Station #26	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$62,486
5	57	Fire Stations	16.70%	Fire Station #26	Exterior Windows	Potentially Critical-12 months	District 4	Exterior Windows	Damaged	Replace Thermal/Dual Pane Glass/Lite to 6 SF	\$648
5	57	Fire Stations	16.70%	Fire Station #26	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Inadequate	Replace Aluminium Windows	\$21,784
5	58	Fire Stations	16.70%	Fire Station #26	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 4	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$7,790
5	58	Fire Stations	16.70%	Fire Station #26	Exhaust Ventilation Systems Other than Vehicle	Necessary- 2-5 Yrs	District 4	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$15,580
5	59	Fire Stations	16.70%	Fire Station #26	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$11,996
5	59	Fire Stations	16.70%	Fire Station #26	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 1X4 Surface Flourescent Fixture S.F.	\$133,423
5	60	Fire Stations	16.70%	Fire Station #26	Communications and Security	Critical / Immediate Need	District 4	Communications/Security	Damaged	Replace or Install Ceiling Smoke Detector	\$1,469

5	61	Fire Stations	16.70%	Fire Station #26	Parking Lots	Necessary- 2-5 Yrs	District 4	Roadways	Damaged	Replace Asphalt Road Surfaces	\$113,645
5	61	Fire Stations	16.70%	Fire Station #26	Parking Lots	Necessary- 2-5 Yrs	District 4	Roadways	Damaged	Replace Concrete Roadway	\$11,550
5	62	Fire Stations	16.70%	Fire Station #26	Landscaping	Potentially Critical-12 months	District 4	Landscaping	Inadequate	Re-grade Site	\$2,208
5	63	Fire Stations	16.70%	Fire Station #26	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$17,995
5	64	Fire Stations	16.70%	Fire Station #26	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$27,777
5	65	Fire Stations	16.70%	Fire Station #26	Water Supply	Necessary- 2-5 Yrs	District 4	WATER Supply	Beyond Expected Life	Replace domestic water service	\$4,737
5	66	Fire Stations	16.70%	Fire Station #26	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Expected Life	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$13,765
5	67	Fire Stations	16.70%	Fire Station #26	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$21,673
5	68	Fire Stations	16.70%	Fire Station #26	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 4	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$26,438
5	69	Fire Stations	16.70%	Fire Station #26	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$28,265
5	70	Fire Stations	16.70%	Fire Station #26	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$35,806
5	71	Fire Stations	16.70%	Fire Station #26	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$36,787
5	72	Fire Stations	16.70%	Fire Station #26	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$93,736
5	73	Fire Stations	16.70%	Fire Station #26	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$167,874
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Seal stone floor	\$12,615
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$25,533
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Ceramic Tile	\$3,127
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Ceramic Tile	\$7,920
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$9,718
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Missing	Replace rubber/vinyl cove base	\$221
6	74	Fire Stations	15.70%	Fire Station #28	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Seal stone floor	\$14,579
6	75	Fire Stations	15.70%	Fire Station #28	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
6	75	Fire Stations	15.70%	Fire Station #28	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
6	75	Fire Stations	15.70%	Fire Station #28	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
6	75	Fire Stations	15.70%	Fire Station #28	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$12,140
6	75	Fire Stations	15.70%	Fire Station #28	Exterior Walls	Potentially Critical-12 months	District 6	Stairs	Damaged	Repaint Handrails	\$3,934
6	75	Fire Stations	15.70%	Fire Station #28	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,852
6	76	Fire Stations	15.70%	Fire Station #28	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
6	76	Fire Stations	15.70%	Fire Station #28	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$11,590
6	76	Fire Stations	15.70%	Fire Station #28	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$9,177
6	76	Fire Stations	15.70%	Fire Station #28	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$24,432
6	76	Fire Stations	15.70%	Fire Station #28	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$22,942
6	76	Fire Stations	15.70%	Fire Station #28	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$4,588
6	77	Fire Stations	15.70%	Fire Station #28	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Replace Fluor. Ltg. Fix. 4'; 2 Lamp Vanity	\$527
6	77	Fire Stations	15.70%	Fire Station #28	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace 2X4 Flourescent Fixture - S.F.	\$25,470
6	77	Fire Stations	15.70%	Fire Station #28	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,385
6	77	Fire Stations	15.70%	Fire Station #28	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,886
6	77	Fire Stations	15.70%	Fire Station #28	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,615
6	78	Fire Stations	15.70%	Fire Station #28	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$18,812
6	78	Fire Stations	15.70%	Fire Station #28	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$11,647
6	78	Fire Stations	15.70%	Fire Station #28	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$10,821
6	78	Fire Stations	15.70%	Fire Station #28	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$3,934
6	78	Fire Stations	15.70%	Fire Station #28	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$6,752
6	79	Fire Stations	15.70%	Fire Station #28	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Counter Top; Solid Surface	\$1,364
6	79	Fire Stations	15.70%	Fire Station #28	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Toilet Partition	\$1,980
6	79	Fire Stations	15.70%	Fire Station #28	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Toilet Partition	\$7,920
6	79	Fire Stations	15.70%	Fire Station #28	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Refinish Base / Wall Cabinets - SF	\$2,674
6	80	Fire Stations	15.70%	Fire Station #28	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$5,866
6	80	Fire Stations	15.70%	Fire Station #28	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$5,718
6	80	Fire Stations	15.70%	Fire Station #28	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$29,160
6	80	Fire Stations	15.70%	Fire Station #28	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$6,704
6	81	Fire Stations	15.70%	Fire Station #28	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install New Pkg. System; DX Cool; Gas Heat to 5T	\$27,699

6	81	Fire Stations	15.70%	Fire Station #28	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Beyond Expected Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$24,568
6	81	Fire Stations	15.70%	Fire Station #28	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$2,424
6	81	Fire Stations	15.70%	Fire Station #28	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$8,829
6	82	Fire Stations	15.70%	Fire Station #28	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$11,881
6	82	Fire Stations	15.70%	Fire Station #28	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$4,699
6	82	Fire Stations	15.70%	Fire Station #28	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$19,725
6	83	Fire Stations	15.70%	Fire Station #28	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$50,217
6	83	Fire Stations	15.70%	Fire Station #28	Parking Lots	Potentially Critical-12 months	District 6	Roadways	Damaged	Replace Concrete Roadway	\$61,877
6	83	Fire Stations	15.70%	Fire Station #28	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Failing	Repaint or restripe Parking Lot/	\$160
6	84	Fire Stations	15.70%	Fire Station #28	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Inadequate	Replace Aluminium Windows	\$34,232
6	84	Fire Stations	15.70%	Fire Station #28	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Inadequate	Replace Aluminium Windows	\$6,225
6	85	Fire Stations	15.70%	Fire Station #28	Site Development	Potentially Critical-12 months	District 6	Roof Covering	Failing	Repaint Metal Roof - Epoxy; Prime Coat; Seal	\$9,870
6	85	Fire Stations	15.70%	Fire Station #28	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,352
6	86	Fire Stations	15.70%	Fire Station #28	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Replace Exh. Sys. Intake Grille; Metal	\$385
6	86	Fire Stations	15.70%	Fire Station #28	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Beyond Expected Life	Install or replace kitchen range exhaust hood syst	\$16,119
6	87	Fire Stations	15.70%	Fire Station #28	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$264
6	87	Fire Stations	15.70%	Fire Station #28	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$23,126
6	88	Fire Stations	15.70%	Fire Station #28	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Failing	Prepare and Paint Concrete Eaves and Fascia	\$25,420
6	88	Fire Stations	15.70%	Fire Station #28	Roof Construction	Potentially Critical-12 months	District 6	Roof Openings	Damaged	Replace Roof Skylights upto 70 SF	\$7,218
6	89	Fire Stations	15.70%	Fire Station #28	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$25,248
6	89	Fire Stations	15.70%	Fire Station #28	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$113,770
6	90	Fire Stations	15.70%	Fire Station #28	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$12,926
6	91	Fire Stations	15.70%	Fire Station #28	Vehicle Exhaust System	Potentially Critical-12 months	District 6	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$13,220
6	92	Fire Stations	15.70%	Fire Station #28	Vehicle Exhaust Systems	Potentially Critical-12 months	District 6	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$26,438
7	93	Fire Stations	13.29%	Fire Station #32	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,708
7	93	Fire Stations	13.29%	Fire Station #32	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,070
7	93	Fire Stations	13.29%	Fire Station #32	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$22,381
7	93	Fire Stations	13.29%	Fire Station #32	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$11,647
7	93	Fire Stations	13.29%	Fire Station #32	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$7,295
7	94	Fire Stations	13.29%	Fire Station #32	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,770
7	94	Fire Stations	13.29%	Fire Station #32	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture Ea.	\$29,952
7	94	Fire Stations	13.29%	Fire Station #32	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
7	94	Fire Stations	13.29%	Fire Station #32	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard - 200A	\$9,163
7	95	Fire Stations	13.29%	Fire Station #32	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$995
7	95	Fire Stations	13.29%	Fire Station #32	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,759
7	95	Fire Stations	13.29%	Fire Station #32	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$3,834
7	96	Fire Stations	13.29%	Fire Station #32	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Ceramic Tile	\$6,212
7	96	Fire Stations	13.29%	Fire Station #32	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$12,619
7	96	Fire Stations	13.29%	Fire Station #32	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Ceramic Tile	\$4,767
7	97	Fire Stations	13.29%	Fire Station #32	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,154
7	97	Fire Stations	13.29%	Fire Station #32	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$10,619
7	97	Fire Stations	13.29%	Fire Station #32	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,771
7	98	Fire Stations	13.29%	Fire Station #32	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$1,280
7	98	Fire Stations	13.29%	Fire Station #32	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$2,664
7	99	Fire Stations	13.29%	Fire Station #32	Site Development	Necessary- 2-5 Yrs	District 4	Fencing	Damaged	Replace concrete block fencing	\$6,953
7	99	Fire Stations	13.29%	Fire Station #32	Site Development	Necessary- 2-5 Yrs	District 4	Fencing	Damaged	Replace Rolling Gate Wheels	\$288
7	100	Fire Stations	13.29%	Fire Station #32	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Lockers	\$32,126
7	100	Fire Stations	13.29%	Fire Station #32	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
7	101	Fire Stations	13.29%	Fire Station #32	Partitions	Potentially Critical-12 months	District 4	Partitions	Damaged	Repair/Re-point Concrete Block Wall	\$1,800
7	102	Fire Stations	13.29%	Fire Station #32	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$130
7	103	Fire Stations	13.29%	Fire Station #32	Electrical Service/Distribution	Potentially Critical-12 months	District 4	Electrical Service/Distribution	Inadequate	Replace electric service entrance -200 Amp	\$7,709
7	104	Fire Stations	13.29%	Fire Station #32	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$10,906
7	105	Fire Stations	13.29%	Fire Station #32	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 4	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$15,580

7	106	Fire Stations	13.29%	Fire Station #32	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$18,454
7	107	Fire Stations	13.29%	Fire Station #32	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$22,138
7	108	Fire Stations	13.29%	Fire Station #32	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 4	Vehicle Exhaust System	Inadequate	Replace vehicle exhaust system-2 bay	\$25,744
7	109	Fire Stations	13.29%	Fire Station #32	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$26,241
7	110	Fire Stations	13.29%	Fire Station #32	Emergency Generators	Necessary- 2-5 Yrs	District 4	Emergency Generators	Beyond Useful Life	Replace diesel emergency generator	\$46,058
7	111	Fire Stations	13.29%	Fire Station #32	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Beyond Useful Life	Replace Intercom/Paging System-50 stations	\$126,904
7	112	Fire Stations	13.29%	Fire Station #32	Electrical Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
8	113	Life Guard Stations	13.05%	Life Guard Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,070
8	113	Life Guard Stations	13.05%	Life Guard Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$12,198
8	113	Life Guard Stations	13.05%	Life Guard Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$6,076
8	113	Life Guard Stations	13.05%	Life Guard Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Shower Tray	\$2,695
8	113	Life Guard Stations	13.05%	Life Guard Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$52,221
8	114	Life Guard Stations	13.05%	Life Guard Headquarters	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,281
8	114	Life Guard Stations	13.05%	Life Guard Headquarters	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$79,462
8	114	Life Guard Stations	13.05%	Life Guard Headquarters	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard -400A	\$10,967
8	115	Life Guard Stations	13.05%	Life Guard Headquarters	Domestic Water Distribution	Potentially Critical-12 months	District 2	Water Heaters	Missing	Install or replace insulation on hot water piping	\$776
8	116	Life Guard Stations	13.05%	Life Guard Headquarters	Site Development	Necessary- 2-5 Yrs	District 2	Other Site Structures	Damaged	Repaint pipe bollards	\$592
8	116	Life Guard Stations	13.05%	Life Guard Headquarters	Site Development	Necessary- 2-5 Yrs	District 2	Fencing	Damaged	Replace chain link fencing	\$4,368
8	117	Life Guard Stations	13.05%	Life Guard Headquarters	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$207,647
8	117	Life Guard Stations	13.05%	Life Guard Headquarters	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Termite Inspection of Roof structure	\$62,018
8	118	Life Guard Stations	13.05%	Life Guard Headquarters	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$6,213
8	119	Life Guard Stations	13.05%	Life Guard Headquarters	Roadways	Potentially Critical-12 months	District 2	Roadways	Damaged	Repair and fill cracks and spalding.	\$10,747
8	120	Life Guard Stations	13.05%	Life Guard Headquarters	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$15,580
8	121	Life Guard Stations	13.05%	Life Guard Headquarters	Storm Sewer	Necessary- 2-5 Yrs	District 2	Rain Water Drainage	Damaged	Replace Area Drain and Piping	\$3,742
8	122	Life Guard Stations	13.05%	Life Guard Headquarters	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$9,342
8	123	Life Guard Stations	13.05%	Life Guard Headquarters	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Toilet Partition	\$12,994
8	124	Life Guard Stations	13.05%	Life Guard Headquarters	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$19,364
8	125	Life Guard Stations	13.05%	Life Guard Headquarters	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$25,109
8	126	Life Guard Stations	13.05%	Life Guard Headquarters	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$50,967
9	127	Fire Stations	12.95%	Fire Station #34	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$12,774
9	127	Fire Stations	12.95%	Fire Station #34	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$662
9	127	Fire Stations	12.95%	Fire Station #34	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Ceramic Tile	\$4,430
9	127	Fire Stations	12.95%	Fire Station #34	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$35,435
9	127	Fire Stations	12.95%	Fire Station #34	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,219
9	127	Fire Stations	12.95%	Fire Station #34	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$5,165
9	128	Fire Stations	12.95%	Fire Station #34	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Replace Ceramic Tile	\$759
9	128	Fire Stations	12.95%	Fire Station #34	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Replace Ceramic Tile	\$5,055
9	128	Fire Stations	12.95%	Fire Station #34	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$7,766
9	129	Fire Stations	12.95%	Fire Station #34	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,805
9	129	Fire Stations	12.95%	Fire Station #34	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$762
9	129	Fire Stations	12.95%	Fire Station #34	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$16,068
9	130	Fire Stations	12.95%	Fire Station #34	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$16,047
9	130	Fire Stations	12.95%	Fire Station #34	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,632
9	130	Fire Stations	12.95%	Fire Station #34	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,910
9	131	Fire Stations	12.95%	Fire Station #34	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,376
9	131	Fire Stations	12.95%	Fire Station #34	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$101,590
9	131	Fire Stations	12.95%	Fire Station #34	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard - 200A	\$7,499
9	132	Fire Stations	12.95%	Fire Station #34	Partitions	Necessary- 2-5 Yrs	District 7	Partitions	Damaged	Repair Drywall Partitions	\$625
9	132	Fire Stations	12.95%	Fire Station #34	Partitions	Necessary- 2-5 Yrs	District 7	Partitions	Damaged	Repair/Patch Concrete Wall	\$3,306
9	133	Fire Stations	12.95%	Fire Station #34	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,913
9	133	Fire Stations	12.95%	Fire Station #34	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Steel Doors	\$4,475
9	134	Fire Stations	12.95%	Fire Station #34	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Damaged	Replace Lockers	\$8,380
9	134	Fire Stations	12.95%	Fire Station #34	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
9	135	Fire Stations	12.95%	Fire Station #34	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace Aluminium Windows	\$13,885
9	135	Fire Stations	12.95%	Fire Station #34	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace mesh window screens	\$2,091
9	136	Fire Stations	12.95%	Fire Station #34	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$19,364
9	136	Fire Stations	12.95%	Fire Station #34	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Shower Door	\$981

9	137	Fire Stations	12.95%	Fire Station #34	Domestic Water Distribution	Potentially Critical-12 months	District 7	Water Heaters	Missing	Install or replace insulation on hot water piping	\$776
9	138	Fire Stations	12.95%	Fire Station #34	Terminal & Package Units	Potentially Critical-12 months	District 7	Terminal and Package Units	Failing	Replace Ductwork Pkg Sys/Ton	\$23,193
9	139	Fire Stations	12.95%	Fire Station #34	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$31,159
9	140	Fire Stations	12.95%	Fire Station #34	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Replace CMU Block Wall	\$2,209
9	141	Fire Stations	12.95%	Fire Station #34	Landscaping	Necessary- 2-5 Yrs	District 7	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
9	142	Fire Stations	12.95%	Fire Station #34	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$6,790
9	143	Fire Stations	12.95%	Fire Station #34	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$22,802
9	144	Fire Stations	12.95%	Fire Station #34	Communications and Security	Necessary- 2-5 Yrs	District 7	Communications/Security	Inadequate	Replace Intercom/Paging System-50 stations	\$49,541
10	145	Fire Stations	12.46%	Fire Station #06	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$962
10	145	Fire Stations	12.46%	Fire Station #06	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$12,136
10	145	Fire Stations	12.46%	Fire Station #06	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$26,049
10	145	Fire Stations	12.46%	Fire Station #06	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$9,377
10	146	Fire Stations	12.46%	Fire Station #06	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$9,234
10	146	Fire Stations	12.46%	Fire Station #06	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,836
10	146	Fire Stations	12.46%	Fire Station #06	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Inadequate	Replace Concrete Sidewalks	\$4,901
10	146	Fire Stations	12.46%	Fire Station #06	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,677
10	147	Fire Stations	12.46%	Fire Station #06	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Bathroom Accessories	\$925
10	147	Fire Stations	12.46%	Fire Station #06	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
10	147	Fire Stations	12.46%	Fire Station #06	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Bathroom Accessories	\$925
10	148	Fire Stations	12.46%	Fire Station #06	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Abandoned	Remove Abandoned Water Heater - Up to 120 Gal.	\$1,896
10	148	Fire Stations	12.46%	Fire Station #06	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Useful Life	Replace Copper Water Pipe <2 in	\$26,532
10	148	Fire Stations	12.46%	Fire Station #06	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Abandoned	Remove abandoned equipment/system	\$4,809
10	149	Fire Stations	12.46%	Fire Station #06	Floor Finishes	Potentially Critical-12 months	District 8	Floor Finishes	Damaged	Replace VCT	\$798
10	149	Fire Stations	12.46%	Fire Station #06	Floor Finishes	Potentially Critical-12 months	District 8	Floor Finishes	Damaged	Replace Carpet	\$14,733
10	150	Fire Stations	12.46%	Fire Station #06	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Failing	Clean, Sanitize and Balance Air Distribution SYS	\$962
10	150	Fire Stations	12.46%	Fire Station #06	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Failing	Replace Ductwork Pkg Sys/Ton	\$14,887
10	151	Fire Stations	12.46%	Fire Station #06	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$3,290
10	152	Fire Stations	12.46%	Fire Station #06	Ventilation and Exhaust	Necessary- 2-5 Yrs	District 8	Distribution Systems	Failing	Replace Roof Mounted Exhaust Fan	\$3,337
10	153	Fire Stations	12.46%	Fire Station #06	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$5,436
10	154	Fire Stations	12.46%	Fire Station #06	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$6,111
10	155	Fire Stations	12.46%	Fire Station #06	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Stucco Wall	\$11,722
10	156	Fire Stations	12.46%	Fire Station #06	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$12,377
10	157	Fire Stations	12.46%	Fire Station #06	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$13,549
10	158	Fire Stations	12.46%	Fire Station #06	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$15,913
10	159	Fire Stations	12.46%	Fire Station #06	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Useful Life	Replace Wood Doors	\$16,817
10	160	Fire Stations	12.46%	Fire Station #06	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$23,078
11	161	Block House	10.43%	Blockhouse Mt. Woodson #000036	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,367
11	161	Block House	10.43%	Blockhouse Mt. Woodson #000036	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Inadequate	Replace 1X4 Surface Flourescent Fixture S.F.	\$14,974
11	162	Block House	10.43%	Blockhouse Mt. Woodson #000036	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$6,627
11	162	Block House	10.43%	Blockhouse Mt. Woodson #000036	Exterior Walls	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
11	163	Block House	10.43%	Blockhouse Mt. Woodson #000036	Landscaping	Critical / Immediate Need	District 5	Landscaping	Failing	Re-grade Site	\$5,364
11	164	Block House	10.43%	Blockhouse Mt. Woodson #000036	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Abandoned	Remove Window AC Unit; Close Opening	\$680
11	165	Block House	10.43%	Blockhouse Mt. Woodson #000036	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
11	166	Block House	10.43%	Blockhouse Mt. Woodson #000036	Exhaust Fans	Necessary- 2-5 Yrs	District 5	Ventilation and Exhaust	Abandoned	Remove Exhaust Fan; up to 2000 CFM; Close Opening	\$1,315

11	167	Block House	10.43%	Blockhouse Mt. Woodson #000036	Site Development	Necessary- 2-5 Yrs	District 5	Site Development	Damaged	Replace Chain Link Fence; up to 8'(H) 3-Strnd; RZR	\$1,785
11	168	Block House	10.43%	Blockhouse Mt. Woodson #000036	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 5	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$2,013
11	169	Block House	10.43%	Blockhouse Mt. Woodson #000036	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 5	Fuel Distribution	Abandoned	Removed Fuel Tank; Above Ground up to 550 Gal.	\$2,447
11	170	Block House	10.43%	Blockhouse Mt. Woodson #000036	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$9,940
12	171	Fire Stations	10.03%	Fire Station #25	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Clean and Preventive Maintenance to Light Fixture	\$1,021
12	171	Fire Stations	10.03%	Fire Station #25	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Incandescent Light Fixtures	\$384
12	171	Fire Stations	10.03%	Fire Station #25	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Light Switch Cover 1-Gang	\$629
12	171	Fire Stations	10.03%	Fire Station #25	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,585
12	172	Fire Stations	10.03%	Fire Station #25	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Foundation Wall Vent Cover; Mtl up to 2 SF	\$837
12	172	Fire Stations	10.03%	Fire Station #25	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Prepare and Paint Exterior Metal Trim	\$732
12	172	Fire Stations	10.03%	Fire Station #25	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
12	173	Fire Stations	10.03%	Fire Station #25	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Replace HVAC Condensing Unit Pad; Level Unit	\$720
12	173	Fire Stations	10.03%	Fire Station #25	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$10,756
12	174	Fire Stations	10.03%	Fire Station #25	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace mesh window screens	\$859
12	174	Fire Stations	10.03%	Fire Station #25	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Inadequate	Replace Aluminium Windows	\$20,747
12	175	Fire Stations	10.03%	Fire Station #25	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Failing	Repaint or restripe Parking Lot/	\$1,408
12	175	Fire Stations	10.03%	Fire Station #25	Parking Lots	Potentially Critical-12 months	District 6	Roadways	Damaged	Replace Concrete Roadway	\$24,751
12	176	Fire Stations	10.03%	Fire Station #25	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$20,674
12	176	Fire Stations	10.03%	Fire Station #25	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Seal stone floor	\$12,246
12	177	Fire Stations	10.03%	Fire Station #25	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Wood Doors	\$20,376
12	177	Fire Stations	10.03%	Fire Station #25	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$23,181
12	178	Fire Stations	10.03%	Fire Station #25	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Inadequate	Replace Fixed Casework Base Cabinets w/S.S. Top	\$28,088
12	178	Fire Stations	10.03%	Fire Station #25	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Inadequate	Replace Fixed Casework Base / Wall Cabinets	\$21,323
12	179	Fire Stations	10.03%	Fire Station #25	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$451
12	180	Fire Stations	10.03%	Fire Station #25	Communications and Security	Potentially Critical-12 months	District 6	Communications/Security	Damaged	Replace Door Bell Push Button; Exterior Wall Mtd.	\$627
12	181	Fire Stations	10.03%	Fire Station #25	Rain Water Drainage	Potentially Critical-12 months	District 6	Rain Water Drainage	Failing	Clean Out Roof Drain Receptor	\$1,141
12	182	Fire Stations	10.03%	Fire Station #25	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$2,578
12	183	Fire Stations	10.03%	Fire Station #25	Water Supply	Potentially Critical-12 months	District 6	Water Supply	Beyond Expected Life	Replace domestic water service	\$3,433
12	184	Fire Stations	10.03%	Fire Station #25	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,645
12	185	Fire Stations	10.03%	Fire Station #25	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$10,055
12	186	Fire Stations	10.03%	Fire Station #25	Partitions	Potentially Critical-12 months	District 6	Partitions	Damaged	Replace Plaster Partition/Wood Stud Backup	\$12,145
12	187	Fire Stations	10.03%	Fire Station #25	Vehicle Exhaust Systems	Potentially Critical-12 months	District 6	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$19,056
12	188	Fire Stations	10.03%	Fire Station #25	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$21,313
12	189	Fire Stations	10.03%	Fire Station #25	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$23,509
12	190	Fire Stations	10.03%	Fire Station #25	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$28,950
12	191	Fire Stations	10.03%	Fire Station #25	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$100,724
13	192	Block House	9.91%	Blockhouse - Mt. Soledad	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Failing	Repaint Metal Fence	\$930
13	192	Block House	9.91%	Blockhouse - Mt. Soledad	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Replace Chain Link Fence; up to 8'(H) 3-Strnd; RZR	\$1,785
13	192	Block House	9.91%	Blockhouse - Mt. Soledad	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Replace Chain Link Fence; up to 8'(H) 3-Strnd; RZR	\$2,083
13	192	Block House	9.91%	Blockhouse - Mt. Soledad	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Replace Barbed Wire Strands; up to 3-Strands	\$8,140
13	193	Block House	9.91%	Blockhouse - Mt. Soledad	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Repaint Fascia	\$759
13	193	Block House	9.91%	Blockhouse - Mt. Soledad	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
13	194	Block House	9.91%	Blockhouse - Mt. Soledad	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,731
13	195	Block House	9.91%	Blockhouse - Mt. Soledad	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Weather Strip on Flashing; 3/4"	\$648
13	196	Block House	9.91%	Blockhouse - Mt. Soledad	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$653
13	197	Block House	9.91%	Blockhouse - Mt. Soledad	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 1	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
14	199	Fire Stations	9.80%	Fire Station #14	Site Lighting	Potentially Critical-12 months	District 3	Site Lighting	Failing	Investigate and Repair Site Ltg Fix; Pole Mtd.	\$2,125
14	199	Fire Stations	9.80%	Fire Station #14	Site Lighting	Necessary- 2-5 Yrs	District 3	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$2,478
14	199	Fire Stations	9.80%	Fire Station #14	Site Lighting	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
14	199	Fire Stations	9.80%	Fire Station #14	Site Lighting	Necessary- 2-5 Yrs	District 3	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$17,309
14	200	Fire Stations	9.80%	Fire Station #14	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Failing	Investigage and Test Roof For Leaks	\$1,366

14	200	Fire Stations	9.80%	Fire Station #14	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Abandoned	Remove Debris from Roof	\$1,646
14	200	Fire Stations	9.80%	Fire Station #14	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$70,335
14	201	Fire Stations	9.80%	Fire Station #14	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$21,962
14	201	Fire Stations	9.80%	Fire Station #14	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$24,568
14	201	Fire Stations	9.80%	Fire Station #14	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace 4T Split System A/C Comp	\$14,040
14	202	Fire Stations	9.80%	Fire Station #14	Site Development	Necessary- 2-5 Yrs	District 3	Site Development	Damaged	Replace Surface Drain Piping; PVC	\$504
14	202	Fire Stations	9.80%	Fire Station #14	Site Development	Necessary- 2-5 Yrs	District 3	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,803
14	202	Fire Stations	9.80%	Fire Station #14	Site Development	Necessary- 2-5 Yrs	District 3	Fencing	Failing	Repaint Metal Fence	\$5,113
14	203	Fire Stations	9.80%	Fire Station #14	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Failing	Repair or restripe Parking Lot/	\$3,037
14	203	Fire Stations	9.80%	Fire Station #14	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Replace expansion joint filler	\$6,594
14	203	Fire Stations	9.80%	Fire Station #14	Parking Lots	Necessary- 2-5 Yrs	District 3	Roadways	Damaged	Replace Concrete Roadway	\$10,725
14	204	Fire Stations	9.80%	Fire Station #14	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Exterior stucco/plaster wall paint single story	\$39,956
14	204	Fire Stations	9.80%	Fire Station #14	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
14	204	Fire Stations	9.80%	Fire Station #14	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Seal and Repaint Ext. Parapet Wall Cap and Coping	\$5,004
14	205	Fire Stations	9.80%	Fire Station #14	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$73,295
14	205	Fire Stations	9.80%	Fire Station #14	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$17,606
14	205	Fire Stations	9.80%	Fire Station #14	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$10,188
14	206	Fire Stations	9.80%	Fire Station #14	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,321
14	206	Fire Stations	9.80%	Fire Station #14	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Replace Light Switch Cover 1-Gang	\$314
14	207	Fire Stations	9.80%	Fire Station #14	Vehicle Exhaust System	Potentially Critical-12 months	District 3	Vehicle Exhaust System	Missing	Replace Vehicle Exhaust System Flexible Hose	\$1,172
14	207	Fire Stations	9.80%	Fire Station #14	Vehicle Exhaust System	Necessary- 2-5 Yrs	District 3	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$31,973
14	208	Fire Stations	9.80%	Fire Station #14	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Replace Carpet	\$38,696
14	208	Fire Stations	9.80%	Fire Station #14	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Seal stone floor	\$24,675
14	209	Fire Stations	9.80%	Fire Station #14	Rain Water Drainage	Necessary- 2-5 Yrs	District 3	Rain Water Drainage	Failing	Prepare and Paint Metal Gutters and Downspouts	\$2,611
14	210	Fire Stations	9.80%	Fire Station #14	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Abandoned	Remove abandoned equipment/system	\$6,731
14	211	Fire Stations	9.80%	Fire Station #14	Roof Openings	Necessary- 2-5 Yrs	District 3	Roof Openings	Failing	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$6,964
14	212	Fire Stations	9.80%	Fire Station #14	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Failing	Perform landscaping maintenance	\$11,106
14	213	Fire Stations	9.80%	Fire Station #14	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Failing	Prepare Paint Wood Fascia and Eaves (SF)	\$14,025
14	214	Fire Stations	9.80%	Fire Station #14	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$21,786
14	215	Fire Stations	9.80%	Fire Station #14	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$46,796
14	216	Fire Stations	9.80%	Fire Station #14	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$55,418
14	217	Fire Stations	9.80%	Fire Station #14	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Inadequate	Replace Aluminium Windows	\$96,472
15	218	Block House	9.62%	Blockhouse - San Ysidro	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,005
15	218	Block House	9.62%	Blockhouse - San Ysidro	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Damaged	Replace Incandescent Light Fixtures	\$384
15	218	Block House	9.62%	Blockhouse - San Ysidro	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Flourescent Fixture S.F.	\$34,227
15	219	Block House	9.62%	Blockhouse - San Ysidro	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
15	219	Block House	9.62%	Blockhouse - San Ysidro	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$12,425
15	220	Block House	9.62%	Blockhouse - San Ysidro	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Damaged	Install or replace thermal insulation on HVAC pipi	\$198
15	221	Block House	9.62%	Blockhouse - San Ysidro	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,117
15	222	Block House	9.62%	Blockhouse - San Ysidro	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$1,126
15	223	Block House	9.62%	Blockhouse - San Ysidro	Site Development	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,352
15	224	Block House	9.62%	Blockhouse - San Ysidro	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Repaint exterior metal doors	\$1,956
15	225	Block House	9.62%	Blockhouse - San Ysidro	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 8	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
15	226	Block House	9.62%	Blockhouse - San Ysidro	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,161
15	227	Block House	9.62%	Blockhouse - San Ysidro	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Failing	Prepare Paint Wood Fascia and Eaves (SF)	\$3,842
15	228	Block House	9.62%	Blockhouse - San Ysidro	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$10,251
15	229	Block House	9.62%	Blockhouse - San Ysidro	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$99,192
16	231	Fire Stations	9.48%	Fire Station #18	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$5,732
16	231	Fire Stations	9.48%	Fire Station #18	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$9,418
16	231	Fire Stations	9.48%	Fire Station #18	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$23,668
16	231	Fire Stations	9.48%	Fire Station #18	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,679
16	231	Fire Stations	9.48%	Fire Station #18	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$37,301
16	231	Fire Stations	9.48%	Fire Station #18	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$7,360
16	232	Fire Stations	9.48%	Fire Station #18	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,366
16	232	Fire Stations	9.48%	Fire Station #18	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$95,787
16	232	Fire Stations	9.48%	Fire Station #18	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456

16	233	Fire Stations	9.48%	Fire Station #18	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$369
16	233	Fire Stations	9.48%	Fire Station #18	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
16	234	Fire Stations	9.48%	Fire Station #18	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,200
16	234	Fire Stations	9.48%	Fire Station #18	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,697
16	235	Fire Stations	9.48%	Fire Station #18	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Shower Door	\$981
16	235	Fire Stations	9.48%	Fire Station #18	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$20,440
16	236	Fire Stations	9.48%	Fire Station #18	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$28,150
16	236	Fire Stations	9.48%	Fire Station #18	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Ceramic Tile	\$3,756
16	237	Fire Stations	9.48%	Fire Station #18	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Repair or replace laminate	\$1,897
16	237	Fire Stations	9.48%	Fire Station #18	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$35,844
16	238	Fire Stations	9.48%	Fire Station #18	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare Paint Exterior Walls up to 3 Floors	\$17,034
16	238	Fire Stations	9.48%	Fire Station #18	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$168,853
16	239	Fire Stations	9.48%	Fire Station #18	Site Lighting	Potentially Critical-12 months	District 3	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$4,814
16	240	Fire Stations	9.48%	Fire Station #18	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$6,366
16	241	Fire Stations	9.48%	Fire Station #18	Stair Construction	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Replace Rubber Treads, Risers and Landing	\$985
16	242	Fire Stations	9.48%	Fire Station #18	Site Development	Necessary- 2-5 Yrs	District 3	Other Site Structures	Damaged	Repaint pipe bollards	\$1,481
16	243	Fire Stations	9.48%	Fire Station #18	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
16	244	Fire Stations	9.48%	Fire Station #18	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Water Heaters	Abandoned	Remove or replace water heater	\$4,809
16	245	Fire Stations	9.48%	Fire Station #18	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,539
16	246	Fire Stations	9.48%	Fire Station #18	Partitions	Necessary- 2-5 Yrs	District 3	Partitions	Damaged	Repair Drywall Partitions	\$12,933
16	247	Fire Stations	9.48%	Fire Station #18	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$24,925
16	248	Fire Stations	9.48%	Fire Station #18	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$26,721
16	249	Fire Stations	9.48%	Fire Station #18	Vehicle Exhaust System	Necessary- 2-5 Yrs	District 3	Vehicle Exhaust System	Failing	Replace vehicle exhaust system-2 bay	\$38,617
16	250	Fire Stations	9.48%	Fire Station #18	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$45,848
17	251	Fire Stations	9.23%	Fire Station #23	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$22,381
17	251	Fire Stations	9.23%	Fire Station #23	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Ceramic Tile	\$5,862
17	251	Fire Stations	9.23%	Fire Station #23	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,762
17	251	Fire Stations	9.23%	Fire Station #23	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$19,536
17	251	Fire Stations	9.23%	Fire Station #23	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$7,899
17	252	Fire Stations	9.23%	Fire Station #23	Fittings	Critical / Immediate Need	District 6	Fittings	Damaged	Reattach and Secure Bath Room Accessory to Wall	\$1,499
17	252	Fire Stations	9.23%	Fire Station #23	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
17	252	Fire Stations	9.23%	Fire Station #23	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Lockers	\$22,348
17	253	Fire Stations	9.23%	Fire Station #23	Site Development	Potentially Critical-12 months	District 6	Fencing	Damaged	Replace chain link fencing	\$29,816
17	253	Fire Stations	9.23%	Fire Station #23	Site Development	Potentially Critical-12 months	District 6	Fencing	Damaged	Replace concrete block fencing	\$2,424
17	253	Fire Stations	9.23%	Fire Station #23	Site Development	Potentially Critical-12 months	District 6	Other Site Structures	Damaged	Repaint pipe bollards	\$1,035
17	254	Fire Stations	9.23%	Fire Station #23	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Roofing Eave	\$3,489
17	254	Fire Stations	9.23%	Fire Station #23	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Asphalt Shingle	\$1,899
17	255	Fire Stations	9.23%	Fire Station #23	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,154
17	255	Fire Stations	9.23%	Fire Station #23	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$13,543
17	256	Fire Stations	9.23%	Fire Station #23	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$11,842
17	256	Fire Stations	9.23%	Fire Station #23	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Replace Ceramic Tile	\$6,499
17	257	Fire Stations	9.23%	Fire Station #23	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$15,950
17	257	Fire Stations	9.23%	Fire Station #23	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$9,687
17	258	Fire Stations	9.23%	Fire Station #23	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$11,935
17	258	Fire Stations	9.23%	Fire Station #23	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$15,613
17	259	Fire Stations	9.23%	Fire Station #23	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,868
17	259	Fire Stations	9.23%	Fire Station #23	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$58,205
17	260	Fire Stations	9.23%	Fire Station #23	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
17	261	Fire Stations	9.23%	Fire Station #23	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,754
17	262	Fire Stations	9.23%	Fire Station #23	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$3,868
17	263	Fire Stations	9.23%	Fire Station #23	Landscaping	Potentially Critical-12 months	District 6	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
17	264	Fire Stations	9.23%	Fire Station #23	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$15,580
17	265	Fire Stations	9.23%	Fire Station #23	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$20,914
17	266	Fire Stations	9.23%	Fire Station #23	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$34,987
17	267	Fire Stations	9.23%	Fire Station #23	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$75,237
18	268	Fire Stations	9.19%	Fire Station #09 - La Jolla	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,161
18	268	Fire Stations	9.19%	Fire Station #09 - La Jolla	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067
18	268	Fire Stations	9.19%	Fire Station #09 - La Jolla	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$93,862
18	268	Fire Stations	9.19%	Fire Station #09 - La Jolla	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$43,732

18	269	Fire Stations	9.19%	Fire Station #09 - La Jolla	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Damaged	Repaint Metal Fence	\$1,023
18	269	Fire Stations	9.19%	Fire Station #09 - La Jolla	Site Development	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Replace Stucco Wall	\$16,049
18	269	Fire Stations	9.19%	Fire Station #09 - La Jolla	Site Development	Necessary- 2-5 Yrs	District 1	Other Site Structures	Damaged	Repaint pipe bollards	\$592
18	270	Fire Stations	9.19%	Fire Station #09 - La Jolla	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$4,161
18	270	Fire Stations	9.19%	Fire Station #09 - La Jolla	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Ductwork	Damaged	replace ductwork dampers registers and insulatio	\$65,463
18	271	Fire Stations	9.19%	Fire Station #09 - La Jolla	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Toilet Partition	\$2,406
18	271	Fire Stations	9.19%	Fire Station #09 - La Jolla	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
18	272	Fire Stations	9.19%	Fire Station #09 - La Jolla	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$10,667
18	272	Fire Stations	9.19%	Fire Station #09 - La Jolla	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$9,075
18	273	Fire Stations	9.19%	Fire Station #09 - La Jolla	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Beyond Useful Life	Repaint drywall/plaster ceiling	\$1,227
18	273	Fire Stations	9.19%	Fire Station #09 - La Jolla	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$19,059
18	274	Fire Stations	9.19%	Fire Station #09 - La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$41,713
18	274	Fire Stations	9.19%	Fire Station #09 - La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$2,620
18	275	Fire Stations	9.19%	Fire Station #09 - La Jolla	Electrical Service/Distribution	Critical / Immediate Need	District 1	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
18	276	Fire Stations	9.19%	Fire Station #09 - La Jolla	Slab on Grade	Potentially Critical-12 months	District 1	Roadways	Damaged	Repair and fill cracks and spalding.	\$5,875
18	277	Fire Stations	9.19%	Fire Station #09 - La Jolla	Roadways	Potentially Critical-12 months	District 1	Roadways	Damaged	Repair and fill cracks and spalding.	\$11,465
18	278	Fire Stations	9.19%	Fire Station #09 - La Jolla	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Domestic Water Distribution	Inadequate	Repair or replace domestic water piping	\$3,643
18	279	Fire Stations	9.19%	Fire Station #09 - La Jolla	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Slurry seal asphalt	\$3,789
18	280	Fire Stations	9.19%	Fire Station #09 - La Jolla	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Exterior stucco/plaster wall paint single story	\$5,848
18	281	Fire Stations	9.19%	Fire Station #09 - La Jolla	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Steel Doors	\$9,177
18	282	Fire Stations	9.19%	Fire Station #09 - La Jolla	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$19,876
18	283	Fire Stations	9.19%	Fire Station #09 - La Jolla	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$27,365
19	285	Fire Stations	9.00%	Fire Station #33	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,039
19	285	Fire Stations	9.00%	Fire Station #33	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$28,319
19	285	Fire Stations	9.00%	Fire Station #33	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$21,101
19	285	Fire Stations	9.00%	Fire Station #33	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$60,781
19	286	Fire Stations	9.00%	Fire Station #33	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace Ceramic Tile	\$11,724
19	286	Fire Stations	9.00%	Fire Station #33	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace VCT	\$2,815
19	286	Fire Stations	9.00%	Fire Station #33	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace Carpet	\$63,039
19	287	Fire Stations	9.00%	Fire Station #33	Parking Lots	Potentially Critical-12 months	District 5	Roadways	Damaged	Repair and fill cracks and spalding.	\$2,150
19	287	Fire Stations	9.00%	Fire Station #33	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Failing	Replace Parking Lot - Asphalt	\$83,084
19	288	Fire Stations	9.00%	Fire Station #33	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$5,452
19	288	Fire Stations	9.00%	Fire Station #33	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$12,215
19	289	Fire Stations	9.00%	Fire Station #33	Site Development	Potentially Critical-12 months	District 5	Fencing	Inadequate	Replace Rolling Gate Wheels	\$1,731
19	290	Fire Stations	9.00%	Fire Station #33	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Failing	Clean, Sanitize and Balance Air Distribution SYS	\$4,039
19	291	Fire Stations	9.00%	Fire Station #33	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Damaged	Install new exhaust system and controls	\$4,488
19	292	Fire Stations	9.00%	Fire Station #33	Site Lighting	Potentially Critical-12 months	District 5	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$9,012
19	293	Fire Stations	9.00%	Fire Station #33	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
19	294	Fire Stations	9.00%	Fire Station #33	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,800
19	295	Fire Stations	9.00%	Fire Station #33	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,468
19	296	Fire Stations	9.00%	Fire Station #33	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$9,033
19	297	Fire Stations	9.00%	Fire Station #33	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 5	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$10,658
19	298	Fire Stations	9.00%	Fire Station #33	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$26,522
19	299	Fire Stations	9.00%	Fire Station #33	Exterior Windows	Necessary- 2-5 Yrs	District 5	Exterior Windows	Beyond Expected Life	Replace Aluminium Windows	\$27,769
19	300	Fire Stations	9.00%	Fire Station #33	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 5	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$28,438
19	301	Fire Stations	9.00%	Fire Station #33	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$39,834
20	302	Fire Stations	8.87%	Fire Station #07	Floor Finishes	Potentially Critical-12 months	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$5,468
20	302	Fire Stations	8.87%	Fire Station #07	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Terrazzo	\$1,298
20	302	Fire Stations	8.87%	Fire Station #07	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$303
20	302	Fire Stations	8.87%	Fire Station #07	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$10,817
20	302	Fire Stations	8.87%	Fire Station #07	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$1,385
20	303	Fire Stations	8.87%	Fire Station #07	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,658
20	303	Fire Stations	8.87%	Fire Station #07	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067
20	303	Fire Stations	8.87%	Fire Station #07	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$85,136
20	303	Fire Stations	8.87%	Fire Station #07	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$39,667
20	304	Fire Stations	8.87%	Fire Station #07	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Inadequate	Replace Aluminium Doors	\$13,730

20	304	Fire Stations	8.87%	Fire Station #07	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$6,571
20	304	Fire Stations	8.87%	Fire Station #07	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Replace Wood Doors	\$1,870
20	304	Fire Stations	8.87%	Fire Station #07	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$6,571
20	305	Fire Stations	8.87%	Fire Station #07	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Replace Ceramic Tile	\$72
20	305	Fire Stations	8.87%	Fire Station #07	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$14,722
20	305	Fire Stations	8.87%	Fire Station #07	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Replace Ceramic Tile	\$361
20	306	Fire Stations	8.87%	Fire Station #07	Exterior Walls	Potentially Critical-12 months	District 8	Exterior Walls	Damaged	Replace Wood Fascia	\$454
20	306	Fire Stations	8.87%	Fire Station #07	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Replace CMU Block Wall	\$1,325
20	307	Fire Stations	8.87%	Fire Station #07	Slab on Grade	Critical / Immediate Need	District 8	Floor Construction	Missing	Install Safety Climb Floor Access Door	\$10,526
20	308	Fire Stations	8.87%	Fire Station #07	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Inadequate	Replace Concrete Sidewalks	\$4,916
20	308	Fire Stations	8.87%	Fire Station #07	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,444
20	309	Fire Stations	8.87%	Fire Station #07	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Lockers	\$9,777
20	309	Fire Stations	8.87%	Fire Station #07	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
20	310	Fire Stations	8.87%	Fire Station #07	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Failing	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$34,343
20	310	Fire Stations	8.87%	Fire Station #07	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Failing	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$34,240
20	311	Fire Stations	8.87%	Fire Station #07	Site Development	Potentially Critical-12 months	District 8	Fencing	Damaged	Replace Rolling Gate Wheels	\$577
20	312	Fire Stations	8.87%	Fire Station #07	Parking Lots	Potentially Critical-12 months	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$16,617
20	313	Fire Stations	8.87%	Fire Station #07	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,759
20	314	Fire Stations	8.87%	Fire Station #07	Ventilation and Exhaust	Necessary- 2-5 Yrs	District 8	Distribution Systems	Failing	Replace Roof Mounted Exhaust Fan	\$12,123
20	315	Fire Stations	8.87%	Fire Station #07	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$31,617
20	316	Fire Stations	8.87%	Fire Station #07	Communications and Security	Necessary- 2-5 Yrs	District 8	Communications/Security	Inadequate	Replace Intercom/Paging System-50 stations	\$36,697
20	317	Fire Stations	8.87%	Fire Station #07	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Useful Life	Replace Copper Water Pipe <2 in	\$53,065
21	318	Police Department	8.59%	Northern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,304
21	318	Police Department	8.59%	Northern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Wood Doors	\$5,094
21	318	Police Department	8.59%	Northern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$36,647
21	319	Police Department	8.59%	Northern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
21	319	Police Department	8.59%	Northern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$33,288
21	319	Police Department	8.59%	Northern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Prepare and Paint Exterior Concrete Wall Surface	\$9,190
21	320	Police Department	8.59%	Northern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,951
21	320	Police Department	8.59%	Northern Garage	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Damaged	Replace Receptacle, 20A 120V ASSY/Ea.	\$706
21	321	Police Department	8.59%	Northern Garage	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Epoxy floor	\$14,062
21	321	Police Department	8.59%	Northern Garage	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Seal stone floor	\$9,677
21	322	Police Department	8.59%	Northern Garage	Roof Coverings	Potentially Critical-12 months	District 1	Roof Covering	Damaged	Reapply reflective asphaltic coating to roof	\$1,558
21	323	Police Department	8.59%	Northern Garage	Rain Water Drainage	Necessary- 2-5 Yrs	District 1	Rain Water Drainage	Damaged	Prepare and Paint Metal Gutters and Downspouts	\$609
21	324	Police Department	8.59%	Northern Garage	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,117
21	325	Police Department	8.59%	Northern Garage	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,254
21	326	Police Department	8.59%	Northern Garage	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Beyond Expected Life	Replace Aluminium Windows	\$2,594
21	327	Police Department	8.59%	Northern Garage	Vehicular Equipment	Necessary- 2-5 Yrs	District 1	Equipment	Beyond Expected Life	Replace Air Compressor =< 5 HP	\$7,277
21	328	Police Department	8.59%	Northern Garage	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$10,600
21	329	Police Department	8.59%	Northern Garage	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$13,912
22	330	Fire Stations	8.50%	Fire Station #35	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$23,078
22	330	Fire Stations	8.50%	Fire Station #35	Terminal & Package Units	Potentially Critical-12 months	District 1	Terminal and Package Units	Damaged	Install or Replace thermal insulation on refrig.	\$833
22	330	Fire Stations	8.50%	Fire Station #35	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace Gas/Electric Pkg. Unit (s)	\$29,643
22	331	Fire Stations	8.50%	Fire Station #35	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Seal stone floor	\$28,542
22	331	Fire Stations	8.50%	Fire Station #35	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace Sheet Vinyl Floor Covering	\$27,598
22	331	Fire Stations	8.50%	Fire Station #35	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace Carpet	\$40,269
22	332	Fire Stations	8.50%	Fire Station #35	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Beyond Expected Life	Install or replace kitchen range exhaust hood syst	\$16,119
22	332	Fire Stations	8.50%	Fire Station #35	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Missing	Replace Exh. Sys. Intake Grille; Metal	\$1,247
22	333	Fire Stations	8.50%	Fire Station #35	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,692
22	333	Fire Stations	8.50%	Fire Station #35	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Flourescent Fixture S.F.	\$60,069
22	334	Fire Stations	8.50%	Fire Station #35	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Failing	Repaint Metal Fence	\$3,719
22	334	Fire Stations	8.50%	Fire Station #35	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$902

22	335	Fire Stations	8.50%	Fire Station #35	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$9,320
22	335	Fire Stations	8.50%	Fire Station #35	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$36,730
22	336	Fire Stations	8.50%	Fire Station #35	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
22	337	Fire Stations	8.50%	Fire Station #35	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Damaged	Replace Electric Water Cooler Wall Mount	\$4,104
22	338	Fire Stations	8.50%	Fire Station #35	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Damaged	Repair Concrete Fascia	\$6,374
22	339	Fire Stations	8.50%	Fire Station #35	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$13,694
22	340	Fire Stations	8.50%	Fire Station #35	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$19,534
22	341	Fire Stations	8.50%	Fire Station #35	Roadways	Necessary- 2-5 Yrs	District 1	Roadways	Damaged	Replace Concrete Roadway	\$29,701
22	342	Fire Stations	8.50%	Fire Station #35	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 1	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$39,657
22	343	Fire Stations	8.50%	Fire Station #35	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$62,116
22	344	Fire Stations	8.50%	Fire Station #35	Emergency Generators	Necessary- 2-5 Yrs	District 1	Emergency Generators	Beyond Expected Life	Replace 100KW D/Emer Gen Set w/ATS	\$79,390
22	345	Fire Stations	8.50%	Fire Station #35	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$116,905
23	346	Fire Stations	8.42%	Fire Station #30	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,302
23	346	Fire Stations	8.42%	Fire Station #30	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$319
23	346	Fire Stations	8.42%	Fire Station #30	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$3,586
23	346	Fire Stations	8.42%	Fire Station #30	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$14,920
23	346	Fire Stations	8.42%	Fire Station #30	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$3,260
23	346	Fire Stations	8.42%	Fire Station #30	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$5,468
23	347	Fire Stations	8.42%	Fire Station #30	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
23	347	Fire Stations	8.42%	Fire Station #30	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Lockers	\$14,666
23	347	Fire Stations	8.42%	Fire Station #30	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Bathroom Accessories	\$369
23	347	Fire Stations	8.42%	Fire Station #30	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Failing	Replace Toilet Partition	\$6,730
23	348	Fire Stations	8.42%	Fire Station #30	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Useful Life	Replace Wall Hung Urinal	\$1,602
23	348	Fire Stations	8.42%	Fire Station #30	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Stall Shower	\$17,383
23	348	Fire Stations	8.42%	Fire Station #30	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Vanity Sink, Marble Top	\$8,111
23	348	Fire Stations	8.42%	Fire Station #30	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Tankless Type Toilet	\$6,481
23	349	Fire Stations	8.42%	Fire Station #30	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Abandoned	Replace Residential Gas Furnace 120MBtu	\$903
23	349	Fire Stations	8.42%	Fire Station #30	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Damaged	Replace Ductwork Pkg Sys/Ton	\$16,310
23	349	Fire Stations	8.42%	Fire Station #30	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Distribution Systems	Failing	Replace Ceiling Mount Exhaust Fan	\$1,665
23	349	Fire Stations	8.42%	Fire Station #30	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Damaged	Replace Ductwork Pkg Sys/Ton	\$16,310
23	350	Fire Stations	8.42%	Fire Station #30	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$412
23	350	Fire Stations	8.42%	Fire Station #30	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,801
23	350	Fire Stations	8.42%	Fire Station #30	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 2X4 Fluorescent Fixture - S.F.	\$72,242
23	351	Fire Stations	8.42%	Fire Station #30	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$4,853
23	351	Fire Stations	8.42%	Fire Station #30	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Replace Ceramic Tile	\$144
23	351	Fire Stations	8.42%	Fire Station #30	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Replace Ceramic Tile	\$1,444
23	352	Fire Stations	8.42%	Fire Station #30	Site Development	Potentially Critical-12 months	District 8	Fencing	Damaged	Replace Rolling Gate Wheels	\$577
23	352	Fire Stations	8.42%	Fire Station #30	Site Development	Necessary- 2-5 Yrs	District 8	Other Site Structures	Damaged	Repaint pipe bollards	\$148
23	353	Fire Stations	8.42%	Fire Station #30	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Beyond Useful Life	Replace Steel Windows	\$2,404
23	353	Fire Stations	8.42%	Fire Station #30	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Beyond Useful Life	Replace Steel Windows	\$1,342
23	354	Fire Stations	8.42%	Fire Station #30	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$12,514
23	354	Fire Stations	8.42%	Fire Station #30	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$5,677
23	355	Fire Stations	8.42%	Fire Station #30	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$10,493
23	355	Fire Stations	8.42%	Fire Station #30	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$19,369
23	356	Fire Stations	8.42%	Fire Station #30	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
23	357	Fire Stations	8.42%	Fire Station #30	Site Lighting	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
23	358	Fire Stations	8.42%	Fire Station #30	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$10,561
23	359	Fire Stations	8.42%	Fire Station #30	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$12,112
23	360	Fire Stations	8.42%	Fire Station #30	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Steel Doors	\$17,711
23	361	Fire Stations	8.42%	Fire Station #30	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare _ Paint Exterior Walls up to 3 Floors	\$19,363
23	362	Fire Stations	8.42%	Fire Station #30	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace sheet metal flashing	\$22,317
23	363	Fire Stations	8.42%	Fire Station #30	Vehicle Exhaust System	Necessary- 2-5 Yrs	District 8	Vehicle Exhaust System	Failing	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$33,648
23	364	Fire Stations	8.42%	Fire Station #30	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$34,635
23	365	Fire Stations	8.42%	Fire Station #30	Communications and Security	Necessary- 2-5 Yrs	District 8	Communications/Security	Inadequate	Replace Intercom/Paging System-50 stations	\$36,697
23	366	Fire Stations	8.42%	Fire Station #30	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Useful Life	Replace Copper Water Pipe <2 in	\$42,452

24	367	Fire Stations	8.19%	Fire Station #39	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,303
24	367	Fire Stations	8.19%	Fire Station #39	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
24	367	Fire Stations	8.19%	Fire Station #39	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Damaged	Replace 2X4 Fluorescent Fixture Ea.	\$12,837
24	367	Fire Stations	8.19%	Fire Station #39	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard - 200A	\$7,499
24	368	Fire Stations	8.19%	Fire Station #39	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,287
24	368	Fire Stations	8.19%	Fire Station #39	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$3,645
24	368	Fire Stations	8.19%	Fire Station #39	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$13,801
24	369	Fire Stations	8.19%	Fire Station #39	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,418
24	369	Fire Stations	8.19%	Fire Station #39	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$32,678
24	370	Fire Stations	8.19%	Fire Station #39	Domestic Water Distribution	Potentially Critical-12 months	District 7	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
24	371	Fire Stations	8.19%	Fire Station #39	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$7,790
24	372	Fire Stations	8.19%	Fire Station #39	Site Lighting	Potentially Critical-12 months	District 7	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$36,047
24	373	Fire Stations	8.19%	Fire Station #39	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,753
24	374	Fire Stations	8.19%	Fire Station #39	Partitions	Necessary- 2-5 Yrs	District 7	Partitions	Damaged	Repair Drywall Partitions	\$1,890
24	375	Fire Stations	8.19%	Fire Station #39	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$2,329
24	376	Fire Stations	8.19%	Fire Station #39	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
24	377	Fire Stations	8.19%	Fire Station #39	Landscaping	Necessary- 2-5 Yrs	District 7	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
24	378	Fire Stations	8.19%	Fire Station #39	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Repair/Reseal Roof Penetration	\$4,809
24	379	Fire Stations	8.19%	Fire Station #39	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$7,570
24	380	Fire Stations	8.19%	Fire Station #39	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Slurry seal asphalt	\$10,959
24	381	Fire Stations	8.19%	Fire Station #39	Site Development	Necessary- 2-5 Yrs	District 7	Fencing	Damaged	Replace chain link fencing	\$18,750
24	382	Fire Stations	8.19%	Fire Station #39	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$23,667
24	383	Fire Stations	8.19%	Fire Station #39	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Steel Doors	\$26,565
25	384	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$6,676
25	384	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$17,508
25	384	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$1,656
25	384	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$7,079
25	384	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Ceramic Tile	\$32,568
25	384	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$22,754
25	385	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
25	385	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Bathroom Accessories	\$18,519
25	385	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Lockers	\$21,649
25	386	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,232
25	386	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$93,775
25	387	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Domestic Water Distribution	Potentially Critical-12 months	District 2	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
25	388	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$15,913
25	388	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$11,260
25	389	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$14,074
25	389	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$17,629
25	390	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,800
25	390	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$29,689
25	391	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Replace Ceramic Tile	\$13,722
25	391	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$23,297
25	392	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$35,677
25	392	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Shower Door	\$1,569
25	393	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$3,895
25	394	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Terminal & Package Units	Potentially Critical-12 months	District 2	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$6,232
25	395	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Site Lighting	Potentially Critical-12 months	District 2	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$18,023
25	396	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Partitions	Necessary- 2-5 Yrs	District 2	Partitions	Damaged	Repair Drywall Partitions	\$690
25	397	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Stair Construction	Necessary- 2-5 Yrs	District 2	Stairs	Damaged	Replace Rubber Treads, Risers and Landing	\$1,810
25	398	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Roof Openings	Necessary- 2-5 Yrs	District 2	Roof Openings	Inadequate	Replace Roof Access Door (through wall)	\$2,249
25	399	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$10,739
25	400	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Site Development	Necessary- 2-5 Yrs	District 2	Fencing	Damaged	Replace chain link fencing	\$13,949
25	401	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Vehicle Exhaust System	Necessary- 2-5 Yrs	District 2	Vehicle Exhaust System	Inadequate	Replace vehicle exhaust system-2 bay	\$25,744
25	402	Fire Stations	7.93%	Fire Station 21 (Pacific Beach	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$31,954
26	403	Block House	7.08%	Blockhouse - Wild Animal Park	Exterior Walls	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
26	403	Block House	7.08%	Blockhouse - Wild Animal Park	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Failing	Repaint Fascia	\$759

26	404	Block House	7.08%	Blockhouse - Wild Animal Park	Electrical Service/Distribution	Potentially Critical-12 months	District 5	Electrical Service/Distribution	Damaged	Rework and Terminate Overhead Svc Connections	\$962
26	405	Block House	7.08%	Blockhouse - Wild Animal Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$693
26	406	Block House	7.08%	Blockhouse - Wild Animal Park	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$653
26	407	Block House	7.08%	Blockhouse - Wild Animal Park	Site Development	Necessary- 2-5 Yrs	District 5	Site Development	Damaged	Replace Chain Link Fence; up to 8'(H) 3-Strnd; RZR	\$2,975
27	408	Fire Stations	7.07%	Fire Station 20	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$9,721
27	408	Fire Stations	7.07%	Fire Station 20	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Ceramic Tile	\$13,027
27	408	Fire Stations	7.07%	Fire Station 20	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$2,269
27	408	Fire Stations	7.07%	Fire Station 20	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$27,043
27	408	Fire Stations	7.07%	Fire Station 20	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,219
27	408	Fire Stations	7.07%	Fire Station 20	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$24,045
27	409	Fire Stations	7.07%	Fire Station 20	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,328
27	409	Fire Stations	7.07%	Fire Station 20	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,914
27	409	Fire Stations	7.07%	Fire Station 20	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Inadequate	Replace 2X4 Fluorescent Fixture - S.F.	\$28,943
27	410	Fire Stations	7.07%	Fire Station 20	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Bathroom Accessories	\$408
27	410	Fire Stations	7.07%	Fire Station 20	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Lockers	\$2,096
27	410	Fire Stations	7.07%	Fire Station 20	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
27	411	Fire Stations	7.07%	Fire Station 20	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Replace Ceramic Tile	\$5,777
27	411	Fire Stations	7.07%	Fire Station 20	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$5,824
27	412	Fire Stations	7.07%	Fire Station 20	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Gutters and downspouts	\$3,133
27	412	Fire Stations	7.07%	Fire Station 20	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace sheet metal flashing	\$12,017
27	413	Fire Stations	7.07%	Fire Station 20	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$30,881
27	413	Fire Stations	7.07%	Fire Station 20	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$30,077
27	414	Fire Stations	7.07%	Fire Station 20	Domestic Water Distribution	Potentially Critical-12 months	District 2	Water Heaters	Missing	Install or replace insulation on hot water piping	\$776
27	415	Fire Stations	7.07%	Fire Station 20	Roadways	Potentially Critical-12 months	District 2	Roadways	Damaged	Repair and fill cracks and spalding.	\$3,009
27	416	Fire Stations	7.07%	Fire Station 20	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$7,790
27	417	Fire Stations	7.07%	Fire Station 20	Site Development	Necessary- 2-5 Yrs	District 2	Other Site Structures	Damaged	Repaint pipe bollards	\$1,185
27	418	Fire Stations	7.07%	Fire Station 20	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,314
27	419	Fire Stations	7.07%	Fire Station 20	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Failing	Replace Plumbing Fixtures	\$4,746
27	420	Fire Stations	7.07%	Fire Station 20	Landscaping	Necessary- 2-5 Yrs	District 2	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
27	421	Fire Stations	7.07%	Fire Station 20	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$8,083
27	422	Fire Stations	7.07%	Fire Station 20	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$9,231
27	423	Fire Stations	7.07%	Fire Station 20	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$17,711
27	424	Fire Stations	7.07%	Fire Station 20	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$17,941
27	425	Fire Stations	7.07%	Fire Station 20	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$69,106
27	426	Fire Stations	7.07%	Fire Station 20	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$78,468
27	427	Fire Stations	7.07%	Fire Station 20	Rain Water Drainage	Necessary- 2-5 Yrs	District 2	Rain Water Drainage	Failing	Replace or Install Roof Drain - 6 in	\$4,843
28	430	Fire Stations	6.97%	Fire Station 15	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$5,286
28	430	Fire Stations	6.97%	Fire Station 15	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Ceramic Tile	\$834
28	430	Fire Stations	6.97%	Fire Station 15	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$3,324
28	430	Fire Stations	6.97%	Fire Station 15	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$20,515
28	430	Fire Stations	6.97%	Fire Station 15	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,302
28	437	Fire Stations	6.97%	Fire Station 15	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Lockers	\$9,079
28	437	Fire Stations	6.97%	Fire Station 15	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
28	438	Fire Stations	6.97%	Fire Station 15	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$11,935
28	438	Fire Stations	6.97%	Fire Station 15	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$2,286
28	439	Fire Stations	6.97%	Fire Station 15	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,976
28	442	Fire Stations	6.97%	Fire Station 15	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$11,684
28	444	Fire Stations	6.97%	Fire Station 15	Roadways	Potentially Critical-12 months	District 2	Roadways	Damaged	Repair and fill cracks and spalding.	\$13,758
28	449	Fire Stations	6.97%	Fire Station 15	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace Brick Veneer/Wood Stud	\$1,040
28	450	Fire Stations	6.97%	Fire Station 15	Landscaping	Necessary- 2-5 Yrs	District 2	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
28	451	Fire Stations	6.97%	Fire Station 15	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,104
28	452	Fire Stations	6.97%	Fire Station 15	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,712
28	453	Fire Stations	6.97%	Fire Station 15	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Aluminium Windows	\$7,343
28	454	Fire Stations	6.97%	Fire Station 15	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$13,395
28	455	Fire Stations	6.97%	Fire Station 15	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$13,615
28	456	Fire Stations	6.97%	Fire Station 15	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$18,427
28	457	Fire Stations	6.97%	Fire Station 15	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$28,232

28	459	Fire Stations	6.97%	Fire Station 15	Terminal & Package Units	Potentially Critical-12 months	District 2	Terminal and Package Units	Inadequate	Install or replace DX split ductless system	\$38,839
29	429	Fire Stations	6.97%	Fire Station #27	Exterior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Remove/ Restore Historic Art Glass Door Transoms	\$544
29	429	Fire Stations	6.97%	Fire Station #27	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$4,637
29	429	Fire Stations	6.97%	Fire Station #27	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace Overhead Door; Roll-Up; Motorized	\$23,181
29	429	Fire Stations	6.97%	Fire Station #27	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,868
29	431	Fire Stations	6.97%	Fire Station #27	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$28,426
29	431	Fire Stations	6.97%	Fire Station #27	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$61,012
29	431	Fire Stations	6.97%	Fire Station #27	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,054
29	432	Fire Stations	6.97%	Fire Station #27	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repair drywall/plaster ceiling	\$5,505
29	432	Fire Stations	6.97%	Fire Station #27	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,805
29	433	Fire Stations	6.97%	Fire Station #27	Site Development	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$1,165
29	433	Fire Stations	6.97%	Fire Station #27	Site Development	Potentially Critical-12 months	District 6	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$1,228
29	434	Fire Stations	6.97%	Fire Station #27	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$607
29	434	Fire Stations	6.97%	Fire Station #27	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$4,849
29	435	Fire Stations	6.97%	Fire Station #27	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Beyond Useful Life	Replace Ceramic Tile	\$11,640
29	435	Fire Stations	6.97%	Fire Station #27	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$14,653
29	436	Fire Stations	6.97%	Fire Station #27	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$18,926
29	436	Fire Stations	6.97%	Fire Station #27	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Ceramic Tile	\$16,832
29	440	Fire Stations	6.97%	Fire Station #27	Water Supply	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Repair or replace domestic water piping	\$3,378
29	441	Fire Stations	6.97%	Fire Station #27	Roadways	Potentially Critical-12 months	District 6	Roadways	Damaged	Repair and fill cracks and spalding.	\$3,582
29	443	Fire Stations	6.97%	Fire Station #27	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$13,181
29	445	Fire Stations	6.97%	Fire Station #27	Sanitary Sewer	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Repair or replace sanitary sewer	\$23,207
29	446	Fire Stations	6.97%	Fire Station #27	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$23,286
29	447	Fire Stations	6.97%	Fire Station #27	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Steel Windows	\$26,368
29	448	Fire Stations	6.97%	Fire Station #27	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Replace Ductwork Pkg Sys/Ton	\$27,182
29	458	Fire Stations	6.97%	Fire Station #27	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Replace Copper Water Pipe <2 in	\$37,118
30	460	Fire Stations	6.88%	Fire Station #03	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Seal stone floor	\$8,601
30	460	Fire Stations	6.88%	Fire Station #03	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Replace Sheet Vinyl Floor Covering	\$8,914
30	460	Fire Stations	6.88%	Fire Station #03	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Replace Carpet	\$20,762
30	461	Fire Stations	6.88%	Fire Station #03	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$8,144
30	461	Fire Stations	6.88%	Fire Station #03	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace Residential Gas Furnace 120MBtu	\$8,803
30	462	Fire Stations	6.88%	Fire Station #03	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
30	462	Fire Stations	6.88%	Fire Station #03	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$679
30	463	Fire Stations	6.88%	Fire Station #03	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$5,094
30	463	Fire Stations	6.88%	Fire Station #03	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$1,753
30	464	Fire Stations	6.88%	Fire Station #03	Floor Construction	Potentially Critical-12 months	District 3	Floor Construction	Damaged	Replace Exteior Wood Deck Structure and Floor	\$595
30	465	Fire Stations	6.88%	Fire Station #03	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,430
30	466	Fire Stations	6.88%	Fire Station #03	Slab on Grade	Potentially Critical-12 months	District 3	Slab on Grade	Damaged	Replace Slab On Grade	\$37,576
30	467	Fire Stations	6.88%	Fire Station #03	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Damaged	Replace Public Address Speaker Wall Mtd.	\$545
30	468	Fire Stations	6.88%	Fire Station #03	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$10,055
30	469	Fire Stations	6.88%	Fire Station #03	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$18,987
30	470	Fire Stations	6.88%	Fire Station #03	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$25,685
31	471	Fire Stations	6.81%	Fire Station #24	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Damaged	Replace Fluor. Ltg. Fix. 4'; 2 Lamp Vanity	\$4,217
31	471	Fire Stations	6.81%	Fire Station #24	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,941
31	471	Fire Stations	6.81%	Fire Station #24	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$102,083
31	471	Fire Stations	6.81%	Fire Station #24	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Prepare Paint Light Fix.Wall Mtd; Steel; to 10 SF	\$4,656
31	472	Fire Stations	6.81%	Fire Station #24	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, gas	\$8,380
31	472	Fire Stations	6.81%	Fire Station #24	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Domestic Water Distribution	Damaged	Replace Pipe Insulation; Alum. Shielded; to 3/4'	\$940
31	472	Fire Stations	6.81%	Fire Station #24	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Domestic Water Distribution	Damaged	Replace Pressue Gauge; 2" Dial; up to 300 PSI	\$687
31	473	Fire Stations	6.81%	Fire Station #24	Site Lighting	Necessary- 2-5 Yrs	District 1	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$17,309

31	473	Fire Stations	6.81%	Fire Station #24	Site Lighting	Necessary- 2-5 Yrs	District 1	Site Lighting	Failing	Prepare Paint; Lgt. Fix. Landscape; Ground Mtd.	\$776
31	473	Fire Stations	6.81%	Fire Station #24	Site Lighting	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Prepare Paint Ext. Lgt. Fix. Bollard Type	\$2,028
31	474	Fire Stations	6.81%	Fire Station #24	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Failing	Repaint Metal Fence	\$17,897
31	474	Fire Stations	6.81%	Fire Station #24	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Failing	Prepar Paint Wood Fench Gate; Both Sides; to 48 SF	\$405
31	474	Fire Stations	6.81%	Fire Station #24	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,705
31	475	Fire Stations	6.81%	Fire Station #24	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Exterior stucco/plaster wall paint single story	\$59,466
31	475	Fire Stations	6.81%	Fire Station #24	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
31	475	Fire Stations	6.81%	Fire Station #24	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Seal and Repaint Ext. Parapet Wall Cap and Coping	\$11,260
31	476	Fire Stations	6.81%	Fire Station #24	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$64,128
31	476	Fire Stations	6.81%	Fire Station #24	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Replace Ceramic Tile	\$607
31	476	Fire Stations	6.81%	Fire Station #24	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Replace Vinyl Wall Covering	\$22,400
31	477	Fire Stations	6.81%	Fire Station #24	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$23,825
31	477	Fire Stations	6.81%	Fire Station #24	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace 4T Split System A/C Comp	\$28,080
31	478	Fire Stations	6.81%	Fire Station #24	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Failing	Repaint or restripe Parking Lot/	\$12,287
31	478	Fire Stations	6.81%	Fire Station #24	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Replace expansion joint filler	\$13,886
31	479	Fire Stations	6.81%	Fire Station #24	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace mesh window screens	\$275
31	479	Fire Stations	6.81%	Fire Station #24	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Inadequate	Replace Aluminium Windows	\$31,120
31	480	Fire Stations	6.81%	Fire Station #24	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$23,475
31	480	Fire Stations	6.81%	Fire Station #24	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$39,246
31	481	Fire Stations	6.81%	Fire Station #24	Emergency Generators	Potentially Critical-12 months	District 1	Emergency Generators	Damaged	Replace Generaltor Day Tank; Diesel; up to 100 Gal	\$47,068
31	482	Fire Stations	6.81%	Fire Station #24	Communications and Security	Necessary- 2-5 Yrs	District 1	Communications/Security	Damaged	Replace Door Bell Push Button; Exeior Wall Mtd.	\$314
31	483	Fire Stations	6.81%	Fire Station #24	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Failing	Prepare Paint Wood Fascia and Eaves (SF)	\$3,243
31	484	Fire Stations	6.81%	Fire Station #24	Roof Openings	Necessary- 2-5 Yrs	District 1	Roof Openings	Failing	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$3,482
31	485	Fire Stations	6.81%	Fire Station #24	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Failing	Prepar Paint Building Ladder; Steel; Up to 20'	\$5,428
31	486	Fire Stations	6.81%	Fire Station #24	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Stairs	Damaged	Repaint Handrails	\$5,620
31	487	Fire Stations	6.81%	Fire Station #24	Roadways	Necessary- 2-5 Yrs	District 1	Roadways	Damaged	Replace Concrete Roadway	\$7,023
31	488	Fire Stations	6.81%	Fire Station #24	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$18,434
31	489	Fire Stations	6.81%	Fire Station #24	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Seal stone floor	\$22,956
31	490	Fire Stations	6.81%	Fire Station #24	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$29,337
31	491	Fire Stations	6.81%	Fire Station #24	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 1	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$31,973
32	493	Block House	6.73%	Blockhouse - Black Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Repaint Fascia	\$759
32	493	Block House	6.73%	Blockhouse - Black Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Repaint Fascia	\$759
32	493	Block House	6.73%	Blockhouse - Black Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
32	493	Block House	6.73%	Blockhouse - Black Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
32	496	Block House	6.73%	Blockhouse - Black Mountain	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
32	496	Block House	6.73%	Blockhouse - Black Mountain	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
32	509	Block House	6.73%	Blockhouse - Black Mountain	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$653
32	510	Block House	6.73%	Blockhouse - Black Mountain	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 1	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
32	511	Block House	6.73%	Blockhouse - Black Mountain	Communications and Security	Necessary- 2-5 Yrs	District 1	Communications/Security	Damaged	Replace or Install Ceiling Smoke Detector	\$2,938
32	512	Block House	6.73%	Blockhouse - Black Mountain	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Replace Barbed Wire Strands; up to 3-Strands	\$10,618
33	492	Police Department	6.73%	Eastern Garage	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Threshold	\$327
33	492	Police Department	6.73%	Eastern Garage	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Seal stone floor	\$16,332
33	492	Police Department	6.73%	Eastern Garage	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$1,979
33	492	Police Department	6.73%	Eastern Garage	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$1,397
33	494	Police Department	6.73%	Eastern Garage	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
33	494	Police Department	6.73%	Eastern Garage	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Weatherstripping	\$2,591
33	494	Police Department	6.73%	Eastern Garage	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$9,962
33	495	Police Department	6.73%	Eastern Garage	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Patch plaster walls	\$5,318
33	495	Police Department	6.73%	Eastern Garage	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
33	495	Police Department	6.73%	Eastern Garage	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$38,513
33	497	Police Department	6.73%	Eastern Garage	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,459
33	497	Police Department	6.73%	Eastern Garage	Site Development	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,608
33	498	Police Department	6.73%	Eastern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Replace Ext. Lgt. Fix. Wall Pack; Up to 200 Watts	\$7,663
33	498	Police Department	6.73%	Eastern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,597
33	499	Police Department	6.73%	Eastern Garage	Vehicle Equipment	Potentially Critical-12 months	District 6	Equipment	Failing	Replace Automotive Hydraulic Lift Seals; 5 Ton	\$16,155
33	499	Police Department	6.73%	Eastern Garage	Vehicle Equipment	Potentially Critical-12 months	District 6	Equipment	Beyond Expected Life	Replace Air Compressor >5HP <= 10HP 2 Stage	\$20,367

33	500	Police Department	6.73%	Eastern Garage	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Failing	Prepare and Paint Ext. Metal Window; Up To 20 SF	\$481
33	501	Police Department	6.73%	Eastern Garage	Vehicle Exhaust System	Potentially Critical-12 months	District 6	Ductwork	Damaged	Replace Duct Work Flexible Connector; Up to 12"	\$776
33	502	Police Department	6.73%	Eastern Garage	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Wooden Canopy/Cover - Wall Mounted	\$2,308
33	503	Police Department	6.73%	Eastern Garage	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Replace Water Heater; Electric; up to 30 Gallons	\$2,395
33	504	Police Department	6.73%	Eastern Garage	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Failing	Replace Electric Water Cooler Wall Mount	\$2,629
33	505	Police Department	6.73%	Eastern Garage	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,793
33	506	Police Department	6.73%	Eastern Garage	Stair Construction	Potentially Critical-12 months	District 6	Stairs	Damaged	Paint Metal Stairs Risers Rails Treads	\$2,799
33	507	Police Department	6.73%	Eastern Garage	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$22,442
33	508	Police Department	6.73%	Eastern Garage	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$23,854
34	513	Block House	6.58%	Blockhouse - Lyons Peak	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,385
34	513	Block House	6.58%	Blockhouse - Lyons Peak	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$15,060
34	514	Block House	6.58%	Blockhouse - Lyons Peak	Exterior Walls	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
34	514	Block House	6.58%	Blockhouse - Lyons Peak	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$7,766
34	515	Block House	6.58%	Blockhouse - Lyons Peak	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Failing	Repaint exterior metal doors	\$1,956
34	516	Block House	6.58%	Blockhouse - Lyons Peak	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 7	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
34	517	Block House	6.58%	Blockhouse - Lyons Peak	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Inadequate	Replace Panel Board; 200A; 240V; 1-Phase; 42 Ckt.	\$7,296
34	518	Block House	6.58%	Blockhouse - Lyons Peak	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Failing	Repaint wall	\$7,642
35	519	Fire Stations		Fire Station #19	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$1,564
35	519	Fire Stations		Fire Station #19	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$30,960
35	519	Fire Stations		Fire Station #19	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,253
35	519	Fire Stations		Fire Station #19	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$10,520
35	519	Fire Stations		Fire Station #19	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,842
35	520	Fire Stations		Fire Station #19	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
35	520	Fire Stations		Fire Station #19	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace 2X4 Fluorescent Fixture - S.F.	\$43,415
35	520	Fire Stations		Fire Station #19	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,892
35	521	Fire Stations		Fire Station #19	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$5,815
35	521	Fire Stations		Fire Station #19	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,260
35	522	Fire Stations		Fire Station #19	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$16,114
35	522	Fire Stations		Fire Station #19	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Ceramic Tile	\$5,200
35	523	Fire Stations		Fire Station #19	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
35	523	Fire Stations		Fire Station #19	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Lockers	\$26,538
35	524	Fire Stations		Fire Station #19	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,522
35	524	Fire Stations		Fire Station #19	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$31,477
35	525	Fire Stations		Fire Station #19	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,193
35	526	Fire Stations		Fire Station #19	Landscaping	Necessary- 2-5 Yrs	District 4	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
35	527	Fire Stations		Fire Station #19	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$11,943
35	528	Fire Stations		Fire Station #19	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$13,243
35	529	Fire Stations		Fire Station #19	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$14,813
35	530	Fire Stations		Fire Station #19	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$17,223
35	531	Fire Stations		Fire Station #19	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$18,079
35	532	Fire Stations		Fire Station #19	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Beyond Useful Life	Replace Intercom/Paging System-50 stations	\$126,904
36	533	Fire Stations	6.02%	Fire Station 08	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,147
36	533	Fire Stations	6.02%	Fire Station 08	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067
36	533	Fire Stations	6.02%	Fire Station 08	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$16,183
36	533	Fire Stations	6.02%	Fire Station 08	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$34,732
36	534	Fire Stations	6.02%	Fire Station 08	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,940
36	534	Fire Stations	6.02%	Fire Station 08	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,867
36	534	Fire Stations	6.02%	Fire Station 08	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$6,448
36	535	Fire Stations	6.02%	Fire Station 08	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$4,432
36	535	Fire Stations	6.02%	Fire Station 08	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Missing	Replace Wood Door/Metal Frame	\$835
36	536	Fire Stations	6.02%	Fire Station 08	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$15,006
36	536	Fire Stations	6.02%	Fire Station 08	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace Stucco Wall	\$1,608
36	537	Fire Stations	6.02%	Fire Station 08	Domestic Water Distribution	Potentially Critical-12 months	District 2	Flue/Exhaust Stack	Missing	Extend flue for natural gas appliance	\$707
36	538	Fire Stations	6.02%	Fire Station 08	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
36	539	Fire Stations	6.02%	Fire Station 08	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,184
36	540	Fire Stations	6.02%	Fire Station 08	Exhaust Ventilation Systems Other than Vehicle	Necessary- 2-5 Yrs	District 2	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$3,895

36	541	Fire Stations	6.02%	Fire Station 08	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$8,813
36	542	Fire Stations	6.02%	Fire Station 08	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$9,027
36	543	Fire Stations	6.02%	Fire Station 08	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 2	Vehicle Exhaust System	Damaged	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$11,330
36	544	Fire Stations	6.02%	Fire Station 08	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$14,618
36	545	Fire Stations	6.02%	Fire Station 08	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$18,485
36	546	Fire Stations	6.02%	Fire Station 08	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Steel Windows	\$29,617
37	547	Fire Stations	5.83%	Fire Station #41	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace resisient base moulding	\$6,895
37	547	Fire Stations	5.83%	Fire Station #41	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$43,456
37	547	Fire Stations	5.83%	Fire Station #41	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Ceramic Tile	\$16,935
37	547	Fire Stations	5.83%	Fire Station #41	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Inadequate	Re-paint or Re-Stain Concrete	\$19,954
37	548	Fire Stations	5.83%	Fire Station #41	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,039
37	548	Fire Stations	5.83%	Fire Station #41	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$7,145
37	548	Fire Stations	5.83%	Fire Station #41	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$1,191
37	549	Fire Stations	5.83%	Fire Station #41	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Inadequate	Balance air flow and clean registers	\$9,341
37	549	Fire Stations	5.83%	Fire Station #41	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Beyond Expected Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$16,378
37	549	Fire Stations	5.83%	Fire Station #41	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Beyond Expected Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$16,378
37	550	Fire Stations	5.83%	Fire Station #41	Exterior Doors	Potentially Critical-12 months	District 5	Exterior Doors	Inadequate	Install or replace exterior hardware	\$5,075
37	550	Fire Stations	5.83%	Fire Station #41	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$894
37	550	Fire Stations	5.83%	Fire Station #41	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$73,295
37	551	Fire Stations	5.83%	Fire Station #41	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,061
37	551	Fire Stations	5.83%	Fire Station #41	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Failing	Repair drywall/plaster ceiling	\$6,107
37	552	Fire Stations	5.83%	Fire Station #41	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Replace Ceramic Tile	\$18,777
37	552	Fire Stations	5.83%	Fire Station #41	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$25,510
37	553	Fire Stations	5.83%	Fire Station #41	Exterior Windows	Necessary- 2-5 Yrs	District 5	Furnishings	Failing	Replace exterior window blinds	\$10,618
37	553	Fire Stations	5.83%	Fire Station #41	Exterior Windows	Necessary- 2-5 Yrs	District 5	Exterior Windows	Failing	Replace Steel Windows	\$116,779
37	554	Fire Stations	5.83%	Fire Station #41	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Replace Stucco Wall	\$4,824
37	555	Fire Stations	5.83%	Fire Station #41	Plumbing Fixtures	Potentially Critical-12 months	District 5	Plumbing Fixtures	Failing	Replace Stall Shower	\$5,794
37	556	Fire Stations	5.83%	Fire Station #41	Site Lighting	Potentially Critical-12 months	District 5	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$9,012
37	557	Fire Stations	5.83%	Fire Station #41	Site Development	Potentially Critical-12 months	District 5	Fencing	Damaged	Repair Parking Lot Gate	\$14,500
37	558	Fire Stations	5.83%	Fire Station #41	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
37	559	Fire Stations	5.83%	Fire Station #41	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$4,080
37	560	Fire Stations	5.83%	Fire Station #41	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$38,108
38	561	Police Department	5.62%	Northeastern Substation	Plumbing Fixtures	Critical / Immediate Need	District 1	Plumbing Fixtures	Failing	Repair Plumbing Fixture	\$1,028
38	561	Police Department	5.62%	Northeastern Substation	Plumbing Fixtures	Critical / Immediate Need	District 1	Plumbing Fixtures	Damaged	Secure Plumbing Fixture	\$513
38	561	Police Department	5.62%	Northeastern Substation	Plumbing Fixtures	Potentially Critical-12 months	District 1	Plumbing Fixtures	Inadequate	Perform Maintenance and Clean Drinking Fountain	\$865
38	561	Police Department	5.62%	Northeastern Substation	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Damaged	Replace Lavator Sink Faucet Drain; Porcelain	\$9,262
38	562	Police Department	5.62%	Northeastern Substation	Lighting and Branch Wiring	Critical / Immediate Need	District 1	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$414
38	562	Police Department	5.62%	Northeastern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$17,175
38	562	Police Department	5.62%	Northeastern Substation	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Install or replace exterior lighting	\$467
38	562	Police Department	5.62%	Northeastern Substation	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Damaged	Replace Flour. Ltg. Fix. 1x4 Surf. Mtd. 2 Lamp	\$725
38	563	Police Department	5.62%	Northeastern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Replace Vinyl Wall Covering	\$39,398
38	563	Police Department	5.62%	Northeastern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$167,425
38	563	Police Department	5.62%	Northeastern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace rubber/vinyl cove base	\$548
38	563	Police Department	5.62%	Northeastern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Replace Ceramic Tile	\$527
38	564	Police Department	5.62%	Northeastern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repair drywall/plaster ceiling	\$9,264
38	564	Police Department	5.62%	Northeastern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$894
38	565	Police Department	5.62%	Northeastern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
38	565	Police Department	5.62%	Northeastern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Patch plaster walls	\$8,518
38	566	Police Department	5.62%	Northeastern Substation	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fittings	Damaged	Replace Cabinets and Counters	\$14,142
38	566	Police Department	5.62%	Northeastern Substation	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Repair or replace laminate	\$6,813
38	567	Police Department	5.62%	Northeastern Substation	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Failing	Repaint Metal Fence	\$31,377
38	567	Police Department	5.62%	Northeastern Substation	Site Development	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Patch plaster walls	\$30,946
38	568	Police Department	5.62%	Northeastern Substation	Rain Water Drainage	Potentially Critical-12 months	District 1	Rain Water Drainage	Inadequate	Replace Roof Drain/Receptor Screen	\$11,923
38	569	Police Department	5.62%	Northeastern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Seal stone floor	\$5,030
38	570	Police Department	5.62%	Northeastern Substation	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Domestic Water Distribution	Abandoned	Remove abandoned equipment/system	\$6,731
38	571	Police Department	5.62%	Northeastern Substation	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Stairs	Damaged	Repaint Handrails	\$10,081

38	572	Police Department	5.62%	Northeastern Substation	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace 3T Heat Pump	\$21,921
38	573	Police Department	5.62%	Northeastern Substation	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$23,475
38	574	Police Department	5.62%	Northeastern Substation	Site Lighting	Necessary- 2-5 Yrs	District 1	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$46,159
38	575	Police Department	5.62%	Northeastern Substation	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$63,682
38	576	Police Department	5.62%	Northeastern Substation	Communications and Security	Necessary- 2-5 Yrs	District 1	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
39	577	Fire Stations	5.27%	Fire Repair Facility	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$9,796
39	577	Fire Stations	5.27%	Fire Repair Facility	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$50,650
39	577	Fire Stations	5.27%	Fire Repair Facility	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$246,015
39	577	Fire Stations	5.27%	Fire Repair Facility	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,658
39	578	Fire Stations	5.27%	Fire Repair Facility	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Failing	Remove and replace domestic water heater, gas	\$3,972
39	578	Fire Stations	5.27%	Fire Repair Facility	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Failing	Replace 40 Gal Gas Water Heater	\$2,873
39	578	Fire Stations	5.27%	Fire Repair Facility	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,294
39	579	Fire Stations	5.27%	Fire Repair Facility	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,785
39	579	Fire Stations	5.27%	Fire Repair Facility	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,847
39	579	Fire Stations	5.27%	Fire Repair Facility	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$29,351
39	580	Fire Stations	5.27%	Fire Repair Facility	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Inadequate	replace ductwork dampers registers and insulatio	\$17,309
39	580	Fire Stations	5.27%	Fire Repair Facility	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Replace unit heaters	\$14,829
39	580	Fire Stations	5.27%	Fire Repair Facility	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Failing	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$16,378
39	581	Fire Stations	5.27%	Fire Repair Facility	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$1,049
39	581	Fire Stations	5.27%	Fire Repair Facility	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$15,441
39	581	Fire Stations	5.27%	Fire Repair Facility	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$64,382
39	582	Fire Stations	5.27%	Fire Repair Facility	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Cabinets and Counters	\$3,558
39	582	Fire Stations	5.27%	Fire Repair Facility	Fittings	Potentially Critical-12 months	District 6	Fittings	Beyond Useful Life	Replace Toilet Partition	\$8,664
39	583	Fire Stations	5.27%	Fire Repair Facility	Fixed Furnishings	Potentially Critical-12 months	District 6	Stairs	Damaged	Sand, Stain and Seal Int. Wood Stairs and Rise	\$1,378
39	583	Fire Stations	5.27%	Fire Repair Facility	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$18,981
39	584	Fire Stations	5.27%	Fire Repair Facility	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Failing	Replace Plumbing Fixtures	\$23,408
39	584	Fire Stations	5.27%	Fire Repair Facility	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Missing	Replace Plumbing Fixtures	\$3,293
39	585	Fire Stations	5.27%	Fire Repair Facility	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$97,585
39	585	Fire Stations	5.27%	Fire Repair Facility	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$13,008
39	586	Fire Stations	5.27%	Fire Repair Facility	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$4,324
39	587	Fire Stations	5.27%	Fire Repair Facility	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$7,027
39	588	Fire Stations	5.27%	Fire Repair Facility	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Reapply reflective asphaltic coating to roof	\$12,298
39	589	Fire Stations	5.27%	Fire Repair Facility	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$38,440
39	590	Fire Stations	5.27%	Fire Repair Facility	Vehicle Exhaust System	Potentially Critical-12 months	District 6	Vehicle Exhaust System	Abandoned	Replace vehicle exhaust system-2 bay	\$88,197
39	591	Fire Stations	5.27%	Fire Repair Facility	Roadways	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$294,010
40	592	Fire Stations	5.19%	Fire Station #43	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Inadequate	Replace 1X4 Surface Flourescent Fixture S.F.	\$940
40	592	Fire Stations	5.19%	Fire Station #43	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Failing	Replace Incandescent Light Fixtures	\$3,835
40	592	Fire Stations	5.19%	Fire Station #43	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$9,544
40	592	Fire Stations	5.19%	Fire Station #43	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$18,642
40	592	Fire Stations	5.19%	Fire Station #43	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$143,615
40	593	Fire Stations	5.19%	Fire Station #43	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$33,061
40	593	Fire Stations	5.19%	Fire Station #43	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$130
40	593	Fire Stations	5.19%	Fire Station #43	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$7,360
40	593	Fire Stations	5.19%	Fire Station #43	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,374
40	593	Fire Stations	5.19%	Fire Station #43	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$13,367
40	593	Fire Stations	5.19%	Fire Station #43	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$37,301
40	594	Fire Stations	5.19%	Fire Station #43	Fittings	Critical / Immediate Need	District 8	Fittings	Damaged	Reattach and Secure Bath Room Accessory to Wall	\$577
40	594	Fire Stations	5.19%	Fire Station #43	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Lockers	\$2,793
40	594	Fire Stations	5.19%	Fire Station #43	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
40	595	Fire Stations	5.19%	Fire Station #43	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$9,544
40	595	Fire Stations	5.19%	Fire Station #43	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Missing	Replace Window Unit < 3T	\$2,605
40	595	Fire Stations	5.19%	Fire Station #43	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Missing	Install condensation piping	\$257

40	596	Fire Stations	5.19%	Fire Station #43	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,414
40	596	Fire Stations	5.19%	Fire Station #43	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$19,511
40	597	Fire Stations	5.19%	Fire Station #43	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Stucco Wall	\$13,515
40	597	Fire Stations	5.19%	Fire Station #43	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$12,961
40	598	Fire Stations	5.19%	Fire Station #43	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 8	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$23,370
40	599	Fire Stations	5.19%	Fire Station #43	Site Lighting	Potentially Critical-12 months	District 8	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$54,070
40	600	Fire Stations	5.19%	Fire Station #43	Site Development	Necessary- 2-5 Yrs	District 8	Other Site Structures	Damaged	Repaint pipe bollards	\$296
40	601	Fire Stations	5.19%	Fire Station #43	Partitions	Necessary- 2-5 Yrs	District 8	Partitions	Damaged	Replace Drywall Partition/Wood Stud Backup	\$491
40	602	Fire Stations	5.19%	Fire Station #43	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Missing	Replace Hatches and Access doors	\$520
40	603	Fire Stations	5.19%	Fire Station #43	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repair exterior metal doors	\$1,490
40	604	Fire Stations	5.19%	Fire Station #43	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
40	605	Fire Stations	5.19%	Fire Station #43	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$5,743
40	606	Fire Stations	5.19%	Fire Station #43	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$19,413
40	607	Fire Stations	5.19%	Fire Station #43	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$48,027
40	608	Fire Stations	5.19%	Fire Station #43	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$48,251
40	609	Fire Stations	5.19%	Fire Station #43	Communications and Security	Necessary- 2-5 Yrs	District 8	Communications/Security	Damaged	Replace Intercom/Paging System-50 stations	\$126,904
41	610	Police Department	4.90%	Western Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$17,695
41	610	Police Department	4.90%	Western Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace 2X4 Flourescent Fixture Ea.	\$222
41	610	Police Department	4.90%	Western Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Flour. Ltg. Fix. 1x4 Surf. Mtd. 2 Lamp	\$2,174
41	610	Police Department	4.90%	Western Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Replace Junction Box Cover; Blank4" Square; Steel	\$353
41	611	Police Department	4.90%	Western Substation	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repair Exterior Block Wall	\$87,964
41	611	Police Department	4.90%	Western Substation	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
41	611	Police Department	4.90%	Western Substation	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Patch plaster walls	\$11,206
41	612	Police Department	4.90%	Western Substation	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Replace Carpet Wall Covering	\$7,589
41	612	Police Department	4.90%	Western Substation	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Replace Vinyl Wall Covering	\$7,905
41	612	Police Department	4.90%	Western Substation	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$119,221
41	613	Police Department	4.90%	Western Substation	Roof Openings	Potentially Critical-12 months	District 6	Exterior Windows	Failing	Prepare and Paint Ext. Metal Window; Up To 20 SF	\$1,054
41	613	Police Department	4.90%	Western Substation	Roof Openings	Potentially Critical-12 months	District 6	Roof Openings	Damaged	Replace Roof Hatch Door Closer/Cylinder	\$684
41	614	Police Department	4.90%	Western Substation	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace mirrors	\$3,541
41	614	Police Department	4.90%	Western Substation	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Counter Top; Solid Surface	\$3,350
41	615	Police Department	4.90%	Western Substation	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,127
41	615	Police Department	4.90%	Western Substation	Site Development	Potentially Critical-12 months	District 6	Fencing	Failing	Repaint Metal Fence	\$14,782
41	616	Police Department	4.90%	Western Substation	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Missing	Replace Gate/Door Latch; Steel; Exterior	\$675
41	616	Police Department	4.90%	Western Substation	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$15,650
41	617	Police Department	4.90%	Western Substation	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Replace Gas Water Heater; Commercial;100 Gallons	\$13,798
41	617	Police Department	4.90%	Western Substation	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Abandoned	Remove abandoned equipment/system	\$6,731
41	618	Police Department	4.90%	Western Substation	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$447
41	618	Police Department	4.90%	Western Substation	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$28,108
41	619	Police Department	4.90%	Western Substation	Site Lighting	Potentially Critical-12 months	District 6	Site Lighting	Damaged	Replace Site Lighting Pole Base Cover; Metal	\$1,060
41	619	Police Department	4.90%	Western Substation	Site Lighting	Potentially Critical-12 months	District 6	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$46,159
41	620	Police Department	4.90%	Western Substation	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$5,239
41	620	Police Department	4.90%	Western Substation	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$118,579
41	621	Police Department	4.90%	Western Substation	Landscaping	Potentially Critical-12 months	District 6	Landscaping	Damaged	Perform landscaping maintenance	\$1,923
41	622	Police Department	4.90%	Western Substation	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,715
41	623	Police Department	4.90%	Western Substation	Rain Water Drainage	Potentially Critical-12 months	District 6	Rain Water Drainage	Inadequate	Replace Roof Drain/Receptor Screen	\$8,942
41	624	Police Department	4.90%	Western Substation	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$46,924
41	625	Police Department	4.90%	Western Substation	Communications and Security	Potentially Critical-12 months	District 6	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
41	626	Police Department	4.90%	Western Substation	Emergency Generator	Potentially Critical-12 months	District 6	Emergency Generators	Damaged	Replace 250KW D/Emer Gen Set w/ATS	\$119,910
41	627	Police Department	4.90%	Western Substation	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Expected Life	Replace Built up Roof	\$190,766
42	628	Block House	4.84%	Blockhouse - North City	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Failing	Repaint Fascia	\$759
42	628	Block House	4.84%	Blockhouse - North City	Exterior Walls	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
42	629	Block House	4.84%	Blockhouse - North City	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
42	630	Block House	4.84%	Blockhouse - North City	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$653
42	631	Block House	4.84%	Blockhouse - North City	Site Development	Necessary- 2-5 Yrs	District 5	Site Development	Damaged	Replace Chain Link Fence; up to 8'(H) 3-Strnd; RZR	\$2,677
43	632	Police Department	4.83%	Eastern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$16,395

43	632	Police Department	4.83%	Eastern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Duplex Receptacle Cover	\$304
43	632	Police Department	4.83%	Eastern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Replace Junction Box Cover; Blank4" Square; Steel	\$294
43	632	Police Department	4.83%	Eastern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Light Switch Cover 1-Gang	\$314
43	633	Police Department	4.83%	Eastern Substation	Site Development	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,304
43	633	Police Department	4.83%	Eastern Substation	Site Development	Potentially Critical-12 months	District 6	Fencing	Failing	Repaint Metal Fence	\$26,032
43	633	Police Department	4.83%	Eastern Substation	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,254
43	633	Police Department	4.83%	Eastern Substation	Site Development	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Stucco Wall	\$12,430
43	634	Police Department	4.83%	Eastern Substation	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Patch plaster walls	\$9,557
43	634	Police Department	4.83%	Eastern Substation	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$867
43	634	Police Department	4.83%	Eastern Substation	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
43	634	Police Department	4.83%	Eastern Substation	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$75,015
43	635	Police Department	4.83%	Eastern Substation	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$2,412
43	635	Police Department	4.83%	Eastern Substation	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Seal stone floor	\$13,832
43	635	Police Department	4.83%	Eastern Substation	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$2,146
43	635	Police Department	4.83%	Eastern Substation	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$88,348
43	636	Police Department	4.83%	Eastern Substation	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replace Faucet Set; Chrome;	\$4,904
43	636	Police Department	4.83%	Eastern Substation	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Inadequate	Perform Maintenance and Clean Drinking Fountain	\$865
43	637	Police Department	4.83%	Eastern Substation	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$16,954
43	637	Police Department	4.83%	Eastern Substation	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$1,660
43	638	Police Department	4.83%	Eastern Substation	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$21,437
43	638	Police Department	4.83%	Eastern Substation	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,831
43	639	Police Department	4.83%	Eastern Substation	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$46,924
43	639	Police Department	4.83%	Eastern Substation	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Missing	Install Door Hardware Blanks	\$435
43	640	Police Department	4.83%	Eastern Substation	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$231,678
43	640	Police Department	4.83%	Eastern Substation	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Replace Vinyl Wall Covering	\$41,439
43	641	Police Department	4.83%	Eastern Substation	Site Lighting	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Junction or Pull Box; 8"x8"x4" N3R	\$1,469
43	642	Police Department	4.83%	Eastern Substation	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace room signage	\$224
43	643	Police Department	4.83%	Eastern Substation	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$1,879
43	644	Police Department	4.83%	Eastern Substation	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Abandoned	Remove abandoned equipment/system	\$6,731
43	645	Police Department	4.83%	Eastern Substation	Landscaping	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Junction or Pull Box; 36"x36"x8" N3R	\$7,881
43	646	Police Department	4.83%	Eastern Substation	Rain Water Drainage	Potentially Critical-12 months	District 6	Rain Water Drainage	Inadequate	Replace Roof Drain/Receptor Screen	\$11,923
43	647	Police Department	4.83%	Eastern Substation	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Beyond Expected Life	Replace 3T Heat Pump	\$21,921
43	648	Police Department	4.83%	Eastern Substation	Communications and Security	Potentially Critical-12 months	District 6	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
43	649	Police Department	4.83%	Eastern Substation	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Failing	Slurry seal asphalt	\$95,307
44	650	Fire Stations	4.66%	Fire Station #10	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$6,418
44	650	Fire Stations	4.66%	Fire Station #10	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Failing	Replace wood siding	\$16,761
44	650	Fire Stations	4.66%	Fire Station #10	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Failing	Repaint Exterior Block Wall	\$997
44	650	Fire Stations	4.66%	Fire Station #10	Exterior Walls	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
44	651	Fire Stations	4.66%	Fire Station #10	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$6,704
44	651	Fire Stations	4.66%	Fire Station #10	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,629
44	651	Fire Stations	4.66%	Fire Station #10	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$6,144
44	652	Fire Stations	4.66%	Fire Station #10	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Failing	Replace Carpet	\$45,163
44	652	Fire Stations	4.66%	Fire Station #10	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Failing	Replace Sheet Vinyl Floor Covering	\$10,634
44	652	Fire Stations	4.66%	Fire Station #10	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Failing	Seal stone floor	\$23,561
44	653	Fire Stations	4.66%	Fire Station #10	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Damaged	Replace Duplex Receptacle Cover	\$304
44	653	Fire Stations	4.66%	Fire Station #10	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,649
44	654	Fire Stations	4.66%	Fire Station #10	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$10,902
44	654	Fire Stations	4.66%	Fire Station #10	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Beyond Expected Life	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$27,529
44	655	Fire Stations	4.66%	Fire Station #10	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$36,284
44	655	Fire Stations	4.66%	Fire Station #10	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$69,588
44	656	Fire Stations	4.66%	Fire Station #10	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Beyond Expected Life	Install or replace kitchen range exhaust hood syst	\$16,119
44	657	Fire Stations	4.66%	Fire Station #10	Terminal & Package Units	Potentially Critical-12 months	District 7	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$25,949
44	658	Fire Stations	4.66%	Fire Station #10	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,104

44	659	Fire Stations	4.66%	Fire Station #10	Site Development	Necessary- 2-5 Yrs	District 7	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$8,772
44	660	Fire Stations	4.66%	Fire Station #10	Site Lighting	Necessary- 2-5 Yrs	District 7	Site Lighting	Damaged	Replace Walkway Bollard Light Fixture	\$10,096
44	661	Fire Stations	4.66%	Fire Station #10	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Failing	Repaint wall	\$27,618
44	662	Fire Stations	4.66%	Fire Station #10	Roof Construction	Necessary- 2-5 Yrs	District 7	Roof Construction	Failing	Prepare and Paint Concrete Eaves and Fascia	\$39,541
44	663	Fire Stations	4.66%	Fire Station #10	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 7	Vehicle Exhaust System	Beyond Expected Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$39,657
44	664	Fire Stations	4.66%	Fire Station #10	Landscaping	Necessary- 2-5 Yrs	District 7	Landscaping	Failing	Perform landscaping maintenance	\$52,889
45	665	Police Department	4.58%	Police Station Mid-City	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
45	665	Police Department	4.58%	Police Station Mid-City	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
45	665	Police Department	4.58%	Police Station Mid-City	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$4,224
45	665	Police Department	4.58%	Police Station Mid-City	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$17,524
45	665	Police Department	4.58%	Police Station Mid-City	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$15,067
45	666	Police Department	4.58%	Police Station Mid-City	Exterior Doors	Potentially Critical-12 months	District 3	Exterior Doors	Damaged	Replace Weatherstripping	\$1,728
45	666	Police Department	4.58%	Police Station Mid-City	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
45	666	Police Department	4.58%	Police Station Mid-City	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$8,301
45	666	Police Department	4.58%	Police Station Mid-City	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$22,171
45	667	Police Department	4.58%	Police Station Mid-City	Communications and Security	Critical / Immediate Need	District 3	Communications/Security	Missing	Install Blank Cover on Security Sys. Component	\$524
45	667	Police Department	4.58%	Police Station Mid-City	Communications and Security	Potentially Critical-12 months	District 3	Communications/Security	Damaged	Replace Conduit; PVC; Up to 1"	\$3,526
45	668	Police Department	4.58%	Police Station Mid-City	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,108
45	668	Police Department	4.58%	Police Station Mid-City	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$31,858
45	669	Police Department	4.58%	Police Station Mid-City	Storm Sewer	Critical / Immediate Need	District 3	Storm Sewer	Failing	Clean out catch basin/drain	\$286
45	670	Police Department	4.58%	Police Station Mid-City	Rain Water Drainage	Necessary- 2-5 Yrs	District 3	Rain Water Drainage	Failing	Prepare and Paint Metal Gutters and Downspouts	\$871
45	670	Police Department	4.58%	Police Station Mid-City	Rain Water Drainage	Necessary- 2-5 Yrs	District 3	Rain Water Drainage	Failing	Prepare and Paint Metal Gutters and Downspouts	\$4,836
45	671	Police Department	4.58%	Police Station Mid-City	Site Development	Necessary- 2-5 Yrs	District 3	Fencing	Failing	Repaint Metal Fence	\$29,797
45	671	Police Department	4.58%	Police Station Mid-City	Site Development	Necessary- 2-5 Yrs	District 3	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,127
45	672	Police Department	4.58%	Police Station Mid-City	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$511
45	672	Police Department	4.58%	Police Station Mid-City	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$36,592
45	673	Police Department	4.58%	Police Station Mid-City	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Seal stone floor	\$5,840
45	673	Police Department	4.58%	Police Station Mid-City	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Replace Carpet	\$162,100
45	674	Police Department	4.58%	Police Station Mid-City	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$190,159
45	674	Police Department	4.58%	Police Station Mid-City	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$2,485
45	675	Police Department	4.58%	Police Station Mid-City	Roof Openings	Necessary- 2-5 Yrs	District 3	Roof Openings	Damaged	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$2,058
45	676	Police Department	4.58%	Police Station Mid-City	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Metal Window; Up To 20 SF	\$7,703
45	677	Police Department	4.58%	Police Station Mid-City	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Counter Top; Solid Surface	\$14,975
45	678	Police Department	4.58%	Police Station Mid-City	Site Lighting	Necessary- 2-5 Yrs	District 3	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$31,735
45	679	Police Department	4.58%	Police Station Mid-City	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$54,465
45	680	Police Department	4.58%	Police Station Mid-City	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Failing	Slurry seal asphalt	\$96,274
45	681	Police Department	4.58%	Police Station Mid-City	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace Gas/Electric Pkg. Unit (s)	\$272,789
46	682	Fire Stations	4.56%	Fire Station #36	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$13,972
46	682	Fire Stations	4.56%	Fire Station #36	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Damaged	Install new exhaust system and controls	\$7,790
46	682	Fire Stations	4.56%	Fire Station #36	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$4,168
46	683	Fire Stations	4.56%	Fire Station #36	Site Development	Potentially Critical-12 months	District 6	Other Site Structures	Damaged	Repaint pipe bollards	\$636
46	683	Fire Stations	4.56%	Fire Station #36	Site Development	Potentially Critical-12 months	District 6	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$832
46	683	Fire Stations	4.56%	Fire Station #36	Site Development	Potentially Critical-12 months	District 6	Fencing	Damaged	Replace chain link fencing	\$5,312
46	684	Fire Stations	4.56%	Fire Station #36	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,385
46	684	Fire Stations	4.56%	Fire Station #36	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Beyond Useful Life	Replace Acoustical Ceiling Tile	\$2,005
46	684	Fire Stations	4.56%	Fire Station #36	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Beyond Useful Life	Replace Acoustical Ceiling Tile	\$3,459
46	685	Fire Stations	4.56%	Fire Station #36	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$2,561
46	685	Fire Stations	4.56%	Fire Station #36	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$5,104
46	685	Fire Stations	4.56%	Fire Station #36	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$5,789
46	686	Fire Stations	4.56%	Fire Station #36	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$1,076
46	686	Fire Stations	4.56%	Fire Station #36	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$7,757
46	687	Fire Stations	4.56%	Fire Station #36	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Toilet Partition	\$8,662
46	687	Fire Stations	4.56%	Fire Station #36	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
46	688	Fire Stations	4.56%	Fire Station #36	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Beyond Useful Life	Replace Ceramic Tile	\$27,444

46	688	Fire Stations	4.56%	Fire Station #36	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$9,919
46	689	Fire Stations	4.56%	Fire Station #36	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Inadequate	Replace electric service entrance -200 Amp	\$7,709
46	690	Fire Stations	4.56%	Fire Station #36	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$962
46	691	Fire Stations	4.56%	Fire Station #36	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$3,449
46	692	Fire Stations	4.56%	Fire Station #36	Roadways	Potentially Critical-12 months	District 6	Roadways	Damaged	Repair and fill cracks and spalding.	\$12,468
46	693	Fire Stations	4.56%	Fire Station #36	Vehicle Exhaust Systems	Potentially Critical-12 months	District 6	Vehicle Exhaust System	Beyond Expected Life	Replace vehicle exhaust system-2 bay	\$13,099
46	694	Fire Stations	4.56%	Fire Station #36	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Ceramic Tile	\$18,889
46	695	Fire Stations	4.56%	Fire Station #36	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Beyond Expected Life	Replace Fixed Casework Base / Wall Cabinets	\$20,651
46	696	Fire Stations	4.56%	Fire Station #36	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$22,208
46	697	Fire Stations	4.56%	Fire Station #36	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$24,223
46	698	Fire Stations	4.56%	Fire Station #36	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$28,803
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$7,973
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,714
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$12,912
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$46,627
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$5,732
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$31,934
47	699	Fire Stations	4.52%	Fire Station #11	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Rubber Flooring	\$177
47	700	Fire Stations	4.52%	Fire Station #11	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,560
47	700	Fire Stations	4.52%	Fire Station #11	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace Branch Panelboard -400A	\$10,967
47	700	Fire Stations	4.52%	Fire Station #11	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$128,796
47	700	Fire Stations	4.52%	Fire Station #11	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Failing	Replace Incandescent Light Fixtures	\$5,754
47	700	Fire Stations	4.52%	Fire Station #11	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
47	701	Fire Stations	4.52%	Fire Station #11	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Decorative Tile	\$3,426
47	701	Fire Stations	4.52%	Fire Station #11	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Prepare Paint Exterior Walls up to 3 Floors	\$20,367
47	701	Fire Stations	4.52%	Fire Station #11	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	RegROUT exterior tiles	\$2,778
47	702	Fire Stations	4.52%	Fire Station #11	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$23,297
47	702	Fire Stations	4.52%	Fire Station #11	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Replace Ceramic Tile	\$1,444
47	703	Fire Stations	4.52%	Fire Station #11	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Damaged	Install or replace thermal insulation of ductwork	\$4,252
47	703	Fire Stations	4.52%	Fire Station #11	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$8,560
47	704	Fire Stations	4.52%	Fire Station #11	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Metal Door/Metal Frame	\$2,463
47	704	Fire Stations	4.52%	Fire Station #11	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Shower Door	\$981
47	705	Fire Stations	4.52%	Fire Station #11	Stair Construction	Necessary- 2-5 Yrs	District 8	Stairs	Damaged	Repaint Handrails	\$689
47	705	Fire Stations	4.52%	Fire Station #11	Stair Construction	Necessary- 2-5 Yrs	District 8	Stairs	Damaged	Replace Rubber Treads, Risers and Landing	\$4,928
47	706	Fire Stations	4.52%	Fire Station #11	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$3,125
47	706	Fire Stations	4.52%	Fire Station #11	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$19,129
47	707	Fire Stations	4.52%	Fire Station #11	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,140
47	707	Fire Stations	4.52%	Fire Station #11	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$26,158
47	708	Fire Stations	4.52%	Fire Station #11	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$14,332
47	708	Fire Stations	4.52%	Fire Station #11	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$20,304
47	709	Fire Stations	4.52%	Fire Station #11	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Damaged	Repaint Metal Fence	\$852
47	710	Fire Stations	4.52%	Fire Station #11	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Repair or replace laminate	\$1,913
47	711	Fire Stations	4.52%	Fire Station #11	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
47	712	Fire Stations	4.52%	Fire Station #11	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
47	713	Fire Stations	4.52%	Fire Station #11	Partitions	Necessary- 2-5 Yrs	District 8	Partitions	Damaged	Repair Drywall Partitions	\$11,209
47	714	Fire Stations	4.52%	Fire Station #11	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Steel Doors	\$30,993
48	719	Block House	4.38%	Blockhouse - Encanto	Exterior Walls	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
48	719	Block House	4.38%	Blockhouse - Encanto	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Fascia	\$759
48	719	Block House	4.38%	Blockhouse - Encanto	Exterior Walls	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
48	720	Block House	4.38%	Blockhouse - Encanto	Electrical Service/Distribution	Potentially Critical-12 months	District 4	Electrical Service/Distribution	Inadequate	Re-Install Panel Board Cover; Cover On-Site	\$1,096
48	720	Block House	4.38%	Blockhouse - Encanto	Electrical Service/Distribution	Potentially Critical-12 months	District 4	Electrical Service/Distribution	Missing	Install Circuit Breaker Knock-Out Blank; Plastic	\$268
48	722	Block House	4.38%	Blockhouse - Encanto	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Replace Junction Box Cover; Blank4" Square; Steel	\$294
48	731	Block House	4.38%	Blockhouse - Encanto	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Weather Strip on Flashing; 3/4"	\$648
48	732	Block House	4.38%	Blockhouse - Encanto	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Failing	Repaint exterior metal doors	\$653
48	733	Block House	4.38%	Blockhouse - Encanto	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 4	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
49	715	Fire Stations	4.38%	Fire Department Comm. Center	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946

49	715	Fire Stations	4.38%	Fire Department Comm. Center	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install or replace dehumidification system	\$41,426
49	715	Fire Stations	4.38%	Fire Department Comm. Center	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Failing	Install or replace thermal insulation on HVAC pipi	\$12,274
49	715	Fire Stations	4.38%	Fire Department Comm. Center	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$11,120
49	715	Fire Stations	4.38%	Fire Department Comm. Center	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Failing	Install or replace water cooled Chiller	\$173,497
49	715	Fire Stations	4.38%	Fire Department Comm. Center	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Missing	Install or replace Energy Management System (BAS)	\$153,812
49	716	Fire Stations	4.38%	Fire Department Comm. Center	Parking Lots	Potentially Critical-12 months	District 6	Fencing	Damaged	Replace chain link fencing	\$1,199
49	716	Fire Stations	4.38%	Fire Department Comm. Center	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$7,886
49	716	Fire Stations	4.38%	Fire Department Comm. Center	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Failing	Slurry seal asphalt	\$25,069
49	716	Fire Stations	4.38%	Fire Department Comm. Center	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$2,301
49	717	Fire Stations	4.38%	Fire Department Comm. Center	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
49	717	Fire Stations	4.38%	Fire Department Comm. Center	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
49	717	Fire Stations	4.38%	Fire Department Comm. Center	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
49	718	Fire Stations	4.38%	Fire Department Comm. Center	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$8,279
49	718	Fire Stations	4.38%	Fire Department Comm. Center	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$11,994
49	718	Fire Stations	4.38%	Fire Department Comm. Center	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$61,360
49	721	Fire Stations	4.38%	Fire Department Comm. Center	Stair Construction	Potentially Critical-12 months	District 6	Stairs	Damaged	Paint stairs	\$2,183
49	721	Fire Stations	4.38%	Fire Department Comm. Center	Stair Construction	Potentially Critical-12 months	District 6	Stairs	Failing	Repaint Handrails	\$892
49	723	Fire Stations	4.38%	Fire Department Comm. Center	Site Development	Potentially Critical-12 months	District 6	Other Site Structures	Failing	Repaint pipe bollards	\$592
49	724	Fire Stations	4.38%	Fire Department Comm. Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$11,120
49	725	Fire Stations	4.38%	Fire Department Comm. Center	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Prepare _ Paint Exterior Walls up to 3 Floors	\$17,314
49	726	Fire Stations	4.38%	Fire Department Comm. Center	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$17,472
49	727	Fire Stations	4.38%	Fire Department Comm. Center	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$21,396
49	728	Fire Stations	4.38%	Fire Department Comm. Center	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$21,518
49	729	Fire Stations	4.38%	Fire Department Comm. Center	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$26,816
49	730	Fire Stations	4.38%	Fire Department Comm. Center	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$51,685
50	734	Block House	4.19%	Blockhouse Mt. Woodson #900528	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,885
50	734	Block House	4.19%	Blockhouse Mt. Woodson #900528	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
50	735	Block House	4.19%	Blockhouse Mt. Woodson #900528	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Failing	Repaint Fascia	\$316
50	735	Block House	4.19%	Blockhouse Mt. Woodson #900528	Exterior Walls	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
50	736	Block House	4.19%	Blockhouse Mt. Woodson #900528	Landscaping	Critical / Immediate Need	District 5	Landscaping	Failing	Re-grade Site	\$5,364
50	737	Block House	4.19%	Blockhouse Mt. Woodson #900528	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
50	738	Block House	4.19%	Blockhouse Mt. Woodson #900528	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$7,766
51	739	Police Department	4.17%	Eastern Traffic Division	Exterior Walls	Critical / Immediate Need	District 6	Exterior Walls	Damaged	Replace Wooden Balustrade	\$35,838
51	739	Police Department	4.17%	Eastern Traffic Division	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
51	740	Police Department	4.17%	Eastern Traffic Division	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$18,583
51	740	Police Department	4.17%	Eastern Traffic Division	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace 2X4 Flourescent Fixture Ea.	\$273
51	741	Police Department	4.17%	Eastern Traffic Division	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Replace Carpet	\$130,012
51	741	Police Department	4.17%	Eastern Traffic Division	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$2,948
51	742	Police Department	4.17%	Eastern Traffic Division	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$115,839
51	742	Police Department	4.17%	Eastern Traffic Division	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Replace Vinyl Wall Covering	\$61,904
51	743	Police Department	4.17%	Eastern Traffic Division	Communications and Security	Critical / Immediate Need	District 6	Communications/Security	Damaged	Secure Fire Alarm Device	\$274
51	744	Police Department	4.17%	Eastern Traffic Division	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$575
51	745	Police Department	4.17%	Eastern Traffic Division	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$6,521
51	746	Police Department	4.17%	Eastern Traffic Division	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Expected Life	Replace Water Heater; Electric; 100 Gallons	\$16,853

51	747	Police Department	4.17%	Eastern Traffic Division	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$29,606
51	748	Police Department	4.17%	Eastern Traffic Division	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Failing	Replace Plumbing Fixtures	\$50,171
51	749	Police Department	4.17%	Eastern Traffic Division	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Failing	Slurry seal asphalt	\$72,579
52	750	Police Department	4.03%	Western Garage	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
52	750	Police Department	4.03%	Western Garage	Exterior Walls	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$22,442
52	750	Police Department	4.03%	Western Garage	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Patch plaster walls	\$5,318
52	751	Police Department	4.03%	Western Garage	Roof Openings	Potentially Critical-12 months	District 6	Roof Openings	Damaged	Replace Roof Hatch Door Closer/Cylinder	\$684
52	751	Police Department	4.03%	Western Garage	Roof Openings	Potentially Critical-12 months	District 6	Roof Openings	Damaged	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$1,029
52	752	Police Department	4.03%	Western Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Flour. Ltg. Fix. 1x4 Surf. Mtd. 2 Lamp	\$1,449
52	752	Police Department	4.03%	Western Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,856
52	753	Police Department	4.03%	Western Garage	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$1,910
52	753	Police Department	4.03%	Western Garage	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Seal stone floor	\$24,504
52	754	Police Department	4.03%	Western Garage	Exhaust Fans (Other Than Vehicle)	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Replace Exh. Sys. Intake Grille; Metal	\$385
52	755	Police Department	4.03%	Western Garage	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,459
52	756	Police Department	4.03%	Western Garage	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Weatherstripping	\$2,591
52	757	Police Department	4.03%	Western Garage	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,793
52	758	Police Department	4.03%	Western Garage	Stair Construction	Potentially Critical-12 months	District 6	Stairs	Damaged	Paint Metal Stairs Risers Rails Treads	\$2,799
52	759	Police Department	4.03%	Western Garage	Vehicle Equipment	Potentially Critical-12 months	District 6	Equipment	Failing	Replace Automotive Hydraulic Lift Seals; 5 Ton	\$5,386
52	760	Police Department	4.03%	Western Garage	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$24,959
52	761	Police Department	4.03%	Western Garage	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Expected Life	Replace Built up Roof	\$63,243
53	762	Block House	3.87%	Blockhouse - Cowles Mountain	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Failing	Replace Emerg. Egress Lght; 2 Lamp; Batt. Backup	\$628
53	762	Block House	3.87%	Blockhouse - Cowles Mountain	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
53	762	Block House	3.87%	Blockhouse - Cowles Mountain	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
53	762	Block House	3.87%	Blockhouse - Cowles Mountain	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Damaged	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
53	762	Block House	3.87%	Blockhouse - Cowles Mountain	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Missing	Close Junction Box Conduit Knock-Out; up to 1"	\$192
53	763	Block House	3.87%	Blockhouse - Cowles Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Failing	Repaint Fascia	\$759
53	763	Block House	3.87%	Blockhouse - Cowles Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
53	763	Block House	3.87%	Blockhouse - Cowles Mountain	Exterior Walls	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
53	764	Block House	3.87%	Blockhouse - Cowles Mountain	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
53	764	Block House	3.87%	Blockhouse - Cowles Mountain	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Failing	Repaint exterior metal doors	\$653
53	765	Block House	3.87%	Blockhouse - Cowles Mountain	Site Development	Necessary- 2-5 Yrs	District 7	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,578
53	765	Block House	3.87%	Blockhouse - Cowles Mountain	Site Development	Necessary- 2-5 Yrs	District 7	Site Development	Failing	Prepare and Paint Chain Link Fench to 8' H	\$11,716
53	766	Block House	3.87%	Blockhouse - Cowles Mountain	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Glue on Tile	\$107
53	767	Block House	3.87%	Blockhouse - Cowles Mountain	Exhaust Fans	Necessary- 2-5 Yrs	District 7	Exhaust Ventilation System	Damaged	Replace Speed Control Switch Rotary 120V 20A	\$347
53	768	Block House	3.87%	Blockhouse - Cowles Mountain	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$676
53	769	Block House	3.87%	Blockhouse - Cowles Mountain	Fuel Distribution - LP Gas	Necessary- 2-5 Yrs	District 7	Fuel Distribution	Failing	Prepare and Paint LP Fuel Tank; Steel; to 5i00 Gal	\$2,006
53	770	Block House	3.87%	Blockhouse - Cowles Mountain	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Failing	Repaint Metal Roof - Epoxy; Prime Coat; Seal	\$6,018
54	771	Police Department	3.77%	SouthEastern Garage	Plumbing Fixtures	Potentially Critical-12 months	District 4	Plumbing Fixtures	Damaged	Replace Faucet Set; Chrome;	\$1,107
54	771	Police Department	3.77%	SouthEastern Garage	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Failing	Replace Electric Water Cooler Wall Mount	\$2,629
54	771	Police Department	3.77%	SouthEastern Garage	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Failing	Replaces fixture flush valve	\$2,608
54	773	Police Department	3.77%	SouthEastern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$41,750
54	773	Police Department	3.77%	SouthEastern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Patch plaster walls	\$5,318
54	773	Police Department	3.77%	SouthEastern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
54	776	Police Department	3.77%	SouthEastern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Damaged	Replace Flour. Ltg. Fix. 1x4 Surf. Mtd. 2 Lamp	\$725
54	776	Police Department	3.77%	SouthEastern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,867
54	777	Police Department	3.77%	SouthEastern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$9,962
54	777	Police Department	3.77%	SouthEastern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
54	779	Police Department	3.77%	SouthEastern Garage	Domestic Water Distribution	Potentially Critical-12 months	District 4	Plumbing Fixtures	Missing	Secure Recess Valve Box; up to 6" x 6"; Steel	\$553
54	780	Police Department	3.77%	SouthEastern Garage	Fittings	Potentially Critical-12 months	District 4	Fittings	Damaged	Replace Soap Dispenser; Wall Mtd.	\$1,087
54	781	Police Department	3.77%	SouthEastern Garage	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Failing	Prepare and Paint Ext. Metal Window; Up To 20 SF	\$963
54	782	Police Department	3.77%	SouthEastern Garage	Site Development	Necessary- 2-5 Yrs	District 4	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,459
54	784	Police Department	3.77%	SouthEastern Garage	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,793
54	785	Police Department	3.77%	SouthEastern Garage	Stair Construction	Necessary- 2-5 Yrs	District 4	Stairs	Damaged	Paint Metal Stairs Risers Rails Treads	\$2,799
54	789	Police Department	3.77%	SouthEastern Garage	Vehicle Exhaust System	Necessary- 2-5 Yrs	District 4	Vehicle Exhaust System	Damaged	Replace Exhaust Fan; Roof Top; Utility; 3600 CFM	\$6,261
54	792	Police Department	3.77%	SouthEastern Garage	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$22,442
54	793	Police Department	3.77%	SouthEastern Garage	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Seal stone floor	\$22,996
54	795	Police Department	3.77%	SouthEastern Garage	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$25,005
55	772	Fire Stations	3.77%	Fire Station #42	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$5,120

55	772	Fire Stations	3.77%	Fire Station #42	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,367
55	774	Fire Stations	3.77%	Fire Station #42	Exterior Doors	Potentially Critical-12 months	District 5	Exterior Doors	Damaged	Install or replace exterior hardware	\$6,345
55	774	Fire Stations	3.77%	Fire Station #42	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$746
55	774	Fire Stations	3.77%	Fire Station #42	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$48,863
55	775	Fire Stations	3.77%	Fire Station #42	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace Carpet	\$51,867
55	775	Fire Stations	3.77%	Fire Station #42	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace Ceramic Tile	\$16,571
55	775	Fire Stations	3.77%	Fire Station #42	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace VCT	\$883
55	778	Fire Stations	3.77%	Fire Station #42	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$13,826
55	778	Fire Stations	3.77%	Fire Station #42	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$9,033
55	783	Fire Stations	3.77%	Fire Station #42	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
55	786	Fire Stations	3.77%	Fire Station #42	Domestic Water Distribution	Necessary- 2-5 Yrs	District 5	Domestic Water Distribution	Abandoned	Remove abandoned equipment/system	\$4,809
55	787	Fire Stations	3.77%	Fire Station #42	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$5,057
55	788	Fire Stations	3.77%	Fire Station #42	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,468
55	790	Fire Stations	3.77%	Fire Station #42	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 5	Vehicle Exhaust System	Failing	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$12,736
55	791	Fire Stations	3.77%	Fire Station #42	Communications and Security	Necessary- 2-5 Yrs	District 5	Communications/Security	Beyond Expected Life	Replace Intercom/Paging System-50 stations	\$19,195
55	794	Fire Stations	3.77%	Fire Station #42	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$24,753
56	797	Police Department	3.75%	Northern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,915
56	797	Police Department	3.75%	Northern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$1,488
56	797	Police Department	3.75%	Northern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,404
56	798	Police Department	3.75%	Northern Substation	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Damaged	Replace Drain Trap; Lavatory; Chrome	\$2,941
56	798	Police Department	3.75%	Northern Substation	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Failing	Replaces fixture flush valve	\$6,520
56	798	Police Department	3.75%	Northern Substation	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Failing	Replace Drinking Fountain	\$3,293
56	799	Police Department	3.75%	Northern Substation	Site Development	Necessary- 2-5 Yrs	District 1	Site Development	Damaged	Repair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$902
56	799	Police Department	3.75%	Northern Substation	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Failing	Repaint Metal Fence	\$3,022
56	800	Police Department	3.75%	Northern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
56	800	Police Department	3.75%	Northern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Exterior stucco/plaster wall paint single story	\$11,807
56	801	Police Department	3.75%	Northern Substation	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Failing	Prepare and Paint Concrete Eaves and Fascia	\$47,661
56	801	Police Department	3.75%	Northern Substation	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Damaged	Repair Concrete Fascia	\$6,374
56	802	Police Department	3.75%	Northern Substation	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Failing	Slurry seal asphalt	\$82,563
56	802	Police Department	3.75%	Northern Substation	Parking Lots	Necessary- 2-5 Yrs	District 1	Roadways	Damaged	Replace Concrete Roadway	\$6,188
56	803	Police Department	3.75%	Northern Substation	Electrical Service/Distribution	Critical / Immediate Need	District 1	Electrical Service/Distribution	Inadequate	Re-Install Panel Board Cover; Cover On-Site	\$1,096
56	804	Police Department	3.75%	Northern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$14,350
56	805	Police Department	3.75%	Northern Substation	Roof Openings	Necessary- 2-5 Yrs	District 1	Roof Openings	Damaged	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$1,029
56	806	Police Department	3.75%	Northern Substation	Communications and Security	Necessary- 2-5 Yrs	District 1	Communications/Security	Damaged	Replace or Install Ceiling Smoke Detector	\$1,469
56	807	Police Department	3.75%	Northern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$9,853
56	808	Police Department	3.75%	Northern Substation	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace 3T Heat Pump	\$10,961
56	809	Police Department	3.75%	Northern Substation	Site Lighting	Necessary- 2-5 Yrs	District 1	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$28,850
56	810	Police Department	3.75%	Northern Substation	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$36,869
56	811	Police Department	3.75%	Northern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$205,322
57	812	Police Department	3.74%	SouthEastern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$4,661
57	812	Police Department	3.74%	SouthEastern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$13,336
57	812	Police Department	3.74%	SouthEastern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$44,761
57	812	Police Department	3.74%	SouthEastern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Rubber Flooring	\$7,453
57	813	Police Department	3.74%	SouthEastern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Metal Panels	\$19,071
57	813	Police Department	3.74%	SouthEastern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$21,356
57	814	Police Department	3.74%	SouthEastern Substation	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Lockers	\$162,722
57	814	Police Department	3.74%	SouthEastern Substation	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
57	815	Police Department	3.74%	SouthEastern Substation	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$15,842
57	815	Police Department	3.74%	SouthEastern Substation	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$238,374
57	816	Police Department	3.74%	SouthEastern Substation	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$15,842
57	817	Police Department	3.74%	SouthEastern Substation	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,412
57	818	Police Department	3.74%	SouthEastern Substation	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Hatches and Access doors	\$2,012
57	819	Police Department	3.74%	SouthEastern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare Paint Exterior Walls up to 3 Floors	\$4,259
57	820	Police Department	3.74%	SouthEastern Substation	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,963
57	821	Police Department	3.74%	SouthEastern Substation	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$9,942

57	822	Police Department	3.74%	SouthEastern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$65,039
58	823	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$60,204
58	823	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace resisient base moulding	\$4,596
58	823	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace Ceramic Tile	\$3,908
58	823	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace VCT	\$5,275
58	824	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$3,056
58	824	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$7,062
58	825	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Replace Ceramic Tile	\$6,818
58	825	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$11,440
58	826	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Failing	Replace 2 T Gas/Elec rooftop Packaged Unit	\$10,080
58	826	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Failing	Replace Ductwork Pkg Sys/Ton	\$9,933
58	827	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$1,791
58	828	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Domestic Water Distribution	Potentially Critical-12 months	District 5	Water Heaters	Missing	Install or replace insulation on hot water piping	\$647
58	829	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,020
58	830	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Exterior Doors	Potentially Critical-12 months	District 5	Exterior Doors	Missing	Install or replace exterior hardware	\$2,538
58	831	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$5,461
58	832	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
58	833	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,007
58	834	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 5	Plumbing Fixtures	Failing	Replace Vanity Sink, Marble Top	\$6,521
58	835	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 5	Vehicle Exhaust System	Beyond Expected Life	Replace vehicle exhaust system-2 bay	\$10,471
58	836	Fire Stations	3.64%	Fire Station #38 (Mira Mesa)	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$13,235
59	837	Fire Stations	3.60%	Fire Station #16	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Failing	Install or replace kitchen range exhaust hood syst	\$10,829
59	837	Fire Stations	3.60%	Fire Station #16	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$4,740
59	837	Fire Stations	3.60%	Fire Station #16	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$1,442
59	838	Fire Stations	3.60%	Fire Station #16	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,919
59	838	Fire Stations	3.60%	Fire Station #16	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$43,935
59	839	Fire Stations	3.60%	Fire Station #16	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Cooling Generation	Beyond Expected Life	Replace air cooled condensing unit	\$9,606
59	839	Fire Stations	3.60%	Fire Station #16	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Heat Generation	Beyond Expected Life	Replace gas fired forced air furnace w/ evap. Coi	\$8,766
59	840	Fire Stations	3.60%	Fire Station #16	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$17,742
59	840	Fire Stations	3.60%	Fire Station #16	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$4,176
59	841	Fire Stations	3.60%	Fire Station #16	Slab on Grade	Potentially Critical-12 months	District 1	Roadways	Damaged	Repair and fill cracks and spalping.	\$6,306
59	842	Fire Stations	3.60%	Fire Station #16	Site Development	Necessary- 2-5 Yrs	District 1	Other Site Structures	Damaged	Repaint pipe bollards	\$889
59	843	Fire Stations	3.60%	Fire Station #16	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
59	844	Fire Stations	3.60%	Fire Station #16	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,312
59	845	Fire Stations	3.60%	Fire Station #16	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,543
59	846	Fire Stations	3.60%	Fire Station #16	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$5,048
59	847	Fire Stations	3.60%	Fire Station #16	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$5,973
59	848	Fire Stations	3.60%	Fire Station #16	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$7,757
60	849	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$60,204
60	849	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace VCT	\$5,275
60	849	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace resisient base moulding	\$4,596
60	849	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace Ceramic Tile	\$5,601
60	850	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Domestic Water Distribution	Failing	Replace Copper Water Pipe <2 in	\$939
60	850	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Domestic Water Distribution	Potentially Critical-12 months	District 1	Water Heaters	Missing	Install or replace insulation on hot water piping	\$647
60	851	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Replace Ceramic Tile	\$12,422
60	851	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$25,529
60	852	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Replace Acoustical Ceiling Tile	\$9,886
60	852	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$4,278
60	853	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Failing	Clean, Sanitize and Balance Air Distribution SYS	\$2,320
60	854	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,320
60	855	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Exterior Doors	Potentially Critical-12 months	District 1	Exterior Doors	Missing	Install or replace exterior hardware	\$3,807
60	856	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$5,461

60	857	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,925
60	858	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
60	859	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Failing	Replace Parking Lot - Concrete	\$7,762
60	860	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$13,549
60	861	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 1	Vehicle Exhaust System	Beyond Expected Life	Replace vehicle exhaust system-2 bay	\$16,052
60	862	Fire Stations	3.47%	Fire Station #40 -Penasquitos	Emergency Generators	Necessary- 2-5 Yrs	District 1	Emergency Generators	Failing	Replace diesel emergency generator	\$71,453
61	863	Police Department	3.31%	Northeastern Garage	Vehicular Equipment	Potentially Critical-12 months	District 1	Equipment	Failing	Replace Automotive Hydraulic Lift Seals; 5 Ton	\$16,155
61	863	Police Department	3.31%	Northeastern Garage	Vehicular Equipment	Necessary- 2-5 Yrs	District 1	Equipment	Beyond Expected Life	Replace Air Compressor >5HP <= 10HP 2 Stage	\$20,367
61	864	Police Department	3.31%	Northeastern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
61	864	Police Department	3.31%	Northeastern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Patch plaster walls	\$5,134
61	865	Police Department	3.31%	Northeastern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,597
61	866	Police Department	3.31%	Northeastern Garage	Roof Openings	Necessary- 2-5 Yrs	District 1	Roof Openings	Damaged	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$1,029
61	867	Police Department	3.31%	Northeastern Garage	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,793
61	868	Police Department	3.31%	Northeastern Garage	Stair Construction	Necessary- 2-5 Yrs	District 1	Stairs	Damaged	Paint Metal Stairs Risers Rails Treads	\$2,799
61	869	Police Department	3.31%	Northeastern Garage	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Seal stone floor	\$16,958
61	870	Police Department	3.31%	Northeastern Garage	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$22,442
61	871	Police Department	3.31%	Northeastern Garage	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$23,854
62	872	Police Department	3.29%	Southern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
62	872	Police Department	3.29%	Southern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$71,555
62	872	Police Department	3.29%	Southern Substation	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$7,720
62	873	Police Department	3.29%	Southern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$20,621
62	873	Police Department	3.29%	Southern Substation	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Damaged	Replace Duplex Receptacle Cover	\$304
62	874	Police Department	3.29%	Southern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$320
62	874	Police Department	3.29%	Southern Substation	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$15,990
62	875	Police Department	3.29%	Southern Substation	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Repair exterior metal doors	\$18,258
62	875	Police Department	3.29%	Southern Substation	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Prepare Paint Overhead Door	\$1,660
62	876	Police Department	3.29%	Southern Substation	Site Development	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$676
62	876	Police Department	3.29%	Southern Substation	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Failing	Repaint Metal Fence	\$20,570
62	877	Police Department	3.29%	Southern Substation	Rain Water Drainage	Potentially Critical-12 months	District 8	Rain Water Drainage	Inadequate	Clean Out Roof Drain Receptor	\$571
62	878	Police Department	3.29%	Southern Substation	Roof Coverings	Potentially Critical-12 months	District 8	Roof Covering	Damaged	Seal Coat Bitumen Roof Membrane Flashng	\$7,951
62	879	Police Department	3.29%	Southern Substation	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Counter Top; Solid Surface	\$2,543
62	880	Police Department	3.29%	Southern Substation	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Damaged	Perform landscaping maintenance	\$3,847
62	881	Police Department	3.29%	Southern Substation	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Lavator Sink Faucet Drain; Porcelain	\$7,718
62	882	Police Department	3.29%	Southern Substation	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$43,573
62	883	Police Department	3.29%	Southern Substation	Site Lighting	Necessary- 2-5 Yrs	District 8	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$60,584
62	884	Police Department	3.29%	Southern Substation	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Replace Carpet	\$67,586
62	885	Police Department	3.29%	Southern Substation	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Failing	Slurry seal asphalt	\$73,840
62	886	Police Department	3.29%	Southern Substation	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$144,257
63	887	Police Department	3.20%	Southern Garage	Exterior Doors	Potentially Critical-12 months	District 8	Exterior Doors	Damaged	Replace Weatherstripping	\$2,591
63	887	Police Department	3.20%	Southern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$9,962
63	887	Police Department	3.20%	Southern Garage	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
63	888	Police Department	3.20%	Southern Garage	Site Development	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,459
63	888	Police Department	3.20%	Southern Garage	Site Development	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,608
63	889	Police Department	3.20%	Southern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$4,504
63	889	Police Department	3.20%	Southern Garage	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
63	890	Police Department	3.20%	Southern Garage	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,052
63	891	Police Department	3.20%	Southern Garage	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Failing	Prepare and Paint Ext. Metal Window; Up To 20 SF	\$963
63	892	Police Department	3.20%	Southern Garage	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,793
63	893	Police Department	3.20%	Southern Garage	Stair Construction	Necessary- 2-5 Yrs	District 8	Stairs	Damaged	Paint Metal Stairs Risers Rails Treads	\$2,799
63	894	Police Department	3.20%	Southern Garage	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$22,442
63	895	Police Department	3.20%	Southern Garage	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$25,496
63	896	Police Department	3.20%	Southern Garage	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Epoxy floor	\$85,049
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install emergency exhaust for Laboratory	\$13,328
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$22,998
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Potentially Critical-12 months	District 2	Fire Supression	Missing	Install exterior vent from the flammable storage	\$3,304
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Potentially Critical-12 months	District 2	Fire Supression	Missing	Install exterior vent from the flammable storage	\$2,447

64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$32,278
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Necessary- 2-5 Yrs	District 2	Distribution Systems	Beyond Expected Life	Install or replace supply air system	\$291,532
64	897	Police Department	2.73%	Police Station Headquarters	Exhaust Fans	Necessary- 2-5 Yrs	District 2	Distribution Systems	Beyond Expected Life	Replace Roof Mounted Exhaust Fan	\$101,220
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Potentially Critical-12 months	District 2	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$251,968
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU	\$66,045
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU	\$91,659
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU	\$66,045
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU	\$66,045
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU	\$66,045
64	898	Police Department	2.73%	Police Station Headquarters	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU	\$66,045
64	899	Police Department	2.73%	Police Station Headquarters	Sprinklers	Critical / Immediate Need	District 2	Fire Supression	Inadequate	Install or replace wet fire suppression system	\$9,616
64	899	Police Department	2.73%	Police Station Headquarters	Sprinklers	Necessary- 2-5 Yrs	District 2	Fire Supression	Inadequate	Install or replace wet fire suppression system	\$10,904
64	899	Police Department	2.73%	Police Station Headquarters	Sprinklers	Necessary- 2-5 Yrs	District 2	Fire Supression	Inadequate	Install or replace wet fire suppression system	\$5,452
64	900	Police Department	2.73%	Police Station Headquarters	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace door hardware	\$3,494
64	900	Police Department	2.73%	Police Station Headquarters	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$70,681
64	900	Police Department	2.73%	Police Station Headquarters	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace transom	\$234
64	900	Police Department	2.73%	Police Station Headquarters	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$10,758
64	901	Police Department	2.73%	Police Station Headquarters	Other Electrical Systems	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$2,404
64	901	Police Department	2.73%	Police Station Headquarters	Other Electrical Systems	Potentially Critical-12 months	District 2	Other Electrical Systems	Missing	Install emergency utility shutoff circuit	\$7,704
64	902	Police Department	2.73%	Police Station Headquarters	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Replace Wall Panelling	\$753
64	902	Police Department	2.73%	Police Station Headquarters	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$414,495
64	902	Police Department	2.73%	Police Station Headquarters	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$5,653
64	903	Police Department	2.73%	Police Station Headquarters	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$251,968
64	903	Police Department	2.73%	Police Station Headquarters	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$14,376
64	903	Police Department	2.73%	Police Station Headquarters	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$14,376
64	904	Police Department	2.73%	Police Station Headquarters	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Stall Shower	\$3,865
64	904	Police Department	2.73%	Police Station Headquarters	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Stall Shower	\$6,183
64	905	Police Department	2.73%	Police Station Headquarters	Electrical Service/Distribution	Potentially Critical-12 months	District 2	Electrical Service/Distribution	Damaged	Inspect clean and service main service switdhgear	\$9,616
64	905	Police Department	2.73%	Police Station Headquarters	Electrical Service/Distribution	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$20,101
64	906	Police Department	2.73%	Police Station Headquarters	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$71,087
64	906	Police Department	2.73%	Police Station Headquarters	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,532,992
64	906	Police Department	2.73%	Police Station Headquarters	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$1,467
64	907	Police Department	2.73%	Police Station Headquarters	Cooling Generating Systems	Potentially Critical-12 months	District 2	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$39,537
64	907	Police Department	2.73%	Police Station Headquarters	Cooling Generating Systems	Necessary- 2-5 Yrs	District 2	Distribution Systems	Damaged	Install or replace piping thermal insulation	\$12,447
64	908	Police Department	2.73%	Police Station Headquarters	Site Development	Necessary- 2-5 Yrs	District 2	Other Site Structures	Beyond Useful Life	Repaint pipe bollards	\$889
64	908	Police Department	2.73%	Police Station Headquarters	Site Development	Necessary- 2-5 Yrs	District 2	Stairs	Failing	Repaint Handrails	\$1,850
64	909	Police Department	2.73%	Police Station Headquarters	Partitions	Necessary- 2-5 Yrs	District 2	Partitions	Damaged	Replace wall insulation	\$4,562
64	909	Police Department	2.73%	Police Station Headquarters	Partitions	Necessary- 2-5 Yrs	District 2	Partitions	Damaged	Replace wall insulation	\$16,630
64	910	Police Department	2.73%	Police Station Headquarters	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Failing	Replace expansion joint filler	\$30,545
64	910	Police Department	2.73%	Police Station Headquarters	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Slurry seal asphalt	\$50,692
64	911	Police Department	2.73%	Police Station Headquarters	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Beyond Expected Life	Replace Bathroom Sink Cabinet	\$379,068
64	911	Police Department	2.73%	Police Station Headquarters	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Equipment	Missing	Install or replace dust collection equipment	\$2,338
64	912	Police Department	2.73%	Police Station Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$3,754,086
64	912	Police Department	2.73%	Police Station Headquarters	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$104,534
64	913	Police Department	2.73%	Police Station Headquarters	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
64	914	Police Department	2.73%	Police Station Headquarters	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Patch concrete	\$4,110
64	915	Police Department	2.73%	Police Station Headquarters	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Fencing	Missing	Install protective security fencing	\$26,624
64	916	Police Department	2.73%	Police Station Headquarters	Roadways	Necessary- 2-5 Yrs	District 2	Slab on Grade	Damaged	Replace Slab On Grade	\$182,850
64	917	Police Department	2.73%	Police Station Headquarters	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Failing	Replace Aluminium Windows	\$240,004
64	918	Police Department	2.73%	Police Station Headquarters	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Built up Roof	\$293,486
64	919	Police Department	2.73%	Police Station Headquarters	Communications and Security	Necessary- 2-5 Yrs	District 2	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 100 devices	\$378,038
64	920	Police Department	2.73%	Police Station Headquarters	Exterior Walls	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$482,856
65	921	Police Department	2.55%	Police Horse Stables Balboa Pk	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$414

65	921	Police Department	2.55%	Police Horse Stables Balboa Pk	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,461
65	921	Police Department	2.55%	Police Horse Stables Balboa Pk	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$6,846
65	922	Police Department	2.55%	Police Horse Stables Balboa Pk	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$4,423
65	923	Police Department	2.55%	Police Horse Stables Balboa Pk	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace door hardware	\$9,103
65	924	Police Department	2.55%	Police Horse Stables Balboa Pk	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Slurry seal asphalt	\$9,251
66	925	Fire Stations	2.40%	Fire Station #13	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$26,545
66	925	Fire Stations	2.40%	Fire Station #13	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$549
66	925	Fire Stations	2.40%	Fire Station #13	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$7,191
66	926	Fire Stations	2.40%	Fire Station #13	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,950
66	926	Fire Stations	2.40%	Fire Station #13	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$21,707
66	927	Fire Stations	2.40%	Fire Station #13	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$1,165
66	928	Fire Stations	2.40%	Fire Station #13	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
66	929	Fire Stations	2.40%	Fire Station #13	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$7,728
66	930	Fire Stations	2.40%	Fire Station #13	Vehicle Exhaust Systems	Necessary- 2-5 Yrs	District 1	Vehicle Exhaust System	Beyond Useful Life	Replace Vehicle Exhaust System - Diesel - 1 Bay	\$10,658
67	931	Fire Stations	1.96%	Fire Station #31 Del Cerro	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,487
67	931	Fire Stations	1.96%	Fire Station #31 Del Cerro	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Failing	Replace Incandescent Light Fixtures	\$2,685
67	931	Fire Stations	1.96%	Fire Station #31 Del Cerro	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$8,700
67	932	Fire Stations	1.96%	Fire Station #31 Del Cerro	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$11,544
67	932	Fire Stations	1.96%	Fire Station #31 Del Cerro	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,138
67	932	Fire Stations	1.96%	Fire Station #31 Del Cerro	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$65,276
67	933	Fire Stations	1.96%	Fire Station #31 Del Cerro	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$23,602
67	933	Fire Stations	1.96%	Fire Station #31 Del Cerro	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Weatherstripping	\$419
67	934	Fire Stations	1.96%	Fire Station #31 Del Cerro	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$42,710
67	936	Fire Stations	1.96%	Fire Station #31 Del Cerro	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$3,895
67	937	Fire Stations	1.96%	Fire Station #31 Del Cerro	Stair Construction	Necessary- 2-5 Yrs	District 7	Stairs	Damaged	Repaint Handrails	\$394
67	938	Fire Stations	1.96%	Fire Station #31 Del Cerro	Site Development	Necessary- 2-5 Yrs	District 7	Fencing	Damaged	Replace concrete block fencing	\$2,012
67	939	Fire Stations	1.96%	Fire Station #31 Del Cerro	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
67	940	Fire Stations	1.96%	Fire Station #31 Del Cerro	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,443
67	941	Fire Stations	1.96%	Fire Station #31 Del Cerro	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,790
67	942	Fire Stations	1.96%	Fire Station #31 Del Cerro	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$7,137
67	943	Fire Stations	1.96%	Fire Station #31 Del Cerro	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Slurry seal asphalt	\$11,409
67	944	Fire Stations	1.96%	Fire Station #31 Del Cerro	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$13,323
68	945	Fire Stations	1.61%	Fire Station #37	Site Development	Necessary- 2-5 Yrs	District 5	Fencing	Failing	Repaint Metal Fence	\$3,874
68	945	Fire Stations	1.61%	Fire Station #37	Site Development	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Re-plaster Wall	\$1,893
68	945	Fire Stations	1.61%	Fire Station #37	Site Development	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Replace Stucco Wall	\$1,320
68	945	Fire Stations	1.61%	Fire Station #37	Site Development	Necessary- 2-5 Yrs	District 5	Other Site Structures	Failing	Repaint pipe bollards	\$1,185
68	946	Fire Stations	1.61%	Fire Station #37	Exterior Doors	Potentially Critical-12 months	District 5	Exterior Doors	Damaged	Install or replace exterior hardware	\$1,269
68	946	Fire Stations	1.61%	Fire Station #37	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$16,692
68	946	Fire Stations	1.61%	Fire Station #37	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Inadequate	Replace Overhead Door; Roll-Up; Motorized	\$73,295
68	947	Fire Stations	1.61%	Fire Station #37	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Repaint or restripe Parking Lot/	\$1,725
68	947	Fire Stations	1.61%	Fire Station #37	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Failing	Replace expansion joint filler	\$539
68	948	Fire Stations	1.61%	Fire Station #37	Exterior Walls	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$1,672
68	948	Fire Stations	1.61%	Fire Station #37	Exterior Walls	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$1,863
68	949	Fire Stations	1.61%	Fire Station #37	Vehicle Exhaust Systems	Potentially Critical-12 months	District 5	Flue/Exhaust Stack	Missing	Install of replace discharge stack	\$1,882
68	950	Fire Stations	1.61%	Fire Station #37	Terminal & Package Units	Potentially Critical-12 months	District 5	Terminal and Package Units	Failing	Install or Replace thermal insulation on refig.	\$2,911
68	951	Fire Stations	1.61%	Fire Station #37	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$7,685
68	952	Fire Stations	1.61%	Fire Station #37	Slab on Grade	Potentially Critical-12 months	District 5	Roadways	Damaged	Repair and fill cracks and spalding.	\$9,315
68	953	Fire Stations	1.61%	Fire Station #37	Roadways	Potentially Critical-12 months	District 5	Roadways	Damaged	Repair and fill cracks and spalding.	\$11,465
68	954	Fire Stations	1.61%	Fire Station #37	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$761
68	955	Fire Stations	1.61%	Fire Station #37	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$776
68	956	Fire Stations	1.61%	Fire Station #37	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$2,408
68	957	Fire Stations	1.61%	Fire Station #37	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
68	958	Fire Stations	1.61%	Fire Station #37	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Failing	Replace Modified Bitumen Roof Coverings	\$2,972
68	959	Fire Stations	1.61%	Fire Station #37	Exterior Windows	Necessary- 2-5 Yrs	District 5	Exterior Windows	Damaged	Replace Aluminium Windows	\$5,737
68	960	Fire Stations	1.61%	Fire Station #37	Roof Construction	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$6,472
69	961	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$443
69	961	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$35,315

69	961	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$4,659
69	961	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$14,278
69	962	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,906
69	962	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Replace 2X4 Flourescent Fixture Ea.	\$8,557
69	963	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Stair Construction	Necessary- 2-5 Yrs	District 4	Stairs	Damaged	Repaint Handrails	\$502
69	963	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Stair Construction	Necessary- 2-5 Yrs	District 4	Stairs	Damaged	Replace Rubber Treads, Risers and Landing	\$1,399
69	964	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,190
69	964	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,914
69	965	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$5,738
69	965	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$994
69	966	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Exhaust Ventilation System - Other than Vehicle	Potentially Critical-12 months	District 4	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$7,790
69	967	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$10,906
69	968	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint exterior metal doors	\$746
69	969	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
69	970	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$6,687
69	971	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$26,209
69	972	Fire Stations	1.56%	Fire Station #12 Lincoln Park	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$52,551
70	973	Fire Stations	1.13%	Fire Station #44 (R)	Terminal & Package Units	Potentially Critical-12 months	District 5	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
70	973	Fire Stations	1.13%	Fire Station #44 (R)	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$4,729
70	974	Fire Stations	1.13%	Fire Station #44 (R)	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,109
70	975	Fire Stations	1.13%	Fire Station #44 (R)	Domestic Water Distribution	Potentially Critical-12 months	District 5	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,294
70	976	Fire Stations	1.13%	Fire Station #44 (R)	Roadways	Potentially Critical-12 months	District 5	Roadways	Damaged	Repair and fill cracks and spalding.	\$2,006
70	977	Fire Stations	1.13%	Fire Station #44 (R)	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,729
70	978	Fire Stations	1.13%	Fire Station #44 (R)	Slab on Grade	Potentially Critical-12 months	District 5	Roadways	Damaged	Repair and fill cracks and spalding.	\$5,159
70	979	Fire Stations	1.13%	Fire Station #44 (R)	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Failing	Replace door hardware	\$850
70	980	Fire Stations	1.13%	Fire Station #44 (R)	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Stairs	Damaged	Repaint Handrails	\$943
70	981	Fire Stations	1.13%	Fire Station #44 (R)	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Damaged	Replace Built up Roof	\$945
70	982	Fire Stations	1.13%	Fire Station #44 (R)	Site Development	Necessary- 2-5 Yrs	District 5	Other Site Structures	Failing	Repaint pipe bollards	\$1,110
70	983	Fire Stations	1.13%	Fire Station #44 (R)	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$1,863
70	984	Fire Stations	1.13%	Fire Station #44 (R)	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
70	985	Fire Stations	1.13%	Fire Station #44 (R)	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Replace Stucco Wall	\$11,079
70	986	Fire Stations	1.13%	Fire Station #44 (R)	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Beyond Useful Life	Replace Overhead Door; Roll-Up; Motorized	\$93,170
71	987	Police Department	0.99%	Central, Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$6,132
71	987	Police Department	0.99%	Central, Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$91,387
71	987	Police Department	0.99%	Central, Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$1,503
71	987	Police Department	0.99%	Central, Lincoln Park	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$608
71	988	Police Department	0.99%	Central, Lincoln Park	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$414
71	988	Police Department	0.99%	Central, Lincoln Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$25,004
71	988	Police Department	0.99%	Central, Lincoln Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$3,423
71	989	Police Department	0.99%	Central, Lincoln Park	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Decorative Tile	\$18,554
71	989	Police Department	0.99%	Central, Lincoln Park	Exterior Walls	Necessary- 2-5 Yrs	District 8	Partitions	Damaged	Repair/Re-point Concrete Block Wall	\$3,861
71	990	Police Department	0.99%	Central, Lincoln Park	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$62,125
71	991	Police Department	0.99%	Central, Lincoln Park	Roadways	Potentially Critical-12 months	District 8	Roadways	Damaged	Repair and fill cracks and spalding.	\$3,224
71	992	Police Department	0.99%	Central, Lincoln Park	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$413
71	993	Police Department	0.99%	Central, Lincoln Park	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
71	994	Police Department	0.99%	Central, Lincoln Park	Partitions	Necessary- 2-5 Yrs	District 8	Partitions	Damaged	Repair Drywall Partitions	\$4,311
71	995	Police Department	0.99%	Central, Lincoln Park	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repaint exterior metal doors	\$7,156
71	996	Police Department	0.99%	Central, Lincoln Park	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,291
71	997	Police Department	0.99%	Central, Lincoln Park	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace sheet metal flashing	\$11,910
71	998	Police Department	0.99%	Central, Lincoln Park	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Bullet Resisting Glass	\$12,082
71	999	Police Department	0.99%	Central, Lincoln Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$24,638
72	1000	Fire Stations	0.46%	Fire Station #29, San Ysidro	Exhaust and Ventilation	Potentially Critical-12 months	District 8	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
72	1001	Fire Stations	0.46%	Fire Station #29, San Ysidro	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
72	1002	Fire Stations	0.46%	Fire Station #29, San Ysidro	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Failing	Repair or replace laminate	\$2,885
72	1003	Fire Stations	0.46%	Fire Station #29, San Ysidro	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
72	1004	Fire Stations	0.46%	Fire Station #29, San Ysidro	Vehicle Exhaust System	Necessary- 2-5 Yrs	District 8	Distribution Systems	Inadequate	Replace Roof Mounted Exhaust Fan	\$5,741
72	1005	Fire Stations	0.46%	Fire Station #29, San Ysidro	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$23,297

73	1006	Fire Stations	0.24%	Fire Station #46	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Flue/Exhaust Stack	Missing	Install of replace discharge stack	\$1,882
73	1006	Fire Stations	0.24%	Fire Station #46	Exhaust Ventilation Systems Other than Vehicle	Potentially Critical-12 months	District 1	Flue/Exhaust Stack	Missing	Install of replace discharge stack	\$3,764
73	1007	Fire Stations	0.24%	Fire Station #46	Sprinklers	Critical / Immediate Need	District 1	Fire Supression	Missing	Install or replace fire extinguisher	\$160
73	1008	Fire Stations	0.24%	Fire Station #46	Electrical Service/Distribution	Critical / Immediate Need	District 1	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
73	1009	Fire Stations	0.24%	Fire Station #46	Domestic Water Distribution	Potentially Critical-12 months	District 1	Water Heaters	Missing	Install or replace insulation on hot water piping	\$647
73	1010	Fire Stations	0.24%	Fire Station #46	Exterior Doors	Potentially Critical-12 months	District 1	Exterior Doors	Missing	Install or replace exterior hardware	\$1,269
73	1011	Fire Stations	0.24%	Fire Station #46	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Failing	Repaint or restripe Parking Lot/	\$126
73	1012	Fire Stations	0.24%	Fire Station #46	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
73	1013	Fire Stations	0.24%	Fire Station #46	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace Carpet	\$14,716
74	1014	Comfort Stations	105.32%	#000532	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$588
74	1014	Comfort Stations	105.32%	#000532	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
74	1015	Comfort Stations	105.32%	#000532	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$11,929
74	1015	Comfort Stations	105.32%	#000532	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,297
74	1016	Comfort Stations	105.32%	#000532	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
74	1016	Comfort Stations	105.32%	#000532	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$9,677
74	1017	Comfort Stations	105.32%	#000532	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$1,048
74	1018	Comfort Stations	105.32%	#000532	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$1,069
74	1019	Comfort Stations	105.32%	#000532	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$1,082
74	1020	Comfort Stations	105.32%	#000532	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
74	1021	Comfort Stations	105.32%	#000532	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Damaged	Replace Domestic Water and Sanitary Piping (SF)	\$1,679
74	1022	Comfort Stations	105.32%	#000532	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Expected Life	Replace domestic water service	\$3,433
74	1023	Comfort Stations	105.32%	#000532	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Beyond Useful Life	Replace Modified Bitumen Roof Coverings	\$7,537
74	1024	Comfort Stations	105.32%	#000532	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$11,794
74	1025	Comfort Stations	105.32%	#000532	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Roof Fascia	\$28,654
75	1026	Comfort Stations	88.30%	#000803	Fittings	Potentially Critical-12 months	District 2	Fittings	Failing	Replace outdoor metal cabinet	\$1,489
75	1026	Comfort Stations	88.30%	#000803	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Toilet Partition	\$7,920
75	1026	Comfort Stations	88.30%	#000803	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
75	1027	Comfort Stations	88.30%	#000803	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$277
75	1027	Comfort Stations	88.30%	#000803	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$6,161
75	1027	Comfort Stations	88.30%	#000803	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$9,709
75	1028	Comfort Stations	88.30%	#000803	Plumbing Fixtures	Potentially Critical-12 months	District 2	Plumbing Fixtures	Failing	Unclog / Clear Drain w/Auger	\$1,077
75	1028	Comfort Stations	88.30%	#000803	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace 3 Fixture Rest Room Assembly; 1 Wall	\$19,419
75	1028	Comfort Stations	88.30%	#000803	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
75	1029	Comfort Stations	88.30%	#000803	Exterior Walls	Potentially Critical-12 months	District 2	Exterior Walls	Damaged	Replace Stucco Wall	\$19,298
75	1029	Comfort Stations	88.30%	#000803	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$7,040
75	1030	Comfort Stations	88.30%	#000803	Exterior Doors	Potentially Critical-12 months	District 2	Exterior Doors	Damaged	Replace Exterior Door Frame up to 3/0x7/0	\$5,153
75	1031	Comfort Stations	88.30%	#000803	Ceiling Finishes	Potentially Critical-12 months	District 2	Ceiling Finishes	Damaged	Replace Plaster and Lath Ceiling	\$9,344
75	1032	Comfort Stations	88.30%	#000803	Wall Finishes	Potentially Critical-12 months	District 2	Wall Finishes	Damaged	Replace Plaster / Lath Interior Wall	\$19,975
75	1033	Comfort Stations	88.30%	#000803	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$1,906
75	1034	Comfort Stations	88.30%	#000803	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
75	1035	Comfort Stations	88.30%	#000803	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Wood Windows	\$6,391
75	1036	Comfort Stations	88.30%	#000803	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
75	1037	Comfort Stations	88.30%	#000803	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$8,298
75	1038	Comfort Stations	88.30%	#000803	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$14,704
76	1039	Comfort Stations	79.97%	#000797	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$512
76	1039	Comfort Stations	79.97%	#000797	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$2,898
76	1039	Comfort Stations	79.97%	#000797	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
76	1039	Comfort Stations	79.97%	#000797	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$425
76	1040	Comfort Stations	79.97%	#000797	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Termite Inspection of Roof structure	\$73,220
76	1040	Comfort Stations	79.97%	#000797	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$6,122
76	1041	Comfort Stations	79.97%	#000797	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
76	1041	Comfort Stations	79.97%	#000797	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
76	1041	Comfort Stations	79.97%	#000797	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,516
76	1042	Comfort Stations	79.97%	#000797	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,580
76	1042	Comfort Stations	79.97%	#000797	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,793

76	1043	Comfort Stations	79.97%	#000797	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
76	1043	Comfort Stations	79.97%	#000797	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$3,957
76	1044	Comfort Stations	79.97%	#000797	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Failing	Replace Modified Bitumen Roof Coverings	\$23,327
76	1045	Comfort Stations	79.97%	#000797	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$834
76	1046	Comfort Stations	79.97%	#000797	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$986
76	1047	Comfort Stations	79.97%	#000797	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,463
76	1048	Comfort Stations	79.97%	#000797	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$2,575
76	1049	Comfort Stations	79.97%	#000797	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,862
76	1050	Comfort Stations	79.97%	#000797	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$2,107
76	1051	Comfort Stations	79.97%	#000797	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$7,709
77	1052	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Walls	Critical / Immediate Need	District 8	Exterior Walls	Inadequate	Install Safety Railing	\$10,888
77	1052	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Concrete Steps	\$17,200
77	1052	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
77	1052	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Concrete Steps	\$7,564
77	1052	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare and Paint Exterior Concrete Wall Surface	\$150,142
77	1052	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Metal Siding	\$170,416
77	1053	OF - Field Office	28.27%	#000030 Central Maintenance	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Replace Carpet	\$117,836
77	1053	OF - Field Office	28.27%	#000030 Central Maintenance	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$22,520
77	1053	OF - Field Office	28.27%	#000030 Central Maintenance	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$11,260
77	1053	OF - Field Office	28.27%	#000030 Central Maintenance	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Seal stone floor	\$8,705
77	1054	OF - Field Office	28.27%	#000030 Central Maintenance	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$27,053
77	1054	OF - Field Office	28.27%	#000030 Central Maintenance	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$189,668
77	1054	OF - Field Office	28.27%	#000030 Central Maintenance	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$115,772
77	1055	OF - Field Office	28.27%	#000030 Central Maintenance	Fittings	Critical / Immediate Need	District 8	Fittings	Inadequate	Remove Building Ladder	\$588
77	1055	OF - Field Office	28.27%	#000030 Central Maintenance	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Beyond Expected Life	Replace Toilet Partition	\$19,800
77	1056	OF - Field Office	28.27%	#000030 Central Maintenance	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Guard Rail; Steel	\$2,930
77	1056	OF - Field Office	28.27%	#000030 Central Maintenance	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$9,754
77	1056	OF - Field Office	28.27%	#000030 Central Maintenance	Parking Lots	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$451
77	1057	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Expected Life	Replace Store Front Door	\$6,335
77	1057	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Expected Life	Replace Commercial Sliding Bay Door	\$12,241
77	1057	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Steel Doors	\$15,362
77	1058	OF - Field Office	28.27%	#000030 Central Maintenance	Roof Construction	Critical / Immediate Need	District 8	Roof Construction	Damaged	Replace roof construction assembly	\$89,619
77	1059	OF - Field Office	28.27%	#000030 Central Maintenance	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$65,805
77	1059	OF - Field Office	28.27%	#000030 Central Maintenance	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace 30 Gal Gas Water Heater	\$2,804
77	1060	OF - Field Office	28.27%	#000030 Central Maintenance	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace Panel Board; 200A; 240V; 1-Phase; 42 Ckt.	\$67,050
77	1060	OF - Field Office	28.27%	#000030 Central Maintenance	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$71,095
77	1061	OF - Field Office	28.27%	#000030 Central Maintenance	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Prepare and Paint Interior Ceiling	\$121,144
77	1061	OF - Field Office	28.27%	#000030 Central Maintenance	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$111,307
77	1062	OF - Field Office	28.27%	#000030 Central Maintenance	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$153,394
77	1062	OF - Field Office	28.27%	#000030 Central Maintenance	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$195,646
77	1063	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Window Awning	\$134,192
77	1063	OF - Field Office	28.27%	#000030 Central Maintenance	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Beyond Expected Life	Replace Steel Windows	\$599,442
77	1064	OF - Field Office	28.27%	#000030 Central Maintenance	Rain Water Drainage	Critical / Immediate Need	District 8	Rain Water Drainage	Damaged	Replace Gutter; Aluminum up to 6" x LF	\$20,615
77	1065	OF - Field Office	28.27%	#000030 Central Maintenance	Roof Coverings	Critical / Immediate Need	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$301,734
77	1066	OF - Field Office	28.27%	#000030 Central Maintenance	Water Supply	Potentially Critical-12 months	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$6,833
77	1067	OF - Field Office	28.27%	#000030 Central Maintenance	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$24,362
77	1068	OF - Field Office	28.27%	#000030 Central Maintenance	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$25,220
77	1069	OF - Field Office	28.27%	#000030 Central Maintenance	Exhaust Fans	Necessary- 2-5 Yrs	District 8	Exhaust Ventilation System	Damaged	Install new exhaust system and controls	\$63,889
77	1070	OF - Field Office	28.27%	#000030 Central Maintenance	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Failing	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$65,512
77	1071	OF - Field Office	28.27%	#000030 Central Maintenance	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$102,930
77	1072	OF - Field Office	28.27%	#000030 Central Maintenance	Elevators and Lifts	Necessary- 2-5 Yrs	District 8	Conveying Systems	Beyond Expected Life	Replace 2500# - 4000# Hydraulic Elevator	\$134,305

77	1073	OF - Field Office	28.27%	#000030 Central Maintenance	Sprinklers	Necessary- 2-5 Yrs	District 8	Sprinklers	Beyond Expected Life	Replace Sprinkler System	\$210,512
77	1074	OF - Field Office	28.27%	#000030 Central Maintenance	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$224,115
78	1075	Comfort Stations	76.77%	#001201	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$677
78	1075	Comfort Stations	76.77%	#001201	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
78	1075	Comfort Stations	76.77%	#001201	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
78	1076	Comfort Stations	76.77%	#001201	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
78	1076	Comfort Stations	76.77%	#001201	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
78	1077	Comfort Stations	76.77%	#001201	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$4,287
78	1077	Comfort Stations	76.77%	#001201	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,095
78	1078	Comfort Stations	76.77%	#001201	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Drinking Fountain	\$3,119
78	1078	Comfort Stations	76.77%	#001201	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
78	1079	Comfort Stations	76.77%	#001201	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Roof Fascia	\$5,731
78	1079	Comfort Stations	76.77%	#001201	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$36,980
78	1080	Comfort Stations	76.77%	#001201	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,734
78	1081	Comfort Stations	76.77%	#001201	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Damaged	Replace Domestic Water and Sanitary Piping (SF)	\$3,357
78	1082	Comfort Stations	76.77%	#001201	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$3,852
78	1083	Comfort Stations	76.77%	#001201	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$4,101
78	1084	Comfort Stations	76.77%	#001201	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$5,919
78	1085	Comfort Stations	76.77%	#001201	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$6,416
78	1086	Comfort Stations	76.77%	#001201	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
78	1087	Comfort Stations	76.77%	#001201	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Failing	Replace Asphalt Shingle	\$11,933
78	1088	Comfort Stations	76.77%	#001201	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,647
79	1089	Comfort Stations	72.34%	#001207	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
79	1089	Comfort Stations	72.34%	#001207	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$15,420
79	1090	Comfort Stations	72.34%	#001207	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$50,597
79	1090	Comfort Stations	72.34%	#001207	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Roof Fascia	\$2,526
79	1091	Comfort Stations	72.34%	#001207	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$1,640
79	1092	Comfort Stations	72.34%	#001207	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$1,966
79	1093	Comfort Stations	72.34%	#001207	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
79	1094	Comfort Stations	72.34%	#001207	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$2,576
79	1095	Comfort Stations	72.34%	#001207	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,608
79	1096	Comfort Stations	72.34%	#001207	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,873
79	1097	Comfort Stations	72.34%	#001207	Water Supply	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Repair or replace domestic water piping	\$3,599
79	1098	Comfort Stations	72.34%	#001207	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Useful Life	Replace Asphalt Shingle	\$4,886
80	1099	Comfort Stations	72.01%	#001013	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
80	1099	Comfort Stations	72.01%	#001013	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle 20A 120V ASSY/S.F.	\$3,560
80	1099	Comfort Stations	72.01%	#001013	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$507
80	1100	Comfort Stations	72.01%	#001013	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
80	1100	Comfort Stations	72.01%	#001013	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,541
80	1101	Comfort Stations	72.01%	#001013	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$3,205
80	1101	Comfort Stations	72.01%	#001013	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
80	1101	Comfort Stations	72.01%	#001013	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,516
80	1102	Comfort Stations	72.01%	#001013	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,793
80	1102	Comfort Stations	72.01%	#001013	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$5,716
80	1103	Comfort Stations	72.01%	#001013	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Asphalt Shingle	\$15,227
80	1104	Comfort Stations	72.01%	#001013	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,962
80	1105	Comfort Stations	72.01%	#001013	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$1,993
80	1106	Comfort Stations	72.01%	#001013	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$6,154
80	1107	Comfort Stations	72.01%	#001013	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$15,831
80	1108	Comfort Stations	72.01%	#001013	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Termite Inspection of Roof structure	\$74,106
80	1109	Comfort Stations	72.01%	#001013	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
80	1110	Comfort Stations	72.01%	#001013	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,726
81	1111	Comfort Stations	67.46%	#000853	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567

81	1111	Comfort Stations	67.46%	#000853	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace Toilet Partition	\$6,324
81	1111	Comfort Stations	67.46%	#000853	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$3,755
81	1112	Comfort Stations	67.46%	#000853	Roof Construction	Potentially Critical-12 months	District 3	Roof Construction	Damaged	Replace roof construction assembly	\$5,609
81	1112	Comfort Stations	67.46%	#000853	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Roof Fascia	\$1,541
81	1113	Comfort Stations	67.46%	#000853	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Asphalt Shingle	\$10,170
81	1113	Comfort Stations	67.46%	#000853	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Termite Inspection of Roof structure	\$72,365
81	1114	Comfort Stations	67.46%	#000853	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Damaged	Replace electric service entrance -200 Amp	\$7,709
81	1114	Comfort Stations	67.46%	#000853	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$2,441
81	1115	Comfort Stations	67.46%	#000853	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$492
81	1115	Comfort Stations	67.46%	#000853	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
81	1116	Comfort Stations	67.46%	#000853	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$2,858
81	1116	Comfort Stations	67.46%	#000853	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$2,793
81	1117	Comfort Stations	67.46%	#000853	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
81	1117	Comfort Stations	67.46%	#000853	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Failing	Replace Stainless Steel Plumbing Fixtures	\$15,516
81	1118	Comfort Stations	67.46%	#000853	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$3,003
81	1119	Comfort Stations	67.46%	#000853	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$5,940
81	1120	Comfort Stations	67.46%	#000853	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$15,332
81	1121	Comfort Stations	67.46%	#000853	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$15,352
82	1122	Libraries	16.36%	Ocean Beach Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$2,440
82	1122	Libraries	16.36%	Ocean Beach Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,872
82	1122	Libraries	16.36%	Ocean Beach Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$34,157
82	1122	Libraries	16.36%	Ocean Beach Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$73,312
82	1122	Libraries	16.36%	Ocean Beach Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$7,034
82	1123	Libraries	16.36%	Ocean Beach Library	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$31,270
82	1123	Libraries	16.36%	Ocean Beach Library	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$805
82	1124	Libraries	16.36%	Ocean Beach Library	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$80,067
82	1124	Libraries	16.36%	Ocean Beach Library	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$4,741
82	1125	Libraries	16.36%	Ocean Beach Library	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
82	1126	Libraries	16.36%	Ocean Beach Library	Site Development	Necessary- 2-5 Yrs	District 2	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$962
82	1127	Libraries	16.36%	Ocean Beach Library	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,243
82	1128	Libraries	16.36%	Ocean Beach Library	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$4,359
82	1129	Libraries	16.36%	Ocean Beach Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$8,633
82	1130	Libraries	16.36%	Ocean Beach Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$8,783
82	1131	Libraries	16.36%	Ocean Beach Library	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$11,737
82	1132	Libraries	16.36%	Ocean Beach Library	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$12,444
82	1133	Libraries	16.36%	Ocean Beach Library	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730
82	1134	Libraries	16.36%	Ocean Beach Library	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$15,417
82	1135	Libraries	16.36%	Ocean Beach Library	Standard Foundations	Necessary- 2-5 Yrs	District 2	Foundations	Damaged	Conduct Engineering Assessment - Foundation	\$19,233
82	1136	Libraries	16.36%	Ocean Beach Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$21,573
82	1137	Libraries	16.36%	Ocean Beach Library	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Terminal and Package Units	Beyond Expected Life	Replace unit heaters	\$22,898
82	1138	Libraries	16.36%	Ocean Beach Library	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$34,595
82	1139	Libraries	16.36%	Ocean Beach Library	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Aluminium Windows	\$43,968
83	1141	Comfort Stations	66.34%	#000851	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$553
83	1141	Comfort Stations	66.34%	#000851	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
83	1141	Comfort Stations	66.34%	#000851	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Receptacle 20A 120V ASSY/S.F.	\$3,877
83	1141	Comfort Stations	66.34%	#000851	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Damaged	Replace 1X4 Surface Fluorescent Fixture S.F.	\$12,300
83	1141	Comfort Stations	66.34%	#000851	Lighting and Branch Wiring	Does Not Meet Current Code/Standards	District 3	Lighting/Branch Wiring	Damaged	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$1,856
83	1142	Comfort Stations	66.34%	#000851	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace bath accessories electric air hand dryers	\$2,036
83	1142	Comfort Stations	66.34%	#000851	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
83	1142	Comfort Stations	66.34%	#000851	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace Bathroom Accessories	\$739
83	1143	Comfort Stations	66.34%	#000851	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,848
83	1143	Comfort Stations	66.34%	#000851	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Termite Inspection of Roof structure	\$2,941
83	1144	Comfort Stations	66.34%	#000851	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Beyond Useful Life	Replace Wallboard Ceiling Finish	\$2,126
83	1144	Comfort Stations	66.34%	#000851	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Beyond Useful Life	Repaint drywall/plaster ceiling	\$1,107

83	1145	Comfort Stations	66.34%	#000851	Exterior Walls	Potentially Critical-12 months	District 3	Ventilation and Exhaust	Damaged	Install or replace exterior louvers	\$3,051
83	1146	Comfort Stations	66.34%	#000851	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
83	1146	Comfort Stations	66.34%	#000851	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Plumbing Fixtures	\$23,857
83	1147	Comfort Stations	66.34%	#000851	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$18,014
83	1149	Comfort Stations	66.34%	#000851	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$2,982
83	1150	Comfort Stations	66.34%	#000851	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
83	1151	Comfort Stations	66.34%	#000851	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
83	1152	Comfort Stations	66.34%	#000851	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,718
83	1153	Comfort Stations	66.34%	#000851	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
83	1154	Comfort Stations	66.34%	#000851	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace exit light fixtures	\$1,058
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$30,523
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$185,590
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace 1X4 recessed exterior light fixtures	\$5,886
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Branch Panelboard - 200A	\$9,163
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$85,569
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067
84	1155	Libraries	15.90%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Site Lighting	Beyond Useful Life	Install/Replace HID/HPS 250W exterior wall pack	\$3,435
84	1156	Libraries	15.90%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$4,169
84	1156	Libraries	15.90%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$621
84	1156	Libraries	15.90%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$546
84	1157	Libraries	15.90%	Paradise Hills	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Beyond Expected Life	Replace air cooled D-X heat pump(s)	\$27,286
84	1157	Libraries	15.90%	Paradise Hills	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Beyond Expected Life	Replace Residential Gas Furnace 120MBtu	\$5,681
84	1157	Libraries	15.90%	Paradise Hills	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Distribution Systems	Beyond Expected Life	Replace AHU 3000 CFM	\$43,136
84	1158	Libraries	15.90%	Paradise Hills	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$24,485
84	1158	Libraries	15.90%	Paradise Hills	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,847
84	1159	Libraries	15.90%	Paradise Hills	Exterior Walls	Potentially Critical-12 months	District 4	Exterior Walls	Damaged	Replace Wood Fascia	\$4,843
84	1160	Libraries	15.90%	Paradise Hills	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Patch concrete	\$1,433
84	1161	Libraries	15.90%	Paradise Hills	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Slurry seal asphalt	\$2,865
84	1162	Libraries	15.90%	Paradise Hills	Landscaping	Necessary- 2-5 Yrs	District 4	Landscaping	Inadequate	Perform landscaping maintenance	\$4,809
84	1163	Libraries	15.90%	Paradise Hills	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Gutters and downspouts	\$4,816
84	1164	Libraries	15.90%	Paradise Hills	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Ceramic Tile	\$6,066
84	1165	Libraries	15.90%	Paradise Hills	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$7,531
84	1166	Libraries	15.90%	Paradise Hills	Electrical Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
84	1167	Libraries	15.90%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
84	1167	Libraries	15.90%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
84	1168	Libraries	15.90%	Paradise Hills	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$15,932
84	1169	Libraries	15.90%	Paradise Hills	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Distribution Systems	Beyond Expected Life	Replace Roof Mounted Exhaust Fan	\$18,479
84	1170	Libraries	15.90%	Paradise Hills	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Wood Windows	\$32,521
84	1171	Libraries	15.90%	Paradise Hills	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$39,556
84	3577	Libraries	15.90%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
84	3577	Libraries	15.90%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
85	1172	Libraries	15.39%	Logan Heights	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Missing	Replace exit light fixtures	\$5,104
85	1172	Libraries	15.39%	Logan Heights	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,846
85	1172	Libraries	15.39%	Logan Heights	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
85	1173	Libraries	15.39%	Logan Heights	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$465
85	1173	Libraries	15.39%	Logan Heights	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,954
85	1173	Libraries	15.39%	Logan Heights	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$3,995
85	1173	Libraries	15.39%	Logan Heights	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$52,221
85	1174	Libraries	15.39%	Logan Heights	Electrical Service/Distribution	Critical / Immediate Need	District 8	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962

85	1174	Libraries	15.39%	Logan Heights	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$7,709
85	1175	Libraries	15.39%	Logan Heights	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$6,601
85	1176	Libraries	15.39%	Logan Heights	Exhaust Fans	Necessary- 2-5 Yrs	District 8	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,465
85	1177	Libraries	15.39%	Logan Heights	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
85	1178	Libraries	15.39%	Logan Heights	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$3,145
85	1179	Libraries	15.39%	Logan Heights	Water Supply	Necessary- 2-5 Yrs	District 8	WATER Supply	Beyond Expected Life	Replace domestic water service	\$3,433
85	1180	Libraries	15.39%	Logan Heights	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,189
85	1181	Libraries	15.39%	Logan Heights	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$4,303
85	1182	Libraries	15.39%	Logan Heights	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,799
85	1183	Libraries	15.39%	Logan Heights	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Useful Life	Replace Janitors Sink	\$5,213
85	1184	Libraries	15.39%	Logan Heights	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$6,524
85	1185	Libraries	15.39%	Logan Heights	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$27,639
85	1186	Libraries	15.39%	Logan Heights	Terminal & Package Units	Potentially Critical-12 months	District 8	Terminal and Package Units	Inadequate	Replace Gas/Electric Pkg. Unit (s)	\$66,884
85	1187	Libraries	15.39%	Logan Heights	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$77,041
85	1188	Libraries	15.39%	Logan Heights	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Clay Tiles	\$91,239
86	1190	Comfort Stations	63.18%	#001046	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace 1X4 Surface Fluorescent Fixture S.F.	\$2,374
86	1190	Comfort Stations	63.18%	#001046	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$854
86	1191	Comfort Stations	63.18%	#001046	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$15,420
86	1191	Comfort Stations	63.18%	#001046	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
86	1192	Comfort Stations	63.18%	#001046	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
86	1193	Comfort Stations	63.18%	#001046	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repair Exterior Block Wall	\$2,283
86	1194	Comfort Stations	63.18%	#001046	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
86	1195	Comfort Stations	63.18%	#001046	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$2,697
86	1196	Comfort Stations	63.18%	#001046	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Beyond Useful Life	Repaint wall	\$2,734
86	1197	Comfort Stations	63.18%	#001046	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,967
86	1198	Comfort Stations	63.18%	#001046	Water Supply	Necessary- 2-5 Yrs	District 4	WATER Supply	Beyond Expected Life	Replace domestic water service	\$3,433
86	1199	Comfort Stations	63.18%	#001046	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Replace Wallboard Ceiling Finish	\$3,496
86	1200	Comfort Stations	63.18%	#001046	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Beyond Useful Life	Replace Modified Bitumen Roof Coverings	\$7,204
86	1201	Comfort Stations	63.18%	#001046	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
86	1202	Comfort Stations	63.18%	#001046	Electrical Distribution	Necessary- 2-5 Yrs	District 4	Electrica Distribution	Beyond Expected Life	Replace exterior electrical distribution	\$12,447
86	1203	Comfort Stations	63.18%	#001046	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Beyond Useful Life	Replace Wood Rafters and Deck	\$50,879
86	1204	Comfort Stations	63.18%	#001046	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$12,344
87	1205	Comfort Stations	63.13%	#001012	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Identifying Devices	\$1,213
87	1205	Comfort Stations	63.13%	#001012	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
87	1206	Comfort Stations	63.13%	#001012	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$831
87	1206	Comfort Stations	63.13%	#001012	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Fluorescent Fixture Ea.	\$3,423
87	1207	Comfort Stations	63.13%	#001012	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
87	1207	Comfort Stations	63.13%	#001012	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$28,073
87	1208	Comfort Stations	63.13%	#001012	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
87	1208	Comfort Stations	63.13%	#001012	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$27,839
87	1209	Comfort Stations	63.13%	#001012	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$7,828
87	1210	Comfort Stations	63.13%	#001012	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Replace Steel Doors	\$2,095
87	1211	Comfort Stations	63.13%	#001012	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Beyond Useful Life	Repaint interior roof structure and deck.	\$2,537
87	1212	Comfort Stations	63.13%	#001012	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$2,896
87	1213	Comfort Stations	63.13%	#001012	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
87	1214	Comfort Stations	63.13%	#001012	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$4,506
87	1215	Comfort Stations	63.13%	#001012	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,218
87	1216	Comfort Stations	63.13%	#001012	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Beyond Useful Life	Replace Built up Roof	\$6,728
87	1217	Comfort Stations	63.13%	#001012	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$19,064
87	1218	Comfort Stations	63.13%	#001012	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,855
88	1219	Libraries	10.74%	University Heights Library	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Inadequate	Replace exit light fixtures	\$4,352
88	1219	Libraries	10.74%	University Heights Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,790
88	1219	Libraries	10.74%	University Heights Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Incandescent Light Fixtures	\$19,951
88	1219	Libraries	10.74%	University Heights Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$8,700
88	1220	Libraries	10.74%	University Heights Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$16,411
88	1220	Libraries	10.74%	University Heights Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,734
88	1220	Libraries	10.74%	University Heights Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$3,908

88	1220	Libraries	10.74%	University Heights Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$74,602
88	1220	Libraries	10.74%	University Heights Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,644
88	1221	Libraries	10.74%	University Heights Library	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Ceramic Tile	\$6,499
88	1221	Libraries	10.74%	University Heights Library	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$15,687
88	1222	Libraries	10.74%	University Heights Library	Roadways	Potentially Critical-12 months	District 3	Roadways	Damaged	Repair and fill cracks and spalding.	\$3,582
88	1223	Libraries	10.74%	University Heights Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$5,041
88	1224	Libraries	10.74%	University Heights Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,396
88	1225	Libraries	10.74%	University Heights Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,203
88	1226	Libraries	10.74%	University Heights Library	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$10,758
88	1227	Libraries	10.74%	University Heights Library	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$16,033
88	1228	Libraries	10.74%	University Heights Library	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$20,376
88	1229	Libraries	10.74%	University Heights Library	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Inadequate	Replace electrical service entrance	\$43,150
88	1230	Libraries	10.74%	University Heights Library	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$99,604
88	1231	Libraries	10.74%	University Heights Library	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace 4T Split System A/C Comp	\$185,698
89	1232	Libraries	9.96%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$5,120
89	1232	Libraries	9.96%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace Receptacle 20A 120V ASSY/S.F.	\$32,364
89	1232	Libraries	9.96%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace Receptacle 20A 120V ASSY/S.F.	\$32,364
89	1232	Libraries	9.96%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$11,722
89	1232	Libraries	9.96%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,616
89	1233	Libraries	9.96%	Clairemont	Pedestrian Paving	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$3,898
89	1233	Libraries	9.96%	Clairemont	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Patch concrete	\$1,433
89	1234	Libraries	9.96%	Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,351
89	1234	Libraries	9.96%	Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Missing	Replace Wood Door/Metal Frame	\$2,506
89	1235	Libraries	9.96%	Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Stucco Wall	\$3,427
89	1235	Libraries	9.96%	Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$3,607
89	1236	Libraries	9.96%	Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Distribution Systems	Beyond Expected Life	Replace AHU 5000 CFM	\$25,179
89	1236	Libraries	9.96%	Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install or replace DX split ductless system	\$12,946
89	1237	Libraries	9.96%	Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$66,906
89	1237	Libraries	9.96%	Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$8,811
89	1238	Libraries	9.96%	Clairemont	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Gutters and downspouts	\$1,906
89	1239	Libraries	9.96%	Clairemont	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Slurry seal asphalt	\$5,406
89	1240	Libraries	9.96%	Clairemont	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$6,213
89	1241	Libraries	9.96%	Clairemont	Site Lighting	Potentially Critical-12 months	District 6	Site Lighting	Failing	Install/Replace site lighting-Lite Pole	\$7,085
89	1242	Libraries	9.96%	Clairemont	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$7,709
89	1243	Libraries	9.96%	Clairemont	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,645
89	1244	Libraries	9.96%	Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$8,836
89	1245	Libraries	9.96%	Clairemont	Water Supply	Potentially Critical-12 months	District 6	WATER Supply	Beyond Expected Life	Replace domestic water service	\$10,978
89	1246	Libraries	9.96%	Clairemont	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$14,405
89	1247	Libraries	9.96%	Clairemont	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Inadequate	Replace Aluminium Windows	\$163,380
90	1249	Comfort Stations	59.29%	#001017	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$638
90	1249	Comfort Stations	59.29%	#001017	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$938
90	1249	Comfort Stations	59.29%	#001017	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace Receptacle 20A 120V ASSY/S.F.	\$4,477
90	1250	Comfort Stations	59.29%	#001017	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
90	1250	Comfort Stations	59.29%	#001017	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
90	1251	Comfort Stations	59.29%	#001017	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,973
90	1251	Comfort Stations	59.29%	#001017	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Termite Inspection of Roof structure	\$20,687
90	1252	Comfort Stations	59.29%	#001017	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
90	1252	Comfort Stations	59.29%	#001017	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$3,755
90	1253	Comfort Stations	59.29%	#001017	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
90	1253	Comfort Stations	59.29%	#001017	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Failing	Replace Stainless Steel Plumbing Fixtures	\$15,516
90	1254	Comfort Stations	59.29%	#001017	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,506
90	1255	Comfort Stations	59.29%	#001017	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,218
90	1256	Comfort Stations	59.29%	#001017	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Failing	Repaint exterior metal doors	\$6,521
90	1257	Comfort Stations	59.29%	#001017	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$7,735

90	1258	Comfort Stations	59.29%	#001017	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$10,614
90	1259	Comfort Stations	59.29%	#001017	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$20,079
90	1260	Comfort Stations	59.29%	#001017	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Failing	Replace Modified Bitumen Roof Coverings	\$23,713
91	1261	Comfort Stations	58.62%	#001205	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$530
91	1261	Comfort Stations	58.62%	#001205	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
91	1261	Comfort Stations	58.62%	#001205	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
91	1261	Comfort Stations	58.62%	#001205	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
91	1262	Comfort Stations	58.62%	#001205	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Termite Inspection of Roof structure	\$10,200
91	1262	Comfort Stations	58.62%	#001205	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Roof Fascia	\$3,142
91	1262	Comfort Stations	58.62%	#001205	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,923
91	1263	Comfort Stations	58.62%	#001205	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
91	1263	Comfort Stations	58.62%	#001205	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
91	1264	Comfort Stations	58.62%	#001205	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
91	1264	Comfort Stations	58.62%	#001205	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
91	1265	Comfort Stations	58.62%	#001205	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,420
91	1265	Comfort Stations	58.62%	#001205	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
91	1266	Comfort Stations	58.62%	#001205	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,776
91	1267	Comfort Stations	58.62%	#001205	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,080
91	1268	Comfort Stations	58.62%	#001205	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$3,348
91	1269	Comfort Stations	58.62%	#001205	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Water Supply	Beyond Useful Life	Replace domestic water service	\$3,433
91	1270	Comfort Stations	58.62%	#001205	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$6,418
91	1271	Comfort Stations	58.62%	#001205	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
91	1272	Comfort Stations	58.62%	#001205	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$10,221
91	1273	Comfort Stations	58.62%	#001205	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Failing	Replace Modified Bitumen Roof Coverings	\$23,976
92	1274	Libraries	8.32%	Kensington/Normal Heights	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$48,491
92	1274	Libraries	8.32%	Kensington/Normal Heights	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$460
92	1274	Libraries	8.32%	Kensington/Normal Heights	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$827
92	1274	Libraries	8.32%	Kensington/Normal Heights	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$1,305
92	1275	Libraries	8.32%	Kensington/Normal Heights	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,628
92	1275	Libraries	8.32%	Kensington/Normal Heights	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Site Lighting	Inadequate	Install/Replace HID/HPS 250W exterior wall pack	\$15,451
92	1276	Libraries	8.32%	Kensington/Normal Heights	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$3,227
92	1277	Libraries	8.32%	Kensington/Normal Heights	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Distribution Systems	Inadequate	Replace Ceiling Mount Exhaust Fan	\$3,672
92	1278	Libraries	8.32%	Kensington/Normal Heights	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Ceramic Tile	\$3,698
92	1279	Libraries	8.32%	Kensington/Normal Heights	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$3,881
92	1280	Libraries	8.32%	Kensington/Normal Heights	Partitions	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$5,824
92	1281	Libraries	8.32%	Kensington/Normal Heights	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$12,533
92	1282	Libraries	8.32%	Kensington/Normal Heights	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$15,242
92	1283	Libraries	8.32%	Kensington/Normal Heights	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$15,282
92	1284	Libraries	8.32%	Kensington/Normal Heights	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$19,129
92	1285	Libraries	8.32%	Kensington/Normal Heights	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$19,452
92	1286	Libraries	8.32%	Kensington/Normal Heights	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$40,053
92	1287	Libraries	8.32%	Kensington/Normal Heights	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Useful Life	Replace 4T Split System A/C Comp	\$56,878
93	1288	Comfort Stations	58.17%	#001023	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$13,011
93	1288	Comfort Stations	58.17%	#001023	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
93	1289	Comfort Stations	58.17%	#001023	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Roof Fascia	\$2,526
93	1289	Comfort Stations	58.17%	#001023	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$50,722
93	1290	Comfort Stations	58.17%	#001023	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$1,966
93	1291	Comfort Stations	58.17%	#001023	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Beyond Useful Life	Repaint drywall/plaster ceiling	\$2,496
93	1292	Comfort Stations	58.17%	#001023	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
93	1293	Comfort Stations	58.17%	#001023	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,899
93	1294	Comfort Stations	58.17%	#001023	Water Supply	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Repair or replace domestic water piping	\$3,599
93	1295	Comfort Stations	58.17%	#001023	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$3,873
93	1296	Comfort Stations	58.17%	#001023	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Beyond Expected Life	Repaint wall	\$4,853
93	1297	Comfort Stations	58.17%	#001023	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Replace Wood Doors	\$5,094

93	1298	Comfort Stations	58.17%	#001023	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Useful Life	Replace Built up Roof	\$11,963
94	1299	Libraries	6.91%	Skyline Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$66,583
94	1299	Libraries	6.91%	Skyline Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,748
94	1299	Libraries	6.91%	Skyline Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$6,845
94	1299	Libraries	6.91%	Skyline Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,823
94	1300	Libraries	6.91%	Skyline Hills	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Incandescent Light Fixtures	\$7,671
94	1300	Libraries	6.91%	Skyline Hills	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,231
94	1300	Libraries	6.91%	Skyline Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Site Lighting	Beyond Expected Life	Install/Replace HID/HPS 250W exterior wall pack	\$6,871
94	1301	Libraries	6.91%	Skyline Hills	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Wall Panelling	\$4,870
94	1301	Libraries	6.91%	Skyline Hills	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$5,242
94	1302	Libraries	6.91%	Skyline Hills	Electrical Service/Distribution	Critical / Immediate Need	District 4	Electrical Service/Distribution	Missing	Replace Electrical Switch Board Door Latch	\$1,442
94	1303	Libraries	6.91%	Skyline Hills	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Failing	Install/Replace site lighting-Lite Pole	\$21,254
94	1304	Libraries	6.91%	Skyline Hills	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$4,231
94	1305	Libraries	6.91%	Skyline Hills	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
94	1306	Libraries	6.91%	Skyline Hills	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,734
94	1307	Libraries	6.91%	Skyline Hills	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$6,455
94	1308	Libraries	6.91%	Skyline Hills	Roadways	Necessary- 2-5 Yrs	District 4	Roadways	Damaged	Repair and fill cracks and spalding.	\$8,599
94	1309	Libraries	6.91%	Skyline Hills	Landscaping	Necessary- 2-5 Yrs	District 4	Landscaping	Damaged	Re-grade Site	\$9,980
94	1310	Libraries	6.91%	Skyline Hills	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$12,047
94	1311	Libraries	6.91%	Skyline Hills	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$23,385
94	1312	Libraries	6.91%	Skyline Hills	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$28,056
94	1313	Libraries	6.91%	Skyline Hills	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$30,607
95	1314	Libraries	6.65%	Rancho Penasquitos	Terminal & Package Units	Potentially Critical-12 months	District 1	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$3,177
95	1314	Libraries	6.65%	Rancho Penasquitos	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace Gas/Electric Pkg. Unit (s)	\$220,946
95	1315	Libraries	6.65%	Rancho Penasquitos	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$759
95	1315	Libraries	6.65%	Rancho Penasquitos	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,906
95	1316	Libraries	6.65%	Rancho Penasquitos	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Stairs	Damaged	Paint stairs	\$3,444
95	1316	Libraries	6.65%	Rancho Penasquitos	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,915
95	1317	Libraries	6.65%	Rancho Penasquitos	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$26,955
95	1317	Libraries	6.65%	Rancho Penasquitos	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Replace Decorative Tile	\$2,205
95	1318	Libraries	6.65%	Rancho Penasquitos	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Failing	Replace Built up Roof	\$337,511
95	1319	Libraries	6.65%	Rancho Penasquitos	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$19,859
95	1320	Libraries	6.65%	Rancho Penasquitos	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$1,801
95	1321	Libraries	6.65%	Rancho Penasquitos	Site Development	Necessary- 2-5 Yrs	District 1	Stairs	Damaged	Repair Handrails	\$2,432
95	1322	Libraries	6.65%	Rancho Penasquitos	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
95	1323	Libraries	6.65%	Rancho Penasquitos	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, gas	\$4,075
95	1324	Libraries	6.65%	Rancho Penasquitos	Exhaust Fans	Necessary- 2-5 Yrs	District 1	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$10,829
95	1325	Libraries	6.65%	Rancho Penasquitos	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$11,780
95	1326	Libraries	6.65%	Rancho Penasquitos	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$13,407
95	1327	Libraries	6.65%	Rancho Penasquitos	Standard Foundations	Necessary- 2-5 Yrs	District 1	Foundations	Failing	Conduct Engineering Assessment - Foundation	\$19,233
95	1328	Libraries	6.65%	Rancho Penasquitos	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$19,776
95	1329	Libraries	6.65%	Rancho Penasquitos	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$22,145
95	1330	Libraries	6.65%	Rancho Penasquitos	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace Aluminium Windows	\$57,053
95	1331	Libraries	6.65%	Rancho Penasquitos	Communications and Security	Necessary- 2-5 Yrs	District 1	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
95	1332	Libraries	6.65%	Rancho Penasquitos	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$316,423
96	1333	Libraries	6.08%	North Clairemont	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,228
96	1333	Libraries	6.08%	North Clairemont	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,066
96	1333	Libraries	6.08%	North Clairemont	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$45,923
96	1333	Libraries	6.08%	North Clairemont	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$1,122
96	1334	Libraries	6.08%	North Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Replace Ductwork Pkg Sys/Ton	\$33,112
96	1334	Libraries	6.08%	North Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Replace Gas/Electric Pkg. Unit (s)	\$6,518
96	1334	Libraries	6.08%	North Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$5,627
96	1335	Libraries	6.08%	North Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,513
96	1335	Libraries	6.08%	North Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Missing	Replace door hardware	\$11,401

96	1336	Libraries	6.08%	North Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Stucco Wall	\$5,284
96	1336	Libraries	6.08%	North Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$9,151
96	1337	Libraries	6.08%	North Clairemont	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$1,869
96	1337	Libraries	6.08%	North Clairemont	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$35,739
96	1338	Libraries	6.08%	North Clairemont	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Failing	Replace Fixed Casework Wall Cabinets - Wood	\$1,751
96	1339	Libraries	6.08%	North Clairemont	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
96	1340	Libraries	6.08%	North Clairemont	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,184
96	1341	Libraries	6.08%	North Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,627
96	1342	Libraries	6.08%	North Clairemont	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$7,709
96	1343	Libraries	6.08%	North Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$8,836
96	1344	Libraries	6.08%	North Clairemont	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$11,932
96	1345	Libraries	6.08%	North Clairemont	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$67,426
96	1346	Libraries	6.08%	North Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$103,547
97	1347	Libraries	6.03%	San Carlos	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$8,389
97	1347	Libraries	6.03%	San Carlos	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,877
97	1347	Libraries	6.03%	San Carlos	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$8,441
97	1347	Libraries	6.03%	San Carlos	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$12,136
97	1348	Libraries	6.03%	San Carlos	Terminal & Package Units	Potentially Critical-12 months	District 7	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$398
97	1348	Libraries	6.03%	San Carlos	Terminal & Package Units	Potentially Critical-12 months	District 7	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$7,877
97	1348	Libraries	6.03%	San Carlos	Terminal & Package Units	Necessary- 2-5 Yrs	District 7	Terminal and Package Units	Damaged	Replace Gas/Electric Pkg. Unit (s)	\$154,755
97	1349	Libraries	6.03%	San Carlos	Pedestrian Paving	Potentially Critical-12 months	District 7	Roadways	Damaged	Repair and fill cracks and spalding.	\$4,299
97	1349	Libraries	6.03%	San Carlos	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,603
97	1349	Libraries	6.03%	San Carlos	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$802
97	1350	Libraries	6.03%	San Carlos	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Slurry seal asphalt	\$28,234
97	1350	Libraries	6.03%	San Carlos	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$3,417
97	1350	Libraries	6.03%	San Carlos	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$2,309
97	1351	Libraries	6.03%	San Carlos	Site Development	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Replace CMU Block Wall	\$11,716
97	1351	Libraries	6.03%	San Carlos	Site Development	Necessary- 2-5 Yrs	District 7	Stairs	Damaged	Repaint Handrails	\$1,676
97	1352	Libraries	6.03%	San Carlos	Other Electrical Systems	Potentially Critical-12 months	District 7	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$7,344
97	1353	Libraries	6.03%	San Carlos	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$9,781
97	1354	Libraries	6.03%	San Carlos	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$8,184
97	1355	Libraries	6.03%	San Carlos	Site Lighting	Potentially Critical-12 months	District 7	Site Lighting	Beyond Expected Life	Install/Replace site lighting-Lite Pole	\$24,261
97	1356	Libraries	6.03%	San Carlos	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$2,118
97	1357	Libraries	6.03%	San Carlos	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,594
97	1358	Libraries	6.03%	San Carlos	Domestic Water Distribution	Necessary- 2-5 Yrs	District 7	Water Heaters	Beyond Expected Life	Remove or replace water heater	\$2,640
97	1359	Libraries	6.03%	San Carlos	Landscaping	Necessary- 2-5 Yrs	District 7	Landscaping	Damaged	Perform landscaping maintenance	\$4,809
97	1360	Libraries	6.03%	San Carlos	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Damaged	Replace Toilet Partition	\$5,072
97	1361	Libraries	6.03%	San Carlos	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Ceramic Tile	\$5,211
97	1362	Libraries	6.03%	San Carlos	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,945
97	1363	Libraries	6.03%	San Carlos	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$8,160
97	1364	Libraries	6.03%	San Carlos	Plumbing Fixtures	Necessary- 2-5 Yrs	District 7	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$10,259
97	1365	Libraries	6.03%	San Carlos	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$31,983
97	1366	Libraries	6.03%	San Carlos	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$33,075
97	1367	Libraries	6.03%	San Carlos	Electrical Distribution	Necessary- 2-5 Yrs	District 7	Electrica Distribution	Beyond Expected Life	Replace exterior electrical distribution	\$36,702
97	1368	Libraries	6.03%	San Carlos	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$89,282
98	1371	Libraries	5.91%	Benjamin	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,240
98	1371	Libraries	5.91%	Benjamin	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$63,791
98	1373	Libraries	5.91%	Benjamin	Site Development	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Replace Exterior Trellis	\$3,688
98	1373	Libraries	5.91%	Benjamin	Site Development	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$2,726
98	1375	Libraries	5.91%	Benjamin	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Glue on Tile	\$28,969
98	1375	Libraries	5.91%	Benjamin	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$3,790
98	1376	Libraries	5.91%	Benjamin	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$3,175
98	1376	Libraries	5.91%	Benjamin	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$102,555
98	1377	Libraries	5.91%	Benjamin	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Inadequate	Replace Metal Door/Metal Frame	\$2,463

98	1378	Libraries	5.91%	Benjamin	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$8,184
98	1380	Libraries	5.91%	Benjamin	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Toilet Partition	\$2,165
98	1381	Libraries	5.91%	Benjamin	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,666
98	1383	Libraries	5.91%	Benjamin	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$4,183
98	1388	Libraries	5.91%	Benjamin	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$12,239
98	1390	Libraries	5.91%	Benjamin	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
98	1391	Libraries	5.91%	Benjamin	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace Aluminium Windows	\$18,056
98	1392	Libraries	5.91%	Benjamin	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$19,199
99	1369	Libraries	5.91%	North Park Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$486
99	1369	Libraries	5.91%	North Park Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,529
99	1369	Libraries	5.91%	North Park Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$920
99	1369	Libraries	5.91%	North Park Library	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$139,878
99	1370	Libraries	5.91%	North Park Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,790
99	1370	Libraries	5.91%	North Park Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$16,171
99	1372	Libraries	5.91%	North Park Library	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,792
99	1372	Libraries	5.91%	North Park Library	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Aluminium Doors	\$3,284
99	1374	Libraries	5.91%	North Park Library	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Termite Inspection of Exterior Trellis	\$14,424
99	1374	Libraries	5.91%	North Park Library	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Exterior Trellis	\$4,624
99	1379	Libraries	5.91%	North Park Library	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Building Automation Systems	Failing	Replace Thermostat	\$919
99	1382	Libraries	5.91%	North Park Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,849
99	1384	Libraries	5.91%	North Park Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,260
99	1385	Libraries	5.91%	North Park Library	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Damaged	Re-grade Site	\$7,459
99	1386	Libraries	5.91%	North Park Library	Rain Water Drainage	Necessary- 2-5 Yrs	District 3	Rain Water Drainage	Failing	Replace or Install Roof Drain - 6 in	\$9,685
99	1387	Libraries	5.91%	North Park Library	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$12,231
99	1389	Libraries	5.91%	North Park Library	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Slurry seal asphalt	\$12,337
99	1393	Libraries	5.91%	North Park Library	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$111,849
99	1394	Libraries	5.91%	North Park Library	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Missing	Replace Fire Alarm System/ASSY for 50 devices	\$60,566
100	1395	Libraries	5.87%	Carmel Valley	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Missing	Replace Wood Door/Metal Frame	\$1,076
100	1395	Libraries	5.87%	Carmel Valley	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace door hardware	\$1,435
100	1395	Libraries	5.87%	Carmel Valley	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace door hardware	\$8,496
100	1395	Libraries	5.87%	Carmel Valley	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,676
100	1395	Libraries	5.87%	Carmel Valley	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$2,382
100	1396	Libraries	5.87%	Carmel Valley	Terminal & Package Units	Potentially Critical-12 months	District 1	Other Plumbing Systems	Inadequate	Install or replace flexible fuel connection	\$1,588
100	1396	Libraries	5.87%	Carmel Valley	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$12,600
100	1396	Libraries	5.87%	Carmel Valley	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace 30T,Gas/Elec,Pkg Unit, Roof Mount	\$188,050
100	1397	Libraries	5.87%	Carmel Valley	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Damaged	Repaint Metal Fence	\$4,862
100	1397	Libraries	5.87%	Carmel Valley	Site Development	Necessary- 2-5 Yrs	District 1	Other Site Structures	Damaged	Replace concrete trash enclosure	\$1,522
100	1397	Libraries	5.87%	Carmel Valley	Site Development	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$1,946
100	1398	Libraries	5.87%	Carmel Valley	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Caulk exterior walls	\$2,707
100	1398	Libraries	5.87%	Carmel Valley	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Powerwash exterior wall	\$3,397
100	1399	Libraries	5.87%	Carmel Valley	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Failing	Slurry seal asphalt	\$15,598
100	1399	Libraries	5.87%	Carmel Valley	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Missing	Repair or restripe Parking Lot/	\$4,471
100	1400	Libraries	5.87%	Carmel Valley	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,582
100	1400	Libraries	5.87%	Carmel Valley	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Glue on Tile	\$118,219
100	1401	Libraries	5.87%	Carmel Valley	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$196,872
100	1401	Libraries	5.87%	Carmel Valley	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Refinish wood floor	\$9,676
100	1402	Libraries	5.87%	Carmel Valley	Communications and Security	Potentially Critical-12 months	District 1	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
100	1403	Libraries	5.87%	Carmel Valley	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$12,700
100	1404	Libraries	5.87%	Carmel Valley	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
100	1405	Libraries	5.87%	Carmel Valley	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,412
100	1406	Libraries	5.87%	Carmel Valley	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace Aluminium Windows	\$5,186
100	1407	Libraries	5.87%	Carmel Valley	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$9,052
100	1408	Libraries	5.87%	Carmel Valley	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$15,065
101	1409	PO - Parks / Recreation	53.94%	Office, Presido Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$481

101	1409	PO - Parks / Recreation	53.94%	Office, Presido Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$6,743
101	1409	PO - Parks / Recreation	53.94%	Office, Presido Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$10,696
101	1410	PO - Parks / Recreation	53.94%	Office, Presido Park	Exterior Walls	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
101	1410	PO - Parks / Recreation	53.94%	Office, Presido Park	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Exterior stucco/plaster wall paint single story	\$8,153
101	1410	PO - Parks / Recreation	53.94%	Office, Presido Park	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Inadequate	Replace Foundation Wall Vent Cover; Mtl up to 2 SF	\$1,254
101	1411	PO - Parks / Recreation	53.94%	Office, Presido Park	Domestic Water Distribution	Potentially Critical-12 months	District 2	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$5,502
101	1412	PO - Parks / Recreation	53.94%	Office, Presido Park	Water Supply	Potentially Critical-12 months	District 2	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$6,833
101	1413	PO - Parks / Recreation	53.94%	Office, Presido Park	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Failing	Refinish Base / Wall Cabinets - SF	\$1,592
101	1414	PO - Parks / Recreation	53.94%	Office, Presido Park	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$1,676
101	1415	PO - Parks / Recreation	53.94%	Office, Presido Park	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Terminal and Package Units	Damaged	Replace Window Unit < 3T	\$2,667
101	1416	PO - Parks / Recreation	53.94%	Office, Presido Park	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Prepare Paint Wood Fascia and Eaves (SF)	\$3,962
101	1417	PO - Parks / Recreation	53.94%	Office, Presido Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Prepare and Paint Interior Ceiling	\$4,207
101	1418	PO - Parks / Recreation	53.94%	Office, Presido Park	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Remove, Salvage, Restore Ext. Door-Wood Historic	\$4,492
101	1419	PO - Parks / Recreation	53.94%	Office, Presido Park	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace Panel Board; 200A; 240V; 1-Phase; 42 Ckt.	\$6,096
101	1420	PO - Parks / Recreation	53.94%	Office, Presido Park	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$7,533
101	1421	PO - Parks / Recreation	53.94%	Office, Presido Park	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$9,383
101	1422	PO - Parks / Recreation	53.94%	Office, Presido Park	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Expected Life	Replace exterior electrical distribution	\$9,518
101	1423	PO - Parks / Recreation	53.94%	Office, Presido Park	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace 3 Fixture Rest Room Assembly; 1 Wall	\$9,709
101	1424	PO - Parks / Recreation	53.94%	Office, Presido Park	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,242
101	1425	PO - Parks / Recreation	53.94%	Office, Presido Park	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Wood Windows	\$25,564
101	1426	PO - Parks / Recreation	53.94%	Office, Presido Park	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Clay Tiles	\$25,999
102	1427	Libraries	3.72%	San Ysidro	Site Development	Necessary- 2-5 Yrs	District 8	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$573
102	1427	Libraries	3.72%	San Ysidro	Site Development	Necessary- 2-5 Yrs	District 8	Other Site Structures	Damaged	Replace Flag Pole	\$3,850
102	1430	Libraries	3.72%	San Ysidro	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,893
102	1433	Libraries	3.72%	San Ysidro	Site Lighting	Potentially Critical-12 months	District 8	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$56,678
102	1435	Libraries	3.72%	San Ysidro	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,709
102	1438	Libraries	3.72%	San Ysidro	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Steel Doors	\$4,070
102	1439	Libraries	3.72%	San Ysidro	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Clay Tiles	\$4,155
102	1442	Libraries	3.72%	San Ysidro	Electrical Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace UG 400A Electrical Feeder	\$7,421
102	1443	Libraries	3.72%	San Ysidro	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$8,799
102	1446	Libraries	3.72%	San Ysidro	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
102	1448	Libraries	3.72%	San Ysidro	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$21,065
103	1428	Libraries	3.72%	University Community	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$1,571
103	1428	Libraries	3.72%	University Community	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$21,595
103	1429	Libraries	3.72%	University Community	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$10,135
103	1431	Libraries	3.72%	University Community	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$6,101
103	1432	Libraries	3.72%	University Community	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,135
103	1434	Libraries	3.72%	University Community	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Patch concrete	\$1,075
103	1436	Libraries	3.72%	University Community	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,956
103	1437	Libraries	3.72%	University Community	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
103	1440	Libraries	3.72%	University Community	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Damaged	Replace Janitors Sink	\$5,213
103	1441	Libraries	3.72%	University Community	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$6,580
103	1444	Libraries	3.72%	University Community	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$13,058
103	1445	Libraries	3.72%	University Community	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Gutters and downspouts	\$13,179
103	1447	Libraries	3.72%	University Community	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$16,191
103	1449	Libraries	3.72%	University Community	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$22,663
103	1450	Libraries	3.72%	University Community	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$25,274
103	1451	Libraries	3.72%	University Community	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$178,434
104	1452	Libraries	3.71%	Mission Hills Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Repaint Fascia	\$3,236
104	1452	Libraries	3.71%	Mission Hills Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace Exterior Wood Structures	\$8,435

104	1452	Libraries	3.71%	Mission Hills Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$5,120
104	1453	Libraries	3.71%	Mission Hills Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
104	1453	Libraries	3.71%	Mission Hills Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,270
104	1454	Libraries	3.71%	Mission Hills Library	Terminal & Package Units	Critical / Immediate Need	District 2	Terminal and Package Units	Beyond Expected Life	Replace 4T Split System A/C Comp	\$7,020
104	1455	Libraries	3.71%	Mission Hills Library	Domestic Water Distribution	Potentially Critical-12 months	District 2	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
104	1456	Libraries	3.71%	Mission Hills Library	Electrical Service/Distribution	Potentially Critical-12 months	District 2	Electrical Service/Distribution	Inadequate	Replace electric service entrance -200 Amp	\$7,709
104	1457	Libraries	3.71%	Mission Hills Library	Site Development	Necessary- 2-5 Yrs	District 2	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$409
104	1458	Libraries	3.71%	Mission Hills Library	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,215
104	1459	Libraries	3.71%	Mission Hills Library	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$1,863
104	1460	Libraries	3.71%	Mission Hills Library	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,631
104	1461	Libraries	3.71%	Mission Hills Library	Exhaust Fans	Necessary- 2-5 Yrs	District 2	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$4,058
104	1462	Libraries	3.71%	Mission Hills Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$4,398
104	1463	Libraries	3.71%	Mission Hills Library	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$18,943
104	1464	Libraries	3.71%	Mission Hills Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$20,147
105	1465	Libraries	3.58%	Beckwourth	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$121,228
105	1465	Libraries	3.58%	Beckwourth	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$546
105	1465	Libraries	3.58%	Beckwourth	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$721
105	1465	Libraries	3.58%	Beckwourth	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$6,898
105	1466	Libraries	3.58%	Beckwourth	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Site Lighting	Beyond Useful Life	Install/Replace HID/HPS 250W exterior wall pack	\$6,871
105	1466	Libraries	3.58%	Beckwourth	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,166
105	1467	Libraries	3.58%	Beckwourth	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Failing	Clean, Sanitize and Balance Air Distribution SYS	\$8,166
105	1468	Libraries	3.58%	Beckwourth	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Beyond Expected Life	Install/Replace site lighting-Lite Pole	\$28,339
105	1469	Libraries	3.58%	Beckwourth	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,595
105	1470	Libraries	3.58%	Beckwourth	Partitions	Necessary- 2-5 Yrs	District 4	Partitions	Damaged	Repair Drywall Partitions	\$1,724
105	1471	Libraries	3.58%	Beckwourth	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$7,679
105	1472	Libraries	3.58%	Beckwourth	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$8,154
105	1473	Libraries	3.58%	Beckwourth	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$11,684
105	1474	Libraries	3.58%	Beckwourth	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$48,205
106	1475	Libraries	3.56%	Tierrasanta	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Replace wood siding	\$106,598
106	1475	Libraries	3.56%	Tierrasanta	Exterior Walls	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
106	1475	Libraries	3.56%	Tierrasanta	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$11,490
106	1476	Libraries	3.56%	Tierrasanta	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$5,539
106	1476	Libraries	3.56%	Tierrasanta	Exhaust Fans	Necessary- 2-5 Yrs	District 7	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
106	1477	Libraries	3.56%	Tierrasanta	Electrical Service/Distribution	Critical / Immediate Need	District 7	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
106	1478	Libraries	3.56%	Tierrasanta	Site Development	Necessary- 2-5 Yrs	District 7	Stairs	Damaged	Repaint Handrails	\$717
106	1478	Libraries	3.56%	Tierrasanta	Site Development	Necessary- 2-5 Yrs	District 7	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$844
106	1479	Libraries	3.56%	Tierrasanta	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Slurry seal asphalt	\$6,016
106	1479	Libraries	3.56%	Tierrasanta	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$1,933
106	1480	Libraries	3.56%	Tierrasanta	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Inadequate	Replace Aluminium Doors	\$13,643
106	1480	Libraries	3.56%	Tierrasanta	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,956
106	1481	Libraries	3.56%	Tierrasanta	Other Electrical Systems	Potentially Critical-12 months	District 7	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$3,254
106	1482	Libraries	3.56%	Tierrasanta	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,430
106	1483	Libraries	3.56%	Tierrasanta	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$3,227
106	1484	Libraries	3.56%	Tierrasanta	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$4,465
106	1485	Libraries	3.56%	Tierrasanta	Plumbing Fixtures	Necessary- 2-5 Yrs	District 7	Plumbing Fixtures	Damaged	Replace Janitors Sink	\$5,213
106	1486	Libraries	3.56%	Tierrasanta	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Glue on Tile	\$94,157
106	1487	Libraries	3.56%	Tierrasanta	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$130,777
107	1488	Comfort Stations	53.50%	#001011	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$3,423
107	1488	Comfort Stations	53.50%	#001011	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$27,839
107	1488	Comfort Stations	53.50%	#001011	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$831
107	1489	Comfort Stations	53.50%	#001011	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Identifying Devices	\$1,213
107	1489	Comfort Stations	53.50%	#001011	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
107	1490	Comfort Stations	53.50%	#001011	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$42,386
107	1490	Comfort Stations	53.50%	#001011	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255

107	1491	Comfort Stations	53.50%	#001011	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$3,914
107	1492	Comfort Stations	53.50%	#001011	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Replace Steel Doors	\$1,397
107	1493	Comfort Stations	53.50%	#001011	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$2,537
107	1494	Comfort Stations	53.50%	#001011	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
107	1495	Comfort Stations	53.50%	#001011	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
107	1496	Comfort Stations	53.50%	#001011	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,411
107	1497	Comfort Stations	53.50%	#001011	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,218
107	1498	Comfort Stations	53.50%	#001011	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Beyond Useful Life	Replace Asphalt Shingle	\$8,686
107	1499	Comfort Stations	53.50%	#001011	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
107	1500	Comfort Stations	53.50%	#001011	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
107	1501	Comfort Stations	53.50%	#001011	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,855
108	1502	Libraries	3.47%	Mira Mesa Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$20,338
108	1502	Libraries	3.47%	Mira Mesa Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
108	1502	Libraries	3.47%	Mira Mesa Library	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Beyond Expected Life	Replace air cooled D-X heat pump(s)	\$148,942
108	1503	Libraries	3.47%	Mira Mesa Library	Site Development	Necessary- 2-5 Yrs	District 5	Landscaping	Failing	Re-grade Site	\$22,649
108	1503	Libraries	3.47%	Mira Mesa Library	Site Development	Necessary- 2-5 Yrs	District 5	Fencing	Damaged	Repaint Metal Fence	\$1,534
108	1503	Libraries	3.47%	Mira Mesa Library	Site Development	Necessary- 2-5 Yrs	District 5	Other Site Structures	Damaged	Replace parking signs	\$2,308
108	1504	Libraries	3.47%	Mira Mesa Library	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,793
108	1504	Libraries	3.47%	Mira Mesa Library	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Failing	Replace door hardware	\$9,709
108	1505	Libraries	3.47%	Mira Mesa Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$14,472
108	1505	Libraries	3.47%	Mira Mesa Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$20,338
108	1506	Libraries	3.47%	Mira Mesa Library	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Slurry seal asphalt	\$38,877
108	1506	Libraries	3.47%	Mira Mesa Library	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$2,780
108	1507	Libraries	3.47%	Mira Mesa Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$318,450
108	1507	Libraries	3.47%	Mira Mesa Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Patch concrete	\$4,299
108	1508	Libraries	3.47%	Mira Mesa Library	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
108	1509	Libraries	3.47%	Mira Mesa Library	Exterior Windows	Necessary- 2-5 Yrs	District 5	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,594
108	1510	Libraries	3.47%	Mira Mesa Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,732
108	1511	Libraries	3.47%	Mira Mesa Library	Exhaust Fans	Necessary- 2-5 Yrs	District 5	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$6,045
108	1512	Libraries	3.47%	Mira Mesa Library	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$9,714
108	1513	Libraries	3.47%	Mira Mesa Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$11,315
108	1514	Libraries	3.47%	Mira Mesa Library	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$13,988
108	1515	Libraries	3.47%	Mira Mesa Library	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$30,200
108	1516	Libraries	3.47%	Mira Mesa Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$33,073
108	1517	Libraries	3.47%	Mira Mesa Library	Communications and Security	Necessary- 2-5 Yrs	District 5	Communications/Security	Failing	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
109	1518	Libraries	3.11%	Balboa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$2,961
109	1518	Libraries	3.11%	Balboa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,397
109	1519	Libraries	3.11%	Balboa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$48,712
109	1519	Libraries	3.11%	Balboa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$6,783
109	1520	Libraries	3.11%	Balboa	Electrical Service/Distribution	Critical / Immediate Need	District 6	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$1,923
109	1521	Libraries	3.11%	Balboa	Communications and Security	Potentially Critical-12 months	District 6	Communications/Security	Inadequate	Replace Local Area Network/ASSY EA outlet	\$13,787
109	1522	Libraries	3.11%	Balboa	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Inadequate	Remove and replace domestic water heater, gas	\$1,698
109	1523	Libraries	3.11%	Balboa	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
109	1524	Libraries	3.11%	Balboa	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,827
109	1525	Libraries	3.11%	Balboa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,093
109	1526	Libraries	3.11%	Balboa	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,640
109	1527	Libraries	3.11%	Balboa	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$8,836
109	1528	Libraries	3.11%	Balboa	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$9,913
109	1529	Libraries	3.11%	Balboa	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$10,080
109	1530	Libraries	3.11%	Balboa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$35,065
110	1531	Libraries	2.71%	Urban Village Park Perf. Annex	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$16,927
110	1531	Libraries	2.71%	Urban Village Park Perf. Annex	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Damaged	Replace floor box receptacle covers/brass	\$2,027
110	1532	Libraries	2.71%	Urban Village Park Perf. Annex	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$16,927

110	1533	Libraries	2.71%	Urban Village Park Perf. Annex	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$889
110	1534	Libraries	2.71%	Urban Village Park Perf. Annex	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$976
110	1535	Libraries	2.71%	Urban Village Park Perf. Annex	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$9,707
110	1536	Libraries	2.71%	Urban Village Park Perf. Annex	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$25,238
110	1537	Libraries	2.71%	Urban Village Park Perf. Annex	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
110	1538	Libraries	2.71%	Urban Village Park Perf. Annex	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$279,758
111	1539	Libraries	2.41%	Scripps Miramar Ranch Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
111	1539	Libraries	2.41%	Scripps Miramar Ranch Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$20,869
111	1539	Libraries	2.41%	Scripps Miramar Ranch Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$6,144
111	1540	Libraries	2.41%	Scripps Miramar Ranch Library	Electrical Service/Distribution	Critical / Immediate Need	District 5	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$1,923
111	1540	Libraries	2.41%	Scripps Miramar Ranch Library	Electrical Service/Distribution	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
111	1541	Libraries	2.41%	Scripps Miramar Ranch Library	Site Development	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Patch concrete	\$1,290
111	1541	Libraries	2.41%	Scripps Miramar Ranch Library	Site Development	Necessary- 2-5 Yrs	District 5	Fencing	Damaged	Repaint Metal Fence	\$1,694
111	1541	Libraries	2.41%	Scripps Miramar Ranch Library	Site Development	Necessary- 2-5 Yrs	District 5	Stairs	Damaged	Paint stairs	\$1,192
111	1542	Libraries	2.41%	Scripps Miramar Ranch Library	Exterior Doors	Potentially Critical-12 months	District 5	Exterior Doors	Damaged	Install or replace exterior hardware	\$794
111	1542	Libraries	2.41%	Scripps Miramar Ranch Library	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$15,464
111	1543	Libraries	2.41%	Scripps Miramar Ranch Library	Electrical Distribution	Critical / Immediate Need	District 5	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$1,923
111	1544	Libraries	2.41%	Scripps Miramar Ranch Library	Other Electrical Systems	Critical / Immediate Need	District 5	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$3,254
111	1545	Libraries	2.41%	Scripps Miramar Ranch Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace decomposed granite	\$1,158
111	1545	Libraries	2.41%	Scripps Miramar Ranch Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,218
111	1546	Libraries	2.41%	Scripps Miramar Ranch Library	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Replace door hardware	\$1,214
111	1546	Libraries	2.41%	Scripps Miramar Ranch Library	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,028
111	1547	Libraries	2.41%	Scripps Miramar Ranch Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$20,869
111	1548	Libraries	2.41%	Scripps Miramar Ranch Library	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$1,801
111	1549	Libraries	2.41%	Scripps Miramar Ranch Library	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
111	1550	Libraries	2.41%	Scripps Miramar Ranch Library	Exhaust Fans	Necessary- 2-5 Yrs	District 5	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$10,829
111	1551	Libraries	2.41%	Scripps Miramar Ranch Library	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$23,432
111	1552	Libraries	2.41%	Scripps Miramar Ranch Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$28,142
111	1553	Libraries	2.41%	Scripps Miramar Ranch Library	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$35,693
111	1554	Libraries	2.41%	Scripps Miramar Ranch Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$300,498
112	1555	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Site Development	Necessary- 2-5 Yrs	District 4	Other Site Structures	Damaged	Repaint pipe bollards	\$592
112	1555	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Site Development	Necessary- 2-5 Yrs	District 4	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$573
112	1556	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$9,919
112	1556	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace Stucco Wall	\$5,145
112	1557	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Landscaping	Necessary- 2-5 Yrs	District 4	Landscaping	Damaged	Re-grade Site	\$42,004
112	1557	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Landscaping	Necessary- 2-5 Yrs	District 4	Landscaping	Damaged	Perform landscaping maintenance	\$4,809
112	1558	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,354
112	1558	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$391,661
112	1559	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$19,234
112	1560	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$25,320
112	1561	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,190
112	1562	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Repaint Interior Metal Door Frames	\$4,648
112	1563	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Inadequate	Engineering study to determine scope of work	\$23,078
112	1564	Libraries	2.36%	Malcolm X, & R.E.A.D. San Dieg	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$108,718
113	1565	Libraries	2.23%	Oak Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,219
113	1565	Libraries	2.23%	Oak Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
113	1566	Libraries	2.23%	Oak Park	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,103
113	1566	Libraries	2.23%	Oak Park	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$303
113	1567	Libraries	2.23%	Oak Park	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$310
113	1568	Libraries	2.23%	Oak Park	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$5,219
113	1569	Libraries	2.23%	Oak Park	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Failing	Install/Replace site lighting-Lite Pole	\$14,169
113	1570	Libraries	2.23%	Oak Park	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,279
113	1571	Libraries	2.23%	Oak Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,908

113	1572	Libraries	2.23%	Oak Park	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Slurry seal asphalt	\$7,628
113	1573	Libraries	2.23%	Oak Park	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Replace Ceramic Tile	\$7,800
113	1574	Libraries	2.23%	Oak Park	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$9,256
113	1575	Libraries	2.23%	Oak Park	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$14,805
113	1576	Libraries	2.23%	Oak Park	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$18,134
114	1577	Libraries	2.19%	Rancho Bernardo Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$4,148
114	1577	Libraries	2.19%	Rancho Bernardo Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Minor Repairs to Concrete Floor	\$752
114	1577	Libraries	2.19%	Rancho Bernardo Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Stairs	Failing	Paint stairs	\$2,119
114	1577	Libraries	2.19%	Rancho Bernardo Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Parking Lot	Failing	Replace expansion joint filler	\$1,005
114	1578	Libraries	2.19%	Rancho Bernardo Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$673
114	1578	Libraries	2.19%	Rancho Bernardo Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,597
114	1578	Libraries	2.19%	Rancho Bernardo Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,165
114	1579	Libraries	2.19%	Rancho Bernardo Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$10,854
114	1579	Libraries	2.19%	Rancho Bernardo Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circut label electric outlets and switches	\$22,119
114	1580	Libraries	2.19%	Rancho Bernardo Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Repair or replace laminate	\$9,905
114	1580	Libraries	2.19%	Rancho Bernardo Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$1,077
114	1581	Libraries	2.19%	Rancho Bernardo Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$5,950
114	1581	Libraries	2.19%	Rancho Bernardo Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Replace Carpet	\$370,142
114	1582	Libraries	2.19%	Rancho Bernardo Library	Sprinklers	Potentially Critical-12 months	District 5	Fire Supression	Inadequate	Install or replace wet fire suppression system	\$2,424
114	1583	Libraries	2.19%	Rancho Bernardo Library	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$11,577
114	1584	Libraries	2.19%	Rancho Bernardo Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$22,119
114	1585	Libraries	2.19%	Rancho Bernardo Library	Storm Sewer	Necessary- 2-5 Yrs	District 5	Rain Water Drainage	Failing	Replace Area Drain and Piping	\$10,251
114	1586	Libraries	2.19%	Rancho Bernardo Library	Site Development	Necessary- 2-5 Yrs	District 5	Parking Lot	Failing	Repaint or restripe Parking Lot/	\$1,173
114	1587	Libraries	2.19%	Rancho Bernardo Library	Domestic Water Distribution	Necessary- 2-5 Yrs	District 5	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, electric	\$2,880
114	1588	Libraries	2.19%	Rancho Bernardo Library	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,412
114	1589	Libraries	2.19%	Rancho Bernardo Library	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$7,774
114	1590	Libraries	2.19%	Rancho Bernardo Library	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$12,122
114	1591	Libraries	2.19%	Rancho Bernardo Library	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$42,749
114	1592	Libraries	2.19%	Rancho Bernardo Library	Communications and Security	Necessary- 2-5 Yrs	District 5	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
115	1593	Libraries	2.02%	Earl & Birdie Taylor Library	Electrical Service/Distribution	Critical / Immediate Need	District 2	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$1,923
115	1594	Libraries	2.02%	Earl & Birdie Taylor Library	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,866
115	1594	Libraries	2.02%	Earl & Birdie Taylor Library	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Failing	Replace door hardware	\$2,427
115	1595	Libraries	2.02%	Earl & Birdie Taylor Library	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Toilet Partition	\$6,214
115	1595	Libraries	2.02%	Earl & Birdie Taylor Library	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
115	1596	Libraries	2.02%	Earl & Birdie Taylor Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$27,436
115	1596	Libraries	2.02%	Earl & Birdie Taylor Library	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,054
115	1597	Libraries	2.02%	Earl & Birdie Taylor Library	Sprinklers	Potentially Critical-12 months	District 2	Fire Supression	Missing	Install protective security barrier for fire riser	\$699
115	1598	Libraries	2.02%	Earl & Birdie Taylor Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,216
115	1599	Libraries	2.02%	Earl & Birdie Taylor Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Repair or replace laminate	\$1,828
115	1600	Libraries	2.02%	Earl & Birdie Taylor Library	Site Development	Necessary- 2-5 Yrs	District 2	Fencing	Damaged	Repaint Metal Fence	\$2,107
115	1601	Libraries	2.02%	Earl & Birdie Taylor Library	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,853
115	1602	Libraries	2.02%	Earl & Birdie Taylor Library	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,412
115	1603	Libraries	2.02%	Earl & Birdie Taylor Library	Exhaust Fans	Necessary- 2-5 Yrs	District 2	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
115	1604	Libraries	2.02%	Earl & Birdie Taylor Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$18,467
115	1605	Libraries	2.02%	Earl & Birdie Taylor Library	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$19,413
115	1606	Libraries	2.02%	Earl & Birdie Taylor Library	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$188,120
116	1608	Comfort Stations	51.88%	#000510	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle 20A 120V ASSY/S.F.	\$4,531
116	1608	Comfort Stations	51.88%	#000510	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Install or replace exterior lighting	\$1,870
116	1608	Comfort Stations	51.88%	#000510	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
116	1608	Comfort Stations	51.88%	#000510	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circut label electric outlets and switches	\$647
116	1609	Comfort Stations	51.88%	#000510	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,541
116	1609	Comfort Stations	51.88%	#000510	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
116	1609	Comfort Stations	51.88%	#000510	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Toilet Partition	\$10,991
116	1610	Comfort Stations	51.88%	#000510	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255

116	1610	Comfort Stations	51.88%	#000510	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$3,205
116	1610	Comfort Stations	51.88%	#000510	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Failing	Replace Drinking Fountain	\$6,237
116	1610	Comfort Stations	51.88%	#000510	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,516
116	1611	Comfort Stations	51.88%	#000510	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,793
116	1611	Comfort Stations	51.88%	#000510	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$5,716
116	1612	Comfort Stations	51.88%	#000510	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Repair Concrete Fascia	\$1,473
116	1613	Comfort Stations	51.88%	#000510	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,754
116	1614	Comfort Stations	51.88%	#000510	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,561
116	1615	Comfort Stations	51.88%	#000510	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$7,828
116	1616	Comfort Stations	51.88%	#000510	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$20,149
116	1617	Comfort Stations	51.88%	#000510	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Beyond Useful Life	Replace Modified Bitumen Roof Coverings	\$55,993
116	1618	Comfort Stations	51.88%	#000510	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
116	1619	Comfort Stations	51.88%	#000510	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,726
117	1620	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Terminal & Package Units	Potentially Critical-12 months	District 6	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$510
117	1620	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Missing	Install ductwork insullation and aces. as req.d	\$3,992
117	1621	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$3,254
117	1621	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,639
117	1623	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,377
117	1624	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$3,641
117	1625	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$5,521
117	1626	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,125
117	1627	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$23,161
117	1628	OF- Field Office - Engineering	1.76%	Eng. & Dev. Offices, Matl Test	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$54,739
118	1629	Libraries	1.68%	Carmel Mountain Ranch Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
118	1629	Libraries	1.68%	Carmel Mountain Ranch Library	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$12,600
118	1630	Libraries	1.68%	Carmel Mountain Ranch Library	Lighting and Branch Wiring	Critical / Immediate Need	District 5	Lighting/Branch Wiring	Missing	Install or replace electrical disconnect switch	\$3,015
118	1630	Libraries	1.68%	Carmel Mountain Ranch Library	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$12,600
118	1631	Libraries	1.68%	Carmel Mountain Ranch Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Missing	Replace Ceramic Tile	\$14,426
118	1631	Libraries	1.68%	Carmel Mountain Ranch Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$8,426
118	1631	Libraries	1.68%	Carmel Mountain Ranch Library	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$183,148
118	1632	Libraries	1.68%	Carmel Mountain Ranch Library	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$2,761
118	1632	Libraries	1.68%	Carmel Mountain Ranch Library	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Slurry seal asphalt	\$9,883
118	1633	Libraries	1.68%	Carmel Mountain Ranch Library	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$12,395
118	1634	Libraries	1.68%	Carmel Mountain Ranch Library	Domestic Water Distribution	Necessary- 2-5 Yrs	District 5	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, electric	\$2,217
118	1635	Libraries	1.68%	Carmel Mountain Ranch Library	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
118	1636	Libraries	1.68%	Carmel Mountain Ranch Library	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$3,695
118	1637	Libraries	1.68%	Carmel Mountain Ranch Library	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$5,640
118	1638	Libraries	1.68%	Carmel Mountain Ranch Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,483
118	1639	Libraries	1.68%	Carmel Mountain Ranch Library	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$6,523
118	1640	Libraries	1.68%	Carmel Mountain Ranch Library	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Paint exposed structural steel	\$9,923
119	1641	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,949
119	1641	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$964

119	1642	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$9,309
119	1642	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$2,427
119	1643	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Terminal & Package Units	Potentially Critical-12 months	District 6	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$510
119	1644	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$8,949
119	1645	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$6,641
119	1646	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$8,062
119	1647	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$24,704
119	1648	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Domestic Water Distribution	Potentially Critical-12 months	District 6	Sanitary Waste	Missing	Install or replace interceptor(clay trap).	\$28,247
119	1649	OF- Field Office - Engineering	1.25%	Eng. & Dev. Lab. Matl. Test	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$35,131
120	1650	Libraries	1.13%	Otay Mesa	Other Electrical Systems	Critical / Immediate Need	District 8	Other Electrical Systems	Failing	Replace 5-KVA Emergency Power Supply-Inverter	\$21,491
120	1651	Libraries	1.13%	Otay Mesa	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Wood Trellis	\$2,334
120	1651	Libraries	1.13%	Otay Mesa	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$11,199
120	1652	Libraries	1.13%	Otay Mesa	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$6,384
120	1652	Libraries	1.13%	Otay Mesa	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$55,952
120	1653	Libraries	1.13%	Otay Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,809
120	1654	Libraries	1.13%	Otay Mesa	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$9,265
120	1655	Libraries	1.13%	Otay Mesa	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,047
120	1656	Libraries	1.13%	Otay Mesa	Site Lighting	Necessary- 2-5 Yrs	District 8	Site Lighting	Failing	Replace in-ground HID light fixture	\$17,642
120	1657	Libraries	1.13%	Otay Mesa	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$26,780
121	1658	Libraries	1.09%	Linda Vista (New)	Lighting and Branch Wiring	Critical / Immediate Need	District 6	Lighting/Branch Wiring	Damaged	Replace exit light fixtures	\$530
121	1658	Libraries	1.09%	Linda Vista (New)	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$9,852
121	1659	Libraries	1.09%	Linda Vista (New)	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$11,999
121	1659	Libraries	1.09%	Linda Vista (New)	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$3,788
121	1660	Libraries	1.09%	Linda Vista (New)	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,035
121	1661	Libraries	1.09%	Linda Vista (New)	Site Development	Potentially Critical-12 months	District 6	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$1,428
121	1662	Libraries	1.09%	Linda Vista (New)	Exhaust Fans	Potentially Critical-12 months	District 6	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
121	1663	Libraries	1.09%	Linda Vista (New)	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Toilet Partition	\$6,497
121	1664	Libraries	1.09%	Linda Vista (New)	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,014
121	1665	Libraries	1.09%	Linda Vista (New)	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$17,149
121	1666	Libraries	1.09%	Linda Vista (New)	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$23,297
122	1667	Comfort Stations	50.94%	#000541	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$3,781
122	1667	Comfort Stations	50.94%	#000541	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$693
122	1668	Comfort Stations	50.94%	#000541	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
122	1668	Comfort Stations	50.94%	#000541	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$15,420
122	1669	Comfort Stations	50.94%	#000541	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$60,972
122	1669	Comfort Stations	50.94%	#000541	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$5,358
122	1670	Comfort Stations	50.94%	#000541	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
122	1671	Comfort Stations	50.94%	#000541	Water Supply	Necessary- 2-5 Yrs	District 2	Water Supply	Beyond Useful Life	Replace domestic water service	\$3,433
122	1672	Comfort Stations	50.94%	#000541	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$4,374
122	1673	Comfort Stations	50.94%	#000541	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Beyond Useful Life	Repaint wall	\$5,358
122	1674	Comfort Stations	50.94%	#000541	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,786
122	1675	Comfort Stations	50.94%	#000541	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$12,266
122	1676	Comfort Stations	50.94%	#000541	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Beyond Useful Life	Replace Wood Rafters and Deck	\$64,056
123	1678	Libraries	0.41%	Mission Valley	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$18,917
123	1678	Libraries	0.41%	Mission Valley	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install or replace Energy Management System (BAS)	\$63,345
123	1679	Libraries	0.41%	Mission Valley	Plumbing Fixtures	Potentially Critical-12 months	District 6	Other Plumbing Systems	Failing	Clean out sump plumbing and pump for fountain	\$1,769
123	1680	Libraries	0.41%	Mission Valley	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Aluminium Doors	\$11,606
124	1681	Libraries	0.34%	College Rolando Library	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,595
124	1681	Libraries	0.34%	College Rolando Library	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Construction	Damaged	Reslope floor to floor slope to floor drain	\$4,977

124	1682	Libraries	0.34%	College Rolando Library	Domestic Water Distribution	Potentially Critical-12 months	District 7	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
124	1683	Libraries	0.34%	College Rolando Library	Terminal & Package Units	Potentially Critical-12 months	District 7	Ductwork	Failing	Install or replace thermal insulation of ductwork	\$38,325
124	1684	Libraries	0.34%	College Rolando Library	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$2,366
124	1685	Libraries	0.34%	College Rolando Library	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
124	1686	Libraries	0.34%	College Rolando Library	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$3,423
124	1687	Libraries	0.34%	College Rolando Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Patch concrete	\$3,582
125	1688	Libraries	0.28%	Florence Riford / La Jolla	Electrical Service/Distribution	Critical / Immediate Need	District 1	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
125	1689	Libraries	0.28%	Florence Riford / La Jolla	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace door hardware	\$2,427
125	1689	Libraries	0.28%	Florence Riford / La Jolla	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,513
125	1690	Libraries	0.28%	Florence Riford / La Jolla	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Missing	Repair or restripe Parking Lot/	\$1,294
125	1690	Libraries	0.28%	Florence Riford / La Jolla	Parking Lots	Necessary- 2-5 Yrs	District 1	Parking Lot	Damaged	Slurry seal asphalt	\$4,399
125	1691	Libraries	0.28%	Florence Riford / La Jolla	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,184
125	1691	Libraries	0.28%	Florence Riford / La Jolla	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Steel Doors	\$13,561
125	1692	Libraries	0.28%	Florence Riford / La Jolla	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$24,427
125	1693	Libraries	0.28%	Florence Riford / La Jolla	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,054
125	1694	Libraries	0.28%	Florence Riford / La Jolla	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Clay Tiles	\$1,204
125	1695	Libraries	0.28%	Florence Riford / La Jolla	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$2,136
125	1696	Libraries	0.28%	Florence Riford / La Jolla	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
125	1697	Libraries	0.28%	Florence Riford / La Jolla	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Failing	Replace Aluminium Windows	\$2,594
125	1698	Libraries	0.28%	Florence Riford / La Jolla	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Missing	Replace Concrete Sidewalks	\$2,649
126	1699	Libraries	0.23%	Point Loma Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace Decorative Tile	\$913
126	1699	Libraries	0.23%	Point Loma Library	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Paint exposed structural steel	\$7,938
126	1700	Libraries	0.23%	Point Loma Library	Domestic Water Distribution	Potentially Critical-12 months	District 2	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
126	1701	Libraries	0.23%	Point Loma Library	Site Lighting	Potentially Critical-12 months	District 2	Site Lighting	Failing	Install/Replace site lighting-Lite Pole	\$21,254
126	1702	Libraries	0.23%	Point Loma Library	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$2,039
126	1703	Libraries	0.23%	Point Loma Library	Site Development	Necessary- 2-5 Yrs	District 2	Fencing	Damaged	Replace concrete block fencing	\$4,370
126	1704	Libraries	0.23%	Point Loma Library	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,905
126	1705	Libraries	0.23%	Point Loma Library	Cooling Generating Systems	Necessary- 2-5 Yrs	District 2	Distribution Systems	Inadequate	Replace AHU 3000 CFM	\$14,702
127	1706	Libraries	0.21%	Serra Mesa/Kearny Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,020
127	1706	Libraries	0.21%	Serra Mesa/Kearny Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$4,809
127	1706	Libraries	0.21%	Serra Mesa/Kearny Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
127	1707	Libraries	0.21%	Serra Mesa/Kearny Mesa	Fuel Distribution - Natural Gas	Potentially Critical-12 months	District 6	Fuel Distribution	Missing	Install protective bollards	\$5,102
127	1708	Libraries	0.21%	Serra Mesa/Kearny Mesa	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Identifying Devices	\$101
127	1709	Libraries	0.21%	Serra Mesa/Kearny Mesa	Site Development	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$815
127	1710	Libraries	0.21%	Serra Mesa/Kearny Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,071
127	1711	Libraries	0.21%	Serra Mesa/Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$2,568
127	1712	Libraries	0.21%	Serra Mesa/Kearny Mesa	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$4,628
127	1713	Libraries	0.21%	Serra Mesa/Kearny Mesa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$4,855
128	1714	Comfort Stations	49.18%	#000509	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$382
128	1714	Comfort Stations	49.18%	#000509	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Receptacle 20A 120V ASSY/S.F.	\$2,676
128	1714	Comfort Stations	49.18%	#000509	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace 1X4 Surface Flourescent Fixture S.F.	\$8,492
128	1715	Comfort Stations	49.18%	#000509	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace Toilet Partition	\$19,446
128	1715	Comfort Stations	49.18%	#000509	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace Bathroom Accessories	\$739
128	1715	Comfort Stations	49.18%	#000509	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
128	1716	Comfort Stations	49.18%	#000509	Exterior Doors	Potentially Critical-12 months	District 3	Exterior Doors	Failing	Repair exterior metal doors	\$2,608
128	1717	Comfort Stations	49.18%	#000509	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$1,627
128	1717	Comfort Stations	49.18%	#000509	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Beyond Useful Life	Replace Plaster Ceiling	\$24,695
128	1718	Comfort Stations	49.18%	#000509	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$42,386
128	1718	Comfort Stations	49.18%	#000509	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
128	1719	Comfort Stations	49.18%	#000509	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Failing	Replace Roof Fascia	\$1,725
128	1720	Comfort Stations	49.18%	#000509	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,412
128	1721	Comfort Stations	49.18%	#000509	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$3,689
128	1722	Comfort Stations	49.18%	#000509	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$5,919
128	1723	Comfort Stations	49.18%	#000509	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
128	1724	Comfort Stations	49.18%	#000509	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,862

128	1725	Comfort Stations	49.18%	#000509	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Copper Water Pipe <2 in	\$12,529
128	1726	Comfort Stations	49.18%	#000509	Water Supply	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Repair or replace domestic water piping	\$23,478
129	1728	Comfort Stations	47.69%	#000540	Exterior Walls	Potentially Critical-12 months	District 2	Ventilation and Exhaust	Damaged	Install or replace exterior louvers	\$797
129	1728	Comfort Stations	47.69%	#000540	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$9,629
129	1728	Comfort Stations	47.69%	#000540	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$164,357
129	1729	Comfort Stations	47.69%	#000540	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
129	1729	Comfort Stations	47.69%	#000540	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
129	1729	Comfort Stations	47.69%	#000540	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$923
129	1730	Comfort Stations	47.69%	#000540	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
129	1731	Comfort Stations	47.69%	#000540	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Damaged	Replace Domestic Water and Sanitary Piping (SF)	\$763
129	1732	Comfort Stations	47.69%	#000540	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$787
129	1733	Comfort Stations	47.69%	#000540	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$2,899
129	1734	Comfort Stations	47.69%	#000540	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$3,059
129	1735	Comfort Stations	47.69%	#000540	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Drinking Fountain	\$3,119
129	1736	Comfort Stations	47.69%	#000540	Partitions	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Toilet Partition	\$3,960
129	1737	Comfort Stations	47.69%	#000540	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Roof Fascia	\$5,748
129	1738	Comfort Stations	47.69%	#000540	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard -400A	\$10,967
129	1739	Comfort Stations	47.69%	#000540	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$18,055
129	1740	Comfort Stations	47.69%	#000540	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Failing	Replace sanitary sewer service	\$3,538
130	1742	Comfort Stations	47.10%	#001090	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$27,839
130	1742	Comfort Stations	47.10%	#001090	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$831
130	1742	Comfort Stations	47.10%	#001090	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$8,557
130	1743	Comfort Stations	47.10%	#001090	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
130	1743	Comfort Stations	47.10%	#001090	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$22,650
130	1744	Comfort Stations	47.10%	#001090	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install or replace exterior lighting	\$935
130	1745	Comfort Stations	47.10%	#001090	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$2,537
130	1746	Comfort Stations	47.10%	#001090	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
130	1747	Comfort Stations	47.10%	#001090	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$4,349
130	1748	Comfort Stations	47.10%	#001090	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,411
130	1749	Comfort Stations	47.10%	#001090	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$5,760
130	1750	Comfort Stations	47.10%	#001090	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$6,410
130	1751	Comfort Stations	47.10%	#001090	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$6,865
130	1752	Comfort Stations	47.10%	#001090	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$9,027
130	1753	Comfort Stations	47.10%	#001090	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$20,100
130	1754	Comfort Stations	47.10%	#001090	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
131	1755	Comfort Stations	46.39%	#001095	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$4,393
131	1755	Comfort Stations	46.39%	#001095	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$693
131	1756	Comfort Stations	46.39%	#001095	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$17,830
131	1756	Comfort Stations	46.39%	#001095	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
131	1757	Comfort Stations	46.39%	#001095	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
131	1758	Comfort Stations	46.39%	#001095	Water Supply	Necessary- 2-5 Yrs	District 4	WATER Supply	Beyond Expected Life	Replace domestic water service	\$3,433
131	1759	Comfort Stations	46.39%	#001095	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Beyond Useful Life	Repaint wall	\$3,680
131	1760	Comfort Stations	46.39%	#001095	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$3,988
131	1761	Comfort Stations	46.39%	#001095	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$4,374
131	1762	Comfort Stations	46.39%	#001095	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,048
131	1763	Comfort Stations	46.39%	#001095	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$5,586
131	1764	Comfort Stations	46.39%	#001095	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Replace Wallboard Ceiling Finish	\$5,669
131	1765	Comfort Stations	46.39%	#001095	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$6,424
131	1766	Comfort Stations	46.39%	#001095	Electrical Distribution	Necessary- 2-5 Yrs	District 4	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$12,447
131	1767	Comfort Stations	46.39%	#001095	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Beyond Useful Life	Replace Modified Bitumen Roof Coverings	\$23,051
131	1768	Comfort Stations	46.39%	#001095	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Beyond Useful Life	Replace Wood Rafters and Deck	\$49,973
131	1769	Comfort Stations	46.39%	#001095	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$12,344
132	1770	Comfort Stations	44.49%	#009939	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Failing	Termite Inspection of Roof structure	\$8,318
132	1770	Comfort Stations	44.49%	#009939	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,323

132	1770	Comfort Stations	44.49%	#009939	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Failing	Replace Roof Fascia	\$1,849
132	1771	Comfort Stations	44.49%	#009939	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace exterior door hardware	\$11,431
132	1771	Comfort Stations	44.49%	#009939	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$10,434
132	1772	Comfort Stations	44.49%	#009939	Roof Coverings	Potentially Critical-12 months	District 2	Roof Covering	Damaged	Replace concrete tile roof	\$77,943
132	1773	Comfort Stations	44.49%	#009939	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$632
132	1774	Comfort Stations	44.49%	#009939	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
133	1775	Comfort Stations	42.21%	#009838	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Failing	Replace bath accessories electric air hand dryers	\$2,036
133	1775	Comfort Stations	42.21%	#009838	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
133	1775	Comfort Stations	42.21%	#009838	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace / Install Grab Bars	\$1,184
133	1776	Comfort Stations	42.21%	#009838	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Failing	Replace Roof Fascia	\$10,706
133	1776	Comfort Stations	42.21%	#009838	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Termite Inspection of Roof structure	\$17,423
133	1776	Comfort Stations	42.21%	#009838	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,743
133	1777	Comfort Stations	42.21%	#009838	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$708
133	1778	Comfort Stations	42.21%	#009838	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$1,956
133	1779	Comfort Stations	42.21%	#009838	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,355
133	1780	Comfort Stations	42.21%	#009838	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$3,509
133	1781	Comfort Stations	42.21%	#009838	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$4,457
133	1782	Comfort Stations	42.21%	#009838	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$7,775
133	1783	Comfort Stations	42.21%	#009838	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,910
133	1784	Comfort Stations	42.21%	#009838	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Beyond Useful Life	Replace concrete tile roof	\$37,028
134	1785	Comfort Stations	39.54%	#001206	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Termite Inspection of Roof structure	\$35,893
134	1785	Comfort Stations	39.54%	#001206	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Roof Fascia	\$78,567
134	1786	Comfort Stations	39.54%	#001206	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repair exterior metal doors	\$1,304
134	1786	Comfort Stations	39.54%	#001206	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Replace exterior door hardware	\$1,429
134	1787	Comfort Stations	39.54%	#001206	Roof Coverings	Potentially Critical-12 months	District 2	Roof Covering	Failing	Replace concrete tile roof	\$16,839
134	1788	Comfort Stations	39.54%	#001206	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$677
134	1789	Comfort Stations	39.54%	#001206	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,295
134	1790	Comfort Stations	39.54%	#001206	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
134	1791	Comfort Stations	39.54%	#001206	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$5,919
134	1792	Comfort Stations	39.54%	#001206	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$6,625
134	1793	Comfort Stations	39.54%	#001206	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Failing	Replaces fixture flush valve	\$7,823
135	1794	Comfort Stations	39.29%	#000508	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,025
135	1794	Comfort Stations	39.29%	#000508	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$27,839
135	1794	Comfort Stations	39.29%	#000508	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Incandescent Light Fixtures	\$4,987
135	1795	Comfort Stations	39.29%	#000508	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
135	1795	Comfort Stations	39.29%	#000508	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$20,806
135	1796	Comfort Stations	39.29%	#000508	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$9,027
135	1797	Comfort Stations	39.29%	#000508	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$2,299
135	1798	Comfort Stations	39.29%	#000508	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
135	1799	Comfort Stations	39.29%	#000508	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,772
135	1800	Comfort Stations	39.29%	#000508	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$2,899
135	1801	Comfort Stations	39.29%	#000508	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
135	1802	Comfort Stations	39.29%	#000508	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,411
135	1803	Comfort Stations	39.29%	#000508	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Repair Concrete Fascia	\$9,815
135	1804	Comfort Stations	39.29%	#000508	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$18,261
135	1805	Comfort Stations	39.29%	#000508	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
136	1806	Comfort Stations	38.61%	#001077	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$27,839
136	1806	Comfort Stations	38.61%	#001077	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$3,423
136	1806	Comfort Stations	38.61%	#001077	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$831
136	1807	Comfort Stations	38.61%	#001077	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
136	1807	Comfort Stations	38.61%	#001077	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$24,964
136	1808	Comfort Stations	38.61%	#001077	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$4,514
136	1809	Comfort Stations	38.61%	#001077	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
136	1810	Comfort Stations	38.61%	#001077	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$2,899
136	1811	Comfort Stations	38.61%	#001077	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$3,262
136	1812	Comfort Stations	38.61%	#001077	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,411
136	1813	Comfort Stations	38.61%	#001077	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,760
136	1814	Comfort Stations	38.61%	#001077	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$6,865
136	1815	Comfort Stations	38.61%	#001077	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744

136	1816	Comfort Stations	38.61%	#001077	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Beyond Useful Life	Replace Built up Roof	\$31,582
136	1817	Comfort Stations	38.61%	#001077	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,374
137	1818	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace wood siding	\$6,896
137	1818	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace exterior aluminum louver	\$1,530
137	1818	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
137	1818	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Prepare and Paint Exterior Concrete Wall Surface	\$6,924
137	1818	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Siding; Metal Corrugated	\$58,871
137	1819	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$3,317
137	1819	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Inadequate	Replace Commercial Sliding Bay Door	\$4,080
137	1820	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Epoxy floor	\$26,985
137	1820	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$3,754
137	1821	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Metal Panel Roof; Corrugated	\$26,813
137	1821	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$4,136
137	1822	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,731
137	1823	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Water Supply	Potentially Critical-12 months	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$20,501
137	1824	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Prepare and Paint Interior Ceiling	\$1,010
137	1825	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Int. Door; Solid; Painted; up to 3/0 x 7/0	\$1,759
137	1826	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$2,742
137	1827	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Rain Water Drainage	Necessary- 2-5 Yrs	District 8	Rain Water Drainage	Missing	Replace Gutter; Aluminum up to 6" x LF	\$2,968
137	1828	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Abandoned	Remove Abandoned Unit Heater; Cap Lines	\$3,231
137	1829	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$3,968
137	1830	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$6,213
137	1831	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Replace Roof Fascia	\$9,759
137	1832	OS - Operations Services	37.87%	#000034 Traffic Signals Shop	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$19,173
138	1833	Comfort Stations	37.29%	#001014	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace Facility Number Signage - Cast Aluminum	\$2,567
138	1833	Comfort Stations	37.29%	#001014	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Bathroom Accessories	\$369
138	1833	Comfort Stations	37.29%	#001014	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$7,920
138	1834	Comfort Stations	37.29%	#001014	Plumbing Fixtures	Potentially Critical-12 months	District 3	Plumbing Fixtures	Missing	Replace Toilet Seat; Elongated	\$107
138	1834	Comfort Stations	37.29%	#001014	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$12,463
138	1834	Comfort Stations	37.29%	#001014	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
138	1835	Comfort Stations	37.29%	#001014	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$950
138	1836	Comfort Stations	37.29%	#001014	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$6,989
138	1837	Comfort Stations	37.29%	#001014	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$1,169
138	1838	Comfort Stations	37.29%	#001014	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,106
138	1839	Comfort Stations	37.29%	#001014	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,411
138	1840	Comfort Stations	37.29%	#001014	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$5,594
138	1841	Comfort Stations	37.29%	#001014	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$6,003
138	1842	Comfort Stations	37.29%	#001014	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$6,865
138	1843	Comfort Stations	37.29%	#001014	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$8,298
138	1844	Comfort Stations	37.29%	#001014	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
138	1845	Comfort Stations	37.29%	#001014	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Inadequate	Replace Clay Tiles	\$26,079
138	1846	Comfort Stations	37.29%	#001014	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$61,466
139	1847	Comfort Stations	37.06%	#000792	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
139	1847	Comfort Stations	37.06%	#000792	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Drinking Fountain	\$3,119
139	1847	Comfort Stations	37.06%	#000792	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$5,407
139	1848	Comfort Stations	37.06%	#000792	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$5,302
139	1848	Comfort Stations	37.06%	#000792	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,516
139	1849	Comfort Stations	37.06%	#000792	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Failing	Replace Facility Number Signage - Cast Aluminum	\$2,567
139	1850	Comfort Stations	37.06%	#000792	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$565
139	1851	Comfort Stations	37.06%	#000792	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$37,329
139	1852	Comfort Stations	37.06%	#000792	Wall Finishes	Potentially Critical-12 months	District 2	Wall Finishes	Beyond Useful Life	Repaint wall	\$3,882
139	1853	Comfort Stations	37.06%	#000792	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$834
139	1854	Comfort Stations	37.06%	#000792	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$3,633
139	1855	Comfort Stations	37.06%	#000792	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$5,974
139	1856	Comfort Stations	37.06%	#000792	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Inadequate	Replace Clay Tiles	\$13,040
139	1857	Comfort Stations	37.06%	#000792	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$5,662
140	1859	Comfort Stations	35.12%	#001093	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,407

140	1859	Comfort Stations	35.12%	#001093	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace CMU Block Wall	\$41,090
140	1860	Comfort Stations	35.12%	#001093	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Missing	Replace Gutters and downspouts	\$1,040
140	1860	Comfort Stations	35.12%	#001093	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Clay Tiles	\$58,178
140	1861	Comfort Stations	35.12%	#001093	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Termite Inspection of Roof structure	\$9,993
140	1862	Comfort Stations	35.12%	#001093	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$553
140	1863	Comfort Stations	35.12%	#001093	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,020
140	1864	Comfort Stations	35.12%	#001093	Domestic Water Distribution	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Replace High Bay Light/Fixture Ea.	\$1,930
140	1865	Comfort Stations	35.12%	#001093	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$2,420
140	1866	Comfort Stations	35.12%	#001093	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
140	1867	Comfort Stations	35.12%	#001093	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$2,826
140	1868	Comfort Stations	35.12%	#001093	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
141	1869	Comfort Stations	35.04%	#001256	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$2,312
141	1869	Comfort Stations	35.04%	#001256	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
141	1870	Comfort Stations	35.04%	#001256	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
141	1870	Comfort Stations	35.04%	#001256	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$454
141	1871	Comfort Stations	35.04%	#001256	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,836
141	1872	Comfort Stations	35.04%	#001256	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,679
141	1873	Comfort Stations	35.04%	#001256	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$2,755
141	1874	Comfort Stations	35.04%	#001256	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$3,899
141	1875	Comfort Stations	35.04%	#001256	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
141	1876	Comfort Stations	35.04%	#001256	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Epoxy floor	\$8,635
141	1877	Comfort Stations	35.04%	#001256	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
141	1878	Comfort Stations	35.04%	#001256	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Beyond Useful Life	Replace Built up Roof	\$19,780
141	1879	Comfort Stations	35.04%	#001256	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,490
142	1880	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Exterior Walls	Critical / Immediate Need	District 8	Exterior Walls	Failing	Replace Exteior Wood Stairs, Rails and Landing	\$46,019
142	1880	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Exterior Walls	Critical / Immediate Need	District 8	Exterior Walls	Inadequate	Seismic Stablization of Chimneys	\$28,849
142	1880	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare _ Paint Exterior Walls up to 3 Floors	\$280,310
142	1881	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Interior Doors	Critical / Immediate Need	District 8	Interior Doors	Damaged	Remove, Salvage, Restore Int. Door-Wood Historic	\$43,389
142	1881	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Failing	Remove/ Restore Historic Art Glass Door Transoms	\$59,957
142	1882	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Exterior Windows	Critical / Immediate Need	District 8	Exterior Windows	Damaged	Remove Salvage Restore Window - Wood Historic	\$90,180
142	1883	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Slab on Grade	Critical / Immediate Need	District 8	Slab on Grade	Failing	Replace Slab On Grade	\$674,804
142	1884	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$27,606
142	1884	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$44,879
142	1885	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Exterior Doors	Potentially Critical-12 months	District 8	Exterior Doors	Damaged	Remove, Salvage, Restore Ext. Door-Wood Historic	\$13,478
142	1886	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Electrical Service/Distribution	Critical / Immediate Need	District 8	Electrical Service/Distribution	Missing	Replace Electrical Switch Board Door Latch	\$433
142	1887	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Fence & Guardrails - Wood	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$1,693
142	1888	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Stair Construction	Necessary- 2-5 Yrs	District 8	Stairs	Damaged	Sand, Stain and Seal Int. Wood Stairs and Rise	\$3,270
142	1889	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Roof Openings	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$5,318
142	1890	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Lawns & Ground Cover	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$10,366
142	1891	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Drainage & Sewage Piping	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$12,530
142	1892	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$33,970
142	1893	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Concrete Sidewalks	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$35,381
142	1894	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Communications and Security	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$43,403
142	1895	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Site Lighting	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$46,986
142	1896	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$63,466
142	1897	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Sprinklers	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$65,435
142	1898	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Dumb Waiter - Manual	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$68,069
142	1899	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Rain Water Drainage	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$72,781
142	1900	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Roadway Pavement - Concrete Driveway	Necessary- 2-5 Yrs	District 8	Roadways	Damaged	Replace Concrete Roadway	\$73,389
142	1901	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Plaster Ceiling	\$93,704
142	1902	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Plumbing Fixtures - Includes Sanitary Lines	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$124,960
142	1903	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Fittings/Specialties	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$131,332

142	1904	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Fence & Guardrails - Historic - Wrought Iron	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$134,203
142	1905	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$192,346
142	1906	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Partitions	Necessary- 2-5 Yrs	District 8	Partitions	Damaged	Replace Plaster Partition/Wood Stud Backup	\$238,187
142	1907	MS - Parks / Recreation	34.25%	Villa Montezuma - Historic	Roof Coverings	Necessary- 2-5 Yrs	District 8	System	Beyond Useful Life	Renew System	\$748,767
143	1908	Comfort Stations	33.58%	#000538	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$10,270
143	1908	Comfort Stations	33.58%	#000538	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$677
143	1909	Comfort Stations	33.58%	#000538	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
143	1909	Comfort Stations	33.58%	#000538	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$15,420
143	1910	Comfort Stations	33.58%	#000538	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
143	1911	Comfort Stations	33.58%	#000538	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Beyond Useful Life	Repaint wall	\$2,734
143	1912	Comfort Stations	33.58%	#000538	Water Supply	Necessary- 2-5 Yrs	District 8	WATER Supply	Beyond Expected Life	Replace domestic water service	\$3,433
143	1913	Comfort Stations	33.58%	#000538	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$3,899
143	1914	Comfort Stations	33.58%	#000538	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Replace Steel Doors	\$4,190
143	1915	Comfort Stations	33.58%	#000538	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$4,278
143	1916	Comfort Stations	33.58%	#000538	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Beyond Useful Life	Replace Acoustical Ceiling Tile	\$5,619
143	1917	Comfort Stations	33.58%	#000538	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$6,096
143	1918	Comfort Stations	33.58%	#000538	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
143	1919	Comfort Stations	33.58%	#000538	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Replace Roof Fascia	\$32,728
143	1920	Comfort Stations	33.58%	#000538	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$14,389
144	1921	Comfort Stations	32.96%	#001007	Fittings	Potentially Critical-12 months	District 6	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
144	1921	Comfort Stations	32.96%	#001007	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Facility Number Signage - Cast Aluminum	\$2,567
144	1922	Comfort Stations	32.96%	#001007	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,095
144	1922	Comfort Stations	32.96%	#001007	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$4,287
144	1923	Comfort Stations	32.96%	#001007	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$7,710
144	1923	Comfort Stations	32.96%	#001007	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
144	1924	Comfort Stations	32.96%	#001007	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
144	1924	Comfort Stations	32.96%	#001007	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$687
144	1925	Comfort Stations	32.96%	#001007	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$1,536
144	1926	Comfort Stations	32.96%	#001007	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,565
144	1927	Comfort Stations	32.96%	#001007	Electrical Distribution	Potentially Critical-12 months	District 6	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$2,490
144	1928	Comfort Stations	32.96%	#001007	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$3,253
144	1929	Comfort Stations	32.96%	#001007	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
144	1930	Comfort Stations	32.96%	#001007	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$12,973
145	1932	Comfort Stations	32.23%	#001010	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Incandescent Light Fixtures	\$3,835
145	1932	Comfort Stations	32.23%	#001010	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$17,149
145	1932	Comfort Stations	32.23%	#001010	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$889
145	1933	Comfort Stations	32.23%	#001010	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
145	1933	Comfort Stations	32.23%	#001010	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Wall Hung Urinal	\$3,206
145	1933	Comfort Stations	32.23%	#001010	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Tankless Type Toilet	\$3,888
145	1934	Comfort Stations	32.23%	#001010	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$5,382
145	1934	Comfort Stations	32.23%	#001010	Wall Finishes	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,522
145	1935	Comfort Stations	32.23%	#001010	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$906
145	1936	Comfort Stations	32.23%	#001010	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$1,956
145	1937	Comfort Stations	32.23%	#001010	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
145	1938	Comfort Stations	32.23%	#001010	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
145	1939	Comfort Stations	32.23%	#001010	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,411
145	1940	Comfort Stations	32.23%	#001010	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
145	1941	Comfort Stations	32.23%	#001010	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$20,744
145	1942	Comfort Stations	32.23%	#001010	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace wood shingle roof	\$25,152
145	1943	Comfort Stations	32.23%	#001010	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,473
146	1944	Comfort Stations	31.48%	#001008	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Toilet Partition	\$11,880
146	1944	Comfort Stations	31.48%	#001008	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
146	1944	Comfort Stations	31.48%	#001008	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace room signage	\$1,342
146	1945	Comfort Stations	31.48%	#001008	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
146	1945	Comfort Stations	31.48%	#001008	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$889
146	1946	Comfort Stations	31.48%	#001008	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,973

146	1947	Comfort Stations	31.48%	#001008	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$2,589
146	1948	Comfort Stations	31.48%	#001008	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$3,039
146	1949	Comfort Stations	31.48%	#001008	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,190
146	1950	Comfort Stations	31.48%	#001008	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Wood Doors	\$10,188
146	1951	Comfort Stations	31.48%	#001008	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$12,797
146	1952	Comfort Stations	31.48%	#001008	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
146	1953	Comfort Stations	31.48%	#001008	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$19,656
146	1954	Comfort Stations	31.48%	#001008	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$22,206
146	1955	Comfort Stations	31.48%	#001008	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
146	1956	Comfort Stations	31.48%	#001008	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$11,378
147	1957	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,328
147	1957	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install Junction Box and Cover; 4" x 4" Steel	\$238
147	1957	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Ext. Lgt. Fix. Wall Pack; Up to 200 Watts	\$3,831
147	1958	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Epoxy floor	\$55,160
147	1958	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$32,976
147	1958	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Chip; Clean Seal Cracks in Concrete Floor; To 1/4"	\$21,671
147	1959	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
147	1959	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Exterior Siding; Fiberglass; Corrugated	\$147,056
147	1959	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$30,662
147	1960	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$2,831
147	1960	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$758
147	1961	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,351
147	1961	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$1,676
147	1962	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$4,268
147	1962	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Parking Lots	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$902
147	1963	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace 4T Split System A/C Comp	\$21,061
147	1963	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Abandoned	Remove Abandoned Unit Heater; Cap Lines	\$1,077
147	1964	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$4,597
147	1964	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$19,881
147	1965	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$13,269
147	1965	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Inadequate	Replace Commercial Sliding Bay Door	\$12,241
147	1966	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Stair Construction	Potentially Critical-12 months	District 8	Stairs	Damaged	Replace Wood Stairs Stringers Treads Risers	\$10,161
147	1967	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Abandoned	Remove Abandoned Plumbing Fixture; Cap Lines	\$566
147	1968	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Rain Water Drainage	Necessary- 2-5 Yrs	District 8	Rain Water Drainage	Inadequate	Replace Gutter; Aluminum up to 6" x LF	\$6,078
147	1969	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Replace Roof Fascia	\$15,682
147	1970	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$31,940
147	1971	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$44,736
147	1972	OS - Operations Services	30.96%	#000033 HVAC Shop Central	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Roof Covering; Fiberglas; Corrugated	\$174,705
148	1973	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Landscaping	Critical / Immediate Need	District 3	Landscaping	Inadequate	Re-grade Site	\$87,419
148	1973	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Landscaping	Critical / Immediate Need	District 3	Landscaping	Failing	Install or replace lawn sod	\$4,952
148	1973	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Landscaping	Critical / Immediate Need	District 3	Landscaping	Inadequate	Re-grade Site	\$87,419
148	1973	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Landscaping	Critical / Immediate Need	District 3	Landscaping	Inadequate	Perform landscaping maintenance	\$13,655
148	1974	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$268
148	1974	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Damaged	Replace Incandescent Light Fixtures	\$708
148	1974	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$17,531
148	1974	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$189,373
148	1974	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$270,967
148	1975	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Construction	Critical / Immediate Need	District 3	Floor Construction	Damaged	Replace Exteior Wood Deck Structure and Floor	\$12,863
148	1975	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Construction	Critical / Immediate Need	District 3	Floor Construction	Failing	Replace Exteior Wood Deck Structure and Floor	\$89,916
148	1975	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Construction	Necessary- 2-5 Yrs	District 3	Floor Construction	Damaged	Replace Conceret Loading Dock Floor Slab	\$103,041
148	1976	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Finishes	Potentially Critical-12 months	District 3	Floor Finishes	Damaged	Replace Stage Floor Covering	\$81,359
148	1976	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Finishes	Potentially Critical-12 months	District 3	Floor Finishes	Damaged	Replace VCT	\$34,890
148	1976	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$92,879
148	1976	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Sheet Vinyl Floor Covering	\$22,348

148	1977	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Remove, Salvage, Restore Ext. Door-Wood Historic	\$40,830
148	1977	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$15,185
148	1977	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$9,630
148	1978	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Pedestrian Paving	Potentially Critical-12 months	District 3	Pedestrian Paving	Damaged	Chip Clean Seal Concrete Pavement - Amphitheater	\$199,237
148	1978	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$44,769
148	1979	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Interior Doors	Potentially Critical-12 months	District 3	Interior Doors	Missing	Replace door hardware	\$1,378
148	1979	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Metal Door/Metal Frame	\$78,338
148	1980	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Stair Construction	Critical / Immediate Need	District 3	Stairs	Missing	Replace Exterior Metal Stairs	\$21,288
148	1981	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Storm Sewer	Critical / Immediate Need	District 3	Storm Sewer	Failing	Investigate and Clear Storm Drains	\$61,746
148	1982	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace room signage	\$509
148	1982	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$17,995
148	1983	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Beyond Expected Life	Replace Intercom/Paging System-50 stations	\$144,169
148	1983	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Inadequate	Replace Fire Alarm System/ASSY for 100 devices	\$143,155
148	1984	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$1,454
148	1984	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$286,745
148	1985	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Site Lighting	Potentially Critical-12 months	District 3	Site Lighting	Failing	Replace Step Light; Recessed up to 8" x 5"	\$157,863
148	1986	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Plumbing Fixtures	Critical / Immediate Need	District 3	Domestic Water Distribution	Damaged	Request Plumbing Consultant	\$156,581
148	1987	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Ceiling Finishes	Potentially Critical-12 months	District 3	Ceiling Finishes	Damaged	Replace Plaster and Lath Ceiling	\$240,355
148	1988	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$148,722
148	1989	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Plaster / Lath Interior Wall	\$615,941
148	1990	PB - Park Balboa	30.91%	Starlight Bowl Theater (L)	Site Development	Necessary- 2-5 Yrs	District 3	Site Development	Damaged	Replace Theater Seating - Outdoor	\$1,476,980
149	1991	Comfort Stations	30.24%	#001079	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$3,423
149	1991	Comfort Stations	30.24%	#001079	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$569
149	1992	Comfort Stations	30.24%	#001079	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
149	1992	Comfort Stations	30.24%	#001079	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$15,420
149	1993	Comfort Stations	30.24%	#001079	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Beyond Useful Life	Repaint wall	\$2,299
149	1994	Comfort Stations	30.24%	#001079	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$3,064
149	1995	Comfort Stations	30.24%	#001079	Water Supply	Necessary- 2-5 Yrs	District 4	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
149	1996	Comfort Stations	30.24%	#001079	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$3,597
149	1997	Comfort Stations	30.24%	#001079	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$4,190
149	1998	Comfort Stations	30.24%	#001079	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
149	1999	Comfort Stations	30.24%	#001079	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$12,266
149	2000	Comfort Stations	30.24%	#001079	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$20,100
150	2002	Comfort Stations	30.15%	#000537	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
150	2002	Comfort Stations	30.15%	#000537	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
150	2002	Comfort Stations	30.15%	#000537	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$647
150	2002	Comfort Stations	30.15%	#000537	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace Receptacle 20A 120V ASSY/S.F.	\$4,909
150	2003	Comfort Stations	30.15%	#000537	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
150	2003	Comfort Stations	30.15%	#000537	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Restroom Accessories	\$5,078
150	2004	Comfort Stations	30.15%	#000537	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repair exterior metal doors	\$5,217
150	2004	Comfort Stations	30.15%	#000537	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Replace exterior door hardware	\$5,716
150	2005	Comfort Stations	30.15%	#000537	Wall Finishes	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$618
150	2006	Comfort Stations	30.15%	#000537	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,190
150	2007	Comfort Stations	30.15%	#000537	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,469
150	2008	Comfort Stations	30.15%	#000537	Partitions	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$7,766
150	2009	Comfort Stations	30.15%	#000537	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
150	2010	Comfort Stations	30.15%	#000537	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Epoxy floor	\$20,149
150	2011	Comfort Stations	30.15%	#000537	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Plaster Ceiling	\$27,868
151	2012	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace Stucco Wall	\$69,142
151	2012	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace exterior aluminum louver	\$1,194
151	2012	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
151	2013	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Wall Finishes	Potentially Critical-12 months	District 8	Wall Finishes	Damaged	Replace Plaster / Lath Interior Wall	\$6,228
151	2013	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$26,014

151	2014	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,616
151	2014	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$102,682
151	2015	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$24,432
151	2015	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$9,952
151	2016	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$32,902
151	2016	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace 30 Gal Gas Water Heater	\$2,804
151	2017	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Beyond Expected Life	Replace VCT	\$6,568
151	2017	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Epoxy floor	\$45,696
151	2018	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Storm Sewer	Potentially Critical-12 months	District 8	Storm Sewer	Inadequate	Provide technical study of storm drainage system	\$7,692
151	2019	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exhaust Fans	Potentially Critical-12 months	District 8	Exhaust Ventilation System	Beyond Expected Life	Replace Exhaust Fan; Util. Belt 1100 CFM; 3 HP	\$10,021
151	2020	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Water Supply	Potentially Critical-12 months	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$20,501
151	2021	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Missing	Replace Cased Openings; Wood	\$1,096
151	2022	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$1,889
151	2023	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Stair Construction	Necessary- 2-5 Yrs	District 8	Stairs	Failing	Sand, Stain and Seal Int. Wood Stairs and Rise	\$2,746
151	2024	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Prepare Paint Wood Fascia and Eaves (SF)	\$7,252
151	2025	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace Unit Heater; Natural Gas; Ceiling Mounted	\$16,701
151	2026	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$19,173
151	2027	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$32,770
151	2028	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Electrical Distribution	Necessary- 2-5 Yrs	District 8	Electrica Distribution	Beyond Expected Life	Replace exterior electrical distribution	\$43,444
151	2029	OS - Operations Services	29.85%	#000046 Comm. Spec. Sys. Group	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$47,240
152	2030	Comfort Stations	29.24%	#001235	Roof Construction	Potentially Critical-12 months	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$51,272
152	2030	Comfort Stations	29.24%	#001235	Roof Construction	Potentially Critical-12 months	District 2	Roof Construction	Damaged	Replace Roof Fascia	\$2,465
152	2030	Comfort Stations	29.24%	#001235	Roof Construction	Potentially Critical-12 months	District 2	Roof Construction	Damaged	Termite Inspection of Roof structure	\$17,728
152	2031	Comfort Stations	29.24%	#001235	Lighting and Branch Wiring	Does Not Meet Current Code/Standards	District 2	Lighting/Branch Wiring	Failing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
152	2031	Comfort Stations	29.24%	#001235	Lighting and Branch Wiring	Does Not Meet Current Code/Standards	District 2	Lighting/Branch Wiring	Failing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
152	2031	Comfort Stations	29.24%	#001235	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$986
152	2032	Comfort Stations	29.24%	#001235	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$7,530
152	2032	Comfort Stations	29.24%	#001235	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
152	2033	Comfort Stations	29.24%	#001235	Exterior Doors	Potentially Critical-12 months	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$1,397
152	2034	Comfort Stations	29.24%	#001235	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$4,660
152	2035	Comfort Stations	29.24%	#001235	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Beyond Expected Life	Repaint wall	\$1,245
152	2036	Comfort Stations	29.24%	#001235	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Beyond Useful Life	Epoxy floor	\$1,859
152	2037	Comfort Stations	29.24%	#001235	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
152	2038	Comfort Stations	29.24%	#001235	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$4,609
152	2039	Comfort Stations	29.24%	#001235	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,726
152	2040	Comfort Stations	29.24%	#001235	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$18,147
152	2041	Comfort Stations	29.24%	#001235	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$18,147
153	2042	Comfort Stations	29.08%	#010372	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
153	2042	Comfort Stations	29.08%	#010372	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$391
153	2043	Comfort Stations	29.08%	#010372	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
153	2043	Comfort Stations	29.08%	#010372	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Restroom Accessories	\$3,710
153	2044	Comfort Stations	29.08%	#010372	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,369
153	2045	Comfort Stations	29.08%	#010372	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$2,621
153	2046	Comfort Stations	29.08%	#010372	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,990
153	2047	Comfort Stations	29.08%	#010372	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Epoxy floor	\$6,522
154	2048	Comfort Stations	28.85%	#000503	Exterior Doors	Potentially Critical-12 months	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$10,188
154	2048	Comfort Stations	28.85%	#000503	Exterior Doors	Potentially Critical-12 months	District 4	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,580
154	2049	Comfort Stations	28.85%	#000503	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$24,964
154	2049	Comfort Stations	28.85%	#000503	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
154	2050	Comfort Stations	28.85%	#000503	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
154	2051	Comfort Stations	28.85%	#000503	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$3,106
154	2052	Comfort Stations	28.85%	#000503	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,190

154	2053	Comfort Stations	28.85%	#000503	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$3,262
154	2054	Comfort Stations	28.85%	#000503	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$3,423
154	2055	Comfort Stations	28.85%	#000503	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$15,332
155	2056	Comfort Stations	28.14%	#001088	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
155	2056	Comfort Stations	28.14%	#001088	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
155	2056	Comfort Stations	28.14%	#001088	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
155	2056	Comfort Stations	28.14%	#001088	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$545
155	2057	Comfort Stations	28.14%	#001088	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
155	2057	Comfort Stations	28.14%	#001088	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
155	2058	Comfort Stations	28.14%	#001088	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
155	2058	Comfort Stations	28.14%	#001088	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
155	2059	Comfort Stations	28.14%	#001088	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace CMU Block Wall	\$5,302
155	2059	Comfort Stations	28.14%	#001088	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,882
155	2060	Comfort Stations	28.14%	#001088	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,420
155	2060	Comfort Stations	28.14%	#001088	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
155	2061	Comfort Stations	28.14%	#001088	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,323
155	2062	Comfort Stations	28.14%	#001088	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,788
155	2063	Comfort Stations	28.14%	#001088	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
155	2064	Comfort Stations	28.14%	#001088	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$6,601
155	2065	Comfort Stations	28.14%	#001088	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
155	2066	Comfort Stations	28.14%	#001088	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$10,221
155	2067	Comfort Stations	28.14%	#001088	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Epoxy floor	\$17,000
156	2068	Comfort Stations	27.58%	#001405	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
156	2068	Comfort Stations	27.58%	#001405	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
156	2069	Comfort Stations	27.58%	#001405	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
156	2070	Comfort Stations	27.58%	#001405	Roof Coverings	Potentially Critical-12 months	District 2	Roof Covering	Damaged	Replace Clay Tiles	\$30,011
156	2071	Comfort Stations	27.58%	#001405	Roof Construction	Potentially Critical-12 months	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$55,547
156	2072	Comfort Stations	27.58%	#001405	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$776
156	2073	Comfort Stations	27.58%	#001405	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,935
156	2074	Comfort Stations	27.58%	#001405	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Beyond Useful Life	Repair or replace domestic water piping	\$4,799
157	2075	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
157	2075	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$7,023
157	2076	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$918
157	2076	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$6,435
157	2077	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Site Lighting	Potentially Critical-12 months	District 3	Site Lighting	Missing	Install/Replace site lighting-Lite Pole	\$13,211
157	2078	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$5,074
157	2079	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$5,293
157	2080	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$6,601
157	2081	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$7,270
157	2082	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$7,401
157	2083	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$7,478
157	2084	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,822
157	2085	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$9,487
157	2086	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$10,890
157	2087	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$18,856
157	2088	PB - Park Balboa	27.55%	Lawn Bowling Clubhouse (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Clay Tiles	\$68,918
158	2089	Comfort Stations	27.16%	#001070	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
158	2089	Comfort Stations	27.16%	#001070	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
158	2089	Comfort Stations	27.16%	#001070	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$703
158	2089	Comfort Stations	27.16%	#001070	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$533
158	2090	Comfort Stations	27.16%	#001070	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
158	2090	Comfort Stations	27.16%	#001070	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace room signage	\$894
158	2091	Comfort Stations	27.16%	#001070	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$13,011
158	2091	Comfort Stations	27.16%	#001070	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replaces fixture flush valve	\$3,912
158	2092	Comfort Stations	27.16%	#001070	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Termite Inspection of Roof structure	\$827

158	2092	Comfort Stations	27.16%	#001070	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Failing	Replace Roof Fascia	\$38,975
158	2093	Comfort Stations	27.16%	#001070	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$1,306
158	2094	Comfort Stations	27.16%	#001070	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,123
158	2095	Comfort Stations	27.16%	#001070	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,123
158	2096	Comfort Stations	27.16%	#001070	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,609
158	2097	Comfort Stations	27.16%	#001070	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$2,647
158	2098	Comfort Stations	27.16%	#001070	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$2,683
158	2099	Comfort Stations	27.16%	#001070	Water Supply	Necessary- 2-5 Yrs	District 8	Water Supply	Beyond Expected Life	Replace domestic water service	\$3,433
158	2100	Comfort Stations	27.16%	#001070	Electrical Distribution	Necessary- 2-5 Yrs	District 8	Electrica Distribution	Beyond Expected Life	Replace exterior electrical distribution	\$4,149
158	2101	Comfort Stations	27.16%	#001070	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
158	2102	Comfort Stations	27.16%	#001070	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$14,625
159	2103	Comfort Stations	27.05%	#001076	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
159	2103	Comfort Stations	27.05%	#001076	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
159	2103	Comfort Stations	27.05%	#001076	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
159	2103	Comfort Stations	27.05%	#001076	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
159	2104	Comfort Stations	27.05%	#001076	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
159	2105	Comfort Stations	27.05%	#001076	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
159	2105	Comfort Stations	27.05%	#001076	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$699
159	2106	Comfort Stations	27.05%	#001076	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,631
159	2107	Comfort Stations	27.05%	#001076	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,703
159	2108	Comfort Stations	27.05%	#001076	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Damaged	Replace Domestic Water and Sanitary Piping (SF)	\$2,060
159	2109	Comfort Stations	27.05%	#001076	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
159	2110	Comfort Stations	27.05%	#001076	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Epoxy floor	\$12,953
159	2111	Comfort Stations	27.05%	#001076	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
159	2112	Comfort Stations	27.05%	#001076	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,076
160	2113	Comfort Stations	26.35%	#001215	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
160	2113	Comfort Stations	26.35%	#001215	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
160	2113	Comfort Stations	26.35%	#001215	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
160	2113	Comfort Stations	26.35%	#001215	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$503
160	2114	Comfort Stations	26.35%	#001215	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
160	2114	Comfort Stations	26.35%	#001215	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
160	2115	Comfort Stations	26.35%	#001215	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
160	2115	Comfort Stations	26.35%	#001215	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
160	2116	Comfort Stations	26.35%	#001215	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
160	2116	Comfort Stations	26.35%	#001215	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$15,420
160	2117	Comfort Stations	26.35%	#001215	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,144
160	2118	Comfort Stations	26.35%	#001215	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Water Supply	Beyond Useful Life	Replace domestic water service	\$3,433
160	2119	Comfort Stations	26.35%	#001215	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$6,096
160	2120	Comfort Stations	26.35%	#001215	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
160	2121	Comfort Stations	26.35%	#001215	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$10,221
160	2122	Comfort Stations	26.35%	#001215	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Epoxy floor	\$15,681
161	2123	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$11,013
161	2123	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
161	2124	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$526
161	2124	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$284,995
161	2125	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,709
161	2126	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$6,857
161	2127	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$11,689
161	2128	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$17,575
161	2129	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$18,395
161	2130	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$23,653
161	2131	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$26,897
161	2132	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$40,511

161	2133	PB - Park Balboa	25.65%	Spanish Village #6 Stds 7-10	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,039
162	2135	Comfort Stations	25.61%	#001089	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$2,048
162	2135	Comfort Stations	25.61%	#001089	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$2,048
162	2135	Comfort Stations	25.61%	#001089	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,914
162	2135	Comfort Stations	25.61%	#001089	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,140
162	2136	Comfort Stations	25.61%	#001089	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
162	2136	Comfort Stations	25.61%	#001089	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Failing	Replace Toilet Partition	\$9,346
162	2137	Comfort Stations	25.61%	#001089	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$5,716
162	2137	Comfort Stations	25.61%	#001089	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,095
162	2138	Comfort Stations	25.61%	#001089	Electrical Distribution	Potentially Critical-12 months	District 2	Site Lighting	Beyond Expected Life	Install/Replace site lighting-Lite Pole	\$7,085
162	2139	Comfort Stations	25.61%	#001089	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,381
162	2140	Comfort Stations	25.61%	#001089	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,428
162	2141	Comfort Stations	25.61%	#001089	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$5,652
162	2142	Comfort Stations	25.61%	#001089	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Damaged	Replace electric service entrance -200 Amp	\$7,709
162	2143	Comfort Stations	25.61%	#001089	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$13,804
162	2144	Comfort Stations	25.61%	#001089	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
162	2145	Comfort Stations	25.61%	#001089	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Failing	Replace Modified Bitumen Roof Coverings	\$53,876
162	2146	Comfort Stations	25.61%	#001089	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$11,794
163	2147	Comfort Stations	25.52%	#000524	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace outdoor metal cabinet	\$1,489
163	2147	Comfort Stations	25.52%	#000524	Fittings	Potentially Critical-12 months	District 6	Fittings	Beyond Useful Life	Replace Toilet Partition	\$14,792
163	2147	Comfort Stations	25.52%	#000524	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
163	2147	Comfort Stations	25.52%	#000524	Fittings	Potentially Critical-12 months	District 6	Fittings	Beyond Expected Life	Replace Restroom Accessories	\$4,151
163	2148	Comfort Stations	25.52%	#000524	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$512
163	2148	Comfort Stations	25.52%	#000524	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$12,428
163	2148	Comfort Stations	25.52%	#000524	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$677
163	2149	Comfort Stations	25.52%	#000524	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$14,777
163	2149	Comfort Stations	25.52%	#000524	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Install or replace exterior hardware	\$1,269
163	2150	Comfort Stations	25.52%	#000524	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
163	2150	Comfort Stations	25.52%	#000524	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replace Drinking Fountain	\$3,119
163	2151	Comfort Stations	25.52%	#000524	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Repair Concrete Fascia	\$1,841
163	2152	Comfort Stations	25.52%	#000524	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$3,106
163	2153	Comfort Stations	25.52%	#000524	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$7,821
163	2154	Comfort Stations	25.52%	#000524	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$15,332
163	2155	Comfort Stations	25.52%	#000524	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
163	2156	Comfort Stations	25.52%	#000524	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$12,136
164	2157	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$5,596
164	2157	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$3,067
164	2157	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$63,189
164	2157	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$156,290
164	2157	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Refinish wood floor	\$445
164	2158	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$231,187
164	2158	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace Stucco Wall	\$20,906
164	2158	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace Exterior Wood Structures	\$15,457
164	2158	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Termite Inspection of Structure	\$9,616
164	2158	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace Metal Siding	\$29,714
164	2159	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$21,654
164	2159	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace exit light fixtures	\$5,292
164	2159	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$162,920
164	2160	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$61,411
164	2160	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Gutters and downspouts	\$12,790
164	2161	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Inadequate	Install or replace DX split ductless system	\$12,946
164	2161	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Beyond Useful Life	Install or replace thermostats	\$2,345
164	2162	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$373
164	2162	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$107,387

164	2163	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Communications and Security	Potentially Critical-12 months	District 4	Communications/Security	Missing	Replace or Install Ceiling Smoke Detector	\$465
164	2163	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Failing	Replace Intercom/Paging System-50 stations	\$126,904
164	2164	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace Electric Service and Distribution - 2000A	\$1,423,251
164	2164	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Electrical Service/Distribution	Critical / Immediate Need	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace Medium Voltage Service	\$107,913
164	2165	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$3,201
164	2165	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,295
164	2166	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$21,003
164	2166	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$73,188
164	2167	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exhaust Fans (Other Than Vehicle)	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Beyond Useful Life	Add/replace fractional HP exhaust fans;incl. duct	\$13,234
164	2168	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$26,800
164	2169	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$29,121
164	2170	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$36,389
164	2171	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Sprinklers	Necessary- 2-5 Yrs	District 4	Fire Supression	Beyond Useful Life	Install or replace wet fire suppression system	\$136,838
164	2172	OS - Operations Services	25.31%	Equip., Fab Shop, Chollas	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$236,722
165	2173	Comfort Stations	24.79%	#001480	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Branch Conduit/Wire 20/30A ASSY/Ea	\$5,567
165	2173	Comfort Stations	24.79%	#001480	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
165	2173	Comfort Stations	24.79%	#001480	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$742
165	2174	Comfort Stations	24.79%	#001480	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$27,721
165	2174	Comfort Stations	24.79%	#001480	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
165	2175	Comfort Stations	24.79%	#001480	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$2,915
165	2176	Comfort Stations	24.79%	#001480	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,702
165	2177	Comfort Stations	24.79%	#001480	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$4,504
165	2178	Comfort Stations	24.79%	#001480	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$6,521
165	2179	Comfort Stations	24.79%	#001480	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Failing	Replace Built up Roof	\$15,950
165	2180	Comfort Stations	24.79%	#001480	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Failing	Replace Wood Rafters and Deck	\$39,978
166	2181	Comfort Stations	24.64%	#010108	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$631
166	2181	Comfort Stations	24.64%	#010108	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
166	2181	Comfort Stations	24.64%	#010108	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
166	2182	Comfort Stations	24.64%	#010108	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
166	2182	Comfort Stations	24.64%	#010108	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Restroom Accessories	\$262
166	2183	Comfort Stations	24.64%	#010108	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,481
166	2183	Comfort Stations	24.64%	#010108	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Failing	Replace Steel Doors	\$1,397
166	2184	Comfort Stations	24.64%	#010108	Roof Coverings	Potentially Critical-12 months	District 4	Roof Covering	Damaged	Replace concrete tile roof	\$55,215
166	2185	Comfort Stations	24.64%	#010108	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,219
166	2186	Comfort Stations	24.64%	#010108	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replaces fixture flush valve	\$1,304
166	2187	Comfort Stations	24.64%	#010108	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,112
166	2188	Comfort Stations	24.64%	#010108	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$3,292
166	2189	Comfort Stations	24.64%	#010108	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Failing	Epoxy floor	\$9,684
167	2190	Senior Centers	24.46%	Memorial	Exterior Walls	Potentially Critical-12 months	District 8	Exterior Walls	Damaged	Replace Wood Fascia	\$32,188
167	2190	Senior Centers	24.46%	Memorial	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Termite Inspection of Structure	\$11,638
167	2190	Senior Centers	24.46%	Memorial	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace wood siding	\$29,993
167	2191	Senior Centers	24.46%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$5,886
167	2191	Senior Centers	24.46%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$8,445
167	2191	Senior Centers	24.46%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$2,355
167	2192	Senior Centers	24.46%	Memorial	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,221
167	2192	Senior Centers	24.46%	Memorial	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$18,379
167	2193	Senior Centers	24.46%	Memorial	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$7,183
167	2193	Senior Centers	24.46%	Memorial	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,766
167	2194	Senior Centers	24.46%	Memorial	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Asphalt Shingle	\$46,719
167	2194	Senior Centers	24.46%	Memorial	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Roofing Eave	\$64,830
167	2195	Senior Centers	24.46%	Memorial	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
167	2196	Senior Centers	24.46%	Memorial	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Damaged	Perform landscaping maintenance	\$4,809
167	2197	Senior Centers	24.46%	Memorial	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$6,038
167	2198	Senior Centers	24.46%	Memorial	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$6,635
167	2199	Senior Centers	24.46%	Memorial	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Damaged	Replace chain link fencing	\$26,142
167	2200	Senior Centers	24.46%	Memorial	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$29,244

168	2201	Comfort Stations	23.90%	#001312	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Failing	Repaint metal toilet compartment doors	\$1,884
168	2201	Comfort Stations	23.90%	#001312	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,982
168	2201	Comfort Stations	23.90%	#001312	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
168	2202	Comfort Stations	23.90%	#001312	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
168	2202	Comfort Stations	23.90%	#001312	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
168	2202	Comfort Stations	23.90%	#001312	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$694
168	2203	Comfort Stations	23.90%	#001312	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace roll up door	\$11,501
168	2203	Comfort Stations	23.90%	#001312	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Repaint exterior metal doors	\$2,608
168	2203	Comfort Stations	23.90%	#001312	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$5,716
168	2204	Comfort Stations	23.90%	#001312	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,864
168	2204	Comfort Stations	23.90%	#001312	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
168	2205	Comfort Stations	23.90%	#001312	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
168	2205	Comfort Stations	23.90%	#001312	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$15,420
168	2206	Comfort Stations	23.90%	#001312	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,097
168	2207	Comfort Stations	23.90%	#001312	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,726
168	2208	Comfort Stations	23.90%	#001312	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$4,387
168	2209	Comfort Stations	23.90%	#001312	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$8,410
168	2210	Comfort Stations	23.90%	#001312	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,076
169	2211	Comfort Stations	23.58%	#001056	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$24,727
169	2211	Comfort Stations	23.58%	#001056	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Clay Tiles	\$22,689
169	2212	Comfort Stations	23.58%	#001056	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
169	2212	Comfort Stations	23.58%	#001056	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,154
169	2213	Comfort Stations	23.58%	#001056	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
169	2213	Comfort Stations	23.58%	#001056	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$11,944
169	2214	Comfort Stations	23.58%	#001056	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
169	2215	Comfort Stations	23.58%	#001056	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$4,262
169	2216	Comfort Stations	23.58%	#001056	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,695
169	2217	Comfort Stations	23.58%	#001056	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
169	2218	Comfort Stations	23.58%	#001056	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Epoxy floor	\$35,981
169	2219	Comfort Stations	23.58%	#001056	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$5,896
169	2220	Comfort Stations	23.58%	#001056	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$13,760
170	2221	Comfort Stations	23.52%	#007504	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$708
170	2222	Comfort Stations	23.52%	#007504	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
170	2223	Comfort Stations	23.52%	#007504	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,609
170	2224	Comfort Stations	23.52%	#007504	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,951
170	2225	Comfort Stations	23.52%	#007504	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Failing	Replace Concrete Sidewalks	\$2,967
170	2226	Comfort Stations	23.52%	#007504	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$2,982
170	2227	Comfort Stations	23.52%	#007504	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Failing	Repaint exterior metal doors	\$3,913
170	2228	Comfort Stations	23.52%	#007504	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,374
170	2229	Comfort Stations	23.52%	#007504	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$26,431
170	2230	Comfort Stations	23.52%	#007504	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$33,458
171	2231	Comfort Stations	23.11%	#000525	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$746
171	2231	Comfort Stations	23.11%	#000525	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$938
171	2231	Comfort Stations	23.11%	#000525	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace 1X4 Surface Fluorescent Fixture S.F.	\$16,600
171	2232	Comfort Stations	23.11%	#000525	Exterior Doors	Potentially Critical-12 months	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
171	2232	Comfort Stations	23.11%	#000525	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Replace Wood Doors	\$15,282
171	2233	Comfort Stations	23.11%	#000525	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace Bathroom Accessories	\$2,216
171	2233	Comfort Stations	23.11%	#000525	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Failing	Replace bath accessories electric air hand dryers	\$2,036
171	2234	Comfort Stations	23.11%	#000525	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
171	2234	Comfort Stations	23.11%	#000525	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
171	2235	Comfort Stations	23.11%	#000525	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$16,406
171	2235	Comfort Stations	23.11%	#000525	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
171	2236	Comfort Stations	23.11%	#000525	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$1,803
171	2237	Comfort Stations	23.11%	#000525	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$3,700
171	2238	Comfort Stations	23.11%	#000525	Water Supply	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Copper Water Pipe <2 in	\$3,758

171	2239	Comfort Stations	23.11%	#000525	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$4,473
171	2240	Comfort Stations	23.11%	#000525	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$4,718
171	2241	Comfort Stations	23.11%	#000525	Electrical Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
172	2243	Comfort Stations	22.29%	#001384	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$365
172	2244	Comfort Stations	22.29%	#001384	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
172	2245	Comfort Stations	22.29%	#001384	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
172	2246	Comfort Stations	22.29%	#001384	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 5	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
172	2247	Comfort Stations	22.29%	#001384	Plumbing Fixtures	Necessary- 2-5 Yrs	District 5	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
172	2248	Comfort Stations	22.29%	#001384	Sanitary Sewer	Necessary- 2-5 Yrs	District 5	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$209,147
173	2249	Comfort Stations	21.80%	#000852	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
173	2249	Comfort Stations	21.80%	#000852	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,154
173	2249	Comfort Stations	21.80%	#000852	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Install or replace exterior lighting	\$2,805
173	2250	Comfort Stations	21.80%	#000852	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace exterior aluminum louver	\$10,244
173	2250	Comfort Stations	21.80%	#000852	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,001
173	2251	Comfort Stations	21.80%	#000852	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
173	2252	Comfort Stations	21.80%	#000852	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$11,648
173	2253	Comfort Stations	21.80%	#000852	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$15,332
173	2254	Comfort Stations	21.80%	#000852	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
173	2255	Comfort Stations	21.80%	#000852	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Epoxy floor	\$35,981
173	2256	Comfort Stations	21.80%	#000852	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$5,723
173	2257	Comfort Stations	21.80%	#000852	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
174	2260	Comfort Stations	21.56%	#000522	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
174	2260	Comfort Stations	21.56%	#000522	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,914
174	2260	Comfort Stations	21.56%	#000522	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
174	2261	Comfort Stations	21.56%	#000522	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
174	2261	Comfort Stations	21.56%	#000522	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace outdoor metal cabinet	\$1,489
174	2263	Comfort Stations	21.56%	#000522	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
174	2264	Comfort Stations	21.56%	#000522	Pedestrian Paving	Potentially Critical-12 months	District 2	Pedestrian Paving	Beyond Expected Life	Replace Concrete Sidewalks	\$4,477
174	2265	Comfort Stations	21.56%	#000522	Exterior Walls	Potentially Critical-12 months	District 2	Exterior Walls	Beyond Expected Life	Replace CMU Block Wall	\$15,464
174	2266	Comfort Stations	21.56%	#000522	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,469
174	2267	Comfort Stations	21.56%	#000522	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Beyond Expected Life	Replace Copper Water Pipe <2 in	\$12,529
174	2268	Comfort Stations	21.56%	#000522	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Epoxy floor	\$43,176
175	2271	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$471
175	2271	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Damaged	Replace Incandescent Light Fixtures	\$708
175	2271	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Inadequate	Install circuit label electric outlets and switches	\$2,327
175	2272	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$1,817
175	2272	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$5,111
175	2272	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$7,308
175	2273	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Communications and Security	Potentially Critical-12 months	District 3	Communications/Security	Failing	Replace Security Sys; Main Pnl; Up to 20 Devices	\$36,277
175	2273	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Missing	Replace Fire Alarm System/ASSY for 100 devices	\$71,578
175	2274	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,270
175	2274	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Missing	Replace Wood Door/Metal Frame	\$2,165
175	2275	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$5,787
175	2275	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$2,222
175	2276	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$762
175	2276	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$11,105
175	2277	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Roof Openings	Potentially Critical-12 months	District 3	Roof Openings	Failing	Cap Off / Close Roof Opening; W/Sheet Metal	\$2,172
175	2278	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Plumbing Fixtures	Critical / Immediate Need	District 3	Domestic Water Distribution	Damaged	Request Plumbing Consultant	\$20,285
175	2279	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Kitchen Equip - Ice Machine	Potentially Critical-12 months	District 3	Equipment	Beyond Expected Life	Replace Air Cooled Condensing Unit - Fridge Unit	\$11,254
175	2280	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$33,744
175	2281	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Built up Roof	\$79,534

175	2282	PB - Park Balboa	21.45%	Starlight Bowl Ticket/Concess	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Failing	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$96,598
176	2283	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Plumbing Fixtures	Critical / Immediate Need	District 3	Plumbing Fixtures	Damaged	Replace Group Wash Fountain	\$13,025
176	2283	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$102,262
176	2283	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replaces fixture flush valve	\$11,734
176	2283	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Water Cooler; Electric; Free Standing	\$4,988
176	2284	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Floor Finishes	Potentially Critical-12 months	District 3	Floor Finishes	Damaged	Replace covered base	\$388
176	2284	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Replace Carpet	\$42,213
176	2284	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Seal stone floor	\$13,058
176	2285	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Abandoned	Remove Debris from Roof	\$1,175
176	2285	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$186,336
176	2286	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Exhaust Ventilation System	Beyond Expected Life	Replace Exhaust Fan; Util. Belt 1100 CFM; 3 HP	\$10,021
176	2286	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Exhaust Ventilation System	Beyond Expected Life	Replace Exhaust Fan; Util. Belt 1100 CFM; 3 HP	\$10,021
176	2286	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Exhaust Ventilation System	Damaged	Prepare and Paint Metal Vents or Stacks; Exposed	\$477
176	2287	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare and Paint Exterior Metal Trim	\$927
176	2287	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
176	2287	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$63,275
176	2288	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Failing	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$98,269
176	2288	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Damaged	Install or replace thermal insulation on HVAC pipi	\$389
176	2288	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace Unit Heater; Natural Gas; Ceiling Mounted	\$16,701
176	2289	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Acrylic Ltg. Fixture Lens; up To 2'x4'	\$288
176	2289	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$13,969
176	2290	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Parking Lots	Necessary- 2-5 Yrs	District 3	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$451
176	2290	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$9,173
176	2291	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$17,876
176	2291	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Missing	Replace door hardware	\$248
176	2292	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$859
176	2292	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Prepare and Paint Interior Ceiling	\$50,939
176	2293	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Expected Life	Replace Overhead Door; Roll-Up; Motorized	\$61,079
176	2293	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Expected Life	Replace Ext. Door and Frame; to 4/0x6/8 Wood/Metal	\$22,942
176	2294	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Beyond Expected Life	Replace Aluminium Windows	\$98,547
176	2294	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Beyond Expected Life	Replace Exterior Window; Jalousie; up to 3/0 4/0	\$16,014
176	2295	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace Switch Board; 1000 Amp; 3-Phase	\$189,664
176	2295	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace Panel Board; 200A; 240V; 1-Phase; 42 Ckt.	\$96,336
176	2296	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Fittings	Critical / Immediate Need	District 3	Fittings	Damaged	Replace Storage Unit	\$283
176	2297	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Water Supply	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$27,335
176	2298	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Rain Water Drainage	Potentially Critical-12 months	District 3	Rain Water Drainage	Damaged	Replace Gutter; Aluminum up to 6" x LF	\$34,283
176	2299	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Roof Openings	Necessary- 2-5 Yrs	District 3	Roof Openings	Damaged	Prepare Paint Roof Hatch; Metal; up to 20 SF	\$1,029
176	2300	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$48,725
176	2301	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$81,461
176	2302	OS - Operations Services	21.19%	#000042 Offices & Craft Shops	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$109,674
177	2303	Comfort Stations	20.55%	#000549	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$663
177	2303	Comfort Stations	20.55%	#000549	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
177	2304	Comfort Stations	20.55%	#000549	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
177	2304	Comfort Stations	20.55%	#000549	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,058
177	2305	Comfort Stations	20.55%	#000549	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,331
177	2305	Comfort Stations	20.55%	#000549	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$5,302
177	2306	Comfort Stations	20.55%	#000549	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$2,858
177	2307	Comfort Stations	20.55%	#000549	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,200

177	2308	Comfort Stations	20.55%	#000549	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
177	2309	Comfort Stations	20.55%	#000549	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$12,814
177	2310	Comfort Stations	20.55%	#000549	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
177	2311	Comfort Stations	20.55%	#000549	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Failing	Replace Built up Roof	\$31,835
177	2312	Comfort Stations	20.55%	#000549	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$11,243
178	2313	Comfort Stations	20.19%	#900025	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace CMU Block Wall	\$1,768
178	2313	Comfort Stations	20.19%	#900025	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,494
178	2314	Comfort Stations	20.19%	#900025	Roof Construction	Potentially Critical-12 months	District 4	Roof Construction	Damaged	Termite Inspection of Roof structure	\$19,074
178	2315	Comfort Stations	20.19%	#900025	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
178	2316	Comfort Stations	20.19%	#900025	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$573
178	2317	Comfort Stations	20.19%	#900025	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replaces fixture flush valve	\$1,304
178	2318	Comfort Stations	20.19%	#900025	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$1,639
178	2319	Comfort Stations	20.19%	#900025	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Clay Tiles	\$6,018
178	2320	Comfort Stations	20.19%	#900025	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$12,814
178	2321	Comfort Stations	20.19%	#900025	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Failing	Repaint exterior metal doors	\$15,650
179	2322	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
179	2322	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$11,013
179	2323	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$4,947
179	2323	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$18,773
179	2324	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$11,327
179	2324	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$12,663
179	2325	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,660
179	2326	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$18,151
179	2327	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$25,142
179	2328	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$31,954
179	2329	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$40,345
179	2330	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$54,045
179	2331	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$69,447
179	2332	PB - Park Balboa	19.84%	Spanish Village #1 Stds 1-6	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,039
180	2334	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,594
180	2334	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,119
180	2335	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace 30 Gal Gas Water Heater	\$3,185
180	2335	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$22,783
180	2336	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$14,303
180	2336	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$15,346
180	2337	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$20,658
180	2337	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$23,975
180	2338	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
180	2339	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$6,784
180	2340	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$18,747
180	2341	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$63,908
180	2342	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$80,690
180	2343	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,039
180	2344	PB - Park Balboa	19.77%	Spanish Village #3 Stds 30-41	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$138,892
181	2346	Comfort Stations	19.69%	#001096	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
181	2346	Comfort Stations	19.69%	#001096	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace Wood Doors	\$5,094
181	2347	Comfort Stations	19.69%	#001096	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
181	2347	Comfort Stations	19.69%	#001096	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$489
181	2348	Comfort Stations	19.69%	#001096	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
181	2349	Comfort Stations	19.69%	#001096	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$4,630
181	2350	Comfort Stations	19.69%	#001096	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,599
181	2351	Comfort Stations	19.69%	#001096	Electrical Distribution	Potentially Critical-12 months	District 6	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$6,390
181	2352	Comfort Stations	19.69%	#001096	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709

181	2353	Comfort Stations	19.69%	#001096	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$8,737
181	2354	Comfort Stations	19.69%	#001096	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$19,579
182	2356	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,489
182	2356	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$4,228
182	2357	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
182	2357	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$7,383
182	2358	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Beyond Useful Life	Replace Wood Door/Metal Frame	\$2,859
182	2358	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Beyond Useful Life	Replace door hardware	\$2,427
182	2359	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$9,478
182	2359	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$6,208
182	2360	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Inadequate	Termite Inspection of Structure	\$4,809
182	2360	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Wood Fascia	\$32,993
182	2361	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace Wood Doors	\$3,317
182	2362	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$7,995
182	2363	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Beyond Useful Life	Replace Wood Windows	\$14,379
182	2364	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Batten Seam Metal Roof	\$44,864
182	2365	Senior Centers	19.34%	Morley Field Sr. Ctr. ClubHse.	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace concrete slab	\$61,290
183	2367	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Counter Top; Solid Surface	\$2,359
183	2367	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Wall Cabinet; Wood; 30" (H); 1 Door;	\$7,436
183	2367	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
183	2367	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Base Cabinet; Wood; 1 Drawer; 1 Door	\$7,032
183	2368	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
183	2368	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
183	2369	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$5,502
183	2370	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Water Supply	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$6,833
183	2371	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Missing	Replace Int. Door; Solid; Painted; up to 3/0 x 7/0	\$1,759
183	2372	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$2,123
183	2373	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$2,923
183	2374	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$4,333
183	2375	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,088
183	2376	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
183	2377	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
183	2378	PB - Park Balboa	18.96%	House Of Pac. Rel. Ukraine/Rus	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$9,202
184	2379	OS - Operations Services	18.78%	#000048 Environmental Services	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Prepare and Paint Exterior Concrete Wall Surface	\$7,115
184	2379	OS - Operations Services	18.78%	#000048 Environmental Services	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
184	2379	OS - Operations Services	18.78%	#000048 Environmental Services	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace wood siding	\$108,035
184	2379	OS - Operations Services	18.78%	#000048 Environmental Services	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace exterior aluminum louver	\$774
184	2380	OS - Operations Services	18.78%	#000048 Environmental Services	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,875
184	2380	OS - Operations Services	18.78%	#000048 Environmental Services	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Replace Acrylic Ltg. Fixture Lens; up To 2'x4'	\$1,154
184	2381	OS - Operations Services	18.78%	#000048 Environmental Services	Parking Lots	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$902
184	2381	OS - Operations Services	18.78%	#000048 Environmental Services	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$1,965
184	2382	OS - Operations Services	18.78%	#000048 Environmental Services	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$23,290
184	2382	OS - Operations Services	18.78%	#000048 Environmental Services	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Epoxy floor	\$2,878
184	2383	OS - Operations Services	18.78%	#000048 Environmental Services	Rain Water Drainage	Necessary- 2-5 Yrs	District 8	Rain Water Drainage	Missing	Replace Gutter; Aluminum up to 6" x LF	\$2,813
184	2384	OS - Operations Services	18.78%	#000048 Environmental Services	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$3,351
184	2385	OS - Operations Services	18.78%	#000048 Environmental Services	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Prepare and Paint Interior Ceiling	\$9,086
184	2386	OS - Operations Services	18.78%	#000048 Environmental Services	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$9,952
184	2387	OS - Operations Services	18.78%	#000048 Environmental Services	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Replace Roof Fascia	\$10,133
184	2388	OS - Operations Services	18.78%	#000048 Environmental Services	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$14,367
184	2389	OS - Operations Services	18.78%	#000048 Environmental Services	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$38,345
185	2390	Comfort Stations	18.46%	#001335	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$919
185	2390	Comfort Stations	18.46%	#001335	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace 2X4 Flourescent Fixture Ea.	\$1,711
185	2391	Comfort Stations	18.46%	#001335	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Identifying Devices	\$1,820
185	2391	Comfort Stations	18.46%	#001335	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
185	2392	Comfort Stations	18.46%	#001335	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Install or replace exterior hardware	\$2,538
185	2392	Comfort Stations	18.46%	#001335	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$4,190
185	2393	Comfort Stations	18.46%	#001335	Wall Finishes	Potentially Critical-12 months	District 3	Wall Finishes	Beyond Useful Life	Repaint wall	\$5,677

185	2394	Comfort Stations	18.46%	#001335	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$2,896
185	2395	Comfort Stations	18.46%	#001335	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$3,608
185	2396	Comfort Stations	18.46%	#001335	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,784
185	2397	Comfort Stations	18.46%	#001335	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Failing	Replace Asphalt Shingle	\$8,957
185	2398	Comfort Stations	18.46%	#001335	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
185	2399	Comfort Stations	18.46%	#001335	Roof Construction	Necessary- 2-5 Yrs	District 3	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$49,473
186	2400	Comfort Stations	18.33%	#001092	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Restroom Accessories	\$598
186	2400	Comfort Stations	18.33%	#001092	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Facility Number Signage - Cast Aluminum	\$2,567
186	2401	Comfort Stations	18.33%	#001092	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$2,858
186	2402	Comfort Stations	18.33%	#001092	Electrical Distribution	Potentially Critical-12 months	District 6	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$6,390
186	2403	Comfort Stations	18.33%	#001092	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$6,684
186	2404	Comfort Stations	18.33%	#001092	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
186	2405	Comfort Stations	18.33%	#001092	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
186	2406	Comfort Stations	18.33%	#001092	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$22,714
186	2407	Comfort Stations	18.33%	#001092	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Clay Tiles	\$60,184
186	2409	Comfort Stations	18.33%	#001092	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,329
187	2413	Comfort Stations	18.03%	#001204	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
187	2413	Comfort Stations	18.03%	#001204	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
187	2415	Comfort Stations	18.03%	#001204	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Replace Steel Doors	\$1,397
187	2415	Comfort Stations	18.03%	#001204	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Replace exterior door hardware	\$1,429
187	2416	Comfort Stations	18.03%	#001204	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
187	2416	Comfort Stations	18.03%	#001204	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$492
187	2423	Comfort Stations	18.03%	#001204	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$898
187	2424	Comfort Stations	18.03%	#001204	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,856
187	2425	Comfort Stations	18.03%	#001204	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$2,792
187	2426	Comfort Stations	18.03%	#001204	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Epoxy floor	\$6,446
187	2428	Comfort Stations	18.03%	#001204	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
187	2429	Comfort Stations	18.03%	#001204	Electrical Distribution	Necessary- 2-5 Yrs	District 8	Electrica Distribution	Beyond Expected Life	Replace exterior electrical distribution	\$8,298
187	2430	Comfort Stations	18.03%	#001204	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Failing	Replace Stainless Steel Plumbing Fixtures	\$15,987
188	2412	Comfort Stations	18.03%	#000520	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$1,024
188	2412	Comfort Stations	18.03%	#000520	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
188	2412	Comfort Stations	18.03%	#000520	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$923
188	2414	Comfort Stations	18.03%	#000520	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Wood Doors	\$45,848
188	2414	Comfort Stations	18.03%	#000520	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$2,858
188	2417	Comfort Stations	18.03%	#000520	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Roof Fascia	\$2,496
188	2418	Comfort Stations	18.03%	#000520	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
188	2419	Comfort Stations	18.03%	#000520	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$5,177
188	2420	Comfort Stations	18.03%	#000520	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$5,504
188	2421	Comfort Stations	18.03%	#000520	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$5,827
188	2422	Comfort Stations	18.03%	#000520	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
188	2427	Comfort Stations	18.03%	#000520	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
189	2431	Comfort Stations	17.89%	#001087	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$2,858
189	2431	Comfort Stations	17.89%	#001087	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$1,397
189	2432	Comfort Stations	17.89%	#001087	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$677
189	2433	Comfort Stations	17.89%	#001087	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
189	2434	Comfort Stations	17.89%	#001087	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$5,436
189	2435	Comfort Stations	17.89%	#001087	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
189	2436	Comfort Stations	17.89%	#001087	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
189	2437	Comfort Stations	17.89%	#001087	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$21,109
189	2438	Comfort Stations	17.89%	#001087	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$9,828
190	2439	Comfort Stations	17.17%	#000790	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$36,880
190	2439	Comfort Stations	17.17%	#000790	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Termite Inspection of Roof structure	\$17,997
190	2440	Comfort Stations	17.17%	#000790	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,016
190	2441	Comfort Stations	17.17%	#000790	Electrical Service/Distribution	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$485
190	2442	Comfort Stations	17.17%	#000790	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
190	2443	Comfort Stations	17.17%	#000790	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,734

190	2444	Comfort Stations	17.17%	#000790	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace exterior door hardware	\$4,287
190	2445	Comfort Stations	17.17%	#000790	Sanitary Sewer	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$9,435
190	2446	Comfort Stations	17.17%	#000790	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
191	2447	Comfort Stations	16.83%	#000521	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
191	2447	Comfort Stations	16.83%	#000521	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,074
191	2448	Comfort Stations	16.83%	#000521	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
191	2448	Comfort Stations	16.83%	#000521	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Drinking Fountain	\$3,119
191	2449	Comfort Stations	16.83%	#000521	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
191	2450	Comfort Stations	16.83%	#000521	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Repair Concrete Fascia	\$16,489
191	2451	Comfort Stations	16.83%	#000521	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,956
191	2452	Comfort Stations	16.83%	#000521	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,218
191	2453	Comfort Stations	16.83%	#000521	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$5,323
191	2454	Comfort Stations	16.83%	#000521	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$7,882
191	2455	Comfort Stations	16.83%	#000521	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$7,882
191	2456	Comfort Stations	16.83%	#000521	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$12,556
191	2457	Comfort Stations	16.83%	#000521	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$16,040
192	2458	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Exterior Walls	Potentially Critical-12 months	District 3	Exterior Walls	Damaged	Structural Study	\$24,256
192	2458	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Foundation Wall Vent Cover; Mtl up to 2 SF	\$628
192	2458	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Exterior Walls	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Repaint Handrails	\$22,809
192	2458	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$121,358
192	2459	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,555
192	2459	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$68,537
192	2460	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Landscaping	Critical / Immediate Need	District 3	Landscaping	Inadequate	Re-grade Site	\$11,486
192	2461	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Inadequate	Replace Electric Thermostat	\$617
192	2461	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Failing	Replace unit heaters	\$1,650
192	2462	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Other HVAC Systems/Equip	Potentially Critical-12 months	District 3	Ventilation and Exhaust	Inadequate	Replace Kitchen Range Hood; Residentl; Incl. Duct	\$1,372
192	2463	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Exterior Doors	Potentially Critical-12 months	District 3	Exterior Doors	Damaged	Remove, Salvage, Restore Ext. Door-Wood Historic	\$62,898
192	2464	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Exterior Windows	Potentially Critical-12 months	District 3	Exterior Windows	Damaged	Remove Salvage Restore Window - Wood Historic	\$130,260
192	2465	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Missing	Replace Quarry Tile	\$716
192	2466	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
192	2467	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$24,362
192	2468	PB - Park Balboa	16.67%	House Of Pac. Rel. Italy	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$79,669
193	2469	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,052
193	2469	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$21,177
193	2470	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$13,702
193	2470	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$19,351
193	2471	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
193	2472	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$8,389
193	2473	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$14,777
193	2474	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$52,725
193	2475	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$53,793
193	2476	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,039
193	2477	PB - Park Balboa	16.62%	Spanish Village #5 Stds 12-19	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$144,680
194	2479	Comfort Stations	16.20%	#001217	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace mirrors	\$1,345
194	2479	Comfort Stations	16.20%	#001217	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$395
194	2479	Comfort Stations	16.20%	#001217	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
194	2480	Comfort Stations	16.20%	#001217	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$568
194	2480	Comfort Stations	16.20%	#001217	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle 20A 120V ASSY/S.F.	\$3,978
194	2480	Comfort Stations	16.20%	#001217	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,914
194	2481	Comfort Stations	16.20%	#001217	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Missing	Replace coved base	\$3,664
194	2482	Comfort Stations	16.20%	#001217	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$9,435
194	2483	Comfort Stations	16.20%	#001217	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
195	2484	PB - Park Balboa	16.17%	Clubhouse & Shuffleboard Balboa	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$582
195	2484	PB - Park Balboa	16.17%	Clubhouse & Shuffleboard Balboa	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,157

195	2484	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$65,400
195	2485	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Kitchen Sink 2 Basin	\$5,461
195	2485	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Plumbing Fixtures	\$29,666
195	2485	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Plumbing Fixtures	\$25,598
195	2485	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Failing	Replace Janitors Sink	\$5,892
195	2486	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$10,992
195	2486	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,566
195	2487	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$5,007
195	2487	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$34,090
195	2488	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$5,036
195	2488	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$34,313
195	2489	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Metal Roof	\$171,989
195	2489	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Repaint Downspouts	\$1,201
195	2490	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$7,441
195	2491	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$6,132
195	2492	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$8,360
195	2493	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$9,746
195	2494	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$15,130
195	2495	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$16,153
195	2496	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$25,829
195	2497	PB - Park Balboa	16.17%	Clubhouse & Shufleboard Balboa	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$98,967
196	2498	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,660
196	2498	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$33,291
196	2499	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,178
196	2499	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$8,614
196	2500	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$6,731
196	2500	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$12,788
196	2501	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$21,943
196	2501	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace 30 Gal Gas Water Heater	\$3,185
196	2502	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$1,861
196	2503	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
196	2504	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$4,237
196	2505	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$6,110
196	2506	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$6,724
196	2507	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$25,363
196	2508	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$25,564
196	2509	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$52,084
196	2510	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$97,101
196	2511	PB - Park Balboa	16.03%	Spanish Village #2 Min & Gem	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,039
197	2513	Senior Centers	15.77%	San Ysidro	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,680
197	2513	Senior Centers	15.77%	San Ysidro	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
197	2514	Senior Centers	15.77%	San Ysidro	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,598
197	2514	Senior Centers	15.77%	San Ysidro	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$8,445
197	2515	Senior Centers	15.77%	San Ysidro	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Wood Windows	\$6,391
197	2515	Senior Centers	15.77%	San Ysidro	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Aluminium Windows	\$7,780
197	2516	Senior Centers	15.77%	San Ysidro	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$11,066
197	2516	Senior Centers	15.77%	San Ysidro	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$11,057
197	2517	Senior Centers	15.77%	San Ysidro	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard -400A	\$10,967
197	2517	Senior Centers	15.77%	San Ysidro	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
197	2518	Senior Centers	15.77%	San Ysidro	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace 10 T Gas/Elec Package Unit, Roof Mount	\$72,190
197	2518	Senior Centers	15.77%	San Ysidro	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Ductwork	Failing	Install ductwork insullation and aces. as req.d	\$78,972
197	2519	Senior Centers	15.77%	San Ysidro	Exhaust Fans	Potentially Critical-12 months	District 8	Exhaust Ventilation System	Beyond Expected Life	Install new exhaust system and controls	\$11,252

197	2520	Senior Centers	15.77%	San Ysidro	Site Lighting	Potentially Critical-12 months	District 8	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$28,339
197	2521	Senior Centers	15.77%	San Ysidro	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Waste	Failing	Replace Grease Trap, 25 GPM, 50# Cap	\$4,322
197	2522	Senior Centers	15.77%	San Ysidro	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$4,602
197	2523	Senior Centers	15.77%	San Ysidro	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,799
197	2524	Senior Centers	15.77%	San Ysidro	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$15,282
197	2525	Senior Centers	15.77%	San Ysidro	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$18,357
197	2526	Senior Centers	15.77%	San Ysidro	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$57,291
197	2527	Senior Centers	15.77%	San Ysidro	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$61,969
198	2528	Comfort Stations	15.50%	#001022	Roof Construction	Critical / Immediate Need	District 6	Exterior Walls	Damaged	Termite Inspection of Structure	\$3,549
198	2528	Comfort Stations	15.50%	#001022	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Failing	Prepare Paint Wood Fascia and Eaves (SF)	\$2,810
198	2529	Comfort Stations	15.50%	#001022	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,423
198	2529	Comfort Stations	15.50%	#001022	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
198	2530	Comfort Stations	15.50%	#001022	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$9,634
198	2530	Comfort Stations	15.50%	#001022	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Inadequate	Remove Debris from Roof	\$439
198	2531	Comfort Stations	15.50%	#001022	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$389
198	2532	Comfort Stations	15.50%	#001022	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,619
198	2533	Comfort Stations	15.50%	#001022	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$3,867
198	2534	Comfort Stations	15.50%	#001022	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Prepare and Paint Interior Ceiling	\$5,393
198	2535	Comfort Stations	15.50%	#001022	Site Earthwork	Potentially Critical-12 months	District 6	Landscaping	Inadequate	Re-grade Site	\$5,436
199	2536	Comfort Stations	14.88%	#000338	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$3,729
199	2536	Comfort Stations	14.88%	#000338	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$727
199	2537	Comfort Stations	14.88%	#000338	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$713
199	2538	Comfort Stations	14.88%	#000338	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace exterior door hardware	\$1,429
199	2539	Comfort Stations	14.88%	#000338	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
199	2540	Comfort Stations	14.88%	#000338	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$3,887
199	2541	Comfort Stations	14.88%	#000338	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
199	2542	Comfort Stations	14.88%	#000338	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$16,513
199	2543	Comfort Stations	14.88%	#000338	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,647
200	2544	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Walls	Critical / Immediate Need	District 8	Exterior Walls	Damaged	Termite Inspection of Structure	\$13,136
200	2544	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Walls	Critical / Immediate Need	District 8	Exterior Walls	Failing	Replace Stucco Wall	\$1,608
200	2544	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Walls	Potentially Critical-12 months	District 8	Exterior Walls	Failing	Repaint Fascia	\$742
200	2544	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
200	2544	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare and Paint Exterior Concrete Wall Surface	\$91,806
200	2545	OS - Operations Services	14.54%	#000041 Rader Hall	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Missing	Replace Junction Box Cover; Blank4" Square; Steel	\$294
200	2545	OS - Operations Services	14.54%	#000041 Rader Hall	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Inadequate	Secure Electrical Device; Receptacle or Switch	\$274
200	2545	OS - Operations Services	14.54%	#000041 Rader Hall	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Replace Acrylic Ltg. Fixture Lens; up To 2'x4'	\$288
200	2545	OS - Operations Services	14.54%	#000041 Rader Hall	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,155
200	2546	OS - Operations Services	14.54%	#000041 Rader Hall	Plumbing Fixtures	Potentially Critical-12 months	District 8	Plumbing Fixtures	Damaged	Replaces fixture flush valve	\$5,216
200	2546	OS - Operations Services	14.54%	#000041 Rader Hall	Plumbing Fixtures	Potentially Critical-12 months	District 8	Plumbing Fixtures	Damaged	Replace Drain Trap; Lavatory; Chrome	\$5,146
200	2546	OS - Operations Services	14.54%	#000041 Rader Hall	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Water Cooler; Electric; Free Standing	\$2,495
200	2546	OS - Operations Services	14.54%	#000041 Rader Hall	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$76,696
200	2547	OS - Operations Services	14.54%	#000041 Rader Hall	Floor Finishes	Critical / Immediate Need	District 8	Floor Finishes	Inadequate	Replace rubber/vinyl cove base	\$225
200	2547	OS - Operations Services	14.54%	#000041 Rader Hall	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Missing	Replace Quarry Tile	\$1,273
200	2547	OS - Operations Services	14.54%	#000041 Rader Hall	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Replace Carpet	\$86,973
200	2548	OS - Operations Services	14.54%	#000041 Rader Hall	Wall Finishes	Critical / Immediate Need	District 8	Wall Finishes	Damaged	Re-plaster Wall	\$2,923
200	2548	OS - Operations Services	14.54%	#000041 Rader Hall	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$75,015
200	2549	OS - Operations Services	14.54%	#000041 Rader Hall	Rain Water Drainage	Potentially Critical-12 months	District 8	Rain Water Drainage	Missing	Replace Roof Drain/Receptor Screen	\$356
200	2549	OS - Operations Services	14.54%	#000041 Rader Hall	Rain Water Drainage	Potentially Critical-12 months	District 8	Rain Water Drainage	Damaged	Replace Down Spout; Meta; 4" to 6"	\$510
200	2550	OS - Operations Services	14.54%	#000041 Rader Hall	Stair Construction	Potentially Critical-12 months	District 8	Stairs	Damaged	Replace Wood Stairs Stringers Treads Risers	\$24,401
200	2550	OS - Operations Services	14.54%	#000041 Rader Hall	Stair Construction	Potentially Critical-12 months	District 8	Stairs	Damaged	Replace Wood Stairs Stringers Treads Risers	\$24,401
200	2551	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Doors	Potentially Critical-12 months	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$9,952
200	2551	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$780
200	2552	OS - Operations Services	14.54%	#000041 Rader Hall	Roof Coverings	Critical / Immediate Need	District 8	Roof Covering	Damaged	Repair/Reseal Roof Penetration	\$1,152
200	2553	OS - Operations Services	14.54%	#000041 Rader Hall	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$16,034
200	2553	OS - Operations Services	14.54%	#000041 Rader Hall	Parking Lots	Necessary- 2-5 Yrs	District 8	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$2,028
200	2554	OS - Operations Services	14.54%	#000041 Rader Hall	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$191
200	2554	OS - Operations Services	14.54%	#000041 Rader Hall	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Prepare and Paint Interior Ceiling	\$33,651
200	2555	OS - Operations Services	14.54%	#000041 Rader Hall	Storm Sewer	Potentially Critical-12 months	District 8	Storm Sewer	Inadequate	Provide technical study of storm drainage system	\$7,692
200	2556	OS - Operations Services	14.54%	#000041 Rader Hall	Water Supply	Potentially Critical-12 months	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$20,501

200	2557	OS - Operations Services	14.54%	#000041 Rader Hall	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$293
200	2558	OS - Operations Services	14.54%	#000041 Rader Hall	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fittings	Failing	Refinish Base / Wall Cabinets - SF	\$1,656
200	2559	OS - Operations Services	14.54%	#000041 Rader Hall	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Missing	Replace Window Awning	\$1,829
200	2560	OS - Operations Services	14.54%	#000041 Rader Hall	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Damaged	Install or replace thermal insulation on HVAC pipi	\$2,722
200	2561	OS - Operations Services	14.54%	#000041 Rader Hall	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$32,902
200	2562	OS - Operations Services	14.54%	#000041 Rader Hall	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$43,851
201	2563	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$11,013
201	2563	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
201	2563	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$11,013
201	2564	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$4,859
201	2564	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$4,385
201	2565	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$774
201	2565	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$15,867
201	2566	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,888
201	2567	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$523
201	2568	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$2,444
201	2569	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$2,756
201	2570	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Useful Life	Replace evaporative cooler	\$8,762
201	2571	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$15,626
201	2572	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$16,153
201	2573	PB - Park Balboa	14.42%	Balboa Park Concessions (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$39,288
202	2574	OS - Operations Services	14.17%	Chollas, Station 38	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$18,244
202	2574	OS - Operations Services	14.17%	Chollas, Station 38	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Failing	Replace 4T Split System A/C Comp	\$21,061
202	2574	OS - Operations Services	14.17%	Chollas, Station 38	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Beyond Useful Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$131,026
202	2574	OS - Operations Services	14.17%	Chollas, Station 38	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Beyond Useful Life	Replace Ductwork Pkg Sys/Ton	\$217,463
202	2575	OS - Operations Services	14.17%	Chollas, Station 38	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$9,326
202	2575	OS - Operations Services	14.17%	Chollas, Station 38	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$28,994
202	2575	OS - Operations Services	14.17%	Chollas, Station 38	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$7,594
202	2575	OS - Operations Services	14.17%	Chollas, Station 38	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$5,289
202	2576	OS - Operations Services	14.17%	Chollas, Station 38	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$18,244
202	2576	OS - Operations Services	14.17%	Chollas, Station 38	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$12,837
202	2576	OS - Operations Services	14.17%	Chollas, Station 38	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$1,711
202	2577	OS - Operations Services	14.17%	Chollas, Station 38	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Tankless Type Toilet	\$9,072
202	2577	OS - Operations Services	14.17%	Chollas, Station 38	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Group Wash Fountain	\$26,049
202	2577	OS - Operations Services	14.17%	Chollas, Station 38	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Wall Hung Urinal	\$8,013
202	2578	OS - Operations Services	14.17%	Chollas, Station 38	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Inadequate	Replace 30 Gal Gas Water Heater	\$2,899
202	2578	OS - Operations Services	14.17%	Chollas, Station 38	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Remove abandoned equipment/system	\$9,616
202	2579	OS - Operations Services	14.17%	Chollas, Station 38	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$1,352
202	2579	OS - Operations Services	14.17%	Chollas, Station 38	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
202	2580	OS - Operations Services	14.17%	Chollas, Station 38	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$13,143
202	2580	OS - Operations Services	14.17%	Chollas, Station 38	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$43,125
202	2581	OS - Operations Services	14.17%	Chollas, Station 38	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$55,006
202	2581	OS - Operations Services	14.17%	Chollas, Station 38	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,396
202	2582	OS - Operations Services	14.17%	Chollas, Station 38	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$69,965
202	2582	OS - Operations Services	14.17%	Chollas, Station 38	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$4,368
202	2583	OS - Operations Services	14.17%	Chollas, Station 38	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Bathroom Accessories	\$49,971
202	2583	OS - Operations Services	14.17%	Chollas, Station 38	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Lockers	\$185,071
202	2584	OS - Operations Services	14.17%	Chollas, Station 38	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$287,297
202	2584	OS - Operations Services	14.17%	Chollas, Station 38	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Gutters and downspouts	\$11,407

202	2585	OS - Operations Services	14.17%	Chollas, Station 38	Electrical Service/Distribution	Critical / Immediate Need	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace Medium Voltage Service	\$107,913
202	2586	OS - Operations Services	14.17%	Chollas, Station 38	Sprinklers	Potentially Critical-12 months	District 4	Sprinklers	Beyond Useful Life	Replace Sprinkler System	\$17,961
202	2587	OS - Operations Services	14.17%	Chollas, Station 38	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,418
202	2588	OS - Operations Services	14.17%	Chollas, Station 38	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$15,139
202	2589	OS - Operations Services	14.17%	Chollas, Station 38	Partitions	Necessary- 2-5 Yrs	District 4	Partitions	Damaged	Repair Drywall Partitions	\$25,867
202	2590	OS - Operations Services	14.17%	Chollas, Station 38	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$32,398
202	2591	OS - Operations Services	14.17%	Chollas, Station 38	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$35,500
202	2592	OS - Operations Services	14.17%	Chollas, Station 38	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$36,887
202	2593	OS - Operations Services	14.17%	Chollas, Station 38	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wooden Canopy	\$54,252
202	2594	OS - Operations Services	14.17%	Chollas, Station 38	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$88,774
202	2595	OS - Operations Services	14.17%	Chollas, Station 38	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Failing	Replace Intercom/Paging System-50 stations	\$126,904
203	2596	PB - Park Balboa	14.06%	United Nations Building (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,306
203	2596	PB - Park Balboa	14.06%	United Nations Building (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$16,162
203	2596	PB - Park Balboa	14.06%	United Nations Building (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$5,327
203	2597	PB - Park Balboa	14.06%	United Nations Building (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$6,910
203	2597	PB - Park Balboa	14.06%	United Nations Building (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$1,599
203	2598	PB - Park Balboa	14.06%	United Nations Building (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Clay Tiles	\$25,069
203	2598	PB - Park Balboa	14.06%	United Nations Building (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$38,706
203	2599	PB - Park Balboa	14.06%	United Nations Building (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$7,023
203	2600	PB - Park Balboa	14.06%	United Nations Building (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Heat Generation	Inadequate	Install or replace heating equip or system	\$14,658
203	2601	PB - Park Balboa	14.06%	United Nations Building (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Failing	Replace electrical service entrance	\$7,478
203	2602	PB - Park Balboa	14.06%	United Nations Building (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$1,397
203	2603	PB - Park Balboa	14.06%	United Nations Building (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,445
203	2604	PB - Park Balboa	14.06%	United Nations Building (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$4,499
203	2605	PB - Park Balboa	14.06%	United Nations Building (L)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$13,264
203	2606	PB - Park Balboa	14.06%	United Nations Building (L)	Water Supply	Necessary- 2-5 Yrs	District 3	WATER Supply	Beyond Expected Life	Replace domestic water service	\$15,598
203	2607	PB - Park Balboa	14.06%	United Nations Building (L)	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$23,596
203	2608	PB - Park Balboa	14.06%	United Nations Building (L)	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$25,010
204	2610	Senior Centers	13.96%	Encanto	Domestic Water Distribution	Critical / Immediate Need	District 4	Domestic Water Distribution	Failing	Request Plumbing Consultant	\$5,289
204	2610	Senior Centers	13.96%	Encanto	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
204	2610	Senior Centers	13.96%	Encanto	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$5,814
204	2611	Senior Centers	13.96%	Encanto	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
204	2611	Senior Centers	13.96%	Encanto	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,172
204	2611	Senior Centers	13.96%	Encanto	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$12,837
204	2612	Senior Centers	13.96%	Encanto	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
204	2612	Senior Centers	13.96%	Encanto	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
204	2613	Senior Centers	13.96%	Encanto	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
204	2614	Senior Centers	13.96%	Encanto	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,869
204	2615	Senior Centers	13.96%	Encanto	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$6,561
204	2616	Senior Centers	13.96%	Encanto	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Wood Siding	\$8,714
204	2617	Senior Centers	13.96%	Encanto	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Plumbing Fixtures	\$12,786
204	2618	Senior Centers	13.96%	Encanto	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$20,681
204	2619	Senior Centers	13.96%	Encanto	Site Development	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wooden Canopy	\$45,839
204	2620	Senior Centers	13.96%	Encanto	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Asphalt Shingle	\$47,554
205	2621	Recreation Centers	13.91%	Mountain View Teen Ctr.	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,848
205	2621	Recreation Centers	13.91%	Mountain View Teen Ctr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
205	2621	Recreation Centers	13.91%	Mountain View Teen Ctr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$4,228
205	2622	Recreation Centers	13.91%	Mountain View Teen Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,449
205	2622	Recreation Centers	13.91%	Mountain View Teen Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,374
205	2622	Recreation Centers	13.91%	Mountain View Teen Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$9,383
205	2623	Recreation Centers	13.91%	Mountain View Teen Ctr.	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
205	2623	Recreation Centers	13.91%	Mountain View Teen Ctr.	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$9,166

205	2624	Recreation Centers	13.91%	Mountain View Teen Ctr.	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$10,484
205	2624	Recreation Centers	13.91%	Mountain View Teen Ctr.	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Wood Windows	\$21,379
205	2625	Recreation Centers	13.91%	Mountain View Teen Ctr.	Communications and Security	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$4,898
205	2626	Recreation Centers	13.91%	Mountain View Teen Ctr.	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$1,906
205	2627	Recreation Centers	13.91%	Mountain View Teen Ctr.	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
205	2628	Recreation Centers	13.91%	Mountain View Teen Ctr.	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Kitchen Sink 1 Basin	\$2,818
205	2629	Recreation Centers	13.91%	Mountain View Teen Ctr.	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$4,190
205	2630	Recreation Centers	13.91%	Mountain View Teen Ctr.	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$4,393
205	2631	Recreation Centers	13.91%	Mountain View Teen Ctr.	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$4,660
205	2632	Recreation Centers	13.91%	Mountain View Teen Ctr.	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,634
205	2633	Recreation Centers	13.91%	Mountain View Teen Ctr.	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$13,628
205	2634	Recreation Centers	13.91%	Mountain View Teen Ctr.	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
205	2635	Recreation Centers	13.91%	Mountain View Teen Ctr.	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$35,094
205	2636	Recreation Centers	13.91%	Mountain View Teen Ctr.	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$46,745
206	2637	Comfort Stations	13.63%	#000834	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
206	2638	Comfort Stations	13.63%	#000834	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$699
206	2638	Comfort Stations	13.63%	#000834	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
206	2639	Comfort Stations	13.63%	#000834	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$17,399
206	2639	Comfort Stations	13.63%	#000834	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,058
206	2640	Comfort Stations	13.63%	#000834	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$4,418
206	2641	Comfort Stations	13.63%	#000834	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,218
206	2642	Comfort Stations	13.63%	#000834	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$5,808
206	2643	Comfort Stations	13.63%	#000834	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$7,091
206	2644	Comfort Stations	13.63%	#000834	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$7,882
206	2645	Comfort Stations	13.63%	#000834	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
206	2646	Comfort Stations	13.63%	#000834	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$7,469
207	2647	Comfort Stations	13.50%	#900614	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Beyond Expected Life	Install or replace GFCI outlets	\$512
207	2647	Comfort Stations	13.50%	#900614	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Beyond Expected Life	Install or replace GFCI outlets	\$512
207	2647	Comfort Stations	13.50%	#900614	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$913
207	2647	Comfort Stations	13.50%	#900614	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
207	2647	Comfort Stations	13.50%	#900614	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$3,729
207	2648	Comfort Stations	13.50%	#900614	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Replace Steel Doors	\$699
207	2648	Comfort Stations	13.50%	#900614	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Replace Steel Doors	\$699
207	2649	Comfort Stations	13.50%	#900614	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Failing	Termite Inspection of Roof structure	\$13,158
207	2649	Comfort Stations	13.50%	#900614	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Failing	Replace Wood Rafters and Deck	\$1,199
207	2650	Comfort Stations	13.50%	#900614	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
207	2651	Comfort Stations	13.50%	#900614	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$5,833
207	2652	Comfort Stations	13.50%	#900614	Partitions	Necessary- 2-5 Yrs	District 5	Fittings	Damaged	Replace Toilet Partition	\$7,920
207	2653	Comfort Stations	13.50%	#900614	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Damaged	Replace Clay Tiles	\$40,122
208	2654	Comfort Stations	13.47%	#001091	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Restroom Accessories	\$786
208	2654	Comfort Stations	13.47%	#001091	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
208	2655	Comfort Stations	13.47%	#001091	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
208	2656	Comfort Stations	13.47%	#001091	Electrical Distribution	Potentially Critical-12 months	District 6	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$7,882
208	2657	Comfort Stations	13.47%	#001091	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
208	2658	Comfort Stations	13.47%	#001091	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$550
208	2659	Comfort Stations	13.47%	#001091	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$14,546
209	2660	Swimming Pools	13.44%	Vista Terrace	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$5,912
209	2660	Swimming Pools	13.44%	Vista Terrace	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$17,717
209	2660	Swimming Pools	13.44%	Vista Terrace	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,557
209	2660	Swimming Pools	13.44%	Vista Terrace	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,300
209	2660	Swimming Pools	13.44%	Vista Terrace	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$2,079
209	2661	Swimming Pools	13.44%	Vista Terrace	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Inadequate	Replace exit light fixtures	\$4,609
209	2661	Swimming Pools	13.44%	Vista Terrace	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Inadequate	Install circuit label electric outlets and switches	\$4,986
209	2661	Swimming Pools	13.44%	Vista Terrace	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$20,058
209	2662	Swimming Pools	13.44%	Vista Terrace	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$3,882
209	2662	Swimming Pools	13.44%	Vista Terrace	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Wood Siding	\$2,476
209	2663	Swimming Pools	13.44%	Vista Terrace	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Replace Ceramic Tile	\$11,845
209	2663	Swimming Pools	13.44%	Vista Terrace	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$8,154

209	2664	Swimming Pools	13.44%	Vista Terrace	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Lockers	\$8,380
209	2664	Swimming Pools	13.44%	Vista Terrace	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Toilet Partition	\$13,840
209	2665	Swimming Pools	13.44%	Vista Terrace	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Damaged	Replace Fabric at Fence	\$13,358
209	2665	Swimming Pools	13.44%	Vista Terrace	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Damaged	Repaint Metal Fence	\$9,297
209	2666	Swimming Pools	13.44%	Vista Terrace	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water and Sanitary Piping (SF)	\$63,642
209	2666	Swimming Pools	13.44%	Vista Terrace	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace 120 Gal Gas Water Heater	\$12,854
209	2667	Swimming Pools	13.44%	Vista Terrace	Exhaust Fans	Potentially Critical-12 months	District 8	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$17,009
209	2668	Swimming Pools	13.44%	Vista Terrace	Site Lighting	Potentially Critical-12 months	District 8	Site Lighting	Beyond Expected Life	Install/Replace site lighting-Lite Pole	\$22,239
209	2669	Swimming Pools	13.44%	Vista Terrace	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$5,846
209	2670	Swimming Pools	13.44%	Vista Terrace	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base Cabinets w/S.S. Top	\$7,570
209	2671	Swimming Pools	13.44%	Vista Terrace	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$8,606
209	2672	Swimming Pools	13.44%	Vista Terrace	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$9,631
209	2673	Swimming Pools	13.44%	Vista Terrace	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$77,776
209	2674	Swimming Pools	13.44%	Vista Terrace	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$103,688
209	2675	Swimming Pools	13.44%	Vista Terrace	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Built up Roof	\$252,114
210	2676	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
210	2676	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Counter Top; Solid Surface	\$2,359
210	2676	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Base Cabinet; Wood; 1 Drawer; 1 Door	\$7,032
210	2676	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Wall Cabinet; Wood; 30" (H); 1 Door;	\$7,436
210	2677	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$573
210	2678	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Water Heater; Electric; up to 30 Gallons	\$2,395
210	2679	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,594
210	2680	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
210	2681	PB - Park Balboa	13.41%	House Of Pac. Rel. U.S.A	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
211	2682	Comfort Stations	13.38%	#001269	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
211	2682	Comfort Stations	13.38%	#001269	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$545
211	2683	Comfort Stations	13.38%	#001269	Fittings	Potentially Critical-12 months	District 6	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,346
211	2683	Comfort Stations	13.38%	#001269	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
211	2684	Comfort Stations	13.38%	#001269	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Failing	Replace Roof Fascia	\$1,849
211	2685	Comfort Stations	13.38%	#001269	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,086
211	2686	Comfort Stations	13.38%	#001269	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
211	2687	Comfort Stations	13.38%	#001269	Water Supply	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Repair or replace domestic water piping	\$3,599
211	2688	Comfort Stations	13.38%	#001269	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$4,368
211	2689	Comfort Stations	13.38%	#001269	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$4,531
211	2690	Comfort Stations	13.38%	#001269	Electrical Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$5,919
211	2691	Comfort Stations	13.38%	#001269	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$6,625
211	2692	Comfort Stations	13.38%	#001269	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Epoxy floor	\$14,708
211	2693	Comfort Stations	13.38%	#001269	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
211	2694	Comfort Stations	13.38%	#001269	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$13,917
212	2695	Comfort Stations	13.30%	#000304	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Damaged	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$1,407
212	2695	Comfort Stations	13.30%	#000304	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
212	2695	Comfort Stations	13.30%	#000304	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$9,163
212	2695	Comfort Stations	13.30%	#000304	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Damaged	Replace Receptacle, 20A 120V ASSY/Ea.	\$2,268
212	2695	Comfort Stations	13.30%	#000304	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
212	2696	Comfort Stations	13.30%	#000304	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$3,538
212	2696	Comfort Stations	13.30%	#000304	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$10,221
212	2697	Comfort Stations	13.30%	#000304	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Damaged	Replace Roof Fascia	\$2,079
212	2697	Comfort Stations	13.30%	#000304	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$62,466
212	2698	Comfort Stations	13.30%	#000304	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
212	2698	Comfort Stations	13.30%	#000304	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Beyond Useful Life	Replace Stainless Steel Plumbing Fixtures	\$31,032
212	2699	Comfort Stations	13.30%	#000304	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,304
212	2700	Comfort Stations	13.30%	#000304	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567

212	2701	Comfort Stations	13.30%	#000304	Electrical Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
212	2702	Comfort Stations	13.30%	#000304	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$7,967
212	2703	Comfort Stations	13.30%	#000304	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$9,629
212	2704	Comfort Stations	13.30%	#000304	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$10,871
212	2705	Comfort Stations	13.30%	#000304	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Beyond Useful Life	Replace Built up Roof	\$16,000
212	2706	Comfort Stations	13.30%	#000304	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Epoxy floor	\$19,430
212	2707	Comfort Stations	13.30%	#000304	Sanitary Sewer	Necessary- 2-5 Yrs	District 1	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$13,052
213	2708	Comfort Stations	13.29%	#000579	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
213	2708	Comfort Stations	13.29%	#000579	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,004
213	2709	Comfort Stations	13.29%	#000579	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$4,287
213	2709	Comfort Stations	13.29%	#000579	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Expected Life	Replace Wood Doors	\$15,282
213	2710	Comfort Stations	13.29%	#000579	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
213	2711	Comfort Stations	13.29%	#000579	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,139
213	2712	Comfort Stations	13.29%	#000579	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$6,077
213	2713	Comfort Stations	13.29%	#000579	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$15,652
213	2714	Comfort Stations	13.29%	#000579	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
213	2715	Comfort Stations	13.29%	#000579	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$15,254
214	2716	Comfort Stations	13.08%	#001239	Roof Construction	Potentially Critical-12 months	District 2	Roof Construction	Damaged	Replace roof construction assembly	\$35,039
214	2716	Comfort Stations	13.08%	#001239	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Termite Inspection of Roof structure	\$10,200
214	2716	Comfort Stations	13.08%	#001239	Roof Construction	Necessary- 2-5 Yrs	District 2	Roof Construction	Damaged	Replace Roof Fascia	\$1,694
214	2717	Comfort Stations	13.08%	#001239	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
214	2718	Comfort Stations	13.08%	#001239	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repair exterior metal doors	\$2,608
214	2719	Comfort Stations	13.08%	#001239	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,973
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Refinish wood floor	\$1,978
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$1,317
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$9,199
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$54,682
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$120,223
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$27,975
215	2720	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,598
215	2721	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Inadequate	Replace exit light fixtures	\$5,292
215	2721	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$24,812
215	2721	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,024
215	2721	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$373,364
215	2721	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
215	2722	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Terminal & Package Units	Critical / Immediate Need	District 4	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
215	2722	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$6,203
215	2722	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Failing	Install or replace DX split ductless system	\$12,946
215	2723	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$356,981
215	2723	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Wood Siding	\$6,380
215	2723	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace Metal Siding	\$43,581
215	2724	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$36,204
215	2724	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$13,773
215	2725	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$171,609
215	2725	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$101,337
215	2726	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$230,666
215	2726	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Gutters and downspouts	\$16,041
215	2727	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$373
215	2728	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exhaust Fans (Other Than Vehicle)	Potentially Critical-12 months	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
215	2729	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Electrical Service/Distribution	Critical / Immediate Need	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace Medium Voltage Service	\$107,913
215	2730	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Partitions	Necessary- 2-5 Yrs	District 4	Partitions	Damaged	Replace wall insulation	\$3,516
215	2731	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$17,213
215	2732	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wooden Canopy	\$19,055
215	2733	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$40,769
215	2734	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$56,590

215	2735	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Failing	Replace Intercom/Paging System-50 stations	\$126,904
215	2736	OS - Operations Services	12.49%	Equip., Auto Rpr Shop, Chollas	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$236,722
216	2737	PB - Park Balboa	12.44%	Photo Arts Building (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,927
216	2737	PB - Park Balboa	12.44%	Photo Arts Building (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$7,526
216	2737	PB - Park Balboa	12.44%	Photo Arts Building (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$5,647
216	2738	PB - Park Balboa	12.44%	Photo Arts Building (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$9,558
216	2738	PB - Park Balboa	12.44%	Photo Arts Building (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Missing	Replace 30 Gal Gas Water Heater	\$2,777
216	2739	PB - Park Balboa	12.44%	Photo Arts Building (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$12,204
216	2739	PB - Park Balboa	12.44%	Photo Arts Building (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,048
216	2740	PB - Park Balboa	12.44%	Photo Arts Building (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$44,121
216	2741	PB - Park Balboa	12.44%	Photo Arts Building (L)	Site Development	Necessary- 2-5 Yrs	District 3	Fencing	Damaged	Replace concrete block fencing	\$2,958
216	2742	PB - Park Balboa	12.44%	Photo Arts Building (L)	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$3,074
216	2743	PB - Park Balboa	12.44%	Photo Arts Building (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,537
216	2744	PB - Park Balboa	12.44%	Photo Arts Building (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$9,744
216	2745	PB - Park Balboa	12.44%	Photo Arts Building (L)	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$10,910
216	2746	PB - Park Balboa	12.44%	Photo Arts Building (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$12,405
216	2747	PB - Park Balboa	12.44%	Photo Arts Building (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$12,723
216	2748	PB - Park Balboa	12.44%	Photo Arts Building (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$29,521
217	2749	Comfort Stations	12.30%	#000576	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
217	2750	Comfort Stations	12.30%	#000576	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Useful Life	Replace domestic water service	\$3,433
217	2750	Comfort Stations	12.30%	#000576	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$2,752
217	2751	Comfort Stations	12.30%	#000576	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Expected Life	Replace Steel Doors	\$2,095
217	2751	Comfort Stations	12.30%	#000576	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace exterior door hardware	\$4,287
217	2752	Comfort Stations	12.30%	#000576	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Replace CMU Block Wall	\$13,255
217	2752	Comfort Stations	12.30%	#000576	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,574
217	2753	Comfort Stations	12.30%	#000576	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,947
217	2754	Comfort Stations	12.30%	#000576	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
217	2755	Comfort Stations	12.30%	#000576	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$2,970
217	2756	Comfort Stations	12.30%	#000576	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
217	2757	Comfort Stations	12.30%	#000576	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Epoxy floor	\$21,588
217	2759	Comfort Stations	12.30%	#000576	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
218	2760	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Exterior Walls	Potentially Critical-12 months	District 8	Exterior Walls	Damaged	Replace Wood Fascia	\$13,590
218	2760	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Termite Inspection of Structure	\$11,638
218	2760	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Replace wood siding	\$54,587
218	2761	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$1,876
218	2761	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$552
218	2761	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,094
218	2762	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,251
218	2762	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Install or replace exterior lighting	\$3,929
218	2763	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Roofing Eave	\$16,561
218	2763	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Asphalt Shingle	\$16,299
218	2764	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
218	2765	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$4,853
218	2766	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$9,952
218	2767	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$12,449
218	2768	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$17,912
218	2769	Senior Centers	12.27%	Memorial Clubhouse & Shuffle	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Steel Windows	\$40,734
219	2771	Senior Centers	12.23%	Florence Riford (L)	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$10,757
219	2771	Senior Centers	12.23%	Florence Riford (L)	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$3,895
219	2771	Senior Centers	12.23%	Florence Riford (L)	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Beyond Expected Life	Install or replace kitchen range exhaust hood syst	\$20,261
219	2771	Senior Centers	12.23%	Florence Riford (L)	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Damaged	Install new exhaust system and controls	\$4,243

219	2772	Senior Centers	12.23%	Florence Riford (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,536
219	2772	Senior Centers	12.23%	Florence Riford (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,252
219	2772	Senior Centers	12.23%	Florence Riford (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$94,065
219	2772	Senior Centers	12.23%	Florence Riford (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$11,722
219	2772	Senior Centers	12.23%	Florence Riford (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$43,826
219	2774	Senior Centers	12.23%	Florence Riford (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Useful Life	Replace evaporative cooler	\$4,556
219	2774	Senior Centers	12.23%	Florence Riford (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace Ductwork Pkg Sys/Ton	\$27,182
219	2774	Senior Centers	12.23%	Florence Riford (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Heat Generation	Beyond Useful Life	Remove abandoned Heat Generation equipment/system	\$11,188
219	2774	Senior Centers	12.23%	Florence Riford (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$16,378
219	2778	Senior Centers	12.23%	Florence Riford (L)	Exterior Walls	Potentially Critical-12 months	District 1	Exterior Walls	Damaged	Replace Wood Fascia	\$1,965
219	2778	Senior Centers	12.23%	Florence Riford (L)	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$12,078
219	2778	Senior Centers	12.23%	Florence Riford (L)	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Replace Brick Veneer/Wood Stud	\$28,129
219	2780	Senior Centers	12.23%	Florence Riford (L)	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$45,744
219	2780	Senior Centers	12.23%	Florence Riford (L)	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$56,318
219	2780	Senior Centers	12.23%	Florence Riford (L)	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,751
219	2785	Senior Centers	12.23%	Florence Riford (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$4,038
219	2785	Senior Centers	12.23%	Florence Riford (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$13,320
219	2787	Senior Centers	12.23%	Florence Riford (L)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Sanitary Waste	Beyond Useful Life	Replace Grease Trap, 25 GPM, 50# Cap	\$7,204
219	2788	Senior Centers	12.23%	Florence Riford (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, gas	\$3,287
219	2789	Senior Centers	12.23%	Florence Riford (L)	Roadways	Potentially Critical-12 months	District 1	Roadways	Damaged	Repair and fill cracks and spalding.	\$5,374
219	2792	Senior Centers	12.23%	Florence Riford (L)	Site Development	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$640
219	2793	Senior Centers	12.23%	Florence Riford (L)	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace door hardware	\$1,214
219	2794	Senior Centers	12.23%	Florence Riford (L)	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
219	2795	Senior Centers	12.23%	Florence Riford (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$7,709
219	2797	Senior Centers	12.23%	Florence Riford (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$10,054
219	2798	Senior Centers	12.23%	Florence Riford (L)	Water Supply	Necessary- 2-5 Yrs	District 1	Water Supply	Beyond Expected Life	Replace domestic water service	\$13,730
219	2800	Senior Centers	12.23%	Florence Riford (L)	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace Steel Windows	\$16,512
219	2801	Senior Centers	12.23%	Florence Riford (L)	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Wood Doors	\$23,313
219	2802	Senior Centers	12.23%	Florence Riford (L)	Sanitary Sewer	Necessary- 2-5 Yrs	District 1	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$34,595
219	2803	Senior Centers	12.23%	Florence Riford (L)	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$34,834
220	2770	OS - Operations Services	12.23%	#000038 Communications Central	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$236
220	2770	OS - Operations Services	12.23%	#000038 Communications Central	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$25,245
220	2770	OS - Operations Services	12.23%	#000038 Communications Central	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Damaged	Replace Junction or Pull Box; 8"x8"x4" N3R	\$839
220	2770	OS - Operations Services	12.23%	#000038 Communications Central	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Damaged	Replace Acrylic Ltg. Fixture Lens; up To 2'x4'	\$288
220	2770	OS - Operations Services	12.23%	#000038 Communications Central	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace Ext. Lgt. Fix. Wall Pack; Up to 200 Watts	\$7,663
220	2773	OS - Operations Services	12.23%	#000038 Communications Central	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Failing	Coating Seal Duct Joints; Meta; Exposed	\$5,361
220	2773	OS - Operations Services	12.23%	#000038 Communications Central	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$32,757
220	2773	OS - Operations Services	12.23%	#000038 Communications Central	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace Rooftop Packaged Heat Pump	\$28,856
220	2773	OS - Operations Services	12.23%	#000038 Communications Central	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Damaged	Install or replace thermal insulation on HVAC pipi	\$3,112
220	2775	OS - Operations Services	12.23%	#000038 Communications Central	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$34,894
220	2775	OS - Operations Services	12.23%	#000038 Communications Central	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Glue on Tile	\$1,253
220	2775	OS - Operations Services	12.23%	#000038 Communications Central	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$7,207
220	2775	OS - Operations Services	12.23%	#000038 Communications Central	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Prepare and Paint Interior Ceiling	\$55,212
220	2776	OS - Operations Services	12.23%	#000038 Communications Central	Electrical Service/Distribution	Potentially Critical-12 months	District 8	Electrical Service/Distribution	Failing	Secure Electrica Conduit	\$281
220	2776	OS - Operations Services	12.23%	#000038 Communications Central	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace Panel Board; 200A; 240V; 1-Phase; 42 Ckt.	\$160,560
220	2776	OS - Operations Services	12.23%	#000038 Communications Central	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace Switch Board; 1000 Amp; 3-Phase	\$189,664
220	2777	OS - Operations Services	12.23%	#000038 Communications Central	Exterior Walls	Potentially Critical-12 months	District 8	Exterior Walls	Damaged	Structural Study	\$30,461
220	2777	OS - Operations Services	12.23%	#000038 Communications Central	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$1,770
220	2777	OS - Operations Services	12.23%	#000038 Communications Central	Exterior Walls	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567

220	2779	OS - Operations Services	12.23%	#000038 Communications Central	Roof Coverings	Potentially Critical-12 months	District 8	Roof Covering	Abandoned	Remove Debris from Roof	\$1,175
220	2779	OS - Operations Services	12.23%	#000038 Communications Central	Roof Coverings	Potentially Critical-12 months	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$254,557
220	2781	OS - Operations Services	12.23%	#000038 Communications Central	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$9,665
220	2781	OS - Operations Services	12.23%	#000038 Communications Central	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Terrazzo	\$12,958
220	2781	OS - Operations Services	12.23%	#000038 Communications Central	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Replace Carpet	\$130,364
220	2782	OS - Operations Services	12.23%	#000038 Communications Central	Communications and Security	Potentially Critical-12 months	District 8	Communications/Security	Abandoned	Remove Comm./Sec. Component	\$312
220	2782	OS - Operations Services	12.23%	#000038 Communications Central	Communications and Security	Necessary- 2-5 Yrs	District 8	Communications/Security	Beyond Expected Life	Replace Public Address Speaker Wall Mtd.	\$4,089
220	2783	OS - Operations Services	12.23%	#000038 Communications Central	Fittings	Potentially Critical-12 months	District 8	Fittings	Damaged	Replace Wood Bulletin Display Case	\$4,918
220	2783	OS - Operations Services	12.23%	#000038 Communications Central	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Information Sign; Wall Mtd	\$1,205
220	2784	OS - Operations Services	12.23%	#000038 Communications Central	Exhaust Fans	Necessary- 2-5 Yrs	District 8	Exhaust Ventilation System	Beyond Expected Life	Replace Exhaust Fan; Util. Belt 1100 CFM; 3 HP	\$10,021
220	2784	OS - Operations Services	12.23%	#000038 Communications Central	Exhaust Fans	Necessary- 2-5 Yrs	District 8	Exhaust Ventilation System	Damaged	Prepare and Paint Metal Vents or Stacks; Exposed	\$3,575
220	2786	OS - Operations Services	12.23%	#000038 Communications Central	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$23,242
220	2786	OS - Operations Services	12.23%	#000038 Communications Central	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$1,948
220	2790	OS - Operations Services	12.23%	#000038 Communications Central	Water Supply	Potentially Critical-12 months	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$27,335
220	2791	OS - Operations Services	12.23%	#000038 Communications Central	Rain Water Drainage	Potentially Critical-12 months	District 8	Rain Water Drainage	Damaged	Replace Gutter; Aluminum up to 6" x LF	\$42,710
220	2796	OS - Operations Services	12.23%	#000038 Communications Central	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$8,625
220	2799	OS - Operations Services	12.23%	#000038 Communications Central	Other Equipment	Necessary- 2-5 Yrs	District 8	Equipment	Beyond Expected Life	Replace Air Compressor =< 5 HP	\$14,553
220	2804	OS - Operations Services	12.23%	#000038 Communications Central	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$43,013
220	2805	OS - Operations Services	12.23%	#000038 Communications Central	Sanitary Sewer	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$48,725
220	2806	OS - Operations Services	12.23%	#000038 Communications Central	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$102,262
220	2807	OS - Operations Services	12.23%	#000038 Communications Central	Domestic Water Distribution	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$109,674
220	2808	OS - Operations Services	12.23%	#000038 Communications Central	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Beyond Expected Life	Replace Aluminium Windows	\$140,040
220	2809	OS - Operations Services	12.23%	#000038 Communications Central	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Failing	Repaint wall	\$233,698
221	2811	Comfort Stations	12.22%	#010086	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$703
221	2811	Comfort Stations	12.22%	#010086	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$8,700
221	2811	Comfort Stations	12.22%	#010086	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$674
221	2812	Comfort Stations	12.22%	#010086	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$1,956
221	2812	Comfort Stations	12.22%	#010086	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace exterior door hardware	\$1,429
221	2813	Comfort Stations	12.22%	#010086	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$11,716
221	2813	Comfort Stations	12.22%	#010086	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$5,197
221	2814	Comfort Stations	12.22%	#010086	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$1,823
221	2815	Comfort Stations	12.22%	#010086	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Clay Tiles	\$2,006
221	2816	Comfort Stations	12.22%	#010086	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
221	2817	Comfort Stations	12.22%	#010086	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$6,563
222	2818	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Fire Supression	Missing	Install exterior vent from the flammable storage	\$328
222	2818	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
222	2818	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Failing	Install new exhaust system and controls	\$3,050
222	2818	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$17,366
222	2818	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exhaust Fans	Necessary- 2-5 Yrs	District 2	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$8,372
222	2819	Recreation Centers	12.06%	Ocean Beach Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,536
222	2819	Recreation Centers	12.06%	Ocean Beach Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,809
222	2819	Recreation Centers	12.06%	Ocean Beach Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$33,713
222	2819	Recreation Centers	12.06%	Ocean Beach Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$9,377
222	2819	Recreation Centers	12.06%	Ocean Beach Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$72,358
222	2820	Recreation Centers	12.06%	Ocean Beach Recreation Center	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Failing	Replace Kitchen Sink 2 Basin	\$11,653
222	2820	Recreation Centers	12.06%	Ocean Beach Recreation Center	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Failing	Replace Drinking Fountain	\$3,260
222	2820	Recreation Centers	12.06%	Ocean Beach Recreation Center	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$27,657
222	2820	Recreation Centers	12.06%	Ocean Beach Recreation Center	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Waste	Missing	Install or replace interceptor(clay trap).	\$4,708
222	2821	Recreation Centers	12.06%	Ocean Beach Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace door hardware	\$7,282
222	2821	Recreation Centers	12.06%	Ocean Beach Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$1,076

222	2821	Recreation Centers	12.06%	Ocean Beach Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$9,488
222	2822	Recreation Centers	12.06%	Ocean Beach Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$5,257
222	2822	Recreation Centers	12.06%	Ocean Beach Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$8,708
222	2822	Recreation Centers	12.06%	Ocean Beach Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$21,288
222	2823	Recreation Centers	12.06%	Ocean Beach Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$975
222	2823	Recreation Centers	12.06%	Ocean Beach Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,262
222	2824	Recreation Centers	12.06%	Ocean Beach Recreation Center	Site Development	Necessary- 2-5 Yrs	District 2	Fencing	Damaged	Replace chain link fencing	\$6,896
222	2824	Recreation Centers	12.06%	Ocean Beach Recreation Center	Site Development	Necessary- 2-5 Yrs	District 2	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$962
222	2825	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$22,208
222	2825	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$29,343
222	2826	Recreation Centers	12.06%	Ocean Beach Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repair drywall/plaster ceiling	\$2,017
222	2826	Recreation Centers	12.06%	Ocean Beach Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Glue on Tile	\$102,930
222	2827	Recreation Centers	12.06%	Ocean Beach Recreation Center	Other Electrical Systems	Potentially Critical-12 months	District 2	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$12,248
222	2828	Recreation Centers	12.06%	Ocean Beach Recreation Center	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Toilet Partition	\$3,249
222	2829	Recreation Centers	12.06%	Ocean Beach Recreation Center	Water Supply	Necessary- 2-5 Yrs	District 2	Water Supply	Beyond Expected Life	Replace domestic water service	\$13,730
222	2830	Recreation Centers	12.06%	Ocean Beach Recreation Center	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$34,595
222	2831	Recreation Centers	12.06%	Ocean Beach Recreation Center	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$34,660
222	2832	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$53,664
222	2833	Recreation Centers	12.06%	Ocean Beach Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$57,749
222	2834	Recreation Centers	12.06%	Ocean Beach Recreation Center	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$65,501
222	2835	Recreation Centers	12.06%	Ocean Beach Recreation Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$97,187
222	2836	Recreation Centers	12.06%	Ocean Beach Recreation Center	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Terminal and Package Units	Beyond Expected Life	Replace unit heaters	\$111,655
222	2837	Recreation Centers	12.06%	Ocean Beach Recreation Center	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Steel Windows	\$223,547
223	2839	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$12,455
223	2839	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Install or replace exterior lighting	\$6,348
223	2839	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$187,421
223	2840	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$373
223	2840	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$61,768
223	2841	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$23,088
223	2841	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Ceramic Tile	\$1,564
223	2842	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Wood Siding	\$8,251
223	2842	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Replace Metal Siding	\$59,428
223	2843	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$61,929
223	2843	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$9,952
223	2844	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$116,516
223	2845	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Blanket Ceiling Insulation	\$4,593
223	2846	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Janitors Sink	\$5,213
223	2847	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$6,794
223	2848	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Site Development	Necessary- 2-5 Yrs	District 4	Fencing	Damaged	Replace chain link fencing	\$13,293
223	2849	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Failing	Replace Intercom/Paging System-50 stations	\$47,756
223	2850	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$118,359
223	2851	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Roof Construction	Necessary- 2-5 Yrs	District 4	Roof Construction	Damaged	Replace Wooden Canopy	\$131,229
223	2852	OS - Operations Services	11.92%	Str,Carpenter,Foresty, Chollas	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$200,014
224	2853	Comfort Stations	11.69%	#010012	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$653
224	2853	Comfort Stations	11.69%	#010012	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Replace exterior door hardware	\$1,429
224	2853	Comfort Stations	11.69%	#010012	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Replace Steel Doors	\$699
224	2854	Comfort Stations	11.69%	#010012	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
224	2854	Comfort Stations	11.69%	#010012	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace / Install Grab Bars	\$887
224	2855	Comfort Stations	11.69%	#010012	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$800
224	2856	Comfort Stations	11.69%	#010012	Roof Coverings	Potentially Critical-12 months	District 5	Roof Covering	Failing	Replace concrete tile roof	\$47,463
224	2857	Comfort Stations	11.69%	#010012	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,544
224	2858	Comfort Stations	11.69%	#010012	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Epoxy floor	\$13,673
225	2859	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$16,442
225	2859	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$15,355
225	2860	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,867

225	2861	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
225	2862	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$19,629
225	2863	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$28,565
225	2864	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$43,138
225	2865	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$67,241
225	2866	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$81,020
225	2867	PB - Park Balboa	11.68%	Spanish Village #4 Stds 20-29	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,039
226	2869	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$458
226	2870	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
226	2871	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$2,889
226	2872	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,037
226	2873	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$4,092
226	2874	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$6,111
226	2875	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
226	2876	PB - Park Balboa	11.66%	House Of Pac. Rel. France/Phil	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
227	2877	Senior Centers	11.58%	North Park Adult Community Ctr	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
227	2877	Senior Centers	11.58%	North Park Adult Community Ctr	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$9,694
227	2877	Senior Centers	11.58%	North Park Adult Community Ctr	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$9,694
227	2878	Senior Centers	11.58%	North Park Adult Community Ctr	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$5,167
227	2878	Senior Centers	11.58%	North Park Adult Community Ctr	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,837
227	2879	Senior Centers	11.58%	North Park Adult Community Ctr	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$79,048
227	2879	Senior Centers	11.58%	North Park Adult Community Ctr	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Asphalt Shingle	\$42,565
227	2880	Senior Centers	11.58%	North Park Adult Community Ctr	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
227	2881	Senior Centers	11.58%	North Park Adult Community Ctr	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,666
227	2882	Senior Centers	11.58%	North Park Adult Community Ctr	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$7,531
227	2883	Senior Centers	11.58%	North Park Adult Community Ctr	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$7,643
227	2884	Senior Centers	11.58%	North Park Adult Community Ctr	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Useful Life	Replace unit heaters	\$7,727
227	2885	Senior Centers	11.58%	North Park Adult Community Ctr	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$8,349
227	2886	Senior Centers	11.58%	North Park Adult Community Ctr	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$15,282
227	2887	Senior Centers	11.58%	North Park Adult Community Ctr	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$22,503
227	2888	Senior Centers	11.58%	North Park Adult Community Ctr	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$24,470
227	2889	Senior Centers	11.58%	North Park Adult Community Ctr	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$44,115
227	2890	Senior Centers	11.58%	North Park Adult Community Ctr	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$96,861
228	2891	Recreation Centers	11.55%	Adams Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,272
228	2891	Recreation Centers	11.55%	Adams Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
228	2892	Recreation Centers	11.55%	Adams Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$7,816
228	2892	Recreation Centers	11.55%	Adams Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$80,402
228	2893	Recreation Centers	11.55%	Adams Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Beyond Useful Life	Replace Wood Doors	\$3,317
228	2894	Recreation Centers	11.55%	Adams Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Cork Ceiling Tile	\$10,371
228	2895	Recreation Centers	11.55%	Adams Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$18,297
228	2896	Recreation Centers	11.55%	Adams Recreation Center	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Inadequate	Replace Aluminium Windows	\$20,747
228	2897	Recreation Centers	11.55%	Adams Recreation Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$39,975
229	2898	Comfort Stations	11.39%	#001071	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
229	2898	Comfort Stations	11.39%	#001071	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$492
229	2899	Comfort Stations	11.39%	#001071	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
229	2900	Comfort Stations	11.39%	#001071	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,175
229	2901	Comfort Stations	11.39%	#001071	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,739
229	2902	Comfort Stations	11.39%	#001071	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$2,928
229	2903	Comfort Stations	11.39%	#001071	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$4,183
229	2904	Comfort Stations	11.39%	#001071	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Epoxy floor	\$5,217
229	2905	Comfort Stations	11.39%	#001071	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Failing	Replace Roof Fascia	\$6,548
230	2906	Comfort Stations	11.37%	#010400	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
230	2906	Comfort Stations	11.37%	#010400	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Repaint Exterior Block Wall	\$3,547
230	2907	Comfort Stations	11.37%	#010400	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$543
230	2908	Comfort Stations	11.37%	#010400	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$3,728
230	2909	Comfort Stations	11.37%	#010400	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$3,913
231	2910	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Prepare Paint Overhead Door	\$9,962
231	2910	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Expected Life	Replace Steel Doors	\$16,760

231	2910	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$146,589
231	2910	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Weatherstripping	\$2,591
231	2910	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$3,913
231	2911	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Cut Out and Patch Concrete Wall Section	\$17,329
231	2911	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Load Dock Wood Rail; 4"x8"x12'	\$16,059
231	2911	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Walls	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
231	2911	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Prepare and Paint Exterior Concrete Wall Surface	\$304,395
231	2911	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Loading Dock Bumper; Rubber	\$1,597
231	2912	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$28,709
231	2912	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Clean and Preventive Maintenance to Light Fixture	\$7,651
231	2912	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Replace Ext. Lgt. Fix. Wall Pack; Up to 200 Watts	\$1,277
231	2912	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Failing	Clean and Preventive Maintenance to Light Fixture	\$1,530
231	2913	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$3,813
231	2913	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Cased Openings; Wood	\$1,790
231	2913	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$8,379
231	2914	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$38,460
231	2914	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$2,991
231	2914	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$35,808
231	2915	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace Switch Board; 1000 Amp; 3-Phase	\$291,777
231	2915	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace Medium Voltage Service	\$107,913
231	2915	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace Panel Board; 200A; 240V; 1-Phase; 42 Ckt.	\$176,617
231	2916	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Slab on Grade	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$109,171
231	2916	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Slab on Grade	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$1,505
231	2917	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Parking Lots	Potentially Critical-12 months	District 6	Roadways	Damaged	Replace Concrete Roadway	\$59,275
231	2917	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$54,541
231	2918	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Site Development	Potentially Critical-12 months	District 6	Site Development	Damaged	Prepair and Paint Pipe Bollard; 4"-6" Dia. to 4' H	\$1,127
231	2919	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Abandoned	Remove Air Cooled Condensing Unit; Cap-Off Lines	\$2,130
231	2920	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Vehicular Equipment	Potentially Critical-12 months	District 6	Equipment	Beyond Expected Life	Replace Air Compressor =< 5 HP	\$7,277
231	2921	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Seal stone floor	\$38,431
231	2922	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Rain Water Drainage	Potentially Critical-12 months	District 6	Rain Water Drainage	Damaged	Replace Gutter; Aluminum up to 6" x LF	\$46,697
231	2923	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Stair Construction	Potentially Critical-12 months	District 6	Stairs	Failing	Sand, Stain and Seal Int. Wood Stairs and Rise	\$69,051
231	2924	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Failing	Replace Exhaust Fan; Util. Belt 1100 CFM; 3 HP	\$135,279
231	2925	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$157,292
231	2926	OS - Operations Services	11.29%	Office, Parks & Rec. Coastal	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Beyond Expected Life	Replace Aluminium Windows	\$165,974
232	2927	Senior Centers	11.08%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$14,210
232	2927	Senior Centers	11.08%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,738
232	2927	Senior Centers	11.08%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$5,161
232	2928	Senior Centers	11.08%	Southcrest	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,634
232	2928	Senior Centers	11.08%	Southcrest	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$15,057
232	2929	Senior Centers	11.08%	Southcrest	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
232	2929	Senior Centers	11.08%	Southcrest	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 1X4 Surface Fluorescent Fixture S.F.	\$21,392
232	2930	Senior Centers	11.08%	Southcrest	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$6,423
232	2931	Senior Centers	11.08%	Southcrest	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$7,684
232	2932	Senior Centers	11.08%	Southcrest	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$12,731
232	2933	Senior Centers	11.08%	Southcrest	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Wood Siding	\$16,502
232	2934	Senior Centers	11.08%	Southcrest	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Aluminium Windows	\$22,140
233	2936	Comfort Stations	10.92%	#001073	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
233	2936	Comfort Stations	10.92%	#001073	Fittings	Potentially Critical-12 months	District 6	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$594
233	2937	Comfort Stations	10.92%	#001073	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$3,729
233	2937	Comfort Stations	10.92%	#001073	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$754
233	2938	Comfort Stations	10.92%	#001073	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$4,102
233	2939	Comfort Stations	10.92%	#001073	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$7,145

233	2940	Comfort Stations	10.92%	#001073	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
233	2941	Comfort Stations	10.92%	#001073	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace CMU Block Wall	\$7,953
233	2942	Comfort Stations	10.92%	#001073	Electrical Distribution	Potentially Critical-12 months	District 6	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$12,447
234	2943	Recreation Centers	10.89%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Damaged	Install new exhaust system and controls	\$3,895
234	2943	Recreation Centers	10.89%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$13,044
234	2943	Recreation Centers	10.89%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Fire Supression	Missing	Install exterior vent from the flamable storage	\$2,230
234	2943	Recreation Centers	10.89%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Damaged	Install new exhaust system and controls	\$3,895
234	2943	Recreation Centers	10.89%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
234	2943	Recreation Centers	10.89%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Fire Supression	Missing	Install exterior vent from the flamable storage	\$1,375
234	2944	Recreation Centers	10.89%	La Jolla	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,024
234	2944	Recreation Centers	10.89%	La Jolla	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,617
234	2944	Recreation Centers	10.89%	La Jolla	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$53,401
234	2944	Recreation Centers	10.89%	La Jolla	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067
234	2944	Recreation Centers	10.89%	La Jolla	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$114,615
234	2945	Recreation Centers	10.89%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$22,183
234	2945	Recreation Centers	10.89%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$5,337
234	2945	Recreation Centers	10.89%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Refinish wood floor	\$4,196
234	2945	Recreation Centers	10.89%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$10,395
234	2945	Recreation Centers	10.89%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$14,162
234	2946	Recreation Centers	10.89%	La Jolla	Exterior Doors	Potentially Critical-12 months	District 1	Exterior Doors	Damaged	Install or replace exterior hardware	\$6,300
234	2946	Recreation Centers	10.89%	La Jolla	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$8,096
234	2947	Recreation Centers	10.89%	La Jolla	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Damaged	Replace Toilet Partition	\$10,723
234	2947	Recreation Centers	10.89%	La Jolla	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
234	2948	Recreation Centers	10.89%	La Jolla	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$10,055
234	2948	Recreation Centers	10.89%	La Jolla	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$4,194
234	2949	Recreation Centers	10.89%	La Jolla	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Plaster Ceiling	\$11,756
234	2949	Recreation Centers	10.89%	La Jolla	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$13,951
234	2950	Recreation Centers	10.89%	La Jolla	Terminal & Package Units	Potentially Critical-12 months	District 1	Terminal and Package Units	Damaged	Install or Replace thermal insulation on refrig.	\$628
234	2951	Recreation Centers	10.89%	La Jolla	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Patch concrete	\$1,062
234	2952	Recreation Centers	10.89%	La Jolla	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, gas	\$3,193
234	2953	Recreation Centers	10.89%	La Jolla	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$7,183
234	2954	Recreation Centers	10.89%	La Jolla	Water Supply	Necessary- 2-5 Yrs	District 1	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730
234	2955	Recreation Centers	10.89%	La Jolla	Sanitary Sewer	Necessary- 2-5 Yrs	District 1	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$34,595
234	2956	Recreation Centers	10.89%	La Jolla	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$51,983
234	2957	Recreation Centers	10.89%	La Jolla	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$73,168
234	2958	Recreation Centers	10.89%	La Jolla	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Damaged	Replace electrical service entrance	\$86,617
235	2960	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Fittings	Critical / Immediate Need	District 1	Fittings	Damaged	Replace Interior Roll-Up Window/Screen	\$1,108
235	2960	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Fittings	Potentially Critical-12 months	District 1	Fittings	Damaged	Replace room signage	\$2,685
235	2960	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Damaged	Replace room signage	\$671
235	2961	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Rain Water Drainage	Critical / Immediate Need	District 1	Rain Water Drainage	Inadequate	Clean Out Roof Drain Receptor	\$1,712
235	2961	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Rain Water Drainage	Necessary- 2-5 Yrs	District 1	Rain Water Drainage	Damaged	Prepare and Paint Roof Drain Piping	\$1,907
235	2962	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Electrical Service/Distribution	Potentially Critical-12 months	District 1	Electrical Service/Distribution	Abandoned	Remove Abandoned Electrical Service Equipment	\$269
235	2962	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Electrical Service/Distribution	Potentially Critical-12 months	District 1	Electrical Service/Distribution	Damaged	Replace Panel Board Cover Door Latch	\$288
235	2963	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,090

235	2963	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Flour. Ltg. Fix. 1x4 Surf. Mtd. 2 Lamp	\$52,178
235	2964	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Pool Equipment	Potentially Critical-12 months	District 1	Equipment	Damaged	Replace Valve; Swimming Pool; 6"-8"	\$24,938
235	2964	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Pool Equipment	Necessary- 2-5 Yrs	District 1	Equipment	Beyond Expected Life	Replace Swimming Pool Heater/Boiler	\$101,001
235	2965	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Epoxy floor	\$58,288
235	2965	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Replace rubber/vinyl cove base	\$373
235	2966	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Heat Generation	Beyond Expected Life	Replace Gas/Oil Boiler 584 MBTU	\$52,813
235	2966	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Terminal and Package Units	Beyond Expected Life	Replace Fan Coil Unit	\$17,812
235	2967	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Wall Finishes	Potentially Critical-12 months	District 1	Wall Finishes	Damaged	Repaint wall	\$3,728
235	2968	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Exterior Doors	Potentially Critical-12 months	District 1	Exterior Doors	Failing	Install or replace exterior hardware	\$17,764
235	2969	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Damaged	Replace Exhaust Fan; Centrifugal; Direct Drive	\$19,373
235	2970	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
235	2971	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,911
235	2972	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Site Lighting	Necessary- 2-5 Yrs	District 1	Site Lighting	Failing	Prepare Paint Site Lighting; Pole; Steel to 40'	\$8,655
235	2973	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Domestic Water Distribution	Beyond Expected Life	Replace Gas Water Heater; Commercial;100 Gallons	\$13,798
235	2974	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Beyond Expected Life	Replace Modified Bitumen Roof Coverings	\$106,330
235	2975	Swimming Pools	10.81%	Standley-Swanson Swimming Pool	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$110,529
236	2978	PB - Park Balboa	10.72%	House Of Pac. Rel. Scotland	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$427
236	2979	PB - Park Balboa	10.72%	House Of Pac. Rel. Scotland	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$5,502
236	2980	PB - Park Balboa	10.72%	House Of Pac. Rel. Scotland	Water Supply	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$6,833
236	2981	PB - Park Balboa	10.72%	House Of Pac. Rel. Scotland	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
236	2983	PB - Park Balboa	10.72%	House Of Pac. Rel. Scotland	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
236	2984	PB - Park Balboa	10.72%	House Of Pac. Rel. Scotland	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
237	2976	OS - Operations Services	10.72%	Streets Division, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,818
237	2976	OS - Operations Services	10.72%	Streets Division, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$2,458
237	2976	OS - Operations Services	10.72%	Streets Division, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
237	2976	OS - Operations Services	10.72%	Streets Division, Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$57,452
237	2977	OS - Operations Services	10.72%	Streets Division, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$66,303
237	2977	OS - Operations Services	10.72%	Streets Division, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$2,146
237	2977	OS - Operations Services	10.72%	Streets Division, Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,897
237	2982	OS - Operations Services	10.72%	Streets Division, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$5,607
237	2985	OS - Operations Services	10.72%	Streets Division, Chollas	Floor Construction	Necessary- 2-5 Yrs	District 4	Floor Construction	Damaged	Repair Balcony Floor	\$9,616
237	2986	OS - Operations Services	10.72%	Streets Division, Chollas	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$9,901
237	2987	OS - Operations Services	10.72%	Streets Division, Chollas	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$18,513
237	2988	OS - Operations Services	10.72%	Streets Division, Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$29,531
237	2989	OS - Operations Services	10.72%	Streets Division, Chollas	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$88,774
238	2990	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$207
238	2990	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$573
238	2991	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$2,166
238	2991	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Inadequate	Replace Aluminium Windows	\$2,594
238	2992	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Exterior Walls	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Repaint Handrails	\$9,124
238	2992	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Powerwash exterior wall	\$1,829
238	2993	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Inadequate	Remove Debris from Roof	\$1,293

238	2994	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
238	2995	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$5,262
238	2996	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
238	2997	PB - Park Balboa	10.68%	House Of Pac. Rel. Sweden	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
239	2998	Comfort Stations	10.18%	#010262	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
239	2999	Comfort Stations	10.18%	#010262	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$323
239	3000	Comfort Stations	10.18%	#010262	Plumbing Fixtures	Necessary- 2-5 Yrs	District 5	Plumbing Fixtures	Beyond Useful Life	Replace Drinking Fountain	\$3,119
239	3001	Comfort Stations	10.18%	#010262	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Replace Roof Fascia	\$3,605
239	3002	Comfort Stations	10.18%	#010262	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$6,521
239	3003	Comfort Stations	10.18%	#010262	Site Development	Necessary- 2-5 Yrs	District 5	Fencing	Damaged	Replace Fencing - Wood - Up to 6' (H)	\$8,772
240	3004	Comfort Stations	10.09%	#010381	Plumbing Fixtures	Critical / Immediate Need	District 2	Plumbing Fixtures	Missing	Replace Toilet Seat; Elongated	\$323
240	3004	Comfort Stations	10.09%	#010381	Plumbing Fixtures	Critical / Immediate Need	District 2	Plumbing Fixtures	Failing	Unclog / Clear Drain w/Auger	\$657
240	3004	Comfort Stations	10.09%	#010381	Plumbing Fixtures	Potentially Critical-12 months	District 2	Plumbing Fixtures	Damaged	Perform Maintenance and Clean Drinking Fountain	\$433
240	3005	Comfort Stations	10.09%	#010381	Fittings	Potentially Critical-12 months	District 2	Fittings	Damaged	Replace room signage	\$2,237
240	3005	Comfort Stations	10.09%	#010381	Fittings	Potentially Critical-12 months	District 2	Fittings	Missing	Replace Soap Dispenser; Wall Mtd.	\$1,087
240	3005	Comfort Stations	10.09%	#010381	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace mirrors	\$1,874
240	3006	Comfort Stations	10.09%	#010381	Exterior Walls	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
240	3006	Comfort Stations	10.09%	#010381	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Prepare and Paint Exterior Concrete Wall Surface	\$4,839
240	3006	Comfort Stations	10.09%	#010381	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$2,168
240	3007	Comfort Stations	10.09%	#010381	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$481
240	3008	Comfort Stations	10.09%	#010381	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Seal stone floor	\$420
240	3009	Comfort Stations	10.09%	#010381	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$3,882
240	3010	Comfort Stations	10.09%	#010381	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$9,128
241	3011	Comfort Stations	9.88%	#900065	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$913
241	3012	Comfort Stations	9.88%	#900065	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$2,011
241	3013	Comfort Stations	9.88%	#900065	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
241	3014	Comfort Stations	9.88%	#900065	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Epoxy floor	\$2,938
241	3015	Comfort Stations	9.88%	#900065	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$45,056
242	3016	Comfort Stations	9.87%	#010283	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$196
242	3017	Comfort Stations	9.87%	#010283	Roof Coverings	Potentially Critical-12 months	District 3	Rain Water Drainage	Failing	Clean Out Gutters	\$1,923
242	3018	Comfort Stations	9.87%	#010283	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Fascia	\$1,076
242	3019	Comfort Stations	9.87%	#010283	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
242	3020	Comfort Stations	9.87%	#010283	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,868
243	3021	Swimming Pools	9.68%	Memorial	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Inadequate	Replace exit light fixtures	\$6,354
243	3021	Swimming Pools	9.68%	Memorial	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,311
243	3021	Swimming Pools	9.68%	Memorial	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Receptacle 20A 120V ASSY/S.F.	\$13,485
243	3021	Swimming Pools	9.68%	Memorial	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 1X4 Surface Fluorescent Fixture S.F.	\$127,023
243	3022	Swimming Pools	9.68%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,219
243	3022	Swimming Pools	9.68%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$10,390
243	3022	Swimming Pools	9.68%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$3,003
243	3022	Swimming Pools	9.68%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$14,902
243	3023	Swimming Pools	9.68%	Memorial	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Drinking Fountain	\$8,219
243	3023	Swimming Pools	9.68%	Memorial	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$47,127
243	3024	Swimming Pools	9.68%	Memorial	Site Development	Necessary- 2-5 Yrs	District 8	Fencing	Damaged	Repaint Metal Fence	\$2,325
243	3025	Swimming Pools	9.68%	Memorial	Exhaust Fans	Necessary- 2-5 Yrs	District 8	Ventilation and Exhaust	Beyond Expected Life	Add/replace fractional HP exhaust fans;incl. duct	\$5,177
243	3026	Swimming Pools	9.68%	Memorial	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$6,923
243	3027	Swimming Pools	9.68%	Memorial	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$13,046
243	3028	Swimming Pools	9.68%	Memorial	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$13,238
243	3029	Swimming Pools	9.68%	Memorial	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$21,444
243	3030	Swimming Pools	9.68%	Memorial	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$26,539
243	3031	Swimming Pools	9.68%	Memorial	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 8	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$38,542
243	3032	Swimming Pools	9.68%	Memorial	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$63,410
243	3033	Swimming Pools	9.68%	Memorial	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$108,200
244	3035	Recreation Centers	9.59%	South Bay	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$5,748
244	3035	Recreation Centers	9.59%	South Bay	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Epoxy floor	\$11,242
244	3035	Recreation Centers	9.59%	South Bay	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$13,863
244	3035	Recreation Centers	9.59%	South Bay	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,823
244	3035	Recreation Centers	9.59%	South Bay	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$20,643

244	3036	Recreation Centers	9.59%	South Bay	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,419
244	3036	Recreation Centers	9.59%	South Bay	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$111,633
244	3036	Recreation Centers	9.59%	South Bay	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
244	3037	Recreation Centers	9.59%	South Bay	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,869
244	3037	Recreation Centers	9.59%	South Bay	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$53,479
244	3038	Recreation Centers	9.59%	South Bay	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$77,885
244	3038	Recreation Centers	9.59%	South Bay	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Asphalt Shingle	\$30,626
244	3039	Recreation Centers	9.59%	South Bay	Site Lighting	Potentially Critical-12 months	District 8	Site Lighting	Beyond Expected Life	Install/Replace site lighting-Lite Pole	\$9,074
244	3040	Recreation Centers	9.59%	South Bay	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$11,437
244	3041	Recreation Centers	9.59%	South Bay	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$11,999
244	3042	Recreation Centers	9.59%	South Bay	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$25,455
244	3043	Recreation Centers	9.59%	South Bay	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$36,658
244	3044	Recreation Centers	9.59%	South Bay	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$60,930
244	3045	Recreation Centers	9.59%	South Bay	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Inadequate	Replace Gas/Electric Pkg. Unit (s)	\$141,810
245	3046	Senior Centers	9.57%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$18,629
245	3046	Senior Centers	9.57%	La Jolla	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$2,647
245	3047	Senior Centers	9.57%	La Jolla	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
245	3048	Senior Centers	9.57%	La Jolla	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Inadequate	Replace electric service entrance -200 Amp	\$9,295
245	3049	Senior Centers	9.57%	La Jolla	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,367
245	3050	Senior Centers	9.57%	La Jolla	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Replace Wall Panelling	\$13,915
245	3051	Senior Centers	9.57%	La Jolla	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Clay Tiles	\$123,416
246	3052	Community Services Centers	9.55%	San Ysidro	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,155
246	3052	Community Services Centers	9.55%	San Ysidro	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$81,040
246	3052	Community Services Centers	9.55%	San Ysidro	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$13,693
246	3053	Community Services Centers	9.55%	San Ysidro	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,777
246	3053	Community Services Centers	9.55%	San Ysidro	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$73,670
246	3053	Community Services Centers	9.55%	San Ysidro	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Terrazzo	\$61,701
246	3054	Community Services Centers	9.55%	San Ysidro	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$6,399
246	3054	Community Services Centers	9.55%	San Ysidro	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Fascia	\$3,020
246	3055	Community Services Centers	9.55%	San Ysidro	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$9,813
246	3055	Community Services Centers	9.55%	San Ysidro	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,679
246	3056	Community Services Centers	9.55%	San Ysidro	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$17,974
246	3056	Community Services Centers	9.55%	San Ysidro	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$49,120
246	3057	Community Services Centers	9.55%	San Ysidro	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$65,813
246	3057	Community Services Centers	9.55%	San Ysidro	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace sheet metal flashing	\$12,875
246	3058	Community Services Centers	9.55%	San Ysidro	Domestic Water Distribution	Potentially Critical-12 months	District 8	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,035
246	3059	Community Services Centers	9.55%	San Ysidro	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$8,155
246	3060	Community Services Centers	9.55%	San Ysidro	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Lockers	\$2,096
246	3061	Community Services Centers	9.55%	San Ysidro	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Domestic Water Distribution	Failing	Request Plumbing Consultant	\$3,526

246	3062	Community Services Centers	9.55%	San Ysidro	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,625
246	3063	Community Services Centers	9.55%	San Ysidro	Landscaping	Necessary- 2-5 Yrs	District 8	Landscaping	Damaged	Re-grade Site	\$4,345
246	3064	Community Services Centers	9.55%	San Ysidro	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$8,443
246	3065	Community Services Centers	9.55%	San Ysidro	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$9,901
246	3066	Community Services Centers	9.55%	San Ysidro	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$16,587
246	3067	Community Services Centers	9.55%	San Ysidro	Roof Construction	Necessary- 2-5 Yrs	District 8	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$44,426
246	3068	Community Services Centers	9.55%	San Ysidro	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Aluminium Windows	\$48,393
247	3070	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Exterior Doors	Potentially Critical-12 months	District 3	Exterior Doors	Damaged	Remove, Salvage, Restore Ext. Door-Wood Historic	\$4,492
247	3070	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$1,753
247	3071	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$418
247	3072	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$2,166
247	3073	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
247	3074	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
247	3075	PB - Park Balboa	9.54%	House Of Pac. Rel. Finland	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
248	3076	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$2,440
248	3076	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$21,488
248	3076	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,724
248	3077	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,418
248	3078	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Patch concrete	\$1,992
248	3079	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$9,707
248	3080	Recreation Centers	9.35%	North Park Teen Ctr/Game Room	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$54,432
249	3081	PO - Parks / Recreation	8.96%	Ranger Office Chollas Lake	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
249	3081	PO - Parks / Recreation	8.96%	Ranger Office Chollas Lake	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Wood Siding	\$8,471
249	3082	PO - Parks / Recreation	8.96%	Ranger Office Chollas Lake	Exterior Windows	Critical / Immediate Need	District 3	Exterior Windows	Damaged	Replace Window Glass Pane; up to 4 SF	\$805
250	3083	Comfort Stations	8.78%	#000814	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$414
250	3083	Comfort Stations	8.78%	#000814	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$931
250	3084	Comfort Stations	8.78%	#000814	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace mirrors	\$1,346
250	3084	Comfort Stations	8.78%	#000814	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
250	3085	Comfort Stations	8.78%	#000814	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint exterior metal doors	\$3,913
250	3086	Comfort Stations	8.78%	#000814	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$9,136
250	3087	Comfort Stations	8.78%	#000814	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Exterior Block Wall	\$10,355
250	3088	Comfort Stations	8.78%	#000814	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$11,648
251	3089	Senior Centers	8.76%	Paradise	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Damaged	Replace floor box receptacle covers/brass	\$4,054
251	3089	Senior Centers	8.76%	Paradise	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,405
251	3089	Senior Centers	8.76%	Paradise	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 1X4 Surface Fluorescent Fixture S.F.	\$53,480
251	3089	Senior Centers	8.76%	Paradise	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$3,729
251	3090	Senior Centers	8.76%	Paradise	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$29,247
251	3090	Senior Centers	8.76%	Paradise	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,138
251	3090	Senior Centers	8.76%	Paradise	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$2,600
251	3091	Senior Centers	8.76%	Paradise	Terminal & Package Units	Potentially Critical-12 months	District 8	Terminal and Package Units	Inadequate	Install or replace DX split ductless system	\$32,372
251	3092	Senior Centers	8.76%	Paradise	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$1,779
251	3093	Senior Centers	8.76%	Paradise	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Repair and reseal leaky gutter	\$4,434
251	3094	Senior Centers	8.76%	Paradise	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Steel Windows	\$5,131
251	3095	Senior Centers	8.76%	Paradise	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$8,728
251	3096	Senior Centers	8.76%	Paradise	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$9,513
251	3097	Senior Centers	8.76%	Paradise	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$9,952
251	3098	Senior Centers	8.76%	Paradise	Standard Foundations	Necessary- 2-5 Yrs	District 8	Foundations	Damaged	Conduct Engineering Assessment - Foundation	\$28,849
252	3100	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$800
252	3101	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$1,553
252	3102	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
252	3103	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$2,923

252	3104	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$3,611
252	3105	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Exterior Walls	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Repaint Handrails	\$5,474
252	3106	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
252	3107	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
252	3108	PB - Park Balboa	8.71%	House Of Pac. Rel. Czech	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Replace Carpet	\$13,863
253	3109	Recreation Centers	8.66%	Grant School Grounds Park	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,737
253	3109	Recreation Centers	8.66%	Grant School Grounds Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$1,057
253	3109	Recreation Centers	8.66%	Grant School Grounds Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$1,057
253	3109	Recreation Centers	8.66%	Grant School Grounds Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$26,136
253	3109	Recreation Centers	8.66%	Grant School Grounds Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$3,751
253	3109	Recreation Centers	8.66%	Grant School Grounds Park	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$12,178
253	3110	Recreation Centers	8.66%	Grant School Grounds Park	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,799
253	3110	Recreation Centers	8.66%	Grant School Grounds Park	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Termite Inspection of Structure	\$6,602
253	3111	Recreation Centers	8.66%	Grant School Grounds Park	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Refinish wood floor	\$12,876
253	3111	Recreation Centers	8.66%	Grant School Grounds Park	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$976
253	3112	Recreation Centers	8.66%	Grant School Grounds Park	Other Electrical systems	Potentially Critical-12 months	District 2	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$3,265
253	3113	Recreation Centers	8.66%	Grant School Grounds Park	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
253	3114	Recreation Centers	8.66%	Grant School Grounds Park	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$6,361
253	3115	Recreation Centers	8.66%	Grant School Grounds Park	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Failing	Replace electric service entrance -200 Amp	\$7,709
253	3116	Recreation Centers	8.66%	Grant School Grounds Park	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Damaged	Replace Kitchen Sink 1 Basin	\$7,873
253	3117	Recreation Centers	8.66%	Grant School Grounds Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Glue on Tile	\$13,070
254	3118	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Plumbing Fixtures	Potentially Critical-12 months	District 3	Domestic Water Distribution	Failing	Replace Water Heater; Electric; up to 30 Gallons	\$2,395
254	3118	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
254	3118	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Damaged	Replace Kitchen Sink 1 Basin	\$2,818
254	3119	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$513
254	3119	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Inadequate	Replace Incandescent Light Fixtures	\$384
254	3120	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$1,165
254	3121	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$1,753
254	3122	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
254	3123	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$5,055
254	3124	PB - Park Balboa	8.46%	House Of Pac. Rel. England	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
255	3125	Swimming Pools	8.34%	Martin Luther King Jr.	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$2,440
255	3125	Swimming Pools	8.34%	Martin Luther King Jr.	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,051
255	3125	Swimming Pools	8.34%	Martin Luther King Jr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$7,034
255	3125	Swimming Pools	8.34%	Martin Luther King Jr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle 20A 120V ASSY/S.F.	\$28,400
255	3125	Swimming Pools	8.34%	Martin Luther King Jr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$11,216
255	3125	Swimming Pools	8.34%	Martin Luther King Jr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Site Lighting	Inadequate	Install/Replace HID/HPS 250W exterior wall pack	\$3,435
255	3126	Swimming Pools	8.34%	Martin Luther King Jr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$6,005
255	3126	Swimming Pools	8.34%	Martin Luther King Jr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$10,329
255	3126	Swimming Pools	8.34%	Martin Luther King Jr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,989
255	3126	Swimming Pools	8.34%	Martin Luther King Jr.	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$12,130
255	3127	Swimming Pools	8.34%	Martin Luther King Jr.	Exterior Walls	Potentially Critical-12 months	District 4	Exterior Walls	Damaged	Replace Wood Fascia	\$11,922
255	3127	Swimming Pools	8.34%	Martin Luther King Jr.	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$6,327
255	3127	Swimming Pools	8.34%	Martin Luther King Jr.	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Caulk exterior walls	\$3,383
255	3128	Swimming Pools	8.34%	Martin Luther King Jr.	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
255	3128	Swimming Pools	8.34%	Martin Luther King Jr.	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$20,088
255	3129	Swimming Pools	8.34%	Martin Luther King Jr.	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$7,787
255	3129	Swimming Pools	8.34%	Martin Luther King Jr.	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,915
255	3130	Swimming Pools	8.34%	Martin Luther King Jr.	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$41,243
255	3130	Swimming Pools	8.34%	Martin Luther King Jr.	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$13,269
255	3131	Swimming Pools	8.34%	Martin Luther King Jr.	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$31,998
255	3131	Swimming Pools	8.34%	Martin Luther King Jr.	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Patch concrete	\$105,195
255	3132	Swimming Pools	8.34%	Martin Luther King Jr.	Partitions	Necessary- 2-5 Yrs	District 4	Partitions	Damaged	Repair Drywall Partitions	\$3,449
255	3133	Swimming Pools	8.34%	Martin Luther King Jr.	Site Development	Necessary- 2-5 Yrs	District 4	Fencing	Damaged	Replace Fabric at Fence	\$4,452
255	3134	Swimming Pools	8.34%	Martin Luther King Jr.	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$8,116
255	3135	Swimming Pools	8.34%	Martin Luther King Jr.	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$11,648

255	3136	Swimming Pools	8.34%	Martin Luther King Jr.	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
255	3137	Swimming Pools	8.34%	Martin Luther King Jr.	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Plumbing Fixtures	\$23,601
255	3138	Swimming Pools	8.34%	Martin Luther King Jr.	Pool Equipment	Necessary- 2-5 Yrs	District 4	Heat Generation	Beyond Useful Life	Replace Gas/Oil Boiler 1600 MBTU	\$104,195
256	3140	Comfort Stations	8.32%	#009963	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$2,048
256	3140	Comfort Stations	8.32%	#009963	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$831
256	3140	Comfort Stations	8.32%	#009963	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace 2X4 Flourescent Fixture Ea.	\$8,557
256	3141	Comfort Stations	8.32%	#009963	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$389
256	3142	Comfort Stations	8.32%	#009963	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Rain Water Drainage	Failing	Replace Area Drain and Piping	\$1,270
256	3143	Comfort Stations	8.32%	#009963	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$1,973
256	3144	Comfort Stations	8.32%	#009963	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repair interior roof structure and deck.	\$2,458
256	3145	Comfort Stations	8.32%	#009963	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
256	3146	Comfort Stations	8.32%	#009963	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Failing	Replace Plumbing Fixtures	\$2,924
256	3147	Comfort Stations	8.32%	#009963	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$15,231
257	3150	Comfort Stations	8.31%	#010379	Electrical Distribution	Potentially Critical-12 months	District 5	Site Lighting	Damaged	Install/Replace site lighting-Lite Pole	\$3,542
257	3151	Comfort Stations	8.31%	#010379	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
257	3152	Comfort Stations	8.31%	#010379	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
257	3155	Comfort Stations	8.31%	#010379	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$1,787
257	3157	Comfort Stations	8.31%	#010379	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
258	3153	PB - Park Balboa	8.31%	House Of Pac. Rel. Ireland	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Powerwash exterior wall	\$1,449
258	3156	PB - Park Balboa	8.31%	House Of Pac. Rel. Ireland	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
258	3158	PB - Park Balboa	8.31%	House Of Pac. Rel. Ireland	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$2,889
258	3159	PB - Park Balboa	8.31%	House Of Pac. Rel. Ireland	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,035
258	3161	PB - Park Balboa	8.31%	House Of Pac. Rel. Ireland	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
258	3162	PB - Park Balboa	8.31%	House Of Pac. Rel. Ireland	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
259	3148	Comfort Stations	8.31%	#010389	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Prepare and Paint Exterior Metal Trim	\$433
259	3148	Comfort Stations	8.31%	#010389	Exterior Walls	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
259	3149	Comfort Stations	8.31%	#010389	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$750
259	3154	Comfort Stations	8.31%	#010389	Roof Construction	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Repaint Wood Trellis	\$1,463
259	3160	Comfort Stations	8.31%	#010389	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Epoxy floor	\$4,497
259	3163	Comfort Stations	8.31%	#010389	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$16,954
259	3164	Comfort Stations	8.31%	#010389	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$17,986
260	3165	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$20,419
260	3165	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
260	3165	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
260	3166	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$1,627
260	3166	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$9,377
260	3166	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$33,929
260	3167	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$1,994
260	3167	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$5,337
260	3167	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$38,074
260	3168	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Repair pavers	\$998
260	3168	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Patch concrete	\$1,060
260	3169	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repair drywall/plaster ceiling	\$3,466
260	3169	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$563
260	3170	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,513
260	3170	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$3,168
260	3171	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
260	3171	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Toilet Partition	\$11,271
260	3172	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Missing	Replace Gutters and downspouts	\$1,332
260	3172	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$58,626
260	3173	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Termite Inspection of Structure	\$8,392
260	3174	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Slurry seal asphalt	\$1,187
260	3175	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,956
260	3176	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Partitions	Necessary- 2-5 Yrs	District 2	Partitions	Inadequate	Replace Drywall Partition/Wood Stud Backup	\$3,693
260	3177	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730

260	3178	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Failing	Replace electric service entrance 400 or 800 Amp	\$17,550
260	3179	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$23,978
260	3180	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Steel Windows	\$28,333
260	3181	Recreation Centers	8.29%	Santa Clara Point. Rec. Center	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$34,595
261	3184	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,194
261	3184	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$17,974
261	3184	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120V/277V ASSY/Ea.	\$3,751
261	3184	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$8,374
261	3185	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Other Electrical Systems	Potentially Critical-12 months	District 3	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$2,452
261	3186	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
261	3187	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Heat Generation	Failing	Install or replace heating equip or system	\$2,476
261	3188	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$3,981
261	3189	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$6,868
261	3190	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$8,258
261	3191	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$11,393
261	3192	Senior Centers	8.03%	Golden Hill Clubhouse & Shufbd	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$15,559
262	3193	Recreation Centers	7.96%	Tecolote	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
262	3193	Recreation Centers	7.96%	Tecolote	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$24,080
262	3193	Recreation Centers	7.96%	Tecolote	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$11,219
262	3193	Recreation Centers	7.96%	Tecolote	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120V/277V ASSY/Ea.	\$4,689
262	3193	Recreation Centers	7.96%	Tecolote	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,600
262	3194	Recreation Centers	7.96%	Tecolote	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
262	3194	Recreation Centers	7.96%	Tecolote	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$17,387
262	3195	Recreation Centers	7.96%	Tecolote	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$14,826
262	3195	Recreation Centers	7.96%	Tecolote	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$5,247
262	3196	Recreation Centers	7.96%	Tecolote	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$3,265
262	3197	Recreation Centers	7.96%	Tecolote	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Install or replace roof ventilation	\$2,071
262	3198	Recreation Centers	7.96%	Tecolote	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,906
262	3199	Recreation Centers	7.96%	Tecolote	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,913
262	3200	Recreation Centers	7.96%	Tecolote	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$6,430
262	3201	Recreation Centers	7.96%	Tecolote	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$6,928
262	3202	Recreation Centers	7.96%	Tecolote	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$7,396
262	3203	Recreation Centers	7.96%	Tecolote	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$10,006
262	3204	Recreation Centers	7.96%	Tecolote	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$10,559
262	3205	Recreation Centers	7.96%	Tecolote	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$18,153
262	3206	Recreation Centers	7.96%	Tecolote	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$45,370
263	3207	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$660
263	3208	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Inadequate	Remove Debris from Roof	\$1,480
263	3209	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$5,502
263	3210	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Water Supply	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Expected Life	Replace Domestic Water Lines; up to 1"; Surf. Mtd.	\$6,833
263	3211	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Powerwash exterior wall	\$1,795
263	3212	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
263	3213	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
263	3214	PB - Park Balboa	7.81%	House Of Pac. Rel. Norway	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
264	3215	Comfort Stations	7.71%	#000561	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
264	3215	Comfort Stations	7.71%	#000561	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,539
264	3216	Comfort Stations	7.71%	#000561	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$1,152
264	3217	Comfort Stations	7.71%	#000561	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
264	3218	Comfort Stations	7.71%	#000561	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
264	3219	Comfort Stations	7.71%	#000561	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$2,752
264	3220	Comfort Stations	7.71%	#000561	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Expected Life	Replace domestic water service	\$3,433
264	3221	Comfort Stations	7.71%	#000561	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$3,899

264	3222	Comfort Stations	7.71%	#000561	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$4,194
264	3223	Comfort Stations	7.71%	#000561	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$5,096
264	3224	Comfort Stations	7.71%	#000561	Electrical Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$5,919
264	3225	Comfort Stations	7.71%	#000561	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Beyond Expected Life	Replace Copper Water Pipe <2 in	\$12,529
264	3226	Comfort Stations	7.71%	#000561	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
265	3227	Comfort Stations	7.50%	#010307	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$4,917
265	3227	Comfort Stations	7.50%	#010307	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
265	3228	Comfort Stations	7.50%	#010307	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$630
265	3229	Comfort Stations	7.50%	#010307	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,359
265	3230	Comfort Stations	7.50%	#010307	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Steel Doors	\$1,397
265	3231	Comfort Stations	7.50%	#010307	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Failing	Repaint wall	\$3,378
265	3232	Comfort Stations	7.50%	#010307	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Water Supply	Failing	Replace domestic water service	\$3,433
265	3233	Comfort Stations	7.50%	#010307	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Failing	Repaint Exterior Block Wall	\$4,390
265	3234	Comfort Stations	7.50%	#010307	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$5,001
266	3235	Comfort Stations	7.43%	#000339	Lighting and Branch Wiring	Critical / Immediate Need	District 2	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
266	3235	Comfort Stations	7.43%	#000339	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,346
266	3236	Comfort Stations	7.43%	#000339	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
266	3237	Comfort Stations	7.43%	#000339	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$5,217
266	3238	Comfort Stations	7.43%	#000339	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$12,425
266	3239	Comfort Stations	7.43%	#000339	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$13,212
266	3240	Comfort Stations	7.43%	#000339	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$14,302
267	3241	PO - Parks / Recreation	7.35%	Serra Museum (L)	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,538
267	3241	PO - Parks / Recreation	7.35%	Serra Museum (L)	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,538
267	3242	PO - Parks / Recreation	7.35%	Serra Museum (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Inadequate	Install or replace GFCI outlets	\$5,120
267	3242	PO - Parks / Recreation	7.35%	Serra Museum (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,470
267	3243	PO - Parks / Recreation	7.35%	Serra Museum (L)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$7,430
267	3243	PO - Parks / Recreation	7.35%	Serra Museum (L)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$6,520
267	3244	PO - Parks / Recreation	7.35%	Serra Museum (L)	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$19,287
267	3244	PO - Parks / Recreation	7.35%	Serra Museum (L)	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$945
267	3245	PO - Parks / Recreation	7.35%	Serra Museum (L)	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$29,980
267	3245	PO - Parks / Recreation	7.35%	Serra Museum (L)	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$443
267	3246	PO - Parks / Recreation	7.35%	Serra Museum (L)	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Patch plaster walls	\$153,064
267	3246	PO - Parks / Recreation	7.35%	Serra Museum (L)	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Patch plaster walls	\$30,613
267	3247	PO - Parks / Recreation	7.35%	Serra Museum (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Other Plumbing Systems	Failing	Replace piping support system	\$13,472
267	3248	PO - Parks / Recreation	7.35%	Serra Museum (L)	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
267	3249	PO - Parks / Recreation	7.35%	Serra Museum (L)	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$4,968
267	3250	PO - Parks / Recreation	7.35%	Serra Museum (L)	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$8,107
267	3251	PO - Parks / Recreation	7.35%	Serra Museum (L)	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$9,217
267	3252	PO - Parks / Recreation	7.35%	Serra Museum (L)	Site Development	Necessary- 2-5 Yrs	District 2	Stairs	Damaged	Paint stairs	\$9,274
267	3253	PO - Parks / Recreation	7.35%	Serra Museum (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$10,504
267	3254	PO - Parks / Recreation	7.35%	Serra Museum (L)	Water Supply	Necessary- 2-5 Yrs	District 2	Water Supply	Beyond Expected Life	Replace domestic water service	\$13,730
267	3255	PO - Parks / Recreation	7.35%	Serra Museum (L)	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$22,015
268	3258	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
268	3258	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Beyond Expected Life	Replace Cabinets and Counters	\$8,556
268	3259	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$660
268	3260	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Failing	Replace Water Heater; Electric; up to 30 Gallons	\$2,395
268	3261	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Missing	Replace exterior door hardware	\$385
268	3262	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
268	3263	PB - Park Balboa	7.33%	House Of Pac. Rel. China	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
269	3264	Recreation Centers	7.31%	Cadman	Exhaust Fans	Potentially Critical-12 months	District 6	Fire Suppression	Missing	Install exterior vent from the flammable storage	\$328
269	3264	Recreation Centers	7.31%	Cadman	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
269	3264	Recreation Centers	7.31%	Cadman	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182

269	3264	Recreation Centers	7.31%	Cadman	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$5,528
269	3264	Recreation Centers	7.31%	Cadman	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Failing	Install or replace kitchen range exhaust hood syst	\$11,577
269	3265	Recreation Centers	7.31%	Cadman	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
269	3265	Recreation Centers	7.31%	Cadman	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
269	3265	Recreation Centers	7.31%	Cadman	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,693
269	3266	Recreation Centers	7.31%	Cadman	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Steel Windows	\$28,209
269	3266	Recreation Centers	7.31%	Cadman	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$1,397
269	3266	Recreation Centers	7.31%	Cadman	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$6,521
269	3267	Recreation Centers	7.31%	Cadman	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,351
269	3267	Recreation Centers	7.31%	Cadman	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$2,427
269	3268	Recreation Centers	7.31%	Cadman	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,098
269	3268	Recreation Centers	7.31%	Cadman	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$9,221
269	3269	Recreation Centers	7.31%	Cadman	Terminal & Package Units	Potentially Critical-12 months	District 6	Heat Generation	Beyond Expected Life	Install or replace heating equip or system	\$7,014
269	3269	Recreation Centers	7.31%	Cadman	Terminal & Package Units	Potentially Critical-12 months	District 6	Ductwork	Failing	Replace ductwork and accessories.	\$10,810
269	3270	Recreation Centers	7.31%	Cadman	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$22,820
269	3270	Recreation Centers	7.31%	Cadman	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$5,517
269	3271	Recreation Centers	7.31%	Cadman	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$6,537
269	3272	Recreation Centers	7.31%	Cadman	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Missing	Repair or replace domestic water piping	\$1,764
269	3273	Recreation Centers	7.31%	Cadman	Roof Coverings	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Wood Fascia	\$2,262
269	3274	Recreation Centers	7.31%	Cadman	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$3,920
269	3275	Recreation Centers	7.31%	Cadman	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$4,272
269	3276	Recreation Centers	7.31%	Cadman	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replace Kitchen Sink 2 Basin	\$4,807
269	3277	Recreation Centers	7.31%	Cadman	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$76,857
270	3278	PB - Park Balboa	7.27%	Redwood Club	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$582
270	3278	PB - Park Balboa	7.27%	Redwood Club	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,715
270	3278	PB - Park Balboa	7.27%	Redwood Club	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$7,458
270	3278	PB - Park Balboa	7.27%	Redwood Club	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$26,044
270	3279	PB - Park Balboa	7.27%	Redwood Club	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
270	3279	PB - Park Balboa	7.27%	Redwood Club	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$22,913
270	3280	PB - Park Balboa	7.27%	Redwood Club	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,747
270	3280	PB - Park Balboa	7.27%	Redwood Club	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$11,594
270	3281	PB - Park Balboa	7.27%	Redwood Club	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$15,329
270	3281	PB - Park Balboa	7.27%	Redwood Club	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$35,435
270	3282	PB - Park Balboa	7.27%	Redwood Club	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$3,715
270	3283	PB - Park Balboa	7.27%	Redwood Club	Site Lighting	Potentially Critical-12 months	District 3	Site Lighting	Missing	Install/Replace site lighting-Lite Pole	\$13,211
270	3284	PB - Park Balboa	7.27%	Redwood Club	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Asphalt Shingle	\$1,233
270	3285	PB - Park Balboa	7.27%	Redwood Club	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$7,309
270	3286	PB - Park Balboa	7.27%	Redwood Club	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$9,372
270	3287	PB - Park Balboa	7.27%	Redwood Club	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$10,410
270	3288	PB - Park Balboa	7.27%	Redwood Club	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$12,375
270	3289	PB - Park Balboa	7.27%	Redwood Club	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$15,313
270	3290	PB - Park Balboa	7.27%	Redwood Club	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$25,285
270	3291	PB - Park Balboa	7.27%	Redwood Club	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$96,139
271	3294	Comfort Stations	7.21%	#900638	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
271	3294	Comfort Stations	7.21%	#900638	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$601
271	3295	Comfort Stations	7.21%	#900638	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Failing	Replace exterior door hardware	\$4,287
271	3295	Comfort Stations	7.21%	#900638	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Beyond Useful Life	Repaint exterior metal doors	\$3,913
271	3301	Comfort Stations	7.21%	#900638	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
271	3303	Comfort Stations	7.21%	#900638	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Beyond Useful Life	Repaint wall	\$3,631
271	3310	Comfort Stations	7.21%	#900638	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Failing	Epoxy floor	\$18,710
272	3296	Comfort Stations	7.21%	#010016	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
272	3297	Comfort Stations	7.21%	#010016	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$742
272	3298	Comfort Stations	7.21%	#010016	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$837
272	3299	Comfort Stations	7.21%	#010016	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,303
272	3300	Comfort Stations	7.21%	#010016	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Beyond Useful Life	Repaint exterior metal doors	\$1,304

272	3302	Comfort Stations	7.21%	#010016	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,882
272	3304	Comfort Stations	7.21%	#010016	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$3,704
272	3306	Comfort Stations	7.21%	#010016	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Failing	Epoxy floor	\$9,295
272	3309	Comfort Stations	7.21%	#010016	Plumbing Fixtures	Necessary- 2-5 Yrs	District 8	Plumbing Fixtures	Failing	Replace Stainless Steel Plumbing Fixtures	\$15,987
273	3292	Recreation Centers	7.21%	Stockton	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,885
273	3292	Recreation Centers	7.21%	Stockton	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$6,214
273	3292	Recreation Centers	7.21%	Stockton	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 1X4 Surface Fluorescent Fixture S.F.	\$27,168
273	3293	Recreation Centers	7.21%	Stockton	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,674
273	3293	Recreation Centers	7.21%	Stockton	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,529
273	3293	Recreation Centers	7.21%	Stockton	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$56,623
273	3305	Recreation Centers	7.21%	Stockton	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$9,222
273	3307	Recreation Centers	7.21%	Stockton	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$9,603
273	3308	Recreation Centers	7.21%	Stockton	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$10,871
273	3311	Recreation Centers	7.21%	Stockton	Communications and Security	Necessary- 2-5 Yrs	District 8	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$39,929
274	3314	Comfort Stations	7.11%	#010001	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
274	3314	Comfort Stations	7.11%	#010001	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
274	3314	Comfort Stations	7.11%	#010001	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$962
274	3315	Comfort Stations	7.11%	#010001	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
274	3315	Comfort Stations	7.11%	#010001	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Restroom Accessories	\$384
274	3318	Comfort Stations	7.11%	#010001	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
274	3319	Comfort Stations	7.11%	#010001	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$1,614
274	3320	Comfort Stations	7.11%	#010001	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$2,388
274	3321	Comfort Stations	7.11%	#010001	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Roof Fascia	\$4,745
274	3322	Comfort Stations	7.11%	#010001	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$5,832
274	3327	Comfort Stations	7.11%	#010001	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Failing	Replace Stainless Steel Plumbing Fixtures	\$7,530
274	3331	Comfort Stations	7.11%	#010001	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$19,343
275	3313	Recreation Centers	7.11%	SouthEast Sports Field	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$3,466
275	3313	Recreation Centers	7.11%	SouthEast Sports Field	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$16,421
275	3313	Recreation Centers	7.11%	SouthEast Sports Field	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,391
275	3313	Recreation Centers	7.11%	SouthEast Sports Field	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,126
275	3316	Recreation Centers	7.11%	SouthEast Sports Field	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,299
275	3316	Recreation Centers	7.11%	SouthEast Sports Field	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
275	3317	Recreation Centers	7.11%	SouthEast Sports Field	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
275	3323	Recreation Centers	7.11%	SouthEast Sports Field	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
275	3324	Recreation Centers	7.11%	SouthEast Sports Field	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$2,748
275	3325	Recreation Centers	7.11%	SouthEast Sports Field	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$4,724
275	3326	Recreation Centers	7.11%	SouthEast Sports Field	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Janitors Sink	\$5,213
275	3328	Recreation Centers	7.11%	SouthEast Sports Field	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$9,552
275	3329	Recreation Centers	7.11%	SouthEast Sports Field	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$9,985
275	3330	Recreation Centers	7.11%	SouthEast Sports Field	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint exterior metal doors	\$12,709
275	3332	Recreation Centers	7.11%	SouthEast Sports Field	Sprinklers	Necessary- 2-5 Yrs	District 4	Fire Supression	Beyond Expected Life	Install or replace wet fire suppression system	\$28,957
275	3333	Recreation Centers	7.11%	SouthEast Sports Field	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$53,716
276	3334	PB - Park Balboa	7.07%	Fire Alarm Building	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$3,284
276	3334	PB - Park Balboa	7.07%	Fire Alarm Building	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Inadequate	Replace air cooled D-X heat pump(s)	\$32,090
276	3334	PB - Park Balboa	7.07%	Fire Alarm Building	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Heat Generation	Abandoned	Remove abandoned Heat Generation equipment/system	\$6,354
276	3335	PB - Park Balboa	7.07%	Fire Alarm Building	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$6,160
276	3335	PB - Park Balboa	7.07%	Fire Alarm Building	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$5,225
276	3336	PB - Park Balboa	7.07%	Fire Alarm Building	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$52,483
276	3336	PB - Park Balboa	7.07%	Fire Alarm Building	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$9,132
276	3337	PB - Park Balboa	7.07%	Fire Alarm Building	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,568
276	3338	PB - Park Balboa	7.07%	Fire Alarm Building	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Patch concrete	\$748
276	3339	PB - Park Balboa	7.07%	Fire Alarm Building	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,226
276	3340	PB - Park Balboa	7.07%	Fire Alarm Building	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Patch plaster walls	\$6,437
276	3341	PB - Park Balboa	7.07%	Fire Alarm Building	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$16,145
276	3342	PB - Park Balboa	7.07%	Fire Alarm Building	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$16,650
277	3343	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Plumbing Fixtures	Potentially Critical-12 months	District 3	Plumbing Fixtures	Damaged	Replace Faucet Set; Chrome;	\$553
277	3343	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670

277	3344	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$537
277	3345	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
277	3346	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$2,889
277	3347	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$2,923
277	3348	PB - Park Balboa	7.00%	House Of Pac. Rel. Denmark	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
278	3349	Swimming Pools	6.95%	Colina Del Sol	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,051
278	3349	Swimming Pools	6.95%	Colina Del Sol	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$2,440
278	3349	Swimming Pools	6.95%	Colina Del Sol	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle 20A 120V ASSY/S.F.	\$28,400
278	3349	Swimming Pools	6.95%	Colina Del Sol	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Site Lighting	Inadequate	Install/Replace HID/HPS 250W exterior wall pack	\$3,435
278	3349	Swimming Pools	6.95%	Colina Del Sol	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$7,034
278	3350	Swimming Pools	6.95%	Colina Del Sol	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$12,130
278	3350	Swimming Pools	6.95%	Colina Del Sol	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,557
278	3350	Swimming Pools	6.95%	Colina Del Sol	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,300
278	3350	Swimming Pools	6.95%	Colina Del Sol	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$35,145
278	3350	Swimming Pools	6.95%	Colina Del Sol	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$3,003
278	3351	Swimming Pools	6.95%	Colina Del Sol	Domestic Water Distribution	Potentially Critical-12 months	District 7	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
278	3351	Swimming Pools	6.95%	Colina Del Sol	Domestic Water Distribution	Necessary- 2-5 Yrs	District 7	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$20,088
278	3352	Swimming Pools	6.95%	Colina Del Sol	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$11,224
278	3352	Swimming Pools	6.95%	Colina Del Sol	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$1,915
278	3353	Swimming Pools	6.95%	Colina Del Sol	Exhaust Fans	Necessary- 2-5 Yrs	District 7	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$5,410
278	3354	Swimming Pools	6.95%	Colina Del Sol	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$7,176
278	3355	Swimming Pools	6.95%	Colina Del Sol	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$13,046
278	3356	Swimming Pools	6.95%	Colina Del Sol	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Wood Doors	\$13,269
278	3357	Swimming Pools	6.95%	Colina Del Sol	Site Development	Necessary- 2-5 Yrs	District 7	Fencing	Damaged	Replace Fabric at Fence	\$13,358
278	3358	Swimming Pools	6.95%	Colina Del Sol	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
278	3359	Swimming Pools	6.95%	Colina Del Sol	Pool Equipment	Necessary- 2-5 Yrs	District 7	Heat Generation	Beyond Useful Life	Replace Gas/Oil Boiler 1600 MBTU	\$20,839
278	3360	Swimming Pools	6.95%	Colina Del Sol	Plumbing Fixtures	Necessary- 2-5 Yrs	District 7	Plumbing Fixtures	Beyond Useful Life	Replace Plumbing Fixtures	\$23,601
278	3361	Swimming Pools	6.95%	Colina Del Sol	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Patch concrete	\$162,301
279	3362	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Inadequate	Install circuit label electric outlets and switches	\$647
279	3363	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Inadequate	Remove Debris from Roof	\$1,450
279	3364	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$1,753
279	3365	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
279	3366	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Failing	Prepare and Paint Ext. Wood Window up to 4' x 4'	\$3,611
279	3367	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$3,860
279	3368	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
279	3369	PB - Park Balboa	6.84%	House Of Pac. Rel. Israel	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
280	3370	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,652
280	3370	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,119
280	3370	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$14,582
280	3370	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard - 200A	\$10,410
280	3371	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Domestic Water Distribution	Critical / Immediate Need	District 3	Domestic Water Distribution	Missing	Replace Domestic Water and Sanitary Piping (SF)	\$52,827
280	3371	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$588
280	3372	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Roof Openings	Potentially Critical-12 months	District 3	Roof Openings	Missing	Replace Roof Access Door (through wall)	\$2,555
280	3373	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Storm Sewer	Potentially Critical-12 months	District 3	Storm Sewer	Failing	Provide technical study of storm drainage system	\$21,849
280	3374	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$27,824
280	3375	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
280	3376	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$9,042
280	3377	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$10,999
280	3378	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Inadequate	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$18,606
280	3379	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$23,149
280	3380	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$31,323
280	3381	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$63,563
280	3382	PB - Park Balboa	6.73%	World Beat, S. Pepper Grove	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Built up Roof	\$189,336
281	3383	Recreation Centers	6.70%	South Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$20,170

281	3383	Recreation Centers	6.70%	South Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
281	3383	Recreation Centers	6.70%	South Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$5,528
281	3383	Recreation Centers	6.70%	South Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
281	3383	Recreation Centers	6.70%	South Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
281	3384	Recreation Centers	6.70%	South Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
281	3384	Recreation Centers	6.70%	South Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$57,307
281	3384	Recreation Centers	6.70%	South Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,808
281	3384	Recreation Centers	6.70%	South Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$9,377
281	3384	Recreation Centers	6.70%	South Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$26,701
281	3385	Recreation Centers	6.70%	South Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$2,400
281	3386	Recreation Centers	6.70%	South Clairemont	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Patch concrete	\$3,180
281	3387	Recreation Centers	6.70%	South Clairemont	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$3,318
281	3388	Recreation Centers	6.70%	South Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$4,190
281	3389	Recreation Centers	6.70%	South Clairemont	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$5,699
281	3390	Recreation Centers	6.70%	South Clairemont	Water Supply	Potentially Critical-12 months	District 6	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730
281	3391	Recreation Centers	6.70%	South Clairemont	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$18,307
281	3392	Recreation Centers	6.70%	South Clairemont	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$22,015
281	3393	Recreation Centers	6.70%	South Clairemont	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Damaged	Replace electrical service entrance	\$22,044
281	3394	Recreation Centers	6.70%	South Clairemont	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replace Plumbing Fixtures	\$22,534
281	3395	Recreation Centers	6.70%	South Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$36,680
281	3396	Recreation Centers	6.70%	South Clairemont	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$66,341
281	3397	Recreation Centers	6.70%	South Clairemont	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$67,426
282	3399	Comfort Stations	6.64%	#001094	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$361
282	3400	Comfort Stations	6.64%	#001094	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$1,397
282	3401	Comfort Stations	6.64%	#001094	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
282	3402	Comfort Stations	6.64%	#001094	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$2,970
282	3403	Comfort Stations	6.64%	#001094	Electrical Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
283	3404	Comfort Stations	6.56%	#000335	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$2,677
283	3404	Comfort Stations	6.56%	#000335	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$5,716
283	3405	Comfort Stations	6.56%	#000335	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
283	3406	Comfort Stations	6.56%	#000335	Water Supply	Potentially Critical-12 months	District 6	Domestic Water Distribution	Beyond Useful Life	Repair or replace domestic water piping	\$3,599
283	3407	Comfort Stations	6.56%	#000335	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$6,625
283	3408	Comfort Stations	6.56%	#000335	Electrical Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$7,709
283	3409	Comfort Stations	6.56%	#000335	Plumbing Fixtures	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$16,255
283	3410	Comfort Stations	6.56%	#000335	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,385
283	3411	Comfort Stations	6.56%	#000335	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$16,119
284	3412	PB - Park Balboa	6.47%	House Of Pac. Rel. Germany	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$431
284	3413	PB - Park Balboa	6.47%	House Of Pac. Rel. Germany	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
284	3414	PB - Park Balboa	6.47%	House Of Pac. Rel. Germany	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
284	3415	PB - Park Balboa	6.47%	House Of Pac. Rel. Germany	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
285	3417	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,758
285	3417	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$41,495
285	3417	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$19,333
285	3417	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$3,739
285	3418	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$10,926
285	3418	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$2,878
285	3425	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$1,676
285	3429	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Termite Inspection of Structure	\$4,924
285	3430	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,013
285	3431	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$5,644
285	3434	PB - Park Balboa	6.43%	Tennis Lounge Concession Bldg.	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$41,747

286	3416	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$13,063
286	3416	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$15,695
286	3416	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture - S.F.	\$236,175
286	3416	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace exit light fixtures	\$1,588
286	3419	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$13,428
286	3419	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,208
286	3420	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$6,635
286	3420	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Overhead Door; Roll-Up; Motorized	\$56,299
286	3421	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$373
286	3422	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Exhaust Fans	Potentially Critical-12 months	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
286	3423	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Terminal & Package Units	Potentially Critical-12 months	District 4	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$15,695
286	3424	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Electrical Service/Distribution	Critical / Immediate Need	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace Medium Voltage Service	\$107,913
286	3426	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$3,227
286	3427	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Damaged	Replace Toilet Partition	\$4,332
286	3428	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$4,400
286	3432	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$6,116
286	3433	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$27,179
286	3435	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$62,881
286	3436	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$106,525
286	3437	OS - Operations Services	6.43%	Prch, Central Store #2,Chollas	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Failing	Replace Intercom/Paging System-50 stations	\$126,904
287	3438	Comfort Stations	6.35%	#010385	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$536
287	3439	Comfort Stations	6.35%	#010385	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$2,175
287	3440	Comfort Stations	6.35%	#010385	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
287	3441	Comfort Stations	6.35%	#010385	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$3,913
288	3442	Comfort Stations	6.32%	#010367	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$519
288	3443	Comfort Stations	6.32%	#010367	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$1,048
288	3444	Comfort Stations	6.32%	#010367	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
288	3445	Comfort Stations	6.32%	#010367	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Beyond Useful Life	Repaint exterior metal doors	\$2,935
289	3446	Recreation Centers	6.29%	Memorial	Lighting and Branch Wiring	Critical / Immediate Need	District 8	Lighting/Branch Wiring	Damaged	Replace exit light fixtures	\$2,664
289	3446	Recreation Centers	6.29%	Memorial	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$12,560
289	3446	Recreation Centers	6.29%	Memorial	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$68,462
289	3446	Recreation Centers	6.29%	Memorial	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Abandoned	Replace 1X4 Surface Flourescent Fixture S.F.	\$27,973
289	3447	Recreation Centers	6.29%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,823
289	3447	Recreation Centers	6.29%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$46,917
289	3447	Recreation Centers	6.29%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$7,818
289	3447	Recreation Centers	6.29%	Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Ceramic Tile	\$104,216
289	3448	Recreation Centers	6.29%	Memorial	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,845
289	3448	Recreation Centers	6.29%	Memorial	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Patch concrete	\$5,016
289	3449	Recreation Centers	6.29%	Memorial	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Wood Trellis	\$10,004
289	3449	Recreation Centers	6.29%	Memorial	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$11,001
289	3450	Recreation Centers	6.29%	Memorial	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Weatherstripping	\$2,096
289	3450	Recreation Centers	6.29%	Memorial	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repaint exterior metal doors	\$19,562
289	3451	Recreation Centers	6.29%	Memorial	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$27,665
289	3451	Recreation Centers	6.29%	Memorial	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$52,346
289	3452	Recreation Centers	6.29%	Memorial	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Ductwork	Damaged	Install ductwork insulation and aces. as req.d	\$2,144
289	3453	Recreation Centers	6.29%	Memorial	Fittings	Necessary- 2-5 Yrs	District 8	Fittings	Damaged	Replace Toilet Partition	\$11,880
289	3454	Recreation Centers	6.29%	Memorial	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$41,621
289	3455	Recreation Centers	6.29%	Memorial	Partitions	Necessary- 2-5 Yrs	District 8	Partitions	Damaged	Replace Drywall Partition/Wood Stud Backup	\$58,231
289	3456	Recreation Centers	6.29%	Memorial	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$218,309
290	3457	Comfort Stations	6.25%	#009991	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$1,024
290	3457	Comfort Stations	6.25%	#009991	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
290	3457	Comfort Stations	6.25%	#009991	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$853
290	3458	Comfort Stations	6.25%	#009991	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
290	3459	Comfort Stations	6.25%	#009991	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Roof Fascia	\$2,588
290	3460	Comfort Stations	6.25%	#009991	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,608
290	3461	Comfort Stations	6.25%	#009991	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$4,934
290	3462	Comfort Stations	6.25%	#009991	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$5,389
290	3463	Comfort Stations	6.25%	#009991	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Beyond Useful Life	Repaint drywall/plaster ceiling	\$6,688

290	3464	Comfort Stations	6.25%	#009991	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$6,944
291	3465	Comfort Stations	6.04%	#001314	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Useful Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
291	3465	Comfort Stations	6.04%	#001314	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$566
291	3466	Comfort Stations	6.04%	#001314	Electrical Service/Distribution	Potentially Critical-12 months	District 7	Electrical Service/Distribution	Damaged	Inspect clean and service main service switdhgear	\$962
291	3467	Comfort Stations	6.04%	#001314	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
291	3468	Comfort Stations	6.04%	#001314	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Steel Doors	\$2,793
291	3469	Comfort Stations	6.04%	#001314	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$3,262
291	3470	Comfort Stations	6.04%	#001314	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Failing	Epoxy floor	\$12,953
292	3471	Recreation Centers	6.02%	Allied Gardens	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
292	3471	Recreation Centers	6.02%	Allied Gardens	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
292	3471	Recreation Centers	6.02%	Allied Gardens	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
292	3471	Recreation Centers	6.02%	Allied Gardens	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$8,470
292	3472	Recreation Centers	6.02%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$598
292	3472	Recreation Centers	6.02%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$28,121
292	3472	Recreation Centers	6.02%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$28,072
292	3472	Recreation Centers	6.02%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$8,995
292	3472	Recreation Centers	6.02%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,713
292	3473	Recreation Centers	6.02%	Allied Gardens	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,373
292	3473	Recreation Centers	6.02%	Allied Gardens	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067
292	3473	Recreation Centers	6.02%	Allied Gardens	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$80,837
292	3473	Recreation Centers	6.02%	Allied Gardens	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$37,664
292	3474	Recreation Centers	6.02%	Allied Gardens	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$1,395
292	3474	Recreation Centers	6.02%	Allied Gardens	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace door hardware	\$4,551
292	3474	Recreation Centers	6.02%	Allied Gardens	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$20,949
292	3475	Recreation Centers	6.02%	Allied Gardens	Domestic Water Distribution	Necessary- 2-5 Yrs	District 7	Domestic Water Distribution	Inadequate	Replace Copper Water Pipe <2 in	\$6,265
292	3475	Recreation Centers	6.02%	Allied Gardens	Domestic Water Distribution	Necessary- 2-5 Yrs	District 7	Sanitary Waste	Missing	Install or replace sink waste valve	\$1,763
292	3476	Recreation Centers	6.02%	Allied Gardens	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$12,792
292	3476	Recreation Centers	6.02%	Allied Gardens	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Replace Wall Panelling	\$13,915
292	3477	Recreation Centers	6.02%	Allied Gardens	Terminal & Package Units	Necessary- 2-5 Yrs	District 7	Terminal and Package Units	Beyond Expected Life	Replace Window Unit < 3T	\$5,990
292	3477	Recreation Centers	6.02%	Allied Gardens	Terminal & Package Units	Necessary- 2-5 Yrs	District 7	Terminal and Package Units	Beyond Expected Life	Replace unit heaters	\$59,020
292	3478	Recreation Centers	6.02%	Allied Gardens	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Glue on Tile	\$76,827
292	3478	Recreation Centers	6.02%	Allied Gardens	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,921
292	3479	Recreation Centers	6.02%	Allied Gardens	Emergency Generator	Potentially Critical-12 months	District 7	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$4,882
292	3480	Recreation Centers	6.02%	Allied Gardens	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$959
292	3481	Recreation Centers	6.02%	Allied Gardens	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,033
292	3482	Recreation Centers	6.02%	Allied Gardens	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$32,170
292	3483	Recreation Centers	6.02%	Allied Gardens	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$33,238
292	3484	Recreation Centers	6.02%	Allied Gardens	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace Aluminium Windows	\$75,081
292	3485	Recreation Centers	6.02%	Allied Gardens	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$121,767
292	3486	Recreation Centers	6.02%	Allied Gardens	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$134,782
293	3487	Comfort Stations	5.97%	#010377	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$787
293	3488	Comfort Stations	5.97%	#010377	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
293	3489	Comfort Stations	5.97%	#010377	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$21,518
294	3490	Comfort Stations	5.94%	#010060	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
294	3490	Comfort Stations	5.94%	#010060	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
294	3490	Comfort Stations	5.94%	#010060	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,079
294	3491	Comfort Stations	5.94%	#010060	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
294	3492	Comfort Stations	5.94%	#010060	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Steel Doors	\$4,190
294	3493	Comfort Stations	5.94%	#010060	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$5,565
294	3494	Comfort Stations	5.94%	#010060	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$6,817
294	3495	Comfort Stations	5.94%	#010060	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$13,070

295	3496	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
295	3496	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Damaged	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
295	3496	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$573
295	3497	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Fittings	Potentially Critical-12 months	District 3	Fittings	Damaged	Replace Base Cabinet Door Hinge	\$452
295	3497	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$2,567
295	3498	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Other HVAC Systems - Kitchen Exhaust Fan	Potentially Critical-12 months	District 3	Ventilation and Exhaust	Inadequate	Replace Kitchen Range Hood; Residentl; Incl. Duct	\$1,372
295	3499	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Failing	Repaint Exterior Wood Doors	\$584
295	3500	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Wall Finishes	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Repaint Handrails	\$684
295	3501	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$7,670
295	3502	PB - Park Balboa	5.84%	House Of Pac. Rel. Poland	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$8,121
296	3503	Community Services Centers	5.79%	College/Rolando	Electrical Service/Distribution	Critical / Immediate Need	District 7	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
296	3503	Community Services Centers	5.79%	College/Rolando	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Inadequate	Replace electrical service entrance	\$3,291
296	3504	Community Services Centers	5.79%	College/Rolando	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Damaged	Install or replace exterior lighting	\$2,338
296	3504	Community Services Centers	5.79%	College/Rolando	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,847
296	3505	Community Services Centers	5.79%	College/Rolando	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$1,299
296	3505	Community Services Centers	5.79%	College/Rolando	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$3,119
296	3506	Community Services Centers	5.79%	College/Rolando	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$959
296	3507	Community Services Centers	5.79%	College/Rolando	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,956
296	3508	Community Services Centers	5.79%	College/Rolando	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
296	3509	Community Services Centers	5.79%	College/Rolando	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace Steel Windows	\$28,209
296	3510	Community Services Centers	5.79%	College/Rolando	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$30,960
297	3511	Recreation Centers	5.77%	North Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
297	3511	Recreation Centers	5.77%	North Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$9,377
297	3511	Recreation Centers	5.77%	North Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,732
297	3511	Recreation Centers	5.77%	North Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$12,136
297	3512	Recreation Centers	5.77%	North Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$5,528
297	3512	Recreation Centers	5.77%	North Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
297	3512	Recreation Centers	5.77%	North Clairemont	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$9,590
297	3513	Recreation Centers	5.77%	North Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$9,618
297	3513	Recreation Centers	5.77%	North Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Refinish wood floor	\$73,854
297	3514	Recreation Centers	5.77%	North Clairemont	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$4,904
297	3515	Recreation Centers	5.77%	North Clairemont	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$699
297	3516	Recreation Centers	5.77%	North Clairemont	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,381
297	3517	Recreation Centers	5.77%	North Clairemont	Domestic Water Distribution	Potentially Critical-12 months	District 6	Sanitary Waste	Missing	Replace Grease Trap, 25 GPM, 50# Cap	\$6,330
297	3518	Recreation Centers	5.77%	North Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$9,471
297	3519	Recreation Centers	5.77%	North Clairemont	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replace Plumbing Fixtures	\$24,316
297	3520	Recreation Centers	5.77%	North Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Heat Generation	Failing	Install or replace heating equip or system	\$67,995
297	3521	Recreation Centers	5.77%	North Clairemont	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$77,480
297	3522	Recreation Centers	5.77%	North Clairemont	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$96,804
297	3523	Recreation Centers	5.77%	North Clairemont	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Steel Windows	\$116,362
298	3524	PB - Park Balboa	5.70%	Veteran's War Memorial	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Ceramic Tile	\$4,923
298	3524	PB - Park Balboa	5.70%	Veteran's War Memorial	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$32,421
298	3524	PB - Park Balboa	5.70%	Veteran's War Memorial	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Wall Panelling	\$11,855
298	3525	PB - Park Balboa	5.70%	Veteran's War Memorial	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$11,472
298	3525	PB - Park Balboa	5.70%	Veteran's War Memorial	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$7,526

298	3526	PB - Park Balboa	5.70%	Veteran's War Memorial	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$23,267
298	3527	PB - Park Balboa	5.70%	Veteran's War Memorial	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$3,074
298	3528	PB - Park Balboa	5.70%	Veteran's War Memorial	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$4,779
298	3529	PB - Park Balboa	5.70%	Veteran's War Memorial	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$28,773
298	3530	PB - Park Balboa	5.70%	Veteran's War Memorial	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$31,755
298	3531	PB - Park Balboa	5.70%	Veteran's War Memorial	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$37,459
298	3532	PB - Park Balboa	5.70%	Veteran's War Memorial	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$46,560
298	3533	PB - Park Balboa	5.70%	Veteran's War Memorial	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$72,700
298	3534	PB - Park Balboa	5.70%	Veteran's War Memorial	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$94,493
298	3535	PB - Park Balboa	5.70%	Veteran's War Memorial	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Repair pavers	\$101,637
298	3536	PB - Park Balboa	5.70%	Veteran's War Memorial	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$113,782
298	3537	PB - Park Balboa	5.70%	Veteran's War Memorial	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$360,523
299	3538	Comfort Stations	5.67%	#010317	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Failing	Replace Restroom Accessories	\$793
299	3538	Comfort Stations	5.67%	#010317	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
299	3539	Comfort Stations	5.67%	#010317	Plumbing Fixtures	Critical / Immediate Need	District 7	Plumbing Fixtures	Failing	Replace Drinking Fountain	\$6,237
299	3540	Comfort Stations	5.67%	#010317	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$304
300	3541	Comfort Stations	5.65%	#000838	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace CMU Block Wall	\$6,627
300	3541	Comfort Stations	5.65%	#000838	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$4,178
300	3542	Comfort Stations	5.65%	#000838	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
300	3542	Comfort Stations	5.65%	#000838	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,552
300	3543	Comfort Stations	5.65%	#000838	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
300	3544	Comfort Stations	5.65%	#000838	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Beyond Useful Life	Repair exterior metal doors	\$2,608
300	3545	Comfort Stations	5.65%	#000838	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,418
300	3546	Comfort Stations	5.65%	#000838	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrica Distribution	Beyond Useful Life	Replace exterior electrical distribution	\$7,302
300	3547	Comfort Stations	5.65%	#000838	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Epoxy floor	\$21,228
300	3548	Comfort Stations	5.65%	#000838	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$13,131
301	3549	Comfort Stations	5.61%	#010376	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$655
301	3550	Comfort Stations	5.61%	#010376	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
302	3552	Comfort Stations	5.57%	#010393	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace Receptacle, 20A 120V ASSY/Ea.	\$3,024
302	3552	Comfort Stations	5.57%	#010393	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$696
302	3553	Comfort Stations	5.57%	#010393	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
303	3554	Comfort Stations	5.52%	#010378	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
303	3554	Comfort Stations	5.52%	#010378	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$408
303	3555	Comfort Stations	5.52%	#010378	Exterior Doors	Critical / Immediate Need	District 2	Exterior Doors	Damaged	Replace exterior door hardware	\$1,429
303	3556	Comfort Stations	5.52%	#010378	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
303	3557	Comfort Stations	5.52%	#010378	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Failing	Repaint wall	\$5,940
304	3558	Recreation Centers	5.38%	North Park Craft & Social Room	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
304	3558	Recreation Centers	5.38%	North Park Craft & Social Room	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,254
304	3558	Recreation Centers	5.38%	North Park Craft & Social Room	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
304	3559	Recreation Centers	5.38%	North Park Craft & Social Room	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
304	3559	Recreation Centers	5.38%	North Park Craft & Social Room	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$16,140
304	3560	Recreation Centers	5.38%	North Park Craft & Social Room	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,300
304	3560	Recreation Centers	5.38%	North Park Craft & Social Room	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$15,013
304	3561	Recreation Centers	5.38%	North Park Craft & Social Room	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$3,277
304	3562	Recreation Centers	5.38%	North Park Craft & Social Room	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$1,352
304	3563	Recreation Centers	5.38%	North Park Craft & Social Room	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$6,083
304	3564	Recreation Centers	5.38%	North Park Craft & Social Room	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$7,172
304	3565	Recreation Centers	5.38%	North Park Craft & Social Room	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$10,483
304	3566	Recreation Centers	5.38%	North Park Craft & Social Room	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$12,598
304	3567	Recreation Centers	5.38%	North Park Craft & Social Room	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$46,228
305	1167	Recreation Centers	5.24%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
305	1167	Recreation Centers	5.24%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
305	3568	Recreation Centers	5.24%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$42,225
305	3568	Recreation Centers	5.24%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$1,401
305	3568	Recreation Centers	5.24%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$6,208

305	3568	Recreation Centers	5.24%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Refinish wood floor	\$74,600
305	3568	Recreation Centers	5.24%	Paradise Hills	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$9,219
305	3569	Recreation Centers	5.24%	Paradise Hills	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,868
305	3569	Recreation Centers	5.24%	Paradise Hills	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
305	3569	Recreation Centers	5.24%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$18,327
305	3569	Recreation Centers	5.24%	Paradise Hills	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$3,423
305	3570	Recreation Centers	5.24%	Paradise Hills	Domestic Water Distribution	Potentially Critical-12 months	District 4	Domestic Water Distribution	Failing	Request Plumbing Consultant	\$3,526
305	3570	Recreation Centers	5.24%	Paradise Hills	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,553
305	3570	Recreation Centers	5.24%	Paradise Hills	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Inadequate	Replace Domestic Water and Sanitary Piping (SF)	\$60,022
305	3571	Recreation Centers	5.24%	Paradise Hills	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Termite Inspection of Structure	\$13,649
305	3571	Recreation Centers	5.24%	Paradise Hills	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$11,417
305	3572	Recreation Centers	5.24%	Paradise Hills	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$12,946
305	3573	Recreation Centers	5.24%	Paradise Hills	Communications and Security	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$16,328
305	3574	Recreation Centers	5.24%	Paradise Hills	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Slurry seal asphalt	\$7,042
305	3575	Recreation Centers	5.24%	Paradise Hills	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$8,116
305	3576	Recreation Centers	5.24%	Paradise Hills	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$12,296
305	3577	Recreation Centers	5.24%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
305	3577	Recreation Centers	5.24%	Paradise Hills	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$14,219
305	3578	Recreation Centers	5.24%	Paradise Hills	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$34,119
305	3579	Recreation Centers	5.24%	Paradise Hills	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Plumbing Fixtures	\$38,013
305	3580	Recreation Centers	5.24%	Paradise Hills	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$48,317
305	3581	Recreation Centers	5.24%	Paradise Hills	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$49,451
305	3582	Recreation Centers	5.24%	Paradise Hills	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$74,620
306	3583	Recreation Centers	5.16%	Golden Hill Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
306	3583	Recreation Centers	5.16%	Golden Hill Recreation Center	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$5,528
306	3583	Recreation Centers	5.16%	Golden Hill Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$22,248
306	3584	Recreation Centers	5.16%	Golden Hill Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,732
306	3584	Recreation Centers	5.16%	Golden Hill Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Install or replace exterior lighting	\$15,870
306	3584	Recreation Centers	5.16%	Golden Hill Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$1,057
306	3585	Recreation Centers	5.16%	Golden Hill Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$2,249
306	3585	Recreation Centers	5.16%	Golden Hill Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$27,813
306	3585	Recreation Centers	5.16%	Golden Hill Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,762
306	3586	Recreation Centers	5.16%	Golden Hill Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$448
306	3586	Recreation Centers	5.16%	Golden Hill Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$70,081
306	3586	Recreation Centers	5.16%	Golden Hill Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$10,574
306	3587	Recreation Centers	5.16%	Golden Hill Recreation Center	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Sanitary Waste	Missing	Replace Grease Trap, 25 GPM, 50# Cap	\$7,474
306	3587	Recreation Centers	5.16%	Golden Hill Recreation Center	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Water Heaters	Failing	Remove and replace domestic water heater, gas	\$3,193
306	3588	Recreation Centers	5.16%	Golden Hill Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$6,009
306	3588	Recreation Centers	5.16%	Golden Hill Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,127
306	3589	Recreation Centers	5.16%	Golden Hill Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$12,569
306	3589	Recreation Centers	5.16%	Golden Hill Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace door hardware	\$3,641
306	3590	Recreation Centers	5.16%	Golden Hill Recreation Center	Other Electrical Systems	Potentially Critical-12 months	District 3	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$3,254
306	3591	Recreation Centers	5.16%	Golden Hill Recreation Center	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Failing	Replace Kitchen Sink 2 Basin	\$2,939
306	3592	Recreation Centers	5.16%	Golden Hill Recreation Center	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$5,324
306	3593	Recreation Centers	5.16%	Golden Hill Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$14,910
306	3594	Recreation Centers	5.16%	Golden Hill Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$16,692
306	3595	Recreation Centers	5.16%	Golden Hill Recreation Center	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$19,452
306	3596	Recreation Centers	5.16%	Golden Hill Recreation Center	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace unit heaters	\$29,511
306	3597	Recreation Centers	5.16%	Golden Hill Recreation Center	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$70,523
306	3598	Recreation Centers	5.16%	Golden Hill Recreation Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$87,135

307	3599	Recreation Centers	5.13%	North Park Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$27,490
307	3599	Recreation Centers	5.13%	North Park Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$6,412
307	3599	Recreation Centers	5.13%	North Park Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$9,478
307	3599	Recreation Centers	5.13%	North Park Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,300
307	3600	Recreation Centers	5.13%	North Park Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,040
307	3600	Recreation Centers	5.13%	North Park Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
307	3601	Recreation Centers	5.13%	North Park Recreation Center	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
307	3601	Recreation Centers	5.13%	North Park Recreation Center	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$24,991
307	3602	Recreation Centers	5.13%	North Park Recreation Center	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$3,277
307	3603	Recreation Centers	5.13%	North Park Recreation Center	Electrical Service/Distribution	Potentially Critical-12 months	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance -200 Amp	\$11,838
307	3604	Recreation Centers	5.13%	North Park Recreation Center	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$2,706
307	3605	Recreation Centers	5.13%	North Park Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$4,676
307	3606	Recreation Centers	5.13%	North Park Recreation Center	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Patch plaster walls	\$7,185
307	3607	Recreation Centers	5.13%	North Park Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$11,437
307	3608	Recreation Centers	5.13%	North Park Recreation Center	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Inadequate	Replace Plumbing Fixtures	\$14,161
307	3609	Recreation Centers	5.13%	North Park Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$15,143
307	3610	Recreation Centers	5.13%	North Park Recreation Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$15,379
307	3611	Recreation Centers	5.13%	North Park Recreation Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$21,144
308	3612	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$10,434
308	3612	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
308	3612	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
308	3612	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$7,023
308	3612	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
308	3613	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$582
308	3613	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$30,592
308	3614	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 100 devices	\$143,155
308	3614	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Missing	Replace or Install Ceiling Smoke Detector	\$10,015
308	3615	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$64,768
308	3615	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$4,053
308	3615	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$32,861
308	3616	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Electrical Service/Distribution	Critical / Immediate Need	District 3	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$1,093
308	3617	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$14,777
308	3617	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$2,591
308	3618	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$1,633
308	3618	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$18,153
308	3619	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$9,530
308	3619	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$86,508
308	3620	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$119,999
308	3620	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$31,400
308	3621	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$8,998
308	3622	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$9,079
308	3623	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$20,943
308	3624	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$26,205
308	3625	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Heating Distribution	Necessary- 2-5 Yrs	District 3	Heat Generation	Failing	Replace Gas/Oil Boiler 584 MBTU	\$35,209
308	3626	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$149,151
308	3627	PB - Park Balboa	5.12%	Admin. Parks, Old Navy Hosp #1	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$540,786
309	3628	Recreation Centers	4.96%	Mira Mesa Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$2,048
309	3628	Recreation Centers	4.96%	Mira Mesa Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,410
309	3628	Recreation Centers	4.96%	Mira Mesa Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace exit light fixtures	\$9,526

309	3629	Recreation Centers	4.96%	Mira Mesa Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
309	3629	Recreation Centers	4.96%	Mira Mesa Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
309	3630	Recreation Centers	4.96%	Mira Mesa Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$10,616
309	3630	Recreation Centers	4.96%	Mira Mesa Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Refinish wood floor	\$31,183
309	3630	Recreation Centers	4.96%	Mira Mesa Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$40,639
309	3631	Recreation Centers	4.96%	Mira Mesa Recreation Center	Domestic Water Distribution	Potentially Critical-12 months	District 5	Water Heaters	Damaged	Remove or replace water heater	\$2,815
309	3631	Recreation Centers	4.96%	Mira Mesa Recreation Center	Domestic Water Distribution	Necessary- 2-5 Yrs	District 5	Sanitary Waste	Missing	Install or replace sink waste valve	\$1,763
309	3632	Recreation Centers	4.96%	Mira Mesa Recreation Center	Terminal & Package Units	Potentially Critical-12 months	District 5	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$794
309	3633	Recreation Centers	4.96%	Mira Mesa Recreation Center	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
309	3634	Recreation Centers	4.96%	Mira Mesa Recreation Center	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$11,721
309	3635	Recreation Centers	4.96%	Mira Mesa Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$12,569
309	3636	Recreation Centers	4.96%	Mira Mesa Recreation Center	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Replace Wood Rafters and Deck	\$14,300
309	3637	Recreation Centers	4.96%	Mira Mesa Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$21,603
309	3638	Recreation Centers	4.96%	Mira Mesa Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$33,007
309	3639	Recreation Centers	4.96%	Mira Mesa Recreation Center	Exterior Windows	Necessary- 2-5 Yrs	District 5	Exterior Windows	Damaged	Replace Steel Windows	\$35,261
309	3640	Recreation Centers	4.96%	Mira Mesa Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Glue on Tile	\$94,081
309	3641	Recreation Centers	4.96%	Mira Mesa Recreation Center	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$115,044
309	3642	Recreation Centers	4.96%	Mira Mesa Recreation Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$136,341
310	3644	Comfort Stations	4.93%	#001238	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$715
310	3644	Comfort Stations	4.93%	#001238	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$3,729
310	3645	Comfort Stations	4.93%	#001238	Roof Coverings	Potentially Critical-12 months	District 3	Roof Covering	Failing	Remove Debris from Roof	\$1,528
310	3646	Comfort Stations	4.93%	#001238	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
310	3647	Comfort Stations	4.93%	#001238	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$2,097
310	3648	Comfort Stations	4.93%	#001238	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,608
310	3649	Comfort Stations	4.93%	#001238	Roof Construction	Necessary- 2-5 Yrs	District 3	Exterior Walls	Failing	Repaint Fascia	\$2,804
311	3650	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
311	3650	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$26,956
311	3650	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
311	3651	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,490
311	3651	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$7,624
311	3651	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Glue on Tile	\$21,314
311	3652	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$2,399
311	3652	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$40,934
311	3652	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$36,823
311	3653	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$7,541
311	3653	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Replace transom	\$608
311	3654	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,501
311	3655	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,362
311	3656	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Beyond Expected Life	Replace Kitchen Sink 2 Basin	\$5,249
311	3657	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$6,868
311	3658	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730
311	3659	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Failing	Replace electric service entrance 400 or 800 Amp	\$14,219
311	3660	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$15,215
311	3661	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace sheet metal flashing	\$17,167
311	3662	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$22,015
311	3663	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$30,689
311	3664	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Steel Windows	\$35,261
311	3665	Recreation Centers	4.92%	Pacific Beach Recreation Cente	Fixed Furnishings	Necessary- 2-5 Yrs	District 2	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$125,843
312	3667	Recreation Centers	4.91%	Standley RC & Handball Ct.	Exhaust Fans	Potentially Critical-12 months	District 1	Fire Supression	Inadequate	Install exterior vent from the flammable storage	\$328
312	3667	Recreation Centers	4.91%	Standley RC & Handball Ct.	Exhaust Fans	Potentially Critical-12 months	District 1	Ventilation and Exhaust	Inadequate	Install or replace exterior louvers	\$12,803
312	3667	Recreation Centers	4.91%	Standley RC & Handball Ct.	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
312	3668	Recreation Centers	4.91%	Standley RC & Handball Ct.	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,175
312	3668	Recreation Centers	4.91%	Standley RC & Handball Ct.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$18,756

312	3668	Recreation Centers	4.91%	Standley RC & Handball Ct.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture - S.F.	\$123,008
312	3668	Recreation Centers	4.91%	Standley RC & Handball Ct.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$57,311
312	3669	Recreation Centers	4.91%	Standley RC & Handball Ct.	Electrical Service/Distribution	Critical / Immediate Need	District 1	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$1,923
312	3669	Recreation Centers	4.91%	Standley RC & Handball Ct.	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$31,012
312	3670	Recreation Centers	4.91%	Standley RC & Handball Ct.	Terminal & Package Units	Potentially Critical-12 months	District 1	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$398
312	3670	Recreation Centers	4.91%	Standley RC & Handball Ct.	Terminal & Package Units	Necessary- 2-5 Yrs	District 1	Heat Generation	Beyond Expected Life	Install or replace heating equip or system	\$17,647
312	3671	Recreation Centers	4.91%	Standley RC & Handball Ct.	Exterior Doors	Potentially Critical-12 months	District 1	Exterior Doors	Damaged	Install or replace exterior hardware	\$5,091
312	3671	Recreation Centers	4.91%	Standley RC & Handball Ct.	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$27,744
312	3672	Recreation Centers	4.91%	Standley RC & Handball Ct.	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Glue on Tile	\$56,397
312	3672	Recreation Centers	4.91%	Standley RC & Handball Ct.	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$10,615
312	3673	Recreation Centers	4.91%	Standley RC & Handball Ct.	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Paint exposed structural steel	\$1,744
312	3674	Recreation Centers	4.91%	Standley RC & Handball Ct.	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$3,882
312	3675	Recreation Centers	4.91%	Standley RC & Handball Ct.	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$11,732
312	3676	Recreation Centers	4.91%	Standley RC & Handball Ct.	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Replace concrete slab	\$12,936
312	3677	Recreation Centers	4.91%	Standley RC & Handball Ct.	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$89,431
312	3678	Recreation Centers	4.91%	Standley RC & Handball Ct.	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$165,652
313	3679	Recreation Centers		Jim Howard Hallá (L) Annex	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$7,947
313	3679	Recreation Centers		Jim Howard Hallá (L) Annex	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$15,544
313	3680	Recreation Centers		Jim Howard Hallá (L) Annex	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,070
313	3681	Recreation Centers		Jim Howard Hallá (L) Annex	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Replace Wall Panelling	\$696
313	3682	Recreation Centers		Jim Howard Hallá (L) Annex	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,676
313	3683	Recreation Centers		Jim Howard Hallá (L) Annex	Roof Coverings	Necessary- 2-5 Yrs	District 2	Roof Covering	Damaged	Replace Clay Tiles	\$4,213
313	3684	Recreation Centers		Jim Howard Hallá (L) Annex	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,412
313	3685	Recreation Centers		Jim Howard Hallá (L) Annex	Site Development	Necessary- 2-5 Yrs	District 2	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$5,953
313	3686	Recreation Centers		Jim Howard Hallá (L) Annex	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$20,731
314	3687	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Exterior Doors	Potentially Critical-12 months	District 7	Exterior Doors	Damaged	Install or replace exterior hardware	\$400
314	3687	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Failing	Repaint exterior metal doors	\$3,913
314	3688	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Floor Finishes	Potentially Critical-12 months	District 7	Floor Finishes	Damaged	Replace resisient base moulding	\$493
314	3689	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,001
314	3690	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,117
314	3691	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Failing	Repaint drywall/plaster ceiling	\$2,131
314	3692	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Exterior Walls	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
314	3693	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$3,882
314	3694	PO - Parks / Recreation	4.82%	Ranger Station Kumeyaay	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$8,883
315	3695	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Fascia	\$7,248
315	3695	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Inspection for Mold	\$2,434
315	3695	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$5,918
315	3696	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$310
315	3697	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$24,812
315	3698	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,831
315	3699	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$5,094
315	3700	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$6,794
315	3701	OS - Operations Services	4.74%	Equip., Acq & Fitting, Chollas	Parking Lots	Necessary- 2-5 Yrs	District 4	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$15,978
316	3702	Comfort Stations	4.73%	#001406	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Missing	Replace exterior door hardware	\$1,429
316	3702	Comfort Stations	4.73%	#001406	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,304
316	3702	Comfort Stations	4.73%	#001406	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$2,095
316	3703	Comfort Stations	4.73%	#001406	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,277
316	3703	Comfort Stations	4.73%	#001406	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace CMU Block Wall	\$1,546
316	3704	Comfort Stations	4.73%	#001406	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$207
316	3704	Comfort Stations	4.73%	#001406	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$818
316	3705	Comfort Stations	4.73%	#001406	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
316	3706	Comfort Stations	4.73%	#001406	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$3,473
316	3707	Comfort Stations	4.73%	#001406	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replaces fixture flush valve	\$7,823
317	3710	Comfort Stations	4.60%	#010077	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$602
317	3712	Comfort Stations	4.60%	#010077	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
317	3713	Comfort Stations	4.60%	#010077	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$4,348
317	3714	Comfort Stations	4.60%	#010077	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Epoxy floor	\$8,845
318	3708	Comfort Stations	4.60%	#009934	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Beyond Expected Life	Install or replace GFCI outlets	\$1,024

318	3708	Comfort Stations	4.60%	#009934	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,346
318	3709	Comfort Stations	4.60%	#009934	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Beyond Expected Life	Replace exterior door hardware	\$1,429
318	3709	Comfort Stations	4.60%	#009934	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Beyond Expected Life	Replace Steel Doors	\$699
318	3711	Comfort Stations	4.60%	#009934	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
318	3715	Comfort Stations	4.60%	#009934	Domestic Water Distribution	Necessary- 2-5 Yrs	District 5	Sanitary Sewer	Beyond Useful Life	Replace sanitary sewer service	\$10,221
318	3716	Comfort Stations	4.60%	#009934	Plumbing Fixtures	Necessary- 2-5 Yrs	District 5	Plumbing Fixtures	Damaged	Replace Stainless Steel Plumbing Fixtures	\$26,083
319	3717	Comfort Stations	4.59%	#000635	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
319	3717	Comfort Stations	4.59%	#000635	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace room signage	\$894
319	3717	Comfort Stations	4.59%	#000635	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace mirrors	\$1,009
319	3718	Comfort Stations	4.59%	#000635	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$949
319	3719	Comfort Stations	4.59%	#000635	Partitions	Necessary- 2-5 Yrs	District 3	Wall Finishes	Failing	Repaint wall	\$7,766
319	3720	Comfort Stations	4.59%	#000635	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$14,797
320	3721	Swimming Pools	4.47%	Kearns Municipal Pool	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$12,330
320	3721	Swimming Pools	4.47%	Kearns Municipal Pool	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Fluorescent Fixture Ea.	\$12,837
320	3721	Swimming Pools	4.47%	Kearns Municipal Pool	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$36,653
320	3722	Swimming Pools	4.47%	Kearns Municipal Pool	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$8,142
320	3722	Swimming Pools	4.47%	Kearns Municipal Pool	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$24,303
320	3723	Swimming Pools	4.47%	Kearns Municipal Pool	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$24,591
320	3723	Swimming Pools	4.47%	Kearns Municipal Pool	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Plaster Ceiling	\$12,441
320	3724	Swimming Pools	4.47%	Kearns Municipal Pool	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$36,743
320	3725	Swimming Pools	4.47%	Kearns Municipal Pool	Site Development	Necessary- 2-5 Yrs	District 3	Fencing	Damaged	Replace Fabric at Fence	\$2,227
320	3726	Swimming Pools	4.47%	Kearns Municipal Pool	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$4,058
320	3727	Swimming Pools	4.47%	Kearns Municipal Pool	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Damaged	Replace 40 Gal Gas Water Heater	\$4,289
320	3728	Swimming Pools	4.47%	Kearns Municipal Pool	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Useful Life	Replace Plumbing Fixtures	\$16,786
320	3729	Swimming Pools	4.47%	Kearns Municipal Pool	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$21,458
320	3730	Swimming Pools	4.47%	Kearns Municipal Pool	Pool Equipment	Necessary- 2-5 Yrs	District 3	Heat Generation	Beyond Useful Life	Install or replace heating equip or system	\$50,936
320	3731	Swimming Pools	4.47%	Kearns Municipal Pool	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Patch concrete	\$318,605
321	3733	Recreation Centers	4.44%	Skyline	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,386
321	3733	Recreation Centers	4.44%	Skyline	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$8,455
321	3734	Recreation Centers	4.44%	Skyline	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
321	3734	Recreation Centers	4.44%	Skyline	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$51,509
321	3735	Recreation Centers	4.44%	Skyline	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,557
321	3735	Recreation Centers	4.44%	Skyline	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$4,598
321	3736	Recreation Centers	4.44%	Skyline	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Glue on Tile	\$24,170
321	3736	Recreation Centers	4.44%	Skyline	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$18,443
321	3737	Recreation Centers	4.44%	Skyline	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$26,345
321	3738	Recreation Centers	4.44%	Skyline	Communications and Security	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$32,657
321	3739	Recreation Centers	4.44%	Skyline	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$4,927
321	3740	Recreation Centers	4.44%	Skyline	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$8,116
321	3741	Recreation Centers	4.44%	Skyline	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$8,769
321	3742	Recreation Centers	4.44%	Skyline	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$13,505
321	3743	Recreation Centers	4.44%	Skyline	Interior Doors	Necessary- 2-5 Yrs	District 4	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$19,062
321	3744	Recreation Centers	4.44%	Skyline	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$24,656
321	3745	Recreation Centers	4.44%	Skyline	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$27,952
321	3746	Recreation Centers	4.44%	Skyline	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$33,053
321	3747	Recreation Centers	4.44%	Skyline	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Steel Windows	\$81,326
322	3749	Recreation Centers	4.42%	San Carlos	Exhaust Fans	Potentially Critical-12 months	District 7	Fire Supression	Missing	Install exterior vent from the flammable storage	\$328
322	3749	Recreation Centers	4.42%	San Carlos	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install or replace Kiln Exhaust System	\$5,335
322	3749	Recreation Centers	4.42%	San Carlos	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
322	3749	Recreation Centers	4.42%	San Carlos	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$8,470
322	3750	Recreation Centers	4.42%	San Carlos	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Damaged	Replace 2X4 Fluorescent Fixture Ea.	\$1,711
322	3750	Recreation Centers	4.42%	San Carlos	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Missing	Install or replace electrical disconnect switch	\$3,015
322	3750	Recreation Centers	4.42%	San Carlos	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,290
322	3750	Recreation Centers	4.42%	San Carlos	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$14,067

322	3750	Recreation Centers	4.42%	San Carlos	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$37,084
322	3751	Recreation Centers	4.42%	San Carlos	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$26,884
322	3751	Recreation Centers	4.42%	San Carlos	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,563
322	3751	Recreation Centers	4.42%	San Carlos	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$690
322	3751	Recreation Centers	4.42%	San Carlos	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$1,679
322	3752	Recreation Centers	4.42%	San Carlos	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$843
322	3752	Recreation Centers	4.42%	San Carlos	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,407
322	3752	Recreation Centers	4.42%	San Carlos	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Glue on Tile	\$76,827
322	3753	Recreation Centers	4.42%	San Carlos	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$4,479
322	3753	Recreation Centers	4.42%	San Carlos	Parking Lots	Necessary- 2-5 Yrs	District 7	Parking Lot	Damaged	Patch cracking parking lot	\$1,646
322	3754	Recreation Centers	4.42%	San Carlos	Other Electrical Sytems	Potentially Critical-12 months	District 7	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$4,882
322	3755	Recreation Centers	4.42%	San Carlos	Pedestrian Paving	Potentially Critical-12 months	District 7	Roadways	Damaged	Repair and fill cracks and spalding.	\$2,866
322	3756	Recreation Centers	4.42%	San Carlos	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$2,400
322	3757	Recreation Centers	4.42%	San Carlos	Roof Openings	Necessary- 2-5 Yrs	District 7	Roof Openings	Damaged	Replace Roof Access Door (through wall)	\$2,813
322	3758	Recreation Centers	4.42%	San Carlos	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$4,843
322	3759	Recreation Centers	4.42%	San Carlos	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$8,923
322	3760	Recreation Centers	4.42%	San Carlos	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$16,881
322	3761	Recreation Centers	4.42%	San Carlos	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$33,238
322	3762	Recreation Centers	4.42%	San Carlos	Exterior Windows	Necessary- 2-5 Yrs	District 7	Exterior Windows	Damaged	Replace Aluminium Windows	\$70,020
322	3763	Recreation Centers	4.42%	San Carlos	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$135,645
323	3764	Comfort Stations	4.41%	#010292	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
323	3764	Comfort Stations	4.41%	#010292	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace exterior door hardware	\$1,429
323	3765	Comfort Stations	4.41%	#010292	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,251
323	3766	Comfort Stations	4.41%	#010292	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
323	3767	Comfort Stations	4.41%	#010292	Plumbing Fixtures	Necessary- 2-5 Yrs	District 1	Plumbing Fixtures	Failing	Replace Drinking Fountain	\$3,119
323	3768	Comfort Stations	4.41%	#010292	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$3,356
323	3769	Comfort Stations	4.41%	#010292	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$6,904
323	3770	Comfort Stations	4.41%	#010292	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Epoxy floor	\$11,394
324	3771	Recreation Centers	4.40%	Silverwing	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,014
324	3771	Recreation Centers	4.40%	Silverwing	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Beyond Expected Life	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$4,971
324	3772	Recreation Centers	4.40%	Silverwing	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$8,445
324	3772	Recreation Centers	4.40%	Silverwing	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,368
324	3773	Recreation Centers	4.40%	Silverwing	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,459
324	3774	Recreation Centers	4.40%	Silverwing	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$2,718
324	3775	Recreation Centers	4.40%	Silverwing	Interior Doors	Necessary- 2-5 Yrs	District 8	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$8,577
324	3776	Recreation Centers	4.40%	Silverwing	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace Residential Gas Furnace 120MBtu	\$11,736
324	3777	Recreation Centers	4.40%	Silverwing	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$13,268
324	3778	Recreation Centers	4.40%	Silverwing	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$17,701
324	3779	Recreation Centers	4.40%	Silverwing	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$19,904
324	3780	Recreation Centers	4.40%	Silverwing	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Steel Windows	\$21,371
324	3781	Recreation Centers	4.40%	Silverwing	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$21,436
325	3782	PB - Park Balboa	4.33%	Museum Of Art (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$109,781
325	3782	PB - Park Balboa	4.33%	Museum Of Art (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$208,196
325	3782	PB - Park Balboa	4.33%	Museum Of Art (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard -400A	\$13,420
325	3782	PB - Park Balboa	4.33%	Museum Of Art (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$48,610
325	3783	PB - Park Balboa	4.33%	Museum Of Art (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$368,666
325	3783	PB - Park Balboa	4.33%	Museum Of Art (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$111,475
325	3783	PB - Park Balboa	4.33%	Museum Of Art (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$237,997
325	3784	PB - Park Balboa	4.33%	Museum Of Art (L)	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,764
325	3784	PB - Park Balboa	4.33%	Museum Of Art (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$544,434
325	3785	PB - Park Balboa	4.33%	Museum Of Art (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$50,818
325	3785	PB - Park Balboa	4.33%	Museum Of Art (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$155,954
325	3786	PB - Park Balboa	4.33%	Museum Of Art (L)	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$148,652
325	3787	PB - Park Balboa	4.33%	Museum Of Art (L)	Sprinklers	Necessary- 2-5 Yrs	District 3	Sprinklers	Beyond Useful Life	Replace Sprinkler Head	\$1,624
325	3788	PB - Park Balboa	4.33%	Museum Of Art (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
325	3789	PB - Park Balboa	4.33%	Museum Of Art (L)	Other Electrical Systems	Necessary- 2-5 Yrs	District 3	Emergency Generators	Beyond Useful Life	Replace 500KW D/Emer Gen Set w/ATS	\$82,214
325	3790	PB - Park Balboa	4.33%	Museum Of Art (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$165,412

325	3791	PB - Park Balboa	4.33%	Museum Of Art (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace Electric Service and Distribution - 2000A	\$676,115
325	3792	PB - Park Balboa	4.33%	Museum Of Art (L)	Cooling Generating Systems	Necessary- 2-5 Yrs	District 3	Ductwork	Damaged	Replace ductwork and accessories.	\$891,327
326	3795	Comfort Stations	4.20%	#010087	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Replace Steel Doors	\$5,041
326	3795	Comfort Stations	4.20%	#010087	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$1,304
326	3800	Comfort Stations	4.20%	#010087	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
326	3801	Comfort Stations	4.20%	#010087	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$5,082
326	3803	Comfort Stations	4.20%	#010087	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Failing	Replace Asphalt Shingle	\$8,763
326	3811	Comfort Stations	4.20%	#010087	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$933
327	3793	Recreation Centers	4.20%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,024
327	3793	Recreation Centers	4.20%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$4,882
327	3793	Recreation Centers	4.20%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,926
327	3793	Recreation Centers	4.20%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$8,441
327	3793	Recreation Centers	4.20%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$41,548
327	3794	Recreation Centers	4.20%	Kearny Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,588
327	3794	Recreation Centers	4.20%	Kearny Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Heat Generation	Beyond Expected Life	Install or replace heating equip or system	\$70,590
327	3796	Recreation Centers	4.20%	Kearny Mesa	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$17,919
327	3796	Recreation Centers	4.20%	Kearny Mesa	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$6,501
327	3797	Recreation Centers	4.20%	Kearny Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,664
327	3797	Recreation Centers	4.20%	Kearny Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$25,692
327	3798	Recreation Centers	4.20%	Kearny Mesa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$8,078
327	3798	Recreation Centers	4.20%	Kearny Mesa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$32,400
327	3799	Recreation Centers	4.20%	Kearny Mesa	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Expected Life	Replace Tankless Type Toilet	\$1,296
327	3802	Recreation Centers	4.20%	Kearny Mesa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$6,704
327	3804	Recreation Centers	4.20%	Kearny Mesa	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$12,863
327	3805	Recreation Centers	4.20%	Kearny Mesa	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$21,167
327	3806	Recreation Centers	4.20%	Kearny Mesa	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$28,340
327	3807	Recreation Centers	4.20%	Kearny Mesa	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$38,900
327	3808	Recreation Centers	4.20%	Kearny Mesa	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$40,435
327	3809	Recreation Centers	4.20%	Kearny Mesa	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$44,654
327	3810	Recreation Centers	4.20%	Kearny Mesa	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$89,260
328	3812	Comfort Stations	4.17%	#010230	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
328	3813	Comfort Stations	4.17%	#010230	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
328	3814	Comfort Stations	4.17%	#010230	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$1,304
328	3815	Comfort Stations	4.17%	#010230	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Rubber Flooring	\$17,367
329	3816	Recreation Centers	4.13%	Presidio Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,538
329	3816	Recreation Centers	4.13%	Presidio Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
329	3816	Recreation Centers	4.13%	Presidio Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$20,170
329	3817	Recreation Centers	4.13%	Presidio Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,024
329	3817	Recreation Centers	4.13%	Presidio Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,646
329	3818	Recreation Centers	4.13%	Presidio Recreation Center	Other Electrical Systems	Potentially Critical-12 months	District 2	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$8,170
329	3819	Recreation Centers	4.13%	Presidio Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$684
329	3820	Recreation Centers	4.13%	Presidio Recreation Center	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, gas	\$3,181
329	3821	Recreation Centers	4.13%	Presidio Recreation Center	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$10,055
329	3822	Recreation Centers	4.13%	Presidio Recreation Center	Exterior Windows	Necessary- 2-5 Yrs	District 2	Exterior Windows	Damaged	Replace Wood Windows	\$11,599
329	3823	Recreation Centers	4.13%	Presidio Recreation Center	Water Supply	Necessary- 2-5 Yrs	District 2	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730
329	3824	Recreation Centers	4.13%	Presidio Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$14,193
329	3825	Recreation Centers	4.13%	Presidio Recreation Center	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
329	3826	Recreation Centers	4.13%	Presidio Recreation Center	Sanitary Sewer	Necessary- 2-5 Yrs	District 2	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$22,015
329	3827	Recreation Centers	4.13%	Presidio Recreation Center	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$23,678
329	3828	Recreation Centers	4.13%	Presidio Recreation Center	Parking Lots	Necessary- 2-5 Yrs	District 2	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$27,121
329	3829	Recreation Centers	4.13%	Presidio Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$42,769
330	3832	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$26,813
330	3832	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$2,791
330	3832	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace Metal Door/Metal Frame	\$4,335

330	3833	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
330	3833	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,448
330	3834	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Replace Toilet Partition	\$9,626
330	3834	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
330	3835	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$2,247
330	3835	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$21,603
330	3836	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Built up Roof	\$119,289
330	3836	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$2,506
330	3837	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Sprinklers	Critical / Immediate Need	District 6	Fire Supression	Inadequate	Install or replace wet fire suppression system	\$577
330	3838	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Domestic Water Distribution	Critical / Immediate Need	District 6	Sanitary Waste	Inadequate	Replace Grease Trap, 25 GPM, 50# Cap	\$7,204
330	3839	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$3,254
330	3840	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$1,165
330	3841	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Wood Fascia	\$2,603
330	3842	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Patch cracking parking lot	\$3,317
330	3843	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,880
330	3844	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$9,099
330	3845	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$11,333
330	3846	Senior Centers	4.06%	Clairemont Friendship Cntr (L)	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Failing	Replace Rooftop Packaged Heat Pump	\$129,852
331	3847	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$44,051
331	3847	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$22,026
331	3847	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$22,026
331	3847	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$22,026
331	3847	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Bathroom Accessories	\$22,026
331	3847	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
331	3848	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,764
331	3848	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace 40 Gal Gas Water Heater	\$3,264
331	3848	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$916,592
331	3849	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$1,228,886
331	3849	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$235,489
331	3849	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$73,995
331	3850	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$2,821
331	3850	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$184,825
331	3851	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Install or replace thermal insulation of ductwork	\$4,830
331	3851	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Terminal and Package Units	Missing	Install or replace DX split ductless system	\$14,708
331	3852	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$9,722
331	3852	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Failing	Replace XMFR Dry Type NEMA-1 112.5KVA or > /EA.	\$29,584
331	3853	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$37,588
331	3853	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$65,778
331	3854	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$328,840
331	3854	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$491,668
331	3855	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$40,332
331	3855	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$806,968
331	3856	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Cooling Generating Systems	Necessary- 2-5 Yrs	District 3	Cooling Generation	Beyond Useful Life	Replace Cooling Tower 300Ton Fbg	\$85,587
331	3856	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Cooling Generating Systems	Necessary- 2-5 Yrs	District 3	Ductwork	Damaged	Replace ductwork and accessories.	\$1,500,610
331	3857	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$54,995
331	3858	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$208,338
331	3859	PB - Park Balboa	4.03%	Casa Del Prado & Theatre (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$242,604
332	3860	PB - Park Balboa	4.01%	Museum Of Man Office	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$25,424
332	3860	PB - Park Balboa	4.01%	Museum Of Man Office	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$10,353
332	3860	PB - Park Balboa	4.01%	Museum Of Man Office	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Rubber Flooring	\$55,440
332	3860	PB - Park Balboa	4.01%	Museum Of Man Office	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$127,959

332	3861	PB - Park Balboa	4.01%	Museum Of Man Office	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Failing	Request Plumbing Consultant	\$4,005
332	3861	PB - Park Balboa	4.01%	Museum Of Man Office	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Heat Generation	Abandoned	Remove abandoned Heat Generation equipment/system	\$12,710
332	3862	PB - Park Balboa	4.01%	Museum Of Man Office	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$18,146
332	3862	PB - Park Balboa	4.01%	Museum Of Man Office	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$24,304
332	3863	PB - Park Balboa	4.01%	Museum Of Man Office	Sprinklers	Critical / Immediate Need	District 3	Fire Supression	Inadequate	Repair or replace sprinkler heads	\$3,442
332	3864	PB - Park Balboa	4.01%	Museum Of Man Office	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$7,446
332	3865	PB - Park Balboa	4.01%	Museum Of Man Office	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Bathroom Accessories	\$621
332	3866	PB - Park Balboa	4.01%	Museum Of Man Office	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Metal Door/Metal Frame	\$2,798
332	3867	PB - Park Balboa	4.01%	Museum Of Man Office	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Damaged	Perform landscaping maintenance	\$5,462
332	3868	PB - Park Balboa	4.01%	Museum Of Man Office	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$5,787
332	3869	PB - Park Balboa	4.01%	Museum Of Man Office	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$16,364
332	3870	PB - Park Balboa	4.01%	Museum Of Man Office	Partitions	Necessary- 2-5 Yrs	District 3	Partitions	Damaged	Repair/Patch Concrete Wall	\$26,293
332	3871	PB - Park Balboa	4.01%	Museum Of Man Office	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$26,466
332	3872	PB - Park Balboa	4.01%	Museum Of Man Office	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$32,163
332	3873	PB - Park Balboa	4.01%	Museum Of Man Office	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$52,162
332	3874	PB - Park Balboa	4.01%	Museum Of Man Office	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$96,546
333	3881	Comfort Stations	3.87%	#009950	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Beyond Useful Life	Repaint wall	\$9,396
333	3881	Comfort Stations	3.87%	#009950	Wall Finishes	Necessary- 2-5 Yrs	District 2	Exterior Walls	Failing	Repaint Exterior Block Wall	\$1,516
333	3891	Comfort Stations	3.87%	#009950	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$866
333	3892	Comfort Stations	3.87%	#009950	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
333	3893	Comfort Stations	3.87%	#009950	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Beyond Useful Life	Re-paint or Re-Stain Concrete	\$5,468
334	3875	Recreation Centers	3.87%	Linda Vista Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,869
334	3875	Recreation Centers	3.87%	Linda Vista Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$2,115
334	3875	Recreation Centers	3.87%	Linda Vista Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$2,115
334	3876	Recreation Centers	3.87%	Linda Vista Recreation Center	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Damaged	Repair or replace sanitary sewer	\$4,496
334	3876	Recreation Centers	3.87%	Linda Vista Recreation Center	Domestic Water Distribution	Potentially Critical-12 months	District 6	Domestic Water Distribution	Failing	Install or replace thermal insulation	\$6,646
334	3877	Recreation Centers	3.87%	Linda Vista Recreation Center	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Fascia	\$2,001
334	3877	Recreation Centers	3.87%	Linda Vista Recreation Center	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$1,792
334	3878	Recreation Centers	3.87%	Linda Vista Recreation Center	Site Development	Potentially Critical-12 months	District 6	Stairs	Damaged	Repaint Handrails	\$1,182
334	3878	Recreation Centers	3.87%	Linda Vista Recreation Center	Site Development	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace CMU Block Wall	\$3,527
334	3879	Recreation Centers	3.87%	Linda Vista Recreation Center	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$7,430
334	3879	Recreation Centers	3.87%	Linda Vista Recreation Center	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Blanket Ceiling Insulation	\$2,157
334	3880	Recreation Centers	3.87%	Linda Vista Recreation Center	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$873
334	3882	Recreation Centers	3.87%	Linda Vista Recreation Center	Communications and Security	Potentially Critical-12 months	District 6	Communications/Security	Missing	Replace or Install Ceiling Smoke Detector	\$1,031
334	3883	Recreation Centers	3.87%	Linda Vista Recreation Center	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$2,240
334	3884	Recreation Centers	3.87%	Linda Vista Recreation Center	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$9,773
334	3885	Recreation Centers	3.87%	Linda Vista Recreation Center	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$13,204
334	3886	Recreation Centers	3.87%	Linda Vista Recreation Center	Water Supply	Potentially Critical-12 months	District 6	WATER Supply	Beyond Expected Life	Replace domestic water service	\$13,730
334	3887	Recreation Centers	3.87%	Linda Vista Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$20,026
334	3888	Recreation Centers	3.87%	Linda Vista Recreation Center	Sanitary Sewer	Potentially Critical-12 months	District 6	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$22,015
334	3889	Recreation Centers	3.87%	Linda Vista Recreation Center	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$36,361
334	3890	Recreation Centers	3.87%	Linda Vista Recreation Center	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Aluminium Windows	\$51,867
335	3895	Senior Centers	3.81%	Mira Mesa Senior Center	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$8,470
335	3895	Senior Centers	3.81%	Mira Mesa Senior Center	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
335	3896	Senior Centers	3.81%	Mira Mesa Senior Center	Exterior Doors	Potentially Critical-12 months	District 5	Exterior Doors	Damaged	Install or replace exterior hardware	\$2,538
335	3896	Senior Centers	3.81%	Mira Mesa Senior Center	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Replace Steel Doors	\$1,676
335	3896	Senior Centers	3.81%	Mira Mesa Senior Center	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Replace Weatherstripping	\$691
335	3897	Senior Centers	3.81%	Mira Mesa Senior Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Ceramic Tile	\$573
335	3897	Senior Centers	3.81%	Mira Mesa Senior Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$32,203
335	3897	Senior Centers	3.81%	Mira Mesa Senior Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$2,807
335	3898	Senior Centers	3.81%	Mira Mesa Senior Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,024
335	3898	Senior Centers	3.81%	Mira Mesa Senior Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,532

335	3899	Senior Centers	3.81%	Mira Mesa Senior Center	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Inadequate	Replace Wood Door/Metal Frame	\$1,395
335	3899	Senior Centers	3.81%	Mira Mesa Senior Center	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$7,541
335	3900	Senior Centers	3.81%	Mira Mesa Senior Center	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$8,108
335	3900	Senior Centers	3.81%	Mira Mesa Senior Center	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Replace Awnings	\$22,690
335	3901	Senior Centers	3.81%	Mira Mesa Senior Center	Site Lighting	Potentially Critical-12 months	District 5	Site Lighting	Missing	Install/Replace site lighting-Lite Pole	\$8,048
335	3902	Senior Centers	3.81%	Mira Mesa Senior Center	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$1,243
335	3903	Senior Centers	3.81%	Mira Mesa Senior Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,765
335	3904	Senior Centers	3.81%	Mira Mesa Senior Center	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Patch cracking parking lot	\$3,046
335	3905	Senior Centers	3.81%	Mira Mesa Senior Center	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$50,485
336	3906	Recreation Centers	3.80%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Terrazzo	\$15,425
336	3906	Recreation Centers	3.80%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$3,645
336	3906	Recreation Centers	3.80%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$5,978
336	3906	Recreation Centers	3.80%	Southcrest	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Refinish wood floor	\$37,598
336	3907	Recreation Centers	3.80%	Southcrest	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Replace Receptacle, 20A 120V ASSY/Ea.	\$931
336	3907	Recreation Centers	3.80%	Southcrest	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 8	Lighting/Branch Wiring	Inadequate	Install or replace exterior lighting	\$6,802
336	3908	Recreation Centers	3.80%	Southcrest	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$22,542
336	3908	Recreation Centers	3.80%	Southcrest	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Glue on Tile	\$7,172
336	3909	Recreation Centers	3.80%	Southcrest	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$19,199
336	3909	Recreation Centers	3.80%	Southcrest	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Termite Inspection of Structure	\$26,486
336	3910	Recreation Centers	3.80%	Southcrest	Electrical Service/Distribution	Critical / Immediate Need	District 8	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
336	3911	Recreation Centers	3.80%	Southcrest	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$24,307
336	3912	Recreation Centers	3.80%	Southcrest	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Wood Doors	\$33,173
336	3913	Recreation Centers	3.80%	Southcrest	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$49,523
336	3914	Recreation Centers	3.80%	Southcrest	Exterior Windows	Necessary- 2-5 Yrs	District 8	Exterior Windows	Damaged	Replace Steel Windows	\$52,676
336	3915	Recreation Centers	3.80%	Southcrest	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$59,179
337	3916	Comfort Stations	3.79%	#010056	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$2,345
337	3916	Comfort Stations	3.79%	#010056	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Damaged	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$2,345
337	3916	Comfort Stations	3.79%	#010056	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,251
337	3917	Comfort Stations	3.79%	#010056	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Replace Steel Doors	\$4,889
337	3917	Comfort Stations	3.79%	#010056	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Replace exterior door hardware	\$1,429
337	3918	Comfort Stations	3.79%	#010056	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
337	3919	Comfort Stations	3.79%	#010056	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,675
337	3920	Comfort Stations	3.79%	#010056	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Failing	Repaint Exterior Block Wall	\$6,186
337	3921	Comfort Stations	3.79%	#010056	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Failing	Repaint wall	\$9,796
338	3922	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Terminal & Package Units	Potentially Critical-12 months	District 8	Terminal and Package Units	Beyond Expected Life	Replace 2900CFM 15HP Heater and Ventilator	\$98,288
338	3922	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$9,285
338	3922	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Beyond Expected Life	Replace 10 T Gas/Elec Package Unit, Roof Mount	\$60,159
338	3922	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Damaged	Replace Ductwork Pkg Sys/Ton	\$15,701
338	3923	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$14,367
338	3923	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,305
338	3924	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$20,832
338	3924	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,690
338	3925	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Asphalt Shingle	\$5,429
338	3925	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Built up Roof	\$33,495
338	3926	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Exhaust Fans	Potentially Critical-12 months	District 8	Ventilation and Exhaust	Failing	Install or replace exterior louvers	\$8,517
338	3927	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$9,285
338	3928	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Rain Water Drainage	Necessary- 2-5 Yrs	District 8	Rain Water Drainage	Damaged	Replace Area Drain and Piping	\$5,076
338	3929	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$9,349
338	3930	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Repaint exterior metal doors	\$21,518
338	3931	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Slurry seal asphalt	\$41,022
338	3932	Recreation Centers	3.78%	Cesar Chavez (Larson Field)	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$80,811
339	3933	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,652
339	3933	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace 2X4 Fluorescent Fixture Ea.	\$3,889
339	3934	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$588
339	3935	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Terminal & Package Units	Potentially Critical-12 months	District 3	Other Electrical Systems	Inadequate	Request Engineering Consultant	\$4,005
339	3936	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916

339	3937	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$4,610
339	3938	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$4,889
339	3939	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$15,729
339	3940	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$24,922
339	3941	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$34,723
339	3942	PB - Park Balboa	3.74%	Cultural De La Raza N. Pepper	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Built up Roof	\$189,336
340	3943	PB - Park Balboa	3.73%	San Diego Auto Museum	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Missing	Install condensation piping	\$146
340	3943	PB - Park Balboa	3.73%	San Diego Auto Museum	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Heat Generation	Failing	Install or replace heating equip or system	\$45,048
340	3943	PB - Park Balboa	3.73%	San Diego Auto Museum	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace air cooled D-X heat pump(s)	\$89,179
340	3943	PB - Park Balboa	3.73%	San Diego Auto Museum	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace air cooled D-X heat pump(s)	\$30,477
340	3944	PB - Park Balboa	3.73%	San Diego Auto Museum	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$21,307
340	3944	PB - Park Balboa	3.73%	San Diego Auto Museum	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$106,861
340	3944	PB - Park Balboa	3.73%	San Diego Auto Museum	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$246,493
340	3944	PB - Park Balboa	3.73%	San Diego Auto Museum	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$35,158
340	3945	PB - Park Balboa	3.73%	San Diego Auto Museum	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$296,172
340	3945	PB - Park Balboa	3.73%	San Diego Auto Museum	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$1,437
340	3945	PB - Park Balboa	3.73%	San Diego Auto Museum	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$107,502
340	3946	PB - Park Balboa	3.73%	San Diego Auto Museum	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$151,361
340	3946	PB - Park Balboa	3.73%	San Diego Auto Museum	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Asphalt Shingle	\$6,878
340	3947	PB - Park Balboa	3.73%	San Diego Auto Museum	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$9,622
340	3948	PB - Park Balboa	3.73%	San Diego Auto Museum	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Plaster Ceiling	\$1,199
340	3949	PB - Park Balboa	3.73%	San Diego Auto Museum	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$27,226
340	3950	PB - Park Balboa	3.73%	San Diego Auto Museum	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Handrails and Ornamental Metal	\$84,396
341	3952	Comfort Stations	3.61%	#009843	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,234
341	3953	Comfort Stations	3.61%	#009843	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
341	3954	Comfort Stations	3.61%	#009843	Exterior Walls	Potentially Critical-12 months	District 6	Ventilation and Exhaust	Failing	Install or replace exterior louvers	\$6,504
341	3955	Comfort Stations	3.61%	#009843	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Failing	Repaint wall	\$8,430
341	3956	Comfort Stations	3.61%	#009843	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$15,734
342	3957	Comfort Stations	3.60%	#010131	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$7,456
342	3957	Comfort Stations	3.60%	#010131	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
342	3958	Comfort Stations	3.60%	#010131	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
342	3959	Comfort Stations	3.60%	#010131	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$2,788
342	3960	Comfort Stations	3.60%	#010131	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$2,935
342	3961	Comfort Stations	3.60%	#010131	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$7,946
343	3965	Recreation Centers	3.54%	Encanto	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,101
343	3965	Recreation Centers	3.54%	Encanto	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$16,328
343	3965	Recreation Centers	3.54%	Encanto	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$9,943
343	3967	Recreation Centers	3.54%	Encanto	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$3,757
343	3967	Recreation Centers	3.54%	Encanto	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$4,918
343	3967	Recreation Centers	3.54%	Encanto	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Refinish wood floor	\$73,108
343	3973	Recreation Centers	3.54%	Encanto	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
343	3976	Recreation Centers	3.54%	Encanto	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Patch concrete	\$2,866
343	3978	Recreation Centers	3.54%	Encanto	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Glue on Tile	\$8,951
343	3979	Recreation Centers	3.54%	Encanto	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$10,399
343	3982	Recreation Centers	3.54%	Encanto	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$28,150
343	3983	Recreation Centers	3.54%	Encanto	Communications and Security	Necessary- 2-5 Yrs	District 4	Communications/Security	Beyond Useful Life	Replace Intercom/Paging System-50 stations	\$41,149
343	3985	Recreation Centers	3.54%	Encanto	Exterior Windows	Necessary- 2-5 Yrs	District 4	Exterior Windows	Damaged	Replace Aluminium Windows	\$65,352
343	3986	Recreation Centers	3.54%	Encanto	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$67,739
344	3963	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$43,701
344	3963	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Damaged	Install or replace thermal insulation on HVAC pipi	\$59,191
344	3963	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Inadequate	Install or replace dehumidification system	\$24,740
344	3963	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Failing	Replace Gas/Electric Pkg. Unit (s)	\$3,110,790

344	3964	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$516
344	3964	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace concrete	\$10,423
344	3964	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$415,358
344	3964	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$91,185
344	3964	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$16,895
344	3966	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$21,431
344	3966	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace door hardware	\$7,658
344	3966	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$21,847
344	3968	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace metal ceiling tile	\$235
344	3968	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$21,983
344	3969	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Sprinklers	Potentially Critical-12 months	District 3	Sprinklers	Inadequate	Unauthorized storage is blocking sprinkler spray<	\$2,185
344	3970	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$2,327
344	3971	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Communications and Security	Potentially Critical-12 months	District 3	Communications/Security	Damaged	Replace Fire Alarm System/ASSY for 100 devices	\$572,621
344	3972	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Site Development	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Repaint Handrails	\$5,765
344	3974	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Stairs	Damaged	Patch stairs	\$2,038
344	3975	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$2,569
344	3977	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Repair or replace laminate	\$4,295
344	3980	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$17,135
344	3981	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$23,202
344	3984	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$65,148
344	3987	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$115,046
344	3988	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$172,689
344	3989	PB - Park Balboa	3.54%	Casa De Balboa Electric Bldg.	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Powerwash exterior wall	\$250,211
345	3990	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$16,080
345	3990	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$23,684
345	3990	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$9,202
345	3990	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$7,668
345	3990	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$5,126
345	3991	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$81,349
345	3991	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$37,680
345	3991	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$5,433
345	3991	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$14,890
345	3992	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Fluorescent Fixture - S.F.	\$115,081
345	3992	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$21,307
345	3992	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$53,619
345	3993	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Electrical Service/Distribution	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$21,851
345	3993	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$22,098
345	3994	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$2,775
345	3994	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,711
345	3995	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$35,616
345	3995	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,805
345	3996	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
345	3997	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Other Electrical Systems	Potentially Critical-12 months	District 3	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$6,502
345	3998	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Sprinklers	Potentially Critical-12 months	District 3	Fire Supression	Beyond Expected Life	Install or replace wet fire suppression system	\$48,174
345	3999	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$12,810
345	4000	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$2,249
345	4001	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$2,721
345	4002	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Roof Openings	Necessary- 2-5 Yrs	District 3	Roof Openings	Damaged	Replace Roof Skylights upto 70 SF	\$4,078
345	4003	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$8,136
345	4004	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Patch plaster walls	\$10,732
345	4005	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$40,059
345	4006	PB - Park Balboa	3.49%	Recital Hall Puppet Theatre	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace 10 T Gas/Elec Package Unit, Roof Mount	\$68,342
346	4007	Recreation Centers	3.38%	Doyle Community	Lighting and Branch Wiring	Critical / Immediate Need	District 1	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
346	4007	Recreation Centers	3.38%	Doyle Community	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$9,040

346	4008	Recreation Centers	3.38%	Doyle Community	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
346	4008	Recreation Centers	3.38%	Doyle Community	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
346	4009	Recreation Centers	3.38%	Doyle Community	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$37,027
346	4009	Recreation Centers	3.38%	Doyle Community	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$72,954
346	4009	Recreation Centers	3.38%	Doyle Community	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Refinish wood floor	\$57,971
346	4010	Recreation Centers	3.38%	Doyle Community	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$6,789
346	4010	Recreation Centers	3.38%	Doyle Community	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Replace door hardware	\$3,641
346	4011	Recreation Centers	3.38%	Doyle Community	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Replace Steel Doors	\$4,190
346	4011	Recreation Centers	3.38%	Doyle Community	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repair exterior metal doors	\$33,884
346	4012	Recreation Centers	3.38%	Doyle Community	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$46,516
346	4012	Recreation Centers	3.38%	Doyle Community	Wall Finishes	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$73,503
346	4013	Recreation Centers	3.38%	Doyle Community	Terminal & Package Units	Potentially Critical-12 months	District 1	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,588
346	4014	Recreation Centers	3.38%	Doyle Community	Other Electrical Systems	Potentially Critical-12 months	District 1	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$4,067
346	4015	Recreation Centers	3.38%	Doyle Community	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 1	Electrical Service/Distribution	Failing	Replace electrical service entrance	\$79,951
346	4016	Recreation Centers	3.38%	Doyle Community	Site Development	Necessary- 2-5 Yrs	District 1	Stairs	Damaged	Paint stairs	\$1,192
346	4017	Recreation Centers	3.38%	Doyle Community	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace Steel Windows	\$2,210
346	4018	Recreation Centers	3.38%	Doyle Community	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
346	4019	Recreation Centers	3.38%	Doyle Community	Roof Openings	Necessary- 2-5 Yrs	District 1	Roof Openings	Damaged	Replace Roof Access Door (through wall)	\$3,804
346	4020	Recreation Centers	3.38%	Doyle Community	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$21,835
347	4022	Senior Centers	3.34%	E. San Diego Adult Center (L)	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$2,594
347	4023	Senior Centers	3.34%	E. San Diego Adult Center (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Wood Fascia	\$6,706
347	4024	Senior Centers	3.34%	E. San Diego Adult Center (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Aluminium Doors	\$6,865
347	4025	Senior Centers	3.34%	E. San Diego Adult Center (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace concrete slab	\$21,451
347	4026	Senior Centers	3.34%	E. San Diego Adult Center (L)	Parking Lots	Necessary- 2-5 Yrs	District 3	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$29,331
348	4027	Comfort Stations	3.22%	#010390	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Damaged	Install or replace GFCI outlets	\$1,024
348	4027	Comfort Stations	3.22%	#010390	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$655
348	4028	Comfort Stations	3.22%	#010390	Exterior Doors	Potentially Critical-12 months	District 2	Exterior Doors	Damaged	Install or replace exterior hardware	\$1,269
348	4028	Comfort Stations	3.22%	#010390	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,868
348	4029	Comfort Stations	3.22%	#010390	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
348	4029	Comfort Stations	3.22%	#010390	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Damaged	Replace Identifying Devices	\$687
349	4030	Recreation Centers	3.16%	Canyonside	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$13,156
349	4030	Recreation Centers	3.16%	Canyonside	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$10,509
349	4030	Recreation Centers	3.16%	Canyonside	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Refinish wood floor	\$50,623
349	4030	Recreation Centers	3.16%	Canyonside	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$22,805
349	4031	Recreation Centers	3.16%	Canyonside	Site Development	Potentially Critical-12 months	District 1	Fencing	Damaged	Replace Rolling Gate Wheels	\$6,844
349	4031	Recreation Centers	3.16%	Canyonside	Site Development	Necessary- 2-5 Yrs	District 1	Fencing	Damaged	Repaint Metal Fence	\$1,627
349	4031	Recreation Centers	3.16%	Canyonside	Site Development	Necessary- 2-5 Yrs	District 1	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$3,545
349	4032	Recreation Centers	3.16%	Canyonside	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$2,048
349	4032	Recreation Centers	3.16%	Canyonside	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$115,772
349	4033	Recreation Centers	3.16%	Canyonside	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace Aluminium Windows	\$3,241
349	4033	Recreation Centers	3.16%	Canyonside	Exterior Windows	Necessary- 2-5 Yrs	District 1	Exterior Windows	Damaged	Replace Steel Windows	\$1,444
349	4034	Recreation Centers	3.16%	Canyonside	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
349	4034	Recreation Centers	3.16%	Canyonside	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Damaged	Replace Toilet Partition	\$4,289
349	4035	Recreation Centers	3.16%	Canyonside	Terminal & Package Units	Potentially Critical-12 months	District 1	Terminal and Package Units	Inadequate	Provide secure access for maint and repair	\$1,923
349	4036	Recreation Centers	3.16%	Canyonside	Electrical Service/Distribution	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
349	4037	Recreation Centers	3.16%	Canyonside	Other Electrical Systems	Potentially Critical-12 months	District 1	Other Electrical Systems	Damaged	Install or replace emergency and/or exit lights	\$13,063
349	4038	Recreation Centers	3.16%	Canyonside	Exhaust Fans	Necessary- 2-5 Yrs	District 1	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$7,657
349	4039	Recreation Centers	3.16%	Canyonside	Communications and Security	Necessary- 2-5 Yrs	District 1	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 50 devices	\$67,298
349	4040	Recreation Centers	3.16%	Canyonside	Pedestrian Paving	Potentially Critical-12 months	District 1	Roadways	Damaged	Repair and fill cracks and spalping.	\$14,480
349	4041	Recreation Centers	3.16%	Canyonside	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Caulk exterior walls	\$1,625
349	4042	Recreation Centers	3.16%	Canyonside	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$3,145
349	4043	Recreation Centers	3.16%	Canyonside	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$8,221
349	4044	Recreation Centers	3.16%	Canyonside	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$28,810

350	4045	Comfort Stations	3.13%	#010058	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
350	4046	Comfort Stations	3.13%	#010058	Exterior Doors	Potentially Critical-12 months	District 2	Exterior Doors	Failing	Repaint exterior metal doors	\$7,825
350	4046	Comfort Stations	3.13%	#010058	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Repaint exterior metal doors	\$978
350	4047	Comfort Stations	3.13%	#010058	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$1,021
350	4048	Comfort Stations	3.13%	#010058	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,058
351	4050	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Other Electric	Potentially Critical-12 months	District 5	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$1,368
351	4050	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Other Electric	Potentially Critical-12 months	District 5	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$4,067
351	4051	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
351	4051	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Exhaust Fans	Potentially Critical-12 months	District 5	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
351	4052	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,213
351	4052	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$108,536
351	4052	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Damaged	Install or replace exterior lighting	\$15,549
351	4053	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Electrical Service/Distribution	Critical / Immediate Need	District 5	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
351	4054	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Site Development	Necessary- 2-5 Yrs	District 5	Stairs	Damaged	Repaint Handrails	\$1,613
351	4054	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Site Development	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Repaint Wood Trellis	\$2,858
351	4055	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Replace Ceramic Tile	\$950
351	4055	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$3,815
351	4056	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Exterior Windows	Necessary- 2-5 Yrs	District 5	Exterior Windows	Damaged	Replace Aluminium Windows	\$1,297
351	4057	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Domestic Water Distribution	Necessary- 2-5 Yrs	District 5	Water Heaters	Beyond Expected Life	Remove and replace domestic water heater, electric	\$3,212
351	4058	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,786
351	4059	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$9,944
351	4060	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$19,148
351	4061	Senior Centers	3.12%	Rancho Bernardo Joslyn Sr. Ctr	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$23,585
352	4062	Comfort Stations	3.07%	#009964	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$553
352	4062	Comfort Stations	3.07%	#009964	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
352	4062	Comfort Stations	3.07%	#009964	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
352	4063	Comfort Stations	3.07%	#009964	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Replace Steel Doors	\$699
352	4063	Comfort Stations	3.07%	#009964	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Replace exterior door hardware	\$1,429
352	4064	Comfort Stations	3.07%	#009964	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Replace Roof Fascia	\$2,434
352	4065	Comfort Stations	3.07%	#009964	Plumbing Fixtures	Necessary- 2-5 Yrs	District 5	Domestic Water Distribution	Beyond Useful Life	Replace Hose Bibb w/Vacuum Breaker	\$165
352	4066	Comfort Stations	3.07%	#009964	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Failing	Repaint Exterior Block Wall	\$748
352	4067	Comfort Stations	3.07%	#009964	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$1,376
352	4068	Comfort Stations	3.07%	#009964	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
353	4069	PB - Park Balboa	3.05%	Organ Pavilion	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
353	4069	PB - Park Balboa	3.05%	Organ Pavilion	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
353	4069	PB - Park Balboa	3.05%	Organ Pavilion	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
353	4069	PB - Park Balboa	3.05%	Organ Pavilion	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
353	4070	PB - Park Balboa	3.05%	Organ Pavilion	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,555
353	4070	PB - Park Balboa	3.05%	Organ Pavilion	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$45,959
353	4071	PB - Park Balboa	3.05%	Organ Pavilion	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$4,429
353	4071	PB - Park Balboa	3.05%	Organ Pavilion	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$8,509
353	4072	PB - Park Balboa	3.05%	Organ Pavilion	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$48,880
353	4072	PB - Park Balboa	3.05%	Organ Pavilion	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$2,484
353	4073	PB - Park Balboa	3.05%	Organ Pavilion	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$2,437
353	4074	PB - Park Balboa	3.05%	Organ Pavilion	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,995
353	4075	PB - Park Balboa	3.05%	Organ Pavilion	Site Development	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Patch plaster walls	\$5,701
353	4076	PB - Park Balboa	3.05%	Organ Pavilion	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,711
353	4077	PB - Park Balboa	3.05%	Organ Pavilion	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$42,612
353	4078	PB - Park Balboa	3.05%	Organ Pavilion	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$120,417
353	4079	PB - Park Balboa	3.05%	Organ Pavilion	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$141,576
354	4080	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$7,238

354	4080	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$21,916
354	4080	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$3,227
354	4081	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$76,068
354	4081	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$13,483
354	4081	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$7,445
354	4082	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$21,851
354	4082	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$13,787
354	4083	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$7,767
354	4083	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Clay Tiles	\$5,469
354	4084	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$12,375
354	4084	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$2,165
354	4085	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Wall Panelling	\$26,296
354	4085	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$4,076
354	4086	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$7,023
354	4087	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$2,249
354	4088	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$6,282
354	4089	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$8,889
354	4090	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$24,466
354	4091	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Wood Windows	\$25,411
354	4092	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Heat Generation	Missing	Install or replace heating equip or system	\$43,815
354	4093	PB - Park Balboa	3.02%	Veteran's Memorial Ctr. & Mus.	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$78,153
355	4094	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Communications/Security	Missing	Replace Duct Smoke Detector	\$19,428
355	4094	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Distribution Systems	Damaged	AHU-Clean and flush coils	\$26,218
355	4094	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Cooling Generation	Failing	Replace W/C Chiller 100T	\$178,399
355	4095	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$7,841
355	4095	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$2,614
355	4096	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Sprinklers	Potentially Critical-12 months	District 3	Sprinklers	Inadequate	Unauthorized storage is blocking sprinkler spray<	\$6,555
355	4096	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Sprinklers	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install or replace the "fire curtain" on the stge.	\$257,038
355	4097	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$4,654
355	4097	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$43,731
355	4098	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Electrical Service/Distribution	Critical / Immediate Need	District 3	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$2,185
355	4099	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace door hardware	\$4,413
355	4099	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$19,990
355	4100	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$68,704
355	4100	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$66,913
355	4101	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Roof Openings	Potentially Critical-12 months	District 3	Roof Openings	Missing	Install or replace smoke vents	\$14,967
355	4102	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$23,436
355	4103	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Missing	Replace or Install Ceiling Smoke Detector	\$10,015
355	4104	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$25,620
355	4105	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$116,500
355	4106	PB - Park Balboa	2.95%	Old Globe Theatre (L)	Plumbing Fixtures	Necessary- 2-5 Yrs	District 3	Plumbing Fixtures	Failing	Replace Plumbing Fixtures	\$165,099
356	4107	Recreation Centers	2.91%	Serra Mesa	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Stucco Wall	\$1,166
356	4107	Recreation Centers	2.91%	Serra Mesa	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Wood Fascia	\$1,788
356	4107	Recreation Centers	2.91%	Serra Mesa	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$16,868
356	4108	Recreation Centers	2.91%	Serra Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$12,587
356	4108	Recreation Centers	2.91%	Serra Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Glue on Tile	\$6,293
356	4108	Recreation Centers	2.91%	Serra Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$16,564
356	4109	Recreation Centers	2.91%	Serra Mesa	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install or replace pressure relief sys and contols	\$10,375
356	4109	Recreation Centers	2.91%	Serra Mesa	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$8,372
356	4109	Recreation Centers	2.91%	Serra Mesa	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$17,366
356	4110	Recreation Centers	2.91%	Serra Mesa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$24,805
356	4110	Recreation Centers	2.91%	Serra Mesa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,063

356	4110	Recreation Centers	2.91%	Serra Mesa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$17,724
356	4111	Recreation Centers	2.91%	Serra Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install or Replace thermal insulation on refrig.	\$913
356	4111	Recreation Centers	2.91%	Serra Mesa	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install or Replace thermal insulation on refrig.	\$3,652
356	4112	Recreation Centers	2.91%	Serra Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,536
356	4112	Recreation Centers	2.91%	Serra Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$9,877
356	4119	Recreation Centers	2.91%	Serra Mesa	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$4,882
356	4120	Recreation Centers	2.91%	Serra Mesa	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Beyond Expected Life	Remove or replace water heater	\$2,259
356	4121	Recreation Centers	2.91%	Serra Mesa	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$3,464
356	4122	Recreation Centers	2.91%	Serra Mesa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$7,820
356	4123	Recreation Centers	2.91%	Serra Mesa	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$19,148
356	4124	Recreation Centers	2.91%	Serra Mesa	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace electrical service entrance	\$24,458
356	4125	Recreation Centers	2.91%	Serra Mesa	Exterior Windows	Potentially Critical-12 months	District 6	Exterior Windows	Damaged	Replace Steel Windows	\$31,026
356	4126	Recreation Centers	2.91%	Serra Mesa	Fixed Furnishings	Potentially Critical-12 months	District 6	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$51,931
357	4113	PB - Park Balboa	2.91%	Museum Of Man (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$20,718
357	4113	PB - Park Balboa	2.91%	Museum Of Man (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$33,466
357	4113	PB - Park Balboa	2.91%	Museum Of Man (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$2,984
357	4114	PB - Park Balboa	2.91%	Museum Of Man (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$139,681
357	4114	PB - Park Balboa	2.91%	Museum Of Man (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$6,347
357	4114	PB - Park Balboa	2.91%	Museum Of Man (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$20,848
357	4115	PB - Park Balboa	2.91%	Museum Of Man (L)	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$36,971
357	4115	PB - Park Balboa	2.91%	Museum Of Man (L)	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$18,613
357	4116	PB - Park Balboa	2.91%	Museum Of Man (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$78,662
357	4116	PB - Park Balboa	2.91%	Museum Of Man (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$208,196
357	4117	PB - Park Balboa	2.91%	Museum Of Man (L)	Partitions	Necessary- 2-5 Yrs	District 3	Partitions	Damaged	Repair/Patch Concrete Wall	\$157,754
357	4117	PB - Park Balboa	2.91%	Museum Of Man (L)	Partitions	Necessary- 2-5 Yrs	District 3	Partitions	Damaged	Repair Drywall Partitions	\$5,878
357	4118	PB - Park Balboa	2.91%	Museum Of Man (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$390,108
357	4118	PB - Park Balboa	2.91%	Museum Of Man (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Heat Generation	Abandoned	Remove abandoned Heat Generation equipment/system	\$12,710
357	4127	PB - Park Balboa	2.91%	Museum Of Man (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$1,083
357	4128	PB - Park Balboa	2.91%	Museum Of Man (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$3,321
357	4129	PB - Park Balboa	2.91%	Museum Of Man (L)	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Damaged	Perform landscaping maintenance	\$5,462
357	4130	PB - Park Balboa	2.91%	Museum Of Man (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$32,786
357	4131	PB - Park Balboa	2.91%	Museum Of Man (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$183,363
357	4132	PB - Park Balboa	2.91%	Museum Of Man (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$248,119
357	4133	PB - Park Balboa	2.91%	Museum Of Man (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Clay Tiles	\$487,535
358	4134	Recreation Centers	2.86%	Azalea Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$1,519
358	4134	Recreation Centers	2.86%	Azalea Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$11,260
358	4134	Recreation Centers	2.86%	Azalea Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$1,840
358	4135	Recreation Centers	2.86%	Azalea Recreation Center	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
358	4135	Recreation Centers	2.86%	Azalea Recreation Center	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$3,234
358	4136	Recreation Centers	2.86%	Azalea Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,116
358	4137	Recreation Centers	2.86%	Azalea Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$1,322
358	4138	Recreation Centers	2.86%	Azalea Recreation Center	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$1,352
358	4139	Recreation Centers	2.86%	Azalea Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,500
358	4140	Recreation Centers	2.86%	Azalea Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$5,669
358	4141	Recreation Centers	2.86%	Azalea Recreation Center	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$9,470
359	4142	Recreation Centers	2.84%	Robb Field Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
359	4142	Recreation Centers	2.84%	Robb Field Recreation Center	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
359	4143	Recreation Centers	2.84%	Robb Field Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,616
359	4143	Recreation Centers	2.84%	Robb Field Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$8,441
359	4143	Recreation Centers	2.84%	Robb Field Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$32,364
359	4144	Recreation Centers	2.84%	Robb Field Recreation Center	Electrical Service/Distribution	Critical / Immediate Need	District 2	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962

359	4144	Recreation Centers	2.84%	Robb Field Recreation Center	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$7,709
359	4145	Recreation Centers	2.84%	Robb Field Recreation Center	Terminal & Package Units	Potentially Critical-12 months	District 2	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$2,308
359	4145	Recreation Centers	2.84%	Robb Field Recreation Center	Terminal & Package Units	Necessary- 2-5 Yrs	District 2	Heat Generation	Failing	Install or replace heating equip or system	\$8,559
359	4146	Recreation Centers	2.84%	Robb Field Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$16,947
359	4146	Recreation Centers	2.84%	Robb Field Recreation Center	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$2,638
359	4147	Recreation Centers	2.84%	Robb Field Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$902
359	4148	Recreation Centers	2.84%	Robb Field Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$1,261
359	4149	Recreation Centers	2.84%	Robb Field Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,489
360	4150	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$3,679
360	4150	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,253
360	4150	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,557
360	4150	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$77,584
360	4150	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$30,027
360	4151	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Damaged	Replace Receptacle Covers or Junction Box Covers	\$621
360	4151	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$14,849
360	4151	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace Branch Panelboard - 200A	\$15,285
360	4151	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$5,134
360	4152	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$10,376
360	4152	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$19,686
360	4153	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$776
360	4154	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Inadequate	Request Engineering Consultant	\$5,289
360	4155	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$769
360	4156	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$9,353
360	4157	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$10,674
360	4158	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$21,458
360	4159	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$28,096
360	4160	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Aluminium Windows	\$58,350
360	4161	Recreation Centers	2.81%	Colina Del Sol Recreation Ctr.	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$78,411
361	4162	Recreation Centers	2.80%	Montgomery-Waller	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$6,254
361	4162	Recreation Centers	2.80%	Montgomery-Waller	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace Carpet	\$15,423
361	4162	Recreation Centers	2.80%	Montgomery-Waller	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$23,928
361	4162	Recreation Centers	2.80%	Montgomery-Waller	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$12,134
361	4162	Recreation Centers	2.80%	Montgomery-Waller	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$2,126
361	4163	Recreation Centers	2.80%	Montgomery-Waller	Terminal & Package Units	Potentially Critical-12 months	District 8	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$10,430
361	4163	Recreation Centers	2.80%	Montgomery-Waller	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Ductwork	Damaged	replace ductwork dampers registers and insulatio	\$4,855
361	4163	Recreation Centers	2.80%	Montgomery-Waller	Terminal & Package Units	Necessary- 2-5 Yrs	District 8	Terminal and Package Units	Failing	Replace unit heaters	\$2,269
361	4164	Recreation Centers	2.80%	Montgomery-Waller	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,430
361	4165	Recreation Centers	2.80%	Montgomery-Waller	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$8,479
361	4166	Recreation Centers	2.80%	Montgomery-Waller	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$29,646
361	4167	Recreation Centers	2.80%	Montgomery-Waller	Ceiling Finishes	Necessary- 2-5 Yrs	District 8	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$45,083
361	4168	Recreation Centers	2.80%	Montgomery-Waller	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Slurry seal asphalt	\$64,447
361	4169	Recreation Centers	2.80%	Montgomery-Waller	Roof Coverings	Necessary- 2-5 Yrs	District 8	Roof Covering	Damaged	Replace Clay Tiles	\$120,366
362	4172	Comfort Stations	2.75%	#010286	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Failing	Replaces fixture flush valve	\$1,304
362	4172	Comfort Stations	2.75%	#010286	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Failing	Secure Recess Valve Box; up to 6" x 6"; Steel	\$577
362	4173	Comfort Stations	2.75%	#010286	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Repaint metal toilet compartment doors	\$1,859
362	4173	Comfort Stations	2.75%	#010286	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
362	4175	Comfort Stations	2.75%	#010286	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Failing	Repair and refinish interior doors - 3-0x7-0	\$838
362	4176	Comfort Stations	2.75%	#010286	Roof Coverings	Potentially Critical-12 months	District 6	Rain Water Drainage	Damaged	Replace Gutter; Aluminum up to 6" x LF	\$2,505
362	4177	Comfort Stations	2.75%	#010286	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace 1X4 Surface Flourescent Fixture S.F.	\$3,850
362	4178	Comfort Stations	2.75%	#010286	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$6,911
362	4179	Comfort Stations	2.75%	#010286	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Failing	Repaint exterior metal doors	\$7,825
363	4170	PB - Park Balboa	2.75%	Municipal Gymnasium	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Ceramic Tile	\$32,559
363	4170	PB - Park Balboa	2.75%	Municipal Gymnasium	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$10,788
363	4170	PB - Park Balboa	2.75%	Municipal Gymnasium	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$5,780
363	4170	PB - Park Balboa	2.75%	Municipal Gymnasium	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$2,559
363	4171	PB - Park Balboa	2.75%	Municipal Gymnasium	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$22,260
363	4171	PB - Park Balboa	2.75%	Municipal Gymnasium	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$30,592

363	4171	PB - Park Balboa	2.75%	Municipal Gymnasium	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$41,639
363	4174	PB - Park Balboa	2.75%	Municipal Gymnasium	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$24,261
363	4174	PB - Park Balboa	2.75%	Municipal Gymnasium	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Replace Ceramic Tile	\$49,228
363	4180	PB - Park Balboa	2.75%	Municipal Gymnasium	Terminal & Package Units	Potentially Critical-12 months	District 3	Terminal and Package Units	Beyond Useful Life	Install or replace DX split ductless system	\$29,415
363	4181	PB - Park Balboa	2.75%	Municipal Gymnasium	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Damaged	Perform landscaping maintenance	\$5,462
363	4182	PB - Park Balboa	2.75%	Municipal Gymnasium	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$7,684
363	4183	PB - Park Balboa	2.75%	Municipal Gymnasium	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$7,810
363	4184	PB - Park Balboa	2.75%	Municipal Gymnasium	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$10,783
363	4185	PB - Park Balboa	2.75%	Municipal Gymnasium	Heat Generating Systems	Necessary- 2-5 Yrs	District 3	Heat Generation	Beyond Useful Life	Replace Gas/Oil Boiler 584 MBTU	\$55,598
363	4186	PB - Park Balboa	2.75%	Municipal Gymnasium	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$123,809
363	4187	PB - Park Balboa	2.75%	Municipal Gymnasium	Cooling Generating Systems	Necessary- 2-5 Yrs	District 3	Cooling Generation	Beyond Useful Life	Replace A/C Recip Chiller 100T	\$152,624
364	4188	Comfort Stations	2.71%	#001461	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$1,512
364	4188	Comfort Stations	2.71%	#001461	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
364	4188	Comfort Stations	2.71%	#001461	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$562
364	4189	Comfort Stations	2.71%	#001461	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
364	4189	Comfort Stations	2.71%	#001461	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Beyond Useful Life	Replace bath accessories electric air hand dryers	\$2,036
364	4190	Comfort Stations	2.71%	#001461	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Termite Inspection of Roof structure	\$386
364	4191	Comfort Stations	2.71%	#001461	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Replace Roof Fascia	\$1,541
364	4192	Comfort Stations	2.71%	#001461	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$5,167
364	4193	Comfort Stations	2.71%	#001461	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$5,868
365	4194	Recreation Centers	2.70%	Penn Athletic Area	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$2,529
365	4194	Recreation Centers	2.70%	Penn Athletic Area	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$2,600
365	4194	Recreation Centers	2.70%	Penn Athletic Area	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$3,378
365	4195	Recreation Centers	2.70%	Penn Athletic Area	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$7,599
365	4195	Recreation Centers	2.70%	Penn Athletic Area	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,960
365	4196	Recreation Centers	2.70%	Penn Athletic Area	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
365	4197	Recreation Centers	2.70%	Penn Athletic Area	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,769
365	4198	Recreation Centers	2.70%	Penn Athletic Area	Communications and Security	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$4,898
365	4199	Recreation Centers	2.70%	Penn Athletic Area	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Failing	Install/Replace site lighting-Lite Pole	\$41,112
365	4200	Recreation Centers	2.70%	Penn Athletic Area	Site Development	Necessary- 2-5 Yrs	District 4	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$1,363
365	4201	Recreation Centers	2.70%	Penn Athletic Area	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Missing	Add/replace fractional HP exhaust fans;incl. duct	\$4,058
365	4202	Recreation Centers	2.70%	Penn Athletic Area	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Failing	Replace Wall Hung Lavatory	\$4,936
365	4203	Recreation Centers	2.70%	Penn Athletic Area	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$10,678
366	4205	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Patch concrete	\$696
366	4205	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Pedestrian Paving	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$8,200
366	4206	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Domestic Water Distribution	Potentially Critical-12 months	District 6	Water Heaters	Inadequate	Install or replace insulation on hot water piping	\$647
366	4207	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Terminal & Package Units	Potentially Critical-12 months	District 6	Terminal and Package Units	Inadequate	Install or replace DX split ductless system	\$3,270
366	4208	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
366	4209	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Repair/Reseal Roof Penetration	\$3,847
366	4210	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Site Development	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Exterior Wood Structures	\$4,467
366	4211	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Install or replace exterior hardware	\$15,306
366	4212	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Failing	Replace electric service entrance 400 or 800 Amp	\$17,548
366	4213	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Exhaust Fans	Potentially Critical-12 months	District 6	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$20,170
366	4214	PO - Parks / Recreation	2.59%	Nature & Visitors Center, Teco	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$28,303
367	4215	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$2,614
367	4215	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$7,023
367	4216	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$57,873
367	4216	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$19,365
367	4216	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$237,710
367	4217	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$22,079
367	4217	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$544
367	4218	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$22,419
367	4219	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$8,024
367	4220	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$9,611
367	4221	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$11,424

367	4222	PB - Park Balboa	2.55%	Old Curio Shop (Old Globe Off)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace Gas/Electric Pkg. Unit (s)	\$80,353
368	4223	Comfort Stations	2.54%	#010048	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
368	4224	Comfort Stations	2.54%	#010048	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,444
368	4225	Comfort Stations	2.54%	#010048	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$4,185
368	4226	Comfort Stations	2.54%	#010048	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$5,777
368	4227	Comfort Stations	2.54%	#010048	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$7,825
369	4228	PB - Park Balboa	2.52%	Aerospace Museum (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$9,792
369	4228	PB - Park Balboa	2.52%	Aerospace Museum (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Terminal and Package Units	Inadequate	Install or replace DX split ductless system	\$56,632
369	4228	PB - Park Balboa	2.52%	Aerospace Museum (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Distribution Systems	Failing	Replace heting hot water dist sys pumps _ pipe	\$323,791
369	4228	PB - Park Balboa	2.52%	Aerospace Museum (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Distribution Systems	Failing	Replace AHU 5000 CFM	\$37,073
369	4228	PB - Park Balboa	2.52%	Aerospace Museum (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Heat Generation	Abandoned	Remove abandoned Heat Generation equipment/system	\$12,710
369	4228	PB - Park Balboa	2.52%	Aerospace Museum (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Heat Generation	Beyond Expected Life	Install or replace heating equip or system	\$54,187
369	4229	PB - Park Balboa	2.52%	Aerospace Museum (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$64,216
369	4229	PB - Park Balboa	2.52%	Aerospace Museum (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$602,552
369	4229	PB - Park Balboa	2.52%	Aerospace Museum (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$195,335
369	4229	PB - Park Balboa	2.52%	Aerospace Museum (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Seal stone floor	\$26,601
369	4230	PB - Park Balboa	2.52%	Aerospace Museum (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Inadequate	Install exterior vent from the flammable storage	\$1,493
369	4230	PB - Park Balboa	2.52%	Aerospace Museum (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$4,425
369	4231	PB - Park Balboa	2.52%	Aerospace Museum (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace acoustical ceiling finish	\$2,097
369	4231	PB - Park Balboa	2.52%	Aerospace Museum (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$33,173
369	4231	PB - Park Balboa	2.52%	Aerospace Museum (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$5,790
369	4232	PB - Park Balboa	2.52%	Aerospace Museum (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
369	4232	PB - Park Balboa	2.52%	Aerospace Museum (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$6,822
369	4233	PB - Park Balboa	2.52%	Aerospace Museum (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$23,705
369	4233	PB - Park Balboa	2.52%	Aerospace Museum (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$18,237
369	4234	PB - Park Balboa	2.52%	Aerospace Museum (L)	Other Electrical Systems	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$69,721
369	4235	PB - Park Balboa	2.52%	Aerospace Museum (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 3	Electrical Service/Distribution	Failing	Replace electrical service entrance	\$96,482
369	4236	PB - Park Balboa	2.52%	Aerospace Museum (L)	Standard Foundations	Necessary- 2-5 Yrs	District 3	Foundations	Damaged	Conduct Engineering Assessment - Foundation	\$15,294
369	4237	PB - Park Balboa	2.52%	Aerospace Museum (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$2,449
369	4238	PB - Park Balboa	2.52%	Aerospace Museum (L)	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$55,964
369	4239	PB - Park Balboa	2.52%	Aerospace Museum (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$81,504
369	4240	PB - Park Balboa	2.52%	Aerospace Museum (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$276,410
369	4241	PB - Park Balboa	2.52%	Aerospace Museum (L)	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 100 devices	\$286,310
370	4242	Swimming Pools	2.50%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
370	4242	Swimming Pools	2.50%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture - S.F.	\$62,690
370	4242	Swimming Pools	2.50%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$7,877
370	4242	Swimming Pools	2.50%	Clairemont	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,167
370	4243	Swimming Pools	2.50%	Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,192
370	4243	Swimming Pools	2.50%	Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Heat Generation	Damaged	Install or replace heating equip or system	\$2,229
370	4243	Swimming Pools	2.50%	Clairemont	Terminal & Package Units	Potentially Critical-12 months	District 6	Heat Generation	Damaged	Install or replace heating equip or system	\$12,962
370	4244	Swimming Pools	2.50%	Clairemont	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Replace Steel Doors	\$2,793
370	4244	Swimming Pools	2.50%	Clairemont	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Install or replace exterior hardware	\$3,204
370	4244	Swimming Pools	2.50%	Clairemont	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,184
370	4247	Swimming Pools	2.50%	Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Replace Stucco Wall	\$1,176
370	4247	Swimming Pools	2.50%	Clairemont	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$6,399
370	4248	Swimming Pools	2.50%	Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Carpet	\$13,551
370	4248	Swimming Pools	2.50%	Clairemont	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$31,363
370	4250	Swimming Pools	2.50%	Clairemont	Domestic Water Distribution	Potentially Critical-12 months	District 6	Other Plumbing Systems	Failing	Replace piping support system	\$7,762
370	4251	Swimming Pools	2.50%	Clairemont	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$859
370	4253	Swimming Pools	2.50%	Clairemont	Fittings	Potentially Critical-12 months	District 6	Fittings	Damaged	Refinish bench	\$2,721
370	4254	Swimming Pools	2.50%	Clairemont	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$3,467
370	4255	Swimming Pools	2.50%	Clairemont	Parking Lots	Potentially Critical-12 months	District 6	Parking Lot	Damaged	Replace Parking Lot - Concrete	\$4,788
370	4256	Swimming Pools	2.50%	Clairemont	Pedestrian Paving	Potentially Critical-12 months	District 6	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,655
370	4257	Swimming Pools	2.50%	Clairemont	Roof Coverings	Potentially Critical-12 months	District 6	Roof Covering	Damaged	Replace wood shingle roof	\$28,350

371	4245	PB - Park Balboa	2.50%	Balboa Park Club	Lighting and Branch Wiring	Critical / Immediate Need	District 3	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$2,352
371	4245	PB - Park Balboa	2.50%	Balboa Park Club	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$26,558
371	4245	PB - Park Balboa	2.50%	Balboa Park Club	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$1,343
371	4246	PB - Park Balboa	2.50%	Balboa Park Club	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$40,802
371	4246	PB - Park Balboa	2.50%	Balboa Park Club	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$13,037
371	4246	PB - Park Balboa	2.50%	Balboa Park Club	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Glue on Tile	\$128,140
371	4249	PB - Park Balboa	2.50%	Balboa Park Club	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Replace Stucco Wall	\$91,344
371	4249	PB - Park Balboa	2.50%	Balboa Park Club	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$27,698
371	4252	PB - Park Balboa	2.50%	Balboa Park Club	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,176
371	4258	PB - Park Balboa	2.50%	Balboa Park Club	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,537
371	4259	PB - Park Balboa	2.50%	Balboa Park Club	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repair wall	\$34,757
371	4260	PB - Park Balboa	2.50%	Balboa Park Club	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$41,201
371	4261	PB - Park Balboa	2.50%	Balboa Park Club	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$116,149
372	4262	Comfort Stations	2.48%	#010025	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Restroom Accessories	\$767
372	4262	Comfort Stations	2.48%	#010025	Fittings	Potentially Critical-12 months	District 6	Fittings	Failing	Replace Facility Number Signage - Cast Aluminum	\$2,567
372	4263	Comfort Stations	2.48%	#010025	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
372	4263	Comfort Stations	2.48%	#010025	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$742
372	4265	Comfort Stations	2.48%	#010025	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Damaged	Replace Roof Fascia	\$2,172
373	4267	Comfort Stations	2.47%	#900696	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Plumbing Fixtures	Failing	Replace Plumbing Fixtures	\$773
373	4267	Comfort Stations	2.47%	#900696	Plumbing Fixtures	Necessary- 2-5 Yrs	District 2	Domestic Water Distribution	Beyond Useful Life	Replace Hose Bibb w/Vacuum Breaker	\$496
373	4268	Comfort Stations	2.47%	#900696	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
373	4268	Comfort Stations	2.47%	#900696	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Beyond Useful Life	Replace Steel Doors	\$669
373	4269	Comfort Stations	2.47%	#900696	Roof Coverings	Potentially Critical-12 months	District 2	Roof Covering	Failing	Replace concrete tile roof	\$11,570
373	4270	Comfort Stations	2.47%	#900696	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$1,495
373	4271	Comfort Stations	2.47%	#900696	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,625
373	4272	Comfort Stations	2.47%	#900696	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
374	4273	Comfort Stations	2.39%	#001462	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Replace Roof Fascia	\$2,496
374	4273	Comfort Stations	2.39%	#001462	Roof Construction	Necessary- 2-5 Yrs	District 5	Roof Construction	Damaged	Termite Inspection of Roof structure	\$1,014
374	4274	Comfort Stations	2.39%	#001462	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
374	4274	Comfort Stations	2.39%	#001462	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,467
374	4275	Comfort Stations	2.39%	#001462	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
374	4276	Comfort Stations	2.39%	#001462	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$19,518
375	4277	Recreation Centers	2.30%	Tierrasanta (Old)	Terminal & Package Units	Potentially Critical-12 months	District 7	Terminal and Package Units	Inadequate	Install condensation piping	\$463
375	4278	Recreation Centers	2.30%	Tierrasanta (Old)	Other Electrical Systems	Potentially Critical-12 months	District 7	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$813
375	4279	Recreation Centers	2.30%	Tierrasanta (Old)	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,438
375	4280	Recreation Centers	2.30%	Tierrasanta (Old)	Exhaust Fans	Potentially Critical-12 months	District 7	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$5,468
375	4281	Recreation Centers	2.30%	Tierrasanta (Old)	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
375	4282	Recreation Centers	2.30%	Tierrasanta (Old)	Pedestrian Paving	Necessary- 2-5 Yrs	District 7	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$3,529
375	4283	Recreation Centers	2.30%	Tierrasanta (Old)	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,353
375	4284	Recreation Centers	2.30%	Tierrasanta (Old)	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$12,630
376	4285	Comfort Stations	2.25%	#010032	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
376	4286	Comfort Stations	2.25%	#010032	Roof Construction	Potentially Critical-12 months	District 6	Roof Construction	Failing	Replace Roof Fascia	\$1,679
376	4287	Comfort Stations	2.25%	#010032	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$1,243
376	4288	Comfort Stations	2.25%	#010032	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repair wall	\$5,397
376	4289	Comfort Stations	2.25%	#010032	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
377	4290	Comfort Stations	2.24%	#009846	Fittings	Necessary- 2-5 Yrs	District 4	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
378	4292	Recreation Centers	2.22%	Martin Luther King	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,386
378	4292	Recreation Centers	2.22%	Martin Luther King	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$8,455
378	4292	Recreation Centers	2.22%	Martin Luther King	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$3,423
378	4292	Recreation Centers	2.22%	Martin Luther King	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Damaged	Install or replace exterior lighting	\$7,014
378	4293	Recreation Centers	2.22%	Martin Luther King	Domestic Water Distribution	Critical / Immediate Need	District 4	Domestic Water Distribution	Failing	Request Plumbing Consultant	\$5,289
378	4293	Recreation Centers	2.22%	Martin Luther King	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
378	4294	Recreation Centers	2.22%	Martin Luther King	Exterior Walls	Necessary- 2-5 Yrs	District 4	Landscaping	Failing	Re-grade Site	\$105,149
378	4294	Recreation Centers	2.22%	Martin Luther King	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$12,559
378	4295	Recreation Centers	2.22%	Martin Luther King	Communications and Security	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$16,328
378	4296	Recreation Centers	2.22%	Martin Luther King	Plumbing Fixtures	Necessary- 2-5 Yrs	District 4	Plumbing Fixtures	Beyond Useful Life	Replace Drinking Fountain	\$6,237

378	4297	Recreation Centers	2.22%	Martin Luther King	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$27,267
378	4298	Recreation Centers	2.22%	Martin Luther King	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 4	Electrical Service/Distribution	Beyond Useful Life	Replace electric service entrance 400 or 800 Amp	\$28,860
378	4299	Recreation Centers	2.22%	Martin Luther King	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$32,787
378	4300	Recreation Centers	2.22%	Martin Luther King	Wall Finishes	Necessary- 2-5 Yrs	District 4	Wall Finishes	Damaged	Repaint wall	\$44,991
378	4301	Recreation Centers	2.22%	Martin Luther King	Fixed Furnishings	Necessary- 2-5 Yrs	District 4	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$45,965
379	4302	Senior Centers	2.19%	Soledad Club (L)	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
379	4302	Senior Centers	2.19%	Soledad Club (L)	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$9,590
379	4302	Senior Centers	2.19%	Soledad Club (L)	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$3,895
379	4302	Senior Centers	2.19%	Soledad Club (L)	Exhaust Fans	Potentially Critical-12 months	District 2	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$6,182
379	4303	Senior Centers	2.19%	Soledad Club (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$1,024
379	4303	Senior Centers	2.19%	Soledad Club (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,097
379	4303	Senior Centers	2.19%	Soledad Club (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle 20A 120V ASSY/S.F.	\$56,772
379	4303	Senior Centers	2.19%	Soledad Club (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$7,034
379	4304	Senior Centers	2.19%	Soledad Club (L)	Exterior Doors	Potentially Critical-12 months	District 2	Exterior Doors	Damaged	Install or replace exterior hardware	\$11,114
379	4304	Senior Centers	2.19%	Soledad Club (L)	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Steel Doors	\$3,934
379	4305	Senior Centers	2.19%	Soledad Club (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$8,620
379	4305	Senior Centers	2.19%	Soledad Club (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,501
379	4306	Senior Centers	2.19%	Soledad Club (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Epoxy floor	\$13,643
379	4306	Senior Centers	2.19%	Soledad Club (L)	Pedestrian Paving	Necessary- 2-5 Yrs	District 2	Pedestrian Paving	Damaged	Patch concrete	\$4,240
379	4307	Senior Centers	2.19%	Soledad Club (L)	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace Carpet	\$19,409
379	4307	Senior Centers	2.19%	Soledad Club (L)	Floor Finishes	Necessary- 2-5 Yrs	District 2	Floor Finishes	Damaged	Replace VCT	\$6,099
379	4308	Senior Centers	2.19%	Soledad Club (L)	Other Electrical Systems	Potentially Critical-12 months	District 2	Other Electrical Systems	Inadequate	Install or replace emergency and/or exit lights	\$2,458
379	4309	Senior Centers	2.19%	Soledad Club (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 2	Sanitary Waste	Missing	Replace Grease Trap, 25 GPM, 50# Cap	\$7,474
379	4310	Senior Centers	2.19%	Soledad Club (L)	Interior Doors	Necessary- 2-5 Yrs	District 2	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$838
379	4311	Senior Centers	2.19%	Soledad Club (L)	Site Development	Necessary- 2-5 Yrs	District 2	Stairs	Damaged	Paint stairs	\$1,113
379	4312	Senior Centers	2.19%	Soledad Club (L)	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 2	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance -200 Amp	\$5,919
379	4313	Senior Centers	2.19%	Soledad Club (L)	Exterior Walls	Necessary- 2-5 Yrs	District 2	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$6,242
380	4314	Comfort Stations	2.06%	#010300	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
380	4315	Comfort Stations	2.06%	#010300	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$585
380	4316	Comfort Stations	2.06%	#010300	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$2,608
381	4317	Senior Centers	2.04%	Neighborhood House	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
381	4317	Senior Centers	2.04%	Neighborhood House	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Beyond Useful Life	Replace 30 Gal Gas Water Heater	\$2,804
381	4318	Senior Centers	2.04%	Neighborhood House	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$6,025
381	4319	Senior Centers	2.04%	Neighborhood House	Site Lighting	Potentially Critical-12 months	District 4	Site Lighting	Inadequate	Install/Replace site lighting-Lite Pole	\$26,800
381	4320	Senior Centers	2.04%	Neighborhood House	Roof Coverings	Necessary- 2-5 Yrs	District 4	Roof Covering	Damaged	Repaint Downspouts	\$1,359
381	4321	Senior Centers	2.04%	Neighborhood House	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$2,923
381	4322	Senior Centers	2.04%	Neighborhood House	Exterior Walls	Necessary- 2-5 Yrs	District 4	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$8,479
381	4323	Senior Centers	2.04%	Neighborhood House	Exhaust Fans	Necessary- 2-5 Yrs	District 4	Ventilation and Exhaust	Inadequate	Add/replace fractional HP exhaust fans;incl. duct	\$13,528
381	4324	Senior Centers	2.04%	Neighborhood House	Terminal & Package Units	Necessary- 2-5 Yrs	District 4	Terminal and Package Units	Beyond Useful Life	Replace 5T Gas/Elec Pkg Unit, Roof Mount	\$65,512
382	4325	Recreation Centers	1.95%	City Heights/Urban Village	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$657
382	4325	Recreation Centers	1.95%	City Heights/Urban Village	Exhaust Fans	Necessary- 2-5 Yrs	District 3	Exhaust Ventilation System	Missing	Install or replace Kiln Exhaust System	\$11,057
382	4325	Recreation Centers	1.95%	City Heights/Urban Village	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$20,170
382	4326	Recreation Centers	1.95%	City Heights/Urban Village	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,837
382	4326	Recreation Centers	1.95%	City Heights/Urban Village	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$7,139
382	4326	Recreation Centers	1.95%	City Heights/Urban Village	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$17,660
382	4326	Recreation Centers	1.95%	City Heights/Urban Village	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Epoxy floor	\$29,445
382	4327	Recreation Centers	1.95%	City Heights/Urban Village	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Clay Tiles	\$522
382	4327	Recreation Centers	1.95%	City Heights/Urban Village	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Repair/Reseal Roof Penetration	\$945
382	4328	Recreation Centers	1.95%	City Heights/Urban Village	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$3,677
382	4328	Recreation Centers	1.95%	City Heights/Urban Village	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$11,129

382	4329	Recreation Centers	1.95%	City Heights/Urban Village	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$1,923
382	4330	Recreation Centers	1.95%	City Heights/Urban Village	Storm Sewer	Necessary- 2-5 Yrs	District 3	Rain Water Drainage	Inadequate	Replace Area Drain and Piping	\$4,491
382	4331	Recreation Centers	1.95%	City Heights/Urban Village	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Sanitary Waste	Missing	Replace Grease Trap, 25 GPM, 50# Cap	\$7,474
382	4332	Recreation Centers	1.95%	City Heights/Urban Village	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$539
382	4333	Recreation Centers	1.95%	City Heights/Urban Village	Roof Openings	Necessary- 2-5 Yrs	District 3	Roof Openings	Damaged	Replace Roof Access Door (through wall)	\$2,813
382	4334	Recreation Centers	1.95%	City Heights/Urban Village	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$3,618
382	4335	Recreation Centers	1.95%	City Heights/Urban Village	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$5,048
382	4336	Recreation Centers	1.95%	City Heights/Urban Village	Pedestrian Paving	Necessary- 2-5 Yrs	District 3	Pedestrian Paving	Damaged	Patch concrete	\$5,301
382	4337	Recreation Centers	1.95%	City Heights/Urban Village	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$11,732
383	4338	Comfort Stations	1.94%	#009948	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Replace exterior door hardware	\$1,429
383	4338	Comfort Stations	1.94%	#009948	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Replace Steel Doors	\$699
383	4338	Comfort Stations	1.94%	#009948	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$780
383	4339	Comfort Stations	1.94%	#009948	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$730
383	4340	Comfort Stations	1.94%	#009948	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
383	4341	Comfort Stations	1.94%	#009948	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$3,074
384	4342	PB - Park Balboa	1.86%	Lowell Davies Theater (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,932
384	4342	PB - Park Balboa	1.86%	Lowell Davies Theater (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$3,889
384	4343	PB - Park Balboa	1.86%	Lowell Davies Theater (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
384	4344	PB - Park Balboa	1.86%	Lowell Davies Theater (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$3,309
384	4345	PB - Park Balboa	1.86%	Lowell Davies Theater (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Asphalt Shingle	\$35,382
384	4346	PB - Park Balboa	1.86%	Lowell Davies Theater (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$52,084
385	4347	Recreation Centers	1.78%	Cabrillo Recreation Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,923
385	4347	Recreation Centers	1.78%	Cabrillo Recreation Center	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$5,134
385	4348	Recreation Centers	1.78%	Cabrillo Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,394
385	4348	Recreation Centers	1.78%	Cabrillo Recreation Center	Ceiling Finishes	Necessary- 2-5 Yrs	District 2	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,444
385	4349	Recreation Centers	1.78%	Cabrillo Recreation Center	Domestic Water Distribution	Potentially Critical-12 months	District 2	Water Heaters	Missing	Install or replace insulation on hot water piping	\$518
385	4350	Recreation Centers	1.78%	Cabrillo Recreation Center	Wall Finishes	Necessary- 2-5 Yrs	District 2	Wall Finishes	Damaged	Repaint wall	\$5,824
385	4351	Recreation Centers	1.78%	Cabrillo Recreation Center	Exterior Doors	Necessary- 2-5 Yrs	District 2	Exterior Doors	Damaged	Replace Wood Doors	\$6,635
386	4352	Swimming Pools	1.77%	Kearny Mesa	Plumbing Fixtures	Potentially Critical-12 months	District 6	Water Heaters	Failing	Remove and replace domestic water heater, gas	\$16,398
386	4352	Swimming Pools	1.77%	Kearny Mesa	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$5,985
386	4352	Swimming Pools	1.77%	Kearny Mesa	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Beyond Expected Life	Replace Plumbing Fixtures	\$4,512
386	4353	Swimming Pools	1.77%	Kearny Mesa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$392
386	4353	Swimming Pools	1.77%	Kearny Mesa	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$3,351
386	4354	Swimming Pools	1.77%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,051
386	4354	Swimming Pools	1.77%	Kearny Mesa	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Beyond Expected Life	Replace 2X4 Flourescent Fixture - S.F.	\$39,679
386	4355	Swimming Pools	1.77%	Kearny Mesa	Ceiling Finishes	Potentially Critical-12 months	District 6	Ceiling Finishes	Damaged	Replace Plaster Ceiling	\$919
386	4356	Swimming Pools	1.77%	Kearny Mesa	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Replace Wall Panelling	\$2,305
386	4357	Swimming Pools	1.77%	Kearny Mesa	Fittings	Potentially Critical-12 months	District 6	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
386	4358	Swimming Pools	1.77%	Kearny Mesa	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$2,748
386	4359	Swimming Pools	1.77%	Kearny Mesa	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,479
386	4360	Swimming Pools	1.77%	Kearny Mesa	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Epoxy floor	\$10,795
386	4361	Swimming Pools	1.77%	Kearny Mesa	Electrical Service/Distribution	Potentially Critical-12 months	District 6	Electrical Service/Distribution	Beyond Expected Life	Replace electric service entrance 400 or 800 Amp	\$14,219
387	4362	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Domestic Water Distribution	Potentially Critical-12 months	District 3	Sanitary Waste	Missing	Install proper drain control for 3 tube kit. sink	\$6,492
387	4362	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Domestic Water Distribution	Potentially Critical-12 months	District 3	Sanitary Waste	Missing	Install proper drain control for 3 tube kit. sink	\$6,492
387	4363	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install new exhaust system and controls	\$4,425
387	4363	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Inadequate	Install new exhaust system and controls	\$9,211
387	4364	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace acoustical ceiling finish	\$1,497
387	4364	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$362
387	4365	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$1,361
387	4365	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Fixed Furnishings	Necessary- 2-5 Yrs	District 3	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$15,544
387	4366	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$42,172
387	4366	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Facility Number Signage - Cast Aluminum	\$12,029
387	4367	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$9,295
387	4367	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$69,373
387	4368	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$27,165
387	4369	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$441
387	4370	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Repaint exterior metal doors	\$5,013

387	4371	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$9,541
387	4372	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Water Supply	Necessary- 2-5 Yrs	District 3	Water Supply	Beyond Expected Life	Replace domestic water service	\$15,598
387	4373	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$16,183
387	4374	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$20,085
387	4375	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Sanitary Sewer	Necessary- 2-5 Yrs	District 3	Sanitary Sewer	Beyond Expected Life	Replace sanitary sewer service	\$25,010
387	4376	PB - Park Balboa	1.65%	Hall Of Champions, Gymnasium	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$59,473
388	4378	Comfort Stations	1.63%	#010369	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Failing	Replace Receptacle, 20A 120V ASSY/Ea.	\$3,024
388	4378	Comfort Stations	1.63%	#010369	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$919
388	4379	Comfort Stations	1.63%	#010369	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
388	4380	Comfort Stations	1.63%	#010369	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$8,385
389	4381	Comfort Stations	1.54%	#010085	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$510
389	4381	Comfort Stations	1.54%	#010085	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$2,485
389	4382	Comfort Stations	1.54%	#010085	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
390	4383	Comfort Stations	1.53%	#010261	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$3,781
390	4383	Comfort Stations	1.53%	#010261	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$2,345
390	4383	Comfort Stations	1.53%	#010261	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Replace Receptacle, 20A 120V ASSY/Ea.	\$3,781
390	4384	Comfort Stations	1.53%	#010261	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Beyond Useful Life	Replace mirrors	\$84
390	4384	Comfort Stations	1.53%	#010261	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
390	4385	Comfort Stations	1.53%	#010261	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Failing	Repaint exterior metal doors	\$653
391	4386	Comfort Stations	1.52%	#010289	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
391	4386	Comfort Stations	1.52%	#010289	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
391	4386	Comfort Stations	1.52%	#010289	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Damaged	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$1,243
391	4386	Comfort Stations	1.52%	#010289	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,178
391	4387	Comfort Stations	1.52%	#010289	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
391	4388	Comfort Stations	1.52%	#010289	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Re-paint or Re-Stain Concrete	\$4,193
392	4389	Recreation Centers	1.46%	Linda Vista Gymnasium	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Refinish wood floor	\$44,984
392	4389	Recreation Centers	1.46%	Linda Vista Gymnasium	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace Ceramic Tile	\$468
392	4389	Recreation Centers	1.46%	Linda Vista Gymnasium	Floor Finishes	Potentially Critical-12 months	District 6	Floor Finishes	Damaged	Replace VCT	\$4,504
392	4390	Recreation Centers	1.46%	Linda Vista Gymnasium	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512
392	4390	Recreation Centers	1.46%	Linda Vista Gymnasium	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,273
392	4391	Recreation Centers	1.46%	Linda Vista Gymnasium	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Replace door hardware	\$9,471
392	4391	Recreation Centers	1.46%	Linda Vista Gymnasium	Interior Doors	Potentially Critical-12 months	District 6	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,866
392	4392	Recreation Centers	1.46%	Linda Vista Gymnasium	Terminal & Package Units	Potentially Critical-12 months	District 6	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$828
392	4393	Recreation Centers	1.46%	Linda Vista Gymnasium	Other Electrical Systems	Potentially Critical-12 months	District 6	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$7,350
392	4394	Recreation Centers	1.46%	Linda Vista Gymnasium	Wall Finishes	Potentially Critical-12 months	District 6	Wall Finishes	Damaged	Repaint wall	\$2,190
392	4395	Recreation Centers	1.46%	Linda Vista Gymnasium	Plumbing Fixtures	Potentially Critical-12 months	District 6	Plumbing Fixtures	Damaged	Replace Plumbing Fixtures	\$3,364
392	4396	Recreation Centers	1.46%	Linda Vista Gymnasium	Exterior Walls	Potentially Critical-12 months	District 6	Exterior Walls	Damaged	Repaint Fascia	\$7,158
392	4397	Recreation Centers	1.46%	Linda Vista Gymnasium	Exterior Doors	Potentially Critical-12 months	District 6	Exterior Doors	Damaged	Repaint exterior metal doors	\$7,825
393	4398	PB - Park Balboa	1.41%	House Of Pac. Rel. Hungary	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Caulk exterior walls	\$542
393	4399	PB - Park Balboa	1.41%	House Of Pac. Rel. Hungary	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
393	4400	PB - Park Balboa	1.41%	House Of Pac. Rel. Hungary	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Beyond Expected Life	Replace Air Cooled Condensing Unit up to 3 Tons	\$5,960
394	4401	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,406
394	4401	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace exit light fixtures	\$2,117
394	4402	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Domestic Water Distribution	Potentially Critical-12 months	District 4	Water Heaters	Missing	Install or replace insulation on hot water piping	\$373
394	4403	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$1,651
394	4404	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Wood Doors	\$3,317
394	4405	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Site Development	Necessary- 2-5 Yrs	District 4	Fencing	Damaged	Repair Plaster Fencing	\$5,907
394	4406	OS - Operations Services	1.38%	Equip., Division, Training Ctr	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace Carpet	\$8,953
395	4407	Recreation Centers	1.37%	Mid City Community Gymnasium	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$4,916
395	4408	Recreation Centers	1.37%	Mid City Community Gymnasium	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$9,617
395	4409	Recreation Centers	1.37%	Mid City Community Gymnasium	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$38,343
395	4410	Recreation Centers	1.37%	Mid City Community Gymnasium	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$49,565
396	4411	Comfort Stations	1.31%	#010368	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
396	4411	Comfort Stations	1.31%	#010368	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 5	Lighting/Branch Wiring	Beyond Expected Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$1,875
396	4411	Comfort Stations	1.31%	#010368	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$545
396	4412	Comfort Stations	1.31%	#010368	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
396	4412	Comfort Stations	1.31%	#010368	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Failing	Replace Restroom Accessories	\$4,346
397	4413	Comfort Stations	1.29%	#001460	Lighting and Branch Wiring	Critical / Immediate Need	District 5	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$621
397	4413	Comfort Stations	1.29%	#001460	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$913

397	4414	Comfort Stations	1.29%	#001460	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Beyond Useful Life	Replace Restroom Accessories	\$2,425
397	4414	Comfort Stations	1.29%	#001460	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
397	4415	Comfort Stations	1.29%	#001460	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Beyond Useful Life	Replace exterior door hardware	\$1,429
398	4416	Recreation Centers	1.28%	Hilltop Community Park	Terminal & Package Units	Potentially Critical-12 months	District 1	Terminal and Package Units	Inadequate	Remove unauthorized storage and clean site.	\$2,885
398	4416	Recreation Centers	1.28%	Hilltop Community Park	Terminal & Package Units	Potentially Critical-12 months	District 1	Terminal and Package Units	Inadequate	Provide secure access for maint and repair	\$6,535
398	4417	Recreation Centers	1.28%	Hilltop Community Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$2,951
398	4417	Recreation Centers	1.28%	Hilltop Community Park	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$838
398	4418	Recreation Centers	1.28%	Hilltop Community Park	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$36,220
398	4418	Recreation Centers	1.28%	Hilltop Community Park	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$3,380
398	4419	Recreation Centers	1.28%	Hilltop Community Park	Exhaust Fans	Potentially Critical-12 months	District 1	Exhaust Ventilation System	Inadequate	Install or replace kitchen range exhaust hood syst	\$11,577
398	4420	Recreation Centers	1.28%	Hilltop Community Park	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$808
398	4421	Recreation Centers	1.28%	Hilltop Community Park	Domestic Water Distribution	Necessary- 2-5 Yrs	District 1	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,294
398	4422	Recreation Centers	1.28%	Hilltop Community Park	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
399	4423	PO - Parks / Recreation	1.14%	Tierrasanta Tennis Clubhouse	Terminal & Package Units	Potentially Critical-12 months	District 7	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$923
399	4424	PO - Parks / Recreation	1.14%	Tierrasanta Tennis Clubhouse	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$461
399	4425	PO - Parks / Recreation	1.14%	Tierrasanta Tennis Clubhouse	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$558
399	4426	PO - Parks / Recreation	1.14%	Tierrasanta Tennis Clubhouse	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
400	4427	Comfort Stations	1.11%	#010350	Lighting and Branch Wiring	Critical / Immediate Need	District 7	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
400	4427	Comfort Stations	1.11%	#010350	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,741
400	4428	Comfort Stations	1.11%	#010350	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
400	4429	Comfort Stations	1.11%	#010350	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Failing	Repaint exterior metal doors	\$7,825
401	4437	Comfort Stations	1.05%	#010351	Fittings	Necessary- 2-5 Yrs	District 2	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
401	4439	Comfort Stations	1.05%	#010351	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 2	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
401	4439	Comfort Stations	1.05%	#010351	Lighting and Branch Wiring	Potentially Critical-12 months	District 2	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,116
402	4430	Swimming Pools	1.05%	Tierrasanta Community	Domestic Water Distribution	Potentially Critical-12 months	District 7	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,201
402	4430	Swimming Pools	1.05%	Tierrasanta Community	Domestic Water Distribution	Necessary- 2-5 Yrs	District 7	Domestic Water Distribution	Damaged	Replace Copper Water Pipe <2 in	\$2,218
402	4431	Swimming Pools	1.05%	Tierrasanta Community	Terminal & Package Units	Potentially Critical-12 months	District 7	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$2,405
402	4431	Swimming Pools	1.05%	Tierrasanta Community	Terminal & Package Units	Potentially Critical-12 months	District 7	Terminal and Package Units	Failing	Install or Replace thermal insulation on refrig.	\$2,991
402	4432	Swimming Pools	1.05%	Tierrasanta Community	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$897
402	4432	Swimming Pools	1.05%	Tierrasanta Community	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$5,443
402	4432	Swimming Pools	1.05%	Tierrasanta Community	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$1,715
402	4433	Swimming Pools	1.05%	Tierrasanta Community	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace VCT	\$2,158
402	4433	Swimming Pools	1.05%	Tierrasanta Community	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$22,007
402	4433	Swimming Pools	1.05%	Tierrasanta Community	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$58,423
402	4434	Swimming Pools	1.05%	Tierrasanta Community	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$9,839
402	4434	Swimming Pools	1.05%	Tierrasanta Community	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$14,023
402	4435	Swimming Pools	1.05%	Tierrasanta Community	Wall Finishes	Critical / Immediate Need	District 7	Wall Finishes	Damaged	Caulk walls	\$670
402	4435	Swimming Pools	1.05%	Tierrasanta Community	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$21,531
402	4436	Swimming Pools	1.05%	Tierrasanta Community	Exterior Walls	Critical / Immediate Need	District 7	Exterior Walls	Damaged	Structural Study	\$19,233
402	4436	Swimming Pools	1.05%	Tierrasanta Community	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$4,059
402	4438	Swimming Pools	1.05%	Tierrasanta Community	Sprinklers	Critical / Immediate Need	District 7	Fire Supression	Inadequate	Repair or replace sprinkler heads	\$202
402	4440	Swimming Pools	1.05%	Tierrasanta Community	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$7,454
402	4440	Swimming Pools	1.05%	Tierrasanta Community	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Metal Door/Metal Frame	\$2,905
402	4441	Swimming Pools	1.05%	Tierrasanta Community	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Fixed Casework Base / Wall Cabinets	\$9,603
402	4441	Swimming Pools	1.05%	Tierrasanta Community	Fixed Furnishings	Necessary- 2-5 Yrs	District 7	Fixed Furnishing	Damaged	Replace Bathroom Sink Cabinet	\$1,923
402	4442	Swimming Pools	1.05%	Tierrasanta Community	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$10,471
402	4442	Swimming Pools	1.05%	Tierrasanta Community	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Replace sheet metal flashing	\$3,820
402	4443	Swimming Pools	1.05%	Tierrasanta Community	Site Development	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Epoxy floor	\$899
402	4444	Swimming Pools	1.05%	Tierrasanta Community	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Steel Doors	\$7,895
403	4445	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace rubber/vinyl cove base	\$31,384
403	4445	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$307,221
403	4445	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$23,689
403	4446	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Domestic Water Distribution	Potentially Critical-12 months	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$230,272
403	4446	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$588

403	4447	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$26,620
403	4447	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$106,084
403	4448	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Beyond Useful Life	Install or replace emergency and/or exit lights	\$92,907
403	4449	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$102,699
403	4450	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
403	4451	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$54,697
403	4452	PB - Park Balboa	1.00%	Reuben H. Fleet Space (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Distribution Systems	Beyond Useful Life	Replace AHU 5000 CFM	\$200,228
404	4453	PB - Park Balboa	0.98%	Comfort Station - Auto Museum	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Clean, seal and treat Exterior cement surface	\$7,419
405	4454	Recreation Centers	0.97%	Scripps Ranch Community Gym	Sprinklers	Critical / Immediate Need	District 5	Fire Supression	Inadequate	Remove unauthorized storage or obstruction	\$962
405	4454	Recreation Centers	0.97%	Scripps Ranch Community Gym	Sprinklers	Potentially Critical-12 months	District 5	Fire Supression	Missing	Install protective security barrier for fire riser	\$2,096
405	4454	Recreation Centers	0.97%	Scripps Ranch Community Gym	Sprinklers	Potentially Critical-12 months	District 5	Fire Supression	Missing	Install protective security barrier for fire riser	\$873
405	4455	Recreation Centers	0.97%	Scripps Ranch Community Gym	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Hardwood	\$8,677
405	4455	Recreation Centers	0.97%	Scripps Ranch Community Gym	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Refinish wood floor	\$61,463
405	4455	Recreation Centers	0.97%	Scripps Ranch Community Gym	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$3,003
405	4456	Recreation Centers	0.97%	Scripps Ranch Community Gym	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Replace door hardware	\$1,214
405	4456	Recreation Centers	0.97%	Scripps Ranch Community Gym	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$1,455
405	4457	Recreation Centers	0.97%	Scripps Ranch Community Gym	Terminal & Package Units	Potentially Critical-12 months	District 5	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,020
405	4458	Recreation Centers	0.97%	Scripps Ranch Community Gym	Storm Sewer	Potentially Critical-12 months	District 5	Storm Sewer	Failing	Provide technical study of storm drainage system	\$19,233
405	4459	Recreation Centers	0.97%	Scripps Ranch Community Gym	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$958
405	4460	Recreation Centers	0.97%	Scripps Ranch Community Gym	Site Development	Necessary- 2-5 Yrs	District 5	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$1,397
405	4461	Recreation Centers	0.97%	Scripps Ranch Community Gym	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
405	4462	Recreation Centers	0.97%	Scripps Ranch Community Gym	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,184
405	4463	Recreation Centers	0.97%	Scripps Ranch Community Gym	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Damaged	Repair/Reseal Roof Penetration	\$5,671
406	4464	PB - Park Balboa	0.95%	House Of Pac. Rel. Puerto Rico	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,701
406	4465	PB - Park Balboa	0.95%	House Of Pac. Rel. Puerto Rico	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
407	4466	Senior Centers	0.93%	George Stevens	Lighting and Branch Wiring	Critical / Immediate Need	District 4	Lighting/Branch Wiring	Missing	Replace Receptacle Covers or Junction Box Covers	\$207
407	4466	Senior Centers	0.93%	George Stevens	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Other Electrical Systems	Failing	Request Engineering Consultant	\$7,051
407	4466	Senior Centers	0.93%	George Stevens	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$10,924
407	4467	Senior Centers	0.93%	George Stevens	Terminal & Package Units	Potentially Critical-12 months	District 4	Terminal and Package Units	Missing	Install/Replace condensor core guard for RTUs	\$3,481
407	4468	Senior Centers	0.93%	George Stevens	Domestic Water Distribution	Necessary- 2-5 Yrs	District 4	Domestic Water Distribution	Failing	Request Plumbing Consultant	\$5,289
407	4469	Senior Centers	0.93%	George Stevens	Standard Foundations	Necessary- 2-5 Yrs	District 4	Foundations	Damaged	Conduct Engineering Assessment - Foundation	\$14,424
407	4470	Senior Centers	0.93%	George Stevens	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$69,130
408	4471	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Steel Doors	\$1,535
408	4471	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Exterior Doors	Necessary- 2-5 Yrs	District 8	Exterior Doors	Damaged	Replace Weatherstripping	\$1,117
408	4472	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Terminal & Package Units	Potentially Critical-12 months	District 8	Ventilation and Exhaust	Damaged	Install or replace exterior louvers	\$3,273
408	4473	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Lighting and Branch Wiring	Potentially Critical-12 months	District 8	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$13,761
408	4474	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 8	Floor Finishes	Damaged	Replace VCT	\$4,609
408	4475	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Pedestrian Paving	Necessary- 2-5 Yrs	District 8	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,933
408	4476	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Fixed Furnishings	Necessary- 2-5 Yrs	District 8	Equipment	Damaged	Repair or replace backboard hoist	\$10,176
408	4477	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Exterior Walls	Necessary- 2-5 Yrs	District 8	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$12,479
408	4478	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Parking Lots	Necessary- 2-5 Yrs	District 8	Parking Lot	Damaged	Slurry seal asphalt	\$16,188
408	4479	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Wall Finishes	Necessary- 2-5 Yrs	District 8	Wall Finishes	Damaged	Repaint wall	\$21,356
408	4480	Recreation Centers	0.92%	San Ysidro Comm. Act. Ctr.	Standard Foundations	Necessary- 2-5 Yrs	District 8	Foundations	Damaged	Conduct Engineering Assessment - Foundation	\$28,849
409	4481	PB - Park Balboa	0.83%	House of Pac. Rel. Iran	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,683
409	4482	PB - Park Balboa	0.83%	House of Pac. Rel. Iran	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
410	4483	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace Carpet	\$7,659
410	4483	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$27,043
410	4483	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Refinish wood floor	\$34,585
410	4484	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Pedestrian Paving	Potentially Critical-12 months	District 5	Roadways	Damaged	Repair and fill cracks and spalding.	\$3,224
410	4484	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Pedestrian Paving	Necessary- 2-5 Yrs	District 5	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$7,691
410	4485	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Sprinklers	Critical / Immediate Need	District 5	Fire Supression	Inadequate	Repair or replace sprinkler heads	\$808
410	4486	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$11,637
410	4486	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Replace door hardware	\$1,517
410	4487	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Athletic Equipment	Necessary- 2-5 Yrs	District 5	Equipment	Damaged	Repair or replace backboard hoist	\$5,088
410	4488	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Fixed Furnishings	Necessary- 2-5 Yrs	District 5	Fixed Furnishing	Damaged	Repair or replace laminate	\$7,563
410	4489	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$17,919
410	4490	Recreation Centers	0.81%	Rancho Bernardo Rec. Center	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$20,338
411	4491	Swimming Pools	0.80%	Allied Gardens	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install or replace GFCI outlets	\$512

411	4491	Swimming Pools	0.80%	Allied Gardens	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Damaged	Replace Incandescent Light Fixtures	\$384
411	4491	Swimming Pools	0.80%	Allied Gardens	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$4,167
411	4491	Swimming Pools	0.80%	Allied Gardens	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Inadequate	Replace 2X4 Flourescent Fixture Ea.	\$1,057
411	4492	Swimming Pools	0.80%	Allied Gardens	Terminal & Package Units	Potentially Critical-12 months	District 7	Other Plumbing Systems	Inadequate	Install or replace flexible fuel connection	\$794
411	4492	Swimming Pools	0.80%	Allied Gardens	Terminal & Package Units	Potentially Critical-12 months	District 7	Flue/Exhaust Stack	Damaged	Extend flue for natural gas appliance	\$433
411	4492	Swimming Pools	0.80%	Allied Gardens	Terminal & Package Units	Necessary- 2-5 Yrs	District 7	Heat Generation	Damaged	Install or replace heating equip or system	\$840
411	4493	Swimming Pools	0.80%	Allied Gardens	Electrical Service/Distribution	Critical / Immediate Need	District 7	Electrical Service/Distribution	Damaged	Remove unauthorized storage	\$962
411	4493	Swimming Pools	0.80%	Allied Gardens	Electrical Service/Distribution	Necessary- 2-5 Yrs	District 7	Electrical Service/Distribution	Damaged	Replace electrical service entrance	\$24,884
411	4494	Swimming Pools	0.80%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Missing	Minor Repairs to Concrete Floor	\$3,144
411	4494	Swimming Pools	0.80%	Allied Gardens	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Minor Repairs to Concrete Floor	\$1,127
411	4495	Swimming Pools	0.80%	Allied Gardens	Domestic Water Distribution	Necessary- 2-5 Yrs	District 7	Other Plumbing Systems	Inadequate	Repair or replace natural gas piping.	\$201
411	4496	Swimming Pools	0.80%	Allied Gardens	Site Development	Necessary- 2-5 Yrs	District 7	Other Site Structures	Damaged	Repaint miscellaneous site structures	\$604
411	4497	Swimming Pools	0.80%	Allied Gardens	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Missing	Replace Shower Door	\$981
411	4498	Swimming Pools	0.80%	Allied Gardens	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Repaint wall	\$1,204
411	4499	Swimming Pools	0.80%	Allied Gardens	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$1,362
411	4500	Swimming Pools	0.80%	Allied Gardens	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Repaint Wood Siding	\$1,737
411	4501	Swimming Pools	0.80%	Allied Gardens	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,184
411	4502	Swimming Pools	0.80%	Allied Gardens	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Damaged	Replace Toilet Partition	\$3,850
412	4504	PB - Park Balboa	0.78%	House Of Pac. Rel. Spain	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$2,701
412	4508	PB - Park Balboa	0.78%	House Of Pac. Rel. Spain	Exterior Walls	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
413	4503	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$1,764
413	4505	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Inadequate	Clean, Sanitize and Balance Air Distribution SYS	\$61,450
413	4506	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$61,450
413	4507	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$111,296
413	4509	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace acoustical ceiling finish	\$5,659
413	4510	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$17,796
413	4511	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$30,877
413	4512	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Refinish wood floor	\$56,782
413	4513	PB - Park Balboa	0.78%	House Of Hospitality & Cafe	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$199,656
414	4514	Comfort Stations	0.77%	#010290	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
414	4514	Comfort Stations	0.77%	#010290	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 7	Lighting/Branch Wiring	Beyond Useful Life	Replace Wall Switch 20A 120/277V ASSY/Ea.	\$468
414	4514	Comfort Stations	0.77%	#010290	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,178
414	4515	Comfort Stations	0.77%	#010290	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace concrete	\$867
414	4516	Comfort Stations	0.77%	#010290	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
415	4523	PB - Park Balboa	0.72%	California Tower (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,462
415	4524	PB - Park Balboa	0.72%	California Tower (L)	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Missing	Install or replace emergency and/or exit lights	\$27,824
415	4529	PB - Park Balboa	0.72%	California Tower (L)	Domestic Water Distribution	Necessary- 2-5 Yrs	District 3	Domestic Water Distribution	Beyond Useful Life	Replace Domestic Water and Sanitary Piping (SF)	\$27,090
415	4530	PB - Park Balboa	0.72%	California Tower (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Prepare _ Paint Exterior Walls up to 3 Floors	\$32,712
416	4517	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Replace Parking Lot - Asphalt	\$3,754
416	4517	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Damaged	Slurry seal asphalt	\$7,344
416	4517	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Parking Lots	Necessary- 2-5 Yrs	District 5	Parking Lot	Missing	Repaint or restripe Parking Lot/	\$2,761
416	4518	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Replace door hardware	\$7,282
416	4518	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,334
416	4519	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Refinish wood floor	\$37,867
416	4519	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Floor Finishes	Necessary- 2-5 Yrs	District 5	Floor Finishes	Damaged	Replace VCT	\$1,220
416	4520	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Fuel Distribution - Natural Gas	Potentially Critical-12 months	District 5	Fuel Distribution	Missing	Install protective bollards	\$2,551
416	4521	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Terminal & Package Units	Potentially Critical-12 months	District 5	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$3,847
416	4522	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$3,847
416	4525	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Ceiling Finishes	Necessary- 2-5 Yrs	District 5	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$958
416	4526	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Exterior Walls	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$10,871
416	4527	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Roof Coverings	Necessary- 2-5 Yrs	District 5	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$12,935
416	4528	Recreation Centers	0.72%	Carmel Mountan Ranch Rec. Ctr.	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$21,603
417	4531	Recreation Centers	0.61%	Tierrasanta	Terminal & Package Units	Potentially Critical-12 months	District 7	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$6,732
417	4531	Recreation Centers	0.61%	Tierrasanta	Terminal & Package Units	Potentially Critical-12 months	District 7	Terminal and Package Units	Inadequate	Provide secure access for maint and repair	\$16,390
417	4532	Recreation Centers	0.61%	Tierrasanta	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Replace Wall Panelling	\$437
417	4532	Recreation Centers	0.61%	Tierrasanta	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Replace Wall Panelling	\$7,134

417	4532	Recreation Centers	0.61%	Tierrasanta	Wall Finishes	Necessary- 2-5 Yrs	District 7	Wall Finishes	Damaged	Replace Wall Panelling	\$399
417	4533	Recreation Centers	0.61%	Tierrasanta	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace Wood Door/Metal Frame	\$3,767
417	4533	Recreation Centers	0.61%	Tierrasanta	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$9,217
417	4533	Recreation Centers	0.61%	Tierrasanta	Interior Doors	Necessary- 2-5 Yrs	District 7	Interior Doors	Damaged	Replace door hardware	\$1,214
417	4534	Recreation Centers	0.61%	Tierrasanta	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$2,235
417	4534	Recreation Centers	0.61%	Tierrasanta	Ceiling Finishes	Necessary- 2-5 Yrs	District 7	Ceiling Finishes	Damaged	Replace Glue on Tile	\$1,253
417	4535	Recreation Centers	0.61%	Tierrasanta	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Repaint exterior metal doors	\$15,464
417	4535	Recreation Centers	0.61%	Tierrasanta	Exterior Doors	Necessary- 2-5 Yrs	District 7	Exterior Doors	Damaged	Replace Steel Doors	\$1,397
417	4536	Recreation Centers	0.61%	Tierrasanta	Exhaust Fans	Potentially Critical-12 months	District 7	Fire Supression	Missing	Install exterior vent from the flammable storage	\$328
417	4537	Recreation Centers	0.61%	Tierrasanta	Sprinklers	Potentially Critical-12 months	District 7	Fire Supression	Inadequate	Install protective security barrier for fire riser	\$873
417	4538	Recreation Centers	0.61%	Tierrasanta	Pedestrian Paving	Potentially Critical-12 months	District 7	Roadways	Damaged	Repair and fill cracks and spalding.	\$1,433
417	4539	Recreation Centers	0.61%	Tierrasanta	Lighting and Branch Wiring	Potentially Critical-12 months	District 7	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,290
417	4540	Recreation Centers	0.61%	Tierrasanta	Roof Coverings	Necessary- 2-5 Yrs	District 7	Roof Covering	Damaged	Repair/Reseal Roof Penetration	\$654
417	4541	Recreation Centers	0.61%	Tierrasanta	Site Development	Necessary- 2-5 Yrs	District 7	Stairs	Damaged	Repaint Handrails	\$703
417	4542	Recreation Centers	0.61%	Tierrasanta	Fittings	Necessary- 2-5 Yrs	District 7	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
417	4543	Recreation Centers	0.61%	Tierrasanta	Exterior Walls	Necessary- 2-5 Yrs	District 7	Exterior Walls	Damaged	Caulk exterior walls	\$6,497
417	4544	Recreation Centers	0.61%	Tierrasanta	Partitions	Necessary- 2-5 Yrs	District 7	Fittings	Damaged	Replace Toilet Partition	\$9,900
417	4545	Recreation Centers	0.61%	Tierrasanta	Floor Finishes	Necessary- 2-5 Yrs	District 7	Floor Finishes	Damaged	Replace Carpet	\$51,986
418	4546	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$2,614
418	4546	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$2,614
418	4546	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$1,306
418	4546	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exhaust Fans	Potentially Critical-12 months	District 3	Fire Supression	Missing	Install exterior vent from the flammable storage	\$1,306
418	4547	PB - Park Balboa	0.59%	Natural History Musuem (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Balance air flow and clean registers	\$39,303
418	4547	PB - Park Balboa	0.59%	Natural History Musuem (L)	Terminal & Package Units	Potentially Critical-12 months	District 3	Ductwork	Damaged	Balance air flow and clean registers	\$39,303
418	4547	PB - Park Balboa	0.59%	Natural History Musuem (L)	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Ductwork	Damaged	replace ductwork dampers registers and insulatio	\$16,127
418	4548	PB - Park Balboa	0.59%	Natural History Musuem (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$9,659
418	4548	PB - Park Balboa	0.59%	Natural History Musuem (L)	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$952
418	4549	PB - Park Balboa	0.59%	Natural History Musuem (L)	Sprinklers	Necessary- 2-5 Yrs	District 3	Sprinklers	Failing	Replace Sprinkler System	\$476,089
418	4550	PB - Park Balboa	0.59%	Natural History Musuem (L)	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,916
418	4551	PB - Park Balboa	0.59%	Natural History Musuem (L)	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$3,316
418	4552	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$3,802
418	4553	PB - Park Balboa	0.59%	Natural History Musuem (L)	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$5,711
418	4554	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$7,270
418	4555	PB - Park Balboa	0.59%	Natural History Musuem (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$7,609
418	4556	PB - Park Balboa	0.59%	Natural History Musuem (L)	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Reapply reflective asphaltic coating to roof	\$165,615
418	4557	PB - Park Balboa	0.59%	Natural History Musuem (L)	Exterior Windows	Necessary- 2-5 Yrs	District 3	Exterior Windows	Damaged	Replace Steel Windows	\$168,244
419	4558	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Carpet	\$65,889
419	4558	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace Hardwood	\$874
419	4559	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$8,948
419	4560	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Exhaust Fans	Potentially Critical-12 months	District 3	Exhaust Ventilation System	Missing	Install or replace kitchen range exhaust hood syst	\$22,913
419	4561	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Ceiling Finishes	Necessary- 2-5 Yrs	District 3	Ceiling Finishes	Damaged	Replace Drywall Ceiling	\$629
419	4562	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Missing	Replace Wood Door/Metal Frame	\$3,285
419	4563	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Steel Doors	\$3,485
419	4564	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Roof Coverings	Necessary- 2-5 Yrs	District 3	Roof Covering	Damaged	Replace Modified Bitumen Roof Coverings	\$4,067
419	4565	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Terminal & Package Units	Necessary- 2-5 Yrs	District 3	Terminal and Package Units	Inadequate	Install or replace dehumidification system	\$47,061
419	4566	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Fittings	Necessary- 2-5 Yrs	District 3	Fittings	Damaged	Replace Toilet Partition	\$53,590
419	4567	PB - Park Balboa	0.50%	House Of Charm & Mingei Museum	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Beyond Expected Life	Replace Fire Alarm System/ASSY for 100 devices	\$143,155
420	4568	PB - Park Balboa	0.44%	Balboa Park Activity Center	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$18,613
420	4568	PB - Park Balboa	0.44%	Balboa Park Activity Center	Communications and Security	Potentially Critical-12 months	District 3	Other Electrical Systems	Failing	Install or replace emergency and/or exit lights	\$18,613

420	4568	PB - Park Balboa	0.44%	Balboa Park Activity Center	Communications and Security	Necessary- 2-5 Yrs	District 3	Communications/Security	Failing	Replace Intercom/Paging System-50 stations	\$36,009
420	4569	PB - Park Balboa	0.44%	Balboa Park Activity Center	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$588
420	4570	PB - Park Balboa	0.44%	Balboa Park Activity Center	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$35,835
420	4571	PB - Park Balboa	0.44%	Balboa Park Activity Center	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace exterior door hardware	\$3,246
420	4572	PB - Park Balboa	0.44%	Balboa Park Activity Center	Floor Finishes	Necessary- 2-5 Yrs	District 3	Floor Finishes	Damaged	Replace VCT	\$5,650
421	4576	Comfort Stations	0.43%	#010420	Lighting and Branch Wiring	Potentially Critical-12 months	District 6	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,741
421	4577	Comfort Stations	0.43%	#010420	Fittings	Potentially Critical-12 months	District 6	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Ductwork	Inadequate	replace ductwork dampers registers and insulatio	\$1,442
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Inadequate	Install condensation piping	\$308
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Inadequate	Install condensation piping	\$308
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Inadequate	Install condensation piping	\$308
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Terminal and Package Units	Inadequate	Install condensation piping	\$308
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Ductwork	Inadequate	replace ductwork dampers registers and insulatio	\$1,442
422	4573	Recreation Centers	0.43%	Scripps Ranch Community	Terminal & Package Units	Necessary- 2-5 Yrs	District 5	Ductwork	Inadequate	replace ductwork dampers registers and insulatio	\$1,442
422	4574	Recreation Centers	0.43%	Scripps Ranch Community	Electrical Service/Distribution	Critical / Immediate Need	District 5	Electrical Service/Distribution	Inadequate	Remove unauthorized storage	\$962
422	4575	Recreation Centers	0.43%	Scripps Ranch Community	Exhaust Fans	Potentially Critical-12 months	District 5	Fire Supression	Missing	Install exterior vent from the flammable storage	\$328
422	4578	Recreation Centers	0.43%	Scripps Ranch Community	Site Development	Necessary- 2-5 Yrs	District 5	Exterior Walls	Damaged	Repaint Exterior Block Wall	\$1,165
422	4579	Recreation Centers	0.43%	Scripps Ranch Community	Fittings	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
422	4580	Recreation Centers	0.43%	Scripps Ranch Community	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint exterior metal doors	\$3,913
422	4581	Recreation Centers	0.43%	Scripps Ranch Community	Wall Finishes	Necessary- 2-5 Yrs	District 5	Wall Finishes	Damaged	Repaint wall	\$7,766
422	4582	Recreation Centers	0.43%	Scripps Ranch Community	Interior Doors	Necessary- 2-5 Yrs	District 5	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$8,727
423	4583	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Terminal & Package Units	Potentially Critical-12 months	District 1	Building Automation Systems	Damaged	Test repair and adjust ambient air controls	\$11,539
423	4583	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Terminal & Package Units	Potentially Critical-12 months	District 1	Other Plumbing Systems	Missing	Install or replace flexible fuel connection	\$1,986
423	4583	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Terminal & Package Units	Potentially Critical-12 months	District 1	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$5,770
423	4584	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace VCT	\$4,654
423	4584	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Damaged	Replace Carpet	\$17,432
423	4585	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Exhaust Fans	Potentially Critical-12 months	District 1	Ductwork	Damaged	Clean, Sanitize and Balance Air Distribution SYS	\$5,770
423	4586	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
423	4587	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Fixed Furnishings	Necessary- 2-5 Yrs	District 1	Fixed Furnishing	Damaged	Repair or replace laminate	\$3,739
423	4588	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Damaged	Repaint exterior metal doors	\$4,412
423	4589	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Damaged	Repaint Wood Trellis	\$7,145
423	4590	Recreation Centers	0.41%	Carmel Valley (Old #900713)	Interior Doors	Necessary- 2-5 Yrs	District 1	Interior Doors	Damaged	Repair and refinish interior doors - 3-0x7-0	\$13,576
424	4591	Comfort Stations	0.35%	#000849	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Damaged	Replace Receptacle, 20A 120V ASSY/Ea.	\$756
424	4591	Comfort Stations	0.35%	#000849	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$1,230
424	4592	Comfort Stations	0.35%	#000849	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Failing	Repaint interior roof structure and deck.	\$2,359
424	4593	Comfort Stations	0.35%	#000849	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Failing	Repaint wall	\$2,427
424	4594	Comfort Stations	0.35%	#000849	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
424	4595	Comfort Stations	0.35%	#000849	Floor Finishes	Necessary- 2-5 Yrs	District 1	Floor Finishes	Failing	Re-paint or Re-Stain Concrete	\$3,797
425	4596	Recreation Centers	0.32%	Mountain View Community (New)	Lighting and Branch Wiring	Potentially Critical-12 months	District 4	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$17,311
425	4596	Recreation Centers	0.32%	Mountain View Community (New)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 4	Lighting/Branch Wiring	Failing	Replace 2X4 Flourescent Fixture Ea.	\$3,423
425	4597	Recreation Centers	0.32%	Mountain View Community (New)	Floor Finishes	Necessary- 2-5 Yrs	District 4	Floor Finishes	Damaged	Replace VCT	\$23,838
425	4598	Recreation Centers	0.32%	Mountain View Community (New)	Exterior Doors	Necessary- 2-5 Yrs	District 4	Exterior Doors	Damaged	Replace Weatherstripping	\$1,117
425	4599	Recreation Centers	0.32%	Mountain View Community (New)	Ceiling Finishes	Necessary- 2-5 Yrs	District 4	Ceiling Finishes	Damaged	Replace Acoustical Ceiling Tile	\$4,230
425	4600	Recreation Centers	0.32%	Mountain View Community (New)	Pedestrian Paving	Necessary- 2-5 Yrs	District 4	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$5,178

425	4601	Recreation Centers	0.32%	Mountain View Community (New)	Landscaping	Necessary- 2-5 Yrs	District 4	Landscaping	Damaged	Re-grade Site	\$7,173
426	4602	Comfort Stations	0.31%	#009997	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Useful Life	Replace 1X4 Surface Fluorescent Fixture S.F.	\$20,195
426	4602	Comfort Stations	0.31%	#009997	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$929
426	4603	Comfort Stations	0.31%	#009997	Wall Finishes	Potentially Critical-12 months	District 1	Wall Finishes	Beyond Useful Life	Repaint wall	\$5,358
426	4604	Comfort Stations	0.31%	#009997	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
426	4605	Comfort Stations	0.31%	#009997	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Failing	Repaint Exterior Block Wall	\$2,772
426	4606	Comfort Stations	0.31%	#009997	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint interior roof structure and deck.	\$3,564
426	4607	Comfort Stations	0.31%	#009997	Exterior Doors	Necessary- 2-5 Yrs	District 1	Exterior Doors	Failing	Repaint exterior metal doors	\$4,349
427	4608	Comfort Stations	0.30%	#009936	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Beyond Useful Life	Replace Receptacle, 20A 120V ASSY/Ea.	\$2,268
427	4608	Comfort Stations	0.30%	#009936	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$553
427	4609	Comfort Stations	0.30%	#009936	Roof Coverings	Potentially Critical-12 months	District 1	Roof Covering	Inadequate	Replace concrete tile roof	\$74,091
427	4610	Comfort Stations	0.30%	#009936	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
427	4611	Comfort Stations	0.30%	#009936	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Construction	Damaged	Termite Inspection of Roof structure	\$35,976
428	4612	PB - Park Balboa	0.29%	Botanical Building	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$15,798
428	4612	PB - Park Balboa	0.29%	Botanical Building	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Beyond Useful Life	Replace Branch Panelboard - 200A	\$10,410
428	4613	PB - Park Balboa	0.29%	Botanical Building	Interior Doors	Necessary- 2-5 Yrs	District 3	Interior Doors	Damaged	Remove, Salvage, Restore Int. Door-Wood Historic	\$4,108
429	4617	PB - Park Balboa	0.28%	Old Naval Hospital Library #8	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Missing	Install or replace exterior lighting	\$3,187
429	4619	PB - Park Balboa	0.28%	Old Naval Hospital Library #8	Landscaping	Necessary- 2-5 Yrs	District 3	Landscaping	Damaged	Perform landscaping maintenance	\$5,462
429	4620	PB - Park Balboa	0.28%	Old Naval Hospital Library #8	Exterior Doors	Necessary- 2-5 Yrs	District 3	Exterior Doors	Damaged	Replace Wood Doors	\$7,538
429	4621	PB - Park Balboa	0.28%	Old Naval Hospital Library #8	Exterior Walls	Necessary- 2-5 Yrs	District 3	Exterior Walls	Damaged	Exterior stucco/plaster wall paint single story	\$11,814
430	4614	PB - Park Balboa	0.28%	Timken Art Gallery (L)	Lighting and Branch Wiring	Potentially Critical-12 months	District 3	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$14,658
430	4614	PB - Park Balboa	0.28%	Timken Art Gallery (L)	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 3	Lighting/Branch Wiring	Inadequate	Replace Ext. HPS Wall Pack Lt. Fix Ea.	\$14,119
430	4615	PB - Park Balboa	0.28%	Timken Art Gallery (L)	Sprinklers	Critical / Immediate Need	District 3	Fire Supression	Beyond Useful Life	Repair or replace sprinkler heads	\$4,589
430	4616	PB - Park Balboa	0.28%	Timken Art Gallery (L)	Domestic Water Distribution	Potentially Critical-12 months	District 3	Water Heaters	Missing	Install or replace insulation on hot water piping	\$588
430	4618	PB - Park Balboa	0.28%	Timken Art Gallery (L)	Wall Finishes	Necessary- 2-5 Yrs	District 3	Wall Finishes	Damaged	Repaint wall	\$5,073
431	4622	Community Services Centers	0.10%	Scripps	Lighting and Branch Wiring	Potentially Critical-12 months	District 5	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$5,511
431	4623	Community Services Centers	0.10%	Scripps	Exterior Doors	Necessary- 2-5 Yrs	District 5	Exterior Doors	Damaged	Repaint Exterior Wood Doors	\$780
431	4624	Community Services Centers	0.10%	Scripps	Exterior Walls	Necessary- 2-5 Yrs	District 5	Fittings	Missing	Replace Facility Number Signage - Cast Aluminum	\$2,567
432	4625	Comfort Stations	0.00%	#001315	Lighting and Branch Wiring	Potentially Critical-12 months	District 1	Lighting/Branch Wiring	Missing	Install circuit label electric outlets and switches	\$716
432	4625	Comfort Stations	0.00%	#001315	Lighting and Branch Wiring	Necessary- 2-5 Yrs	District 1	Lighting/Branch Wiring	Failing	Replace Receptacle 20A 120V ASSY/S.F.	\$4,909
432	4626	Comfort Stations	0.00%	#001315	Roof Construction	Potentially Critical-12 months	District 1	Roof Construction	Damaged	Replace roof construction assembly	\$46,169
432	4626	Comfort Stations	0.00%	#001315	Roof Construction	Necessary- 2-5 Yrs	District 1	Roof Covering	Damaged	Replace Roofing Eave	\$4,598
432	4627	Comfort Stations	0.00%	#001315	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Damaged	Replace Restroom Accessories	\$792
432	4627	Comfort Stations	0.00%	#001315	Fittings	Necessary- 2-5 Yrs	District 1	Fittings	Inadequate	Replace Facility Number Signage - Cast Aluminum	\$2,567
432	4628	Comfort Stations	0.00%	#001315	Exterior Walls	Necessary- 2-5 Yrs	District 1	Exterior Walls	Beyond Useful Life	Repaint Exterior Block Wall	\$3,767
432	4629	Comfort Stations	0.00%	#001315	Ceiling Finishes	Necessary- 2-5 Yrs	District 1	Ceiling Finishes	Damaged	Repaint drywall/plaster ceiling	\$4,476
432	4630	Comfort Stations	0.00%	#001315	Wall Finishes	Necessary- 2-5 Yrs	District 1	Wall Finishes	Damaged	Repaint wall	\$6,406
432	4631	Comfort Stations	0.00%	#001315	Pedestrian Paving	Necessary- 2-5 Yrs	District 1	Pedestrian Paving	Damaged	Replace Concrete Sidewalks	\$10,050
432	4632	Comfort Stations	0.00%	#001315	Roof Coverings	Necessary- 2-5 Yrs	District 1	Roof Covering	Beyond Useful Life	Replace Built up Roof	\$34,330