



NOTES:

1. FOR TRENCHES GREATER THAN 6", LESS THAN 7'-0" IN WIDTH
2. RESURFACING PER SDG-107 & SDG-108
3. ANY CITY UTILITY CROSSING THE TRENCH LINE SHOULD NOT BE ENCASED IN SLURRY, IF ENCOUNTERED IT SHOULD BE SLEEVED WITH PVC.
4. WARNING TAPE SHALL BE INSTALLED ABOVE THE CONDUITS.

REVISION	BY	APPROVED	DATE
ORIGINAL	BB	J. NAGELVOORT	07/15
UPDATED	LA	J. NAGELVOORT	07/15

CITY OF SAN DIEGO - STANDARD DRAWING

**TRENCH TYPES G, H & I
BACKFILL FOR DRY UTILITY**

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

Chung

COORDINATOR R.C.E. 56523

7/21/15

DATE

DRAWING NUMBER

SDG-119