



ITEMS CALL OUT:

- ① WATER MAIN
- ② FLANGED TAPPING SLEEVE OR TEE (NO SIZE-ON-SIZE TAPS ALLOWED) (4 X 4, 6 X 6, ETC). NO EXTENSIONS ALLOWED.
- ③ FULL RESILIENT SEAT GATE VALVE . SIZE OF VALVE SHALL MATCH SIZE OF FIRE SERVICE (4" MINIMUM DIAMETER). SEE NOTE #1.
- ④ 4" OR LARGER DIAMETER OF PIPE (DUCTILE IRON OR PVC PER APPROVED MATERIALS LIST).
- ⑤ VALVE WELL.
- ⑥ VALVE WELL COVER SEE SDW-153.

NOTES:

- 1. FOR SMALLER FIRE SERVICE REQUIREMENTS, USE REDUCER AT PROPERTY LINE.
- 2. FOR CORROSION CONTROL REQUIREMENTS, SEE PUBLIC UTILITIES DEPARTMENT DESIGN GUIDE.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL	BB	OSKOU	1009		FIRE SERVICE CONNECTION & ASSEMBLY
NOTES	AO	F. BELOCK	496		
NOTES	JS	A. OSKOU	1206		
UPDATED	KA	J. NAGELVOORT	01/12		
UPDATED	KA	J. NAGELVOORT	12/12		
				DRAWING NUMBER	SDW-118