



NOT TO SCALE

NOTES:

1. ALL BURIED DUCTILE IRON PIPE, FITTINGS, VALVES AND APPURTENANCES SHALL BE COATED WITH A DIELECTRIC COATING, A LIQUID EPOXY COATING SYSTEM PER AWWA C-210 AT 24 MILS MINIMUM DRY FILM THICKNESS (MDF), OR A COLD APPLIED THREE-PART SYSTEM PETROLEUM WAX TAPE PER AWWA C-217, OR A 100% POLYURETHANE COATING OF 24 MILS (MDF) SUITABLE.
2. ANY CHANGES SHALL HAVE PUBLIC UTILITIES DEPARTMENT APPROVAL.
3. PIPING SHALL BE SYMMETRICAL TO SLAB CENTERLINE.
4. SUPPLY PIPE IS ONE COMMERCIAL SIZE LARGER THAN PROPOSED METER.
5. CONCRETE SLAB AND FENCE WILL BE INSTALLED BY CONTRACTOR.

ITEMS CALL OUT:

- ① 90° FLANGED DUCTILE IRON ELBOW (TYP).
- ② FLANGED DUCTILE IRON SPOOL, BOTH ENDS SHALL BE FLANGED (UNI-FLANGE SHALL NOT BE USED).
- ③ DIAMETER OF TEE SHALL BE EQUAL TO THE DIAMETER OF THE SUPPLY PIPE.

SHEET 1 OF 2

REVISION	BY	APPROVED	DATE
ORIGINAL	JC		
REVISION	BM	A. OSKOUI	12/03
NOTES	JS	A. OSKOUI	12/06
UPDATED	KA	J. NAGELVOORT	01/12
UPDATED	KA	J. NAGELVOORT	12/12

CITY OF SAN DIEGO - STANDARD DRAWING

**DUAL ABOVE GROUND METER AND
BACKFLOW PREVENTION ASSEMBLIES**

RECOMMENDED BY THE CITY OF SAN DIEGO
STANDARDS COMMITTEE

H. Hadali 12/17/2012
COORDINATOR R.C.E. 65271 DATE

DRAWING NUMBER **SDW-119**

LETTER CODE	PART DESCRIPTION	METER SIZE				
		3"	4"	6"	8"	10"
A	GATE VALVE	8"	9"	10 1/2"	11 1/2"	1' - 1"
B	PIPE EXTENSION	1' - 0"	1' - 0"	1' - 6"	2' - 0"	2' - 6"
C	STRAINER *	7"	9"	9"	10"	1' - 0"
D	TURBINE WATER METER *	1' - 0"	1' - 2"	1' - 6"	1' - 9"	2' - 2"
E	COMPOUND METER *	1' - 5"	2' - 0"	2' - 5"	3' - 1"	4' - 7"
F	TESTING TEE	11"	1' - 1"	1' - 4"	1' - 6"	1' - 10"
G	90 DEG. ELBOW (SHORT)	5 1/2"	6 1/2"	8"	9"	11"
H	OVERALL SLAB LENGTH *	11' - 10"	12' - 11"	14' - 9"	16' - 3"	18' - 10"
I	SLAB TO CL PIPE	3' - 0"	3' - 0"	3' - 0"	3' - 0"	3' - 6"
J	BACKFLOW *	3' - 2"	3' - 4"	4' - 1/2"	4' - 4 1/2"	4' - 7 1/2"

* NOTES: INDIVIDUAL DIMENSIONS MAY VARY PER MANUFACTURER
OVERALL DIMENSIONS INCREASE WITH USE OF THESE COMPONENTS

SHEET 2 OF 2

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL	JC				<i>A. Hasli</i> 12/17/2012
REVISION	BM	A. OSKUI	12/03	DUAL ABOVE GROUND METER AND BACKFLOW PREVENTION ASSEMBLIES	COORDINATOR R.C.E. 65271 DATE
NOTES	JS	A. OSKUI	12/06		
UPDATED	KA	J. NAGELVOORT	01/12		
UPDATED	KA	J. NAGELVOORT	12/12		
					DRAWING NUMBER SDW-119