



NOTES:

1. BYPASS SHALL BE SAME CLASS AS MAINLINE PIPE.
2. THE VALVE SHALL BE THE SAME SIZE AS THE BYPASS PIPE.
3. SEE THE APPROVED WORKING DRAWINGS FOR X<sub>1</sub> AND X<sub>2</sub>.

MAIN SIZE	BYPASS SIZE
16" TRANSMISSION	3"
> 16" AND = < 36"	4"
> 36"	6"

REVISION	BY	APPROVED	DATE
ORIGINAL	KA	J. NAGELVOORT	01/12
UPDATED	KA	J. NAGELVOORT	12/12

CITY OF SAN DIEGO - STANDARD DRAWING

**WATER VALVE BYPASS DETAILS  
FOR MAINLINES 16" AND LARGER**

RECOMMENDED BY THE CITY OF SAN DIEGO  
STANDARDS COMMITTEE

*H. Hadli* 12/17/2012  
COORDINATOR R.C.E. 65271 DATE

DRAWING NUMBER **SDW-154**