

Summary of Raw Water Quality*
Otay Cottonwood System Reservoirs¹ 2006-2010

| Parameters | Units | DLR**/MDL | Drinking Water Standards ² | | No. of Samples | Raw Water Quality | | | | |
|--|---------|-----------|---------------------------------------|---------|----------------|-------------------|-------|-------|--------|--|
| | | | MCL | SMCL | | Min | Max | Mean | Median | |
| General Physical | | | | | | | | | | |
| Calcium Hardness (CaCO ₃) | mg/L | 20 | | | 57 | 55.2 | 198 | 119 | 122 | |
| Color | Color | 1 | | 15 | 57 | 4 | 239 | 28.3 | 22 | |
| Conductivity | µmho/cm | | | 1600 | 55 | 437 | 1290 | 881 | 921 | |
| Corrosivity ³ | -- | | | | 55 | -0.89 | 1.95 | 0.918 | 0.99 | |
| pH | pH | | | 6.5-8.5 | 52 | 6.67 | 9.38 | 8.40 | 8.44 | |
| Total Alkalinity | mg/L | 20 | | | 54 | 111 | 347 | 192 | 166 | |
| Total Dissolved Solids | mg/L | 10 | | 1000 | 57 | 329 | 753 | 513 | 519 | |
| Total Hardness (CaCO ₃) | mg/L | 20 | | | 56 | 144 | 298 | 227 | 234 | |
| Turbidity | ntu | 0.07 | 0.5 | | 57 | 0.23 | 226 | 10.9 | 3.32 | |
| Pathogens and Indicator Organisms | | | | | | | | | | |
| E. Coli | /100 mL | | | | 487 | 10 | 640 | 64.5 | 41 | |
| Enterococcus | /100 mL | | | | 487 | 1 | 220 | 14.2 | 7 | |
| Total Coliform | /100 mL | | | | 487 | 10 | 24000 | 2840 | 620 | |
| Total Crypto Oocyst Count | /L | | | | 4 | nd | nd | nd | nd | |
| Total Giardia Cyst Count | /L | | | | 4 | nd | nd | nd | nd | |
| Metals | | | | | | | | | | |
| Aluminum | µg/L | 50 | 1000 | 200 | 55 | nd | 418 | nd | nd | |
| Antimony | µg/L | 6 | 6 | | 56 | nd | nd | nd | nd | |
| Arsenic | µg/L | 2 | 10 | | 57 | nd | 6.57 | nd | nd | |
| Barium | µg/L | 100 | 1000 | | 56 | nd | 102 | nd | nd | |
| Beryllium | µg/L | 1 | 4 | | 56 | nd | nd | nd | nd | |
| Boron | µg/L | 100 | | | 55 | nd | 216 | 108 | 101 | |
| Cadmium | µg/L | 1 | 5 | | 56 | nd | 1.03 | nd | nd | |
| Chromium | µg/L | 10 | 50 | | 57 | nd | nd | nd | nd | |
| Copper | µg/L | 50 | 1300 ⁴ | 1000 | 57 | nd | nd | nd | nd | |
| Hexavalent Chromium | µg/L | 1 | | | 1 | nd | nd | nd | nd | |
| Iron | µg/L | 100 | | 300 | 57 | nd | 247 | nd | nd | |
| Lead | µg/L | 5 | 15 ⁴ | | 57 | nd | nd | nd | nd | |
| Magnesium | mg/L | | | | 57 | 4.3 | 47.5 | 25.9 | 25.6 | |
| Manganese | µg/L | 20 | | 50 | 106 | nd | 225 | 34.5 | 22.6 | |
| Mercury | µg/L | 1 | 2 | | 42 | nd | nd | nd | nd | |
| Nickel | µg/L | 10 | 100 | | 56 | nd | nd | nd | nd | |
| Selenium | µg/L | 5 | 50 | | 57 | nd | nd | nd | nd | |
| Silver | µg/L | 10 | | 100 | 56 | nd | nd | nd | nd | |
| Sodium | mg/L | 20 | | | 57 | 53.9 | 144 | 86.6 | 81.9 | |
| Thallium | µg/L | 1 | 2 | | 57 | nd | nd | nd | nd | |
| Vanadium | µg/L | 3 | | | 56 | nd | 22.9 | 5.04 | nd | |
| Zinc | µg/L | 50 | | 5000 | 57 | nd | nd | nd | nd | |
| Radiological | | | | | | | | | | |
| Combined Radium-226 & Radium-228 | pCi/L | | 5 | | 5 | nd | 1.05 | 0.394 | nd | |
| Gross Alpha | pCi/L | 3 | 15 | | 6 | nd | 4.78 | nd | nd | |
| Gross Beta | pCi/L | 4 | 50 | | 6 | nd | nd | nd | nd | |
| Strontium 90 | pCi/L | 2 | 8 | | 1 | nd | nd | nd | nd | |
| Tritium | pCi/L | 1000 | 20000 | | 1 | nd | nd | nd | nd | |
| Uranium | pCi/L | 1 | 20 | | 5 | 1.88 | 3.84 | 2.88 | 3.13 | |
| Inorganic Constituents | | | | | | | | | | |
| Ammonia-N | mg/L | 0.031 | | | 56 | nd | 1.12 | 0.12 | nd | |
| Bicarbonate | mg/L | | | | 56 | 69 | 368 | 216 | 191 | |
| Bromate | µg/L | 5 | 10 | | 3 | nd | nd | nd | nd | |
| Bromide | mg/L | 0.1 | | | 56 | nd | 0.813 | 0.333 | 0.296 | |
| Calcium | mg/L | | | | 57 | 22.1 | 79.2 | 47.5 | 48.8 | |
| Carbonate | mg/L | | | | 56 | nd | 70.8 | 10.3 | nd | |
| Chloride | mg/L | 0.5 | | 500 | 56 | 34 | 148 | 96.7 | 96.3 | |
| Cyanide, Total | mg/L | 0.1 | 0.15 | | 22 | nd | nd | nd | nd | |
| Fluoride | mg/L | 0.1 | 2 | | 55 | 0.207 | 0.631 | 0.362 | 0.321 | |
| MBAS (Detergents) | mg/L | 0.05 | | 0.5 | 5 | nd | 0.06 | nd | nd | |
| Nitrate (as NO ₃) | mg/L | 2 | 45 | | 74 | nd | 5.03 | nd | nd | |
| Nitrite (as NO ₂) | mg/L | 1.31 | 3.29 | | 58 | nd | nd | nd | nd | |
| Perchlorate | µg/L | 4 | 6 | | 118 | nd | 10.3 | nd | nd | |
| Phosphate, Ortho (as PO ₄) | mg/L | 0.2 | | | 69 | nd | 0.858 | nd | nd | |
| Phosphorus | mg/L | 0.078 | | | 112 | nd | 0.385 | nd | nd | |
| Potassium | mg/L | 0.5 | | | 57 | 3.78 | 11.3 | 6.08 | 5.27 | |
| Silica | mg/L | 0.5 | | | 57 | nd | 22.4 | 8.09 | 7.19 | |
| Sulfate | mg/L | 0.5 | | 500 | 56 | 16.8 | 195 | 88.1 | 72 | |
| Total Nitrogen | mg/L | 0.156 | | | 112 | nd | 2.97 | 0.585 | 0.395 | |
| Organic Constituents Regulated | | | | | | | | | | |
| 1,1,1-Trichloroethane (1,1,1-TCA) | µg/L | 0.5 | 200 | | 63 | nd | nd | nd | nd | |
| 1,1,2,2-Tetrachloroethane | µg/L | 0.5 | 1 | | 63 | nd | nd | nd | nd | |
| 1,1,2-Trichloroethane (1,1,2-TCA) | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| 1,1-Dichloroethane (1,1-DCA) | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| 1,1-Dichloroethylene (1,1-DCE) | µg/L | 0.5 | 6 | | 63 | nd | nd | nd | nd | |

Summary of Raw Water Quality*
Otay Cottonwood System Reservoirs¹ 2006-2010

| Parameters | Units | DLR**/MDL | Drinking Water Standards ² | | No. of Samples | Raw Water Quality | | | | |
|---|-------|-----------|---------------------------------------|------|----------------|-------------------|-------|------|--------|--|
| | | | MCL | SMCL | | Min | Max | Mean | Median | |
| 1,2,4-Trichlorobenzene | µg/L | 0.5 | 5 | | 62 | nd | nd | nd | nd | |
| 1,2-Dichlorobenzene (o-DCB) | µg/L | 0.5 | 600 | | 63 | nd | nd | nd | nd | |
| 1,2-Dichloroethane (1,2-DCA) | µg/L | 0.5 | 0.5 | | 63 | nd | nd | nd | nd | |
| 1,2-Dichloropropane | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| 1,4-Dichlorobenzene (p-DCB) | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| 2,4,5-TP (SILVEX) | µg/L | 1 | 50 | | 55 | nd | nd | nd | nd | |
| 2,4-D | µg/L | 10 | 70 | | 55 | nd | nd | nd | nd | |
| Alachlor (ALANEX) | µg/L | 1 | 2 | | 48 | nd | nd | nd | nd | |
| Atrazine (AATREX) | µg/L | 0.5 | 1 | | 48 | nd | nd | nd | nd | |
| Bentazon (BASAGRAN) | µg/L | 2 | 18 | | 55 | nd | nd | nd | nd | |
| Benzene | µg/L | 0.5 | 1 | | 63 | nd | nd | nd | nd | |
| Benzo(a)pyrene | µg/L | 0.1 | 0.2 | | 43 | nd | 0.121 | nd | nd | |
| Bromodichloromethane | µg/L | 1 | | | 63 | nd | 3.06 | nd | nd | |
| Bromoform | µg/L | 1 | | | 63 | nd | 1.61 | nd | nd | |
| Carbofuran (FURADAN) | µg/L | 5 | 18 | | 58 | nd | nd | nd | nd | |
| Carbon Tetrachloride | µg/L | 0.5 | 0.5 | | 63 | nd | nd | nd | nd | |
| Chlordane | µg/L | 0.1 | 0.1 | | 25 | nd | nd | nd | nd | |
| Chloroform (Trichloromethane) | µg/L | 1 | | | 63 | nd | 2.03 | nd | nd | |
| cis-1,2-Dichloroethylene (c-1,2-DCE) | µg/L | 0.5 | 6 | | 63 | nd | nd | nd | nd | |
| Dalapon | µg/L | 10 | 200 | | 1 | nd | nd | nd | nd | |
| Di(2-ethylhexyl) Adipate | µg/L | 5 | 400 | | 50 | nd | nd | nd | nd | |
| Dibromoacetic Acid (DBAA) | µg/L | 1 | | | 1 | nd | nd | nd | nd | |
| Dibromochloromethane | µg/L | 1 | | | 63 | nd | 3.87 | nd | nd | |
| Dibromochloropropane (DBCP) | µg/L | 0.01 | 0.2 | | 94 | nd | nd | nd | nd | |
| Dichloroacetic Acid (DCAA) | µg/L | 1 | | | 1 | nd | nd | nd | nd | |
| Dichloromethane (Methylene Chloride) | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| Diethylhexylphthalate (DEHP) | µg/L | 3 | 4 | | 47 | nd | nd | nd | nd | |
| Dinoseb (DNBP) | µg/L | 2 | 7 | | 55 | nd | nd | nd | nd | |
| Diquat | µg/L | 4 | 20 | | 1 | nd | nd | nd | nd | |
| Endothall | µg/L | 45 | 100 | | 1 | nd | nd | nd | nd | |
| Endrin | µg/L | 0.1 | 2 | | 82 | nd | nd | nd | nd | |
| Ethyl Benzene | µg/L | 0.5 | 300 | | 63 | nd | nd | nd | nd | |
| Ethylene Dibromide (EDB) | µg/L | 0.02 | 0.05 | | 97 | nd | nd | nd | nd | |
| Glyphosate | µg/L | 25 | 700 | | 55 | nd | nd | nd | nd | |
| Haloacetic Acids (five) (HAAs) ⁵ | µg/L | 1 | 60 | | 1 | nd | nd | nd | nd | |
| Heptachlor | µg/L | 0.01 | 0.01 | | 31 | nd | nd | nd | nd | |
| Heptachlor Epoxide | µg/L | 0.01 | 0.01 | | 35 | nd | nd | nd | nd | |
| Hexachlorobenzene | µg/L | 0.5 | 1 | | 85 | nd | nd | nd | nd | |
| Hexachlorocyclopentadiene | µg/L | 1 | 50 | | 64 | nd | nd | nd | nd | |
| Lindane (gamma-BHC) | µg/L | 0.2 | 0.2 | | 38 | nd | nd | nd | nd | |
| m,p- Xylenes | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| Methoxychlor | µg/L | 10 | 30 | | 76 | nd | nd | nd | nd | |
| Methyl-tert-butyl ether (MTBE) | µg/L | 3 | 13 | 5 | 62 | nd | nd | nd | nd | |
| Molinate (ORDRAM) | µg/L | 2 | 20 | | 26 | nd | nd | nd | nd | |
| Monobromoacetic Acid (MBAA) | µg/L | 1 | | | 1 | nd | nd | nd | nd | |
| Monochloroacetic Acid (MCAA) | µg/L | 2 | | | 1 | nd | nd | nd | nd | |
| Monochlorobenzene (Chlorobenzene) | µg/L | 0.2 | 70 | | 63 | nd | nd | nd | nd | |
| Oxamyl (Vydate) | µg/L | 20 | 50 | | 58 | nd | nd | nd | nd | |
| Pentachlorophenol (PCP) | µg/L | 0.2 | 1 | | 55 | nd | nd | nd | nd | |
| Picloram | µg/L | 1 | 500 | | 55 | nd | nd | nd | nd | |
| Polychlorinated Biphenyls, Total, as DCB | µg/L | 0.5 | 0.5 | | 21 | nd | nd | nd | nd | |
| Simazine (PRINCEP) | µg/L | 1 | 4 | | 40 | nd | nd | nd | nd | |
| Styrene | µg/L | 0.5 | 100 | | 63 | nd | nd | nd | nd | |
| Tetrachloroethylene (PCE) | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| Thiobencarb (BOLERO) | µg/L | 1 | 70 | 1 | 49 | nd | nd | nd | nd | |
| Toluene | µg/L | 0.5 | 150 | | 63 | nd | nd | nd | nd | |
| Total Organic Carbon (TOC) | mg/L | 0.3 | | | 62 | 4.21 | 8.73 | 5.71 | 5.25 | |
| Total Trihalomethanes (TTHMs) ⁶ | µg/L | 1 | 80 | | 3 | nd | 10.6 | 3.53 | nd | |
| Total Xylenes (m,p, & o) | µg/L | | 1750 | | 63 | nd | nd | nd | nd | |
| Toxaphene | µg/L | 1 | 3 | | 23 | nd | nd | nd | nd | |
| trans-1,2-Dichloroethylene (t-1,2-DCE) | µg/L | 0.5 | 10 | | 63 | nd | nd | nd | nd | |
| Trichloroacetic Acid (TCAA) | µg/L | 1 | | | 1 | nd | nd | nd | nd | |
| Trichloroethylene (TCE) | µg/L | 0.5 | 5 | | 63 | nd | nd | nd | nd | |
| Trichlorofluoromethane (FREON 11) | µg/L | 5 | 150 | | 63 | nd | nd | nd | nd | |
| Trichlorotrifluoroethane (FREON 113) | µg/L | 10 | 1200 | | 62 | nd | nd | nd | nd | |
| Vinyl Chloride (VC) | µg/L | 0.5 | 0.5 | | 63 | nd | nd | nd | nd | |
| Organic Constituents Unregulated | | | | | | | | | | |
| 1,1,1,2-Tetrachloroethane | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| 1,1-Dichloropropene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| 1,2,3-Trichlorobenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| 1,2,4-Trimethylbenzene | µg/L | 0.4 | | | 63 | nd | nd | nd | nd | |
| 1,3,5-Trimethylbenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| 1,3-Dichlorobenzene (m-DCB) | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| 1,3-Dichloropropane | µg/L | 0.5 | | | 63 | nd | nd | nd | nd | |
| 2,2',3,3',4,4',6-Heptachlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd | |
| 2,2',3,3',4,5',6,6'-Octachlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd | |

Summary of Raw Water Quality*
Otay Cottonwood System Reservoirs¹ 2006-2010

| Parameters | Units | DLR**/MDL | Drinking Water Standards ² | | No. of Samples | Raw Water Quality | | | |
|------------------------------------|-------|-----------|---------------------------------------|------|----------------|-------------------|------|------|--------|
| | | | MCL | SMCL | | Min | Max | Mean | Median |
| 2,2',4,4',5,6'-Hexachlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd |
| 2,2',4,4'-Tetrachlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd |
| 2,2'3'4,6-Pentachlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd |
| 2,2-Dichloropropane | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| 2,3-Dichlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd |
| 2,4,5-T | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| 2,4,5-Trichlorobiphenyl | µg/L | 0.5 | | | 8 | nd | nd | nd | nd |
| 2,4-DB | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| 2-Chlorobiphenyl | µg/L | 0.5 | | | 3 | nd | nd | nd | nd |
| 2-Chlorotoluene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| 2-Methylisoborneol (MIB) | ng/L | 5 | | | 202 | nd | 65.9 | 8.33 | 5.49 |
| 3,5-Dichlorobenzoic acid | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| 3-Hydroxycarbofuran | µg/L | 3 | | | 58 | nd | nd | nd | nd |
| 4-Chlorotoluene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Acenaphthylene | µg/L | 5 | | | 25 | nd | nd | nd | nd |
| Acifluorfen | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| Aldicarb (TEMIK) | µg/L | 3 | | | 58 | nd | nd | nd | nd |
| Aldicarb sulfone | µg/L | 4 | | | 58 | nd | nd | nd | nd |
| Aldicarb sulfoxide | µg/L | 3 | | | 58 | nd | nd | nd | nd |
| Aldrin | µg/L | 0.075 | | | 36 | nd | nd | nd | nd |
| Anthracene | µg/L | 5 | | | 47 | nd | nd | nd | nd |
| Baygon | µg/L | 0.4 | | | 58 | nd | nd | nd | nd |
| Benzo (a) Anthracene | µg/L | 10 | | | 50 | nd | nd | nd | nd |
| Benzo (b) Fluoranthene | µg/L | 10 | | | 44 | nd | nd | nd | nd |
| Benzo (g,h,i) Perylene | µg/L | 10 | | | 44 | nd | nd | nd | nd |
| Benzo (k) Fluoranthene | µg/L | 10 | | | 44 | nd | nd | nd | nd |
| Benzyl Butyl Phthalate | µg/L | 10 | | | 50 | nd | nd | nd | nd |
| Bromobenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Bromochloromethane | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Bromomethane (Methyl Bromide) | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Carbaryl (Sevin) | µg/L | 5 | | | 58 | nd | nd | nd | nd |
| Chloramben | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| Chloroethane | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Chloromethane (Methyl Chloride) | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Chrysene | µg/L | 5 | | | 50 | nd | nd | nd | nd |
| cis-1,3-Dichloropropene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Dibenzo (a,h) anthracene | µg/L | 5 | | | 44 | nd | nd | nd | nd |
| Dibromomethane | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Dicamba (BANVEL) | µg/L | 1.5 | | | 55 | nd | nd | nd | nd |
| Dichlorodifluoromethane (Freon 12) | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Dichlorprop | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| Dieldrin | µg/L | 0.02 | | | 35 | nd | nd | nd | nd |
| Diethylphthalate | µg/L | 5 | | | 48 | nd | nd | nd | nd |
| Diisopropyl Ether (DIPE) | µg/L | 3 | | | 62 | nd | nd | nd | nd |
| Dimethyl phthalate | µg/L | 5 | | | 26 | nd | nd | nd | nd |
| di-n-Butylphthalate | µg/L | 5 | | | 43 | nd | nd | nd | nd |
| Ethyl-tert-butyl ether (ETBE) | µg/L | 3 | | | 62 | nd | nd | nd | nd |
| Fluorene | µg/L | 5 | | | 45 | nd | nd | nd | nd |
| Geosmin | ng/L | 5 | | | 202 | nd | 9.59 | nd | nd |
| Hexachlorobutadiene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Indeno (1,2,3-cd) Pyrene | µg/L | 10 | | | 44 | nd | nd | nd | nd |
| Isopropylbenzene (Cumene) | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| MCPA | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| MCPP | µg/L | 3 | | | 55 | nd | nd | nd | nd |
| Methiocarb | µg/L | 0.4 | | | 58 | nd | nd | nd | nd |
| Methomyl | µg/L | 2 | | | 58 | nd | nd | nd | nd |
| Naphthalene | µg/L | 0.5 | | | 89 | nd | nd | nd | nd |
| n-Butylbenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| n-Propylbenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| Paraquat | µg/L | 4 | | | 1 | nd | nd | nd | nd |
| PCB 1016 / 1242 | µg/L | 0.5 | | | 12 | nd | nd | nd | nd |
| PCB 1016 (as DCB) | µg/L | 0.5 | | | 9 | nd | nd | nd | nd |
| PCB-1221 (as DCB) | µg/L | 0.5 | | | 21 | nd | nd | nd | nd |
| PCB-1232 (as DCB) | µg/L | 0.5 | | | 21 | nd | nd | nd | nd |
| PCB-1242 (as DCB) | µg/L | 0.5 | | | 9 | nd | nd | nd | nd |
| PCB-1248 (as DCB) | µg/L | 0.5 | | | 21 | nd | nd | nd | nd |
| PCB-1254 (as DCB) | µg/L | 0.5 | | | 21 | nd | nd | nd | nd |
| PCB-1260 (as DCB) | µg/L | 0.5 | | | 21 | nd | nd | nd | nd |
| Phenanthrene | µg/L | 5 | | | 48 | nd | nd | nd | nd |
| p-Isopropyltoluene | µg/L | 0.2 | | | 63 | nd | nd | nd | nd |
| Propachlor | µg/L | 0.5 | | | 81 | nd | nd | nd | nd |
| Pyrene | µg/L | 0.5 | | | 48 | nd | nd | nd | nd |
| sec-Butylbenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| tert-Amyl Methyl Ether (TAME) | µg/L | 3 | | | 63 | nd | nd | nd | nd |
| tert-Butyl Alcohol (TBA) | µg/L | 2 | | | 62 | nd | nd | nd | nd |
| tert-Butylbenzene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |
| trans-1,3-Dichloropropene | µg/L | 0.5 | | | 63 | nd | nd | nd | nd |

Summary of Raw Water Quality*
Otay Cottonwood System Reservoirs¹ 2006-2010

| Parameters | Units | DLR**/MDL | Drinking Water Standards ² | | No. of Samples | Raw Water Quality | | | |
|-------------|-------|-----------|---------------------------------------|------|----------------|-------------------|-----|------|--------|
| | | | MCL | SMCL | | Min | Max | Mean | Median |
| Trifluralin | µg/L | 0.5 | | | 47 | nd | nd | nd | nd |

NOTES:

**The acceptance criteria in this table apply to finished, potable water, and are for reference only.

* The State of California DLR values are used when available. Parameters without DLR values were reported at MDL levels.

(1) The sampling points summarized are: BAA-0, MOA-0, OTA-0.

(2) State MCL and MCLG values may be more stringent than federal standards for treated water.

(3) Based on the Langelier Index. A positive value indicates non-corrosive tendencies. A negative value indicates corrosive tendencies.

(4) Lead and Copper Rule Action Level.

nd: non-detect at State DLR or MDL if DLR not available