

City of San Diego
Annual Report 2004 - North City Water Reclamation Plant - Reclaimed Water - Annual & Monthly Averages

North City Water Reclamation Plant
Annual Monitoring Report
2004

NCWRP (N34-REC) Reclaimed Water

Month	Monthly Averages				pH	Turbidity
	Biochemical Oxygen Demand (mg/L)	Total Dissolved Solids (mg/L)	Total Suspended Solids (mg/L)	Volatile Suspended Solids (mg/L)	Grab (pH)	† (NTU)
JAN	ND	913	ND	ND	7.45	1.09
FEB	<2	886	ND	ND	7.51	0.724
MAR	ND	901	ND	ND	7.52	0.766
APR	<2	917	<1.6	ND	7.52	1.29
MAY	<2	906	ND	ND	7.45	1.44
JUN	ND	967	ND	ND	7.45	1.6
JUL	ND	940	<1.6	ND	7.47	NS
AUG	<2	970	<1.6	ND	7.36	NS
SEP	<2	925	<1.6	ND	7.4	NS
OCT	<2	978	ND	ND	7.38	NS
NOV	<2	1040	ND	ND	7.54	NS
DEC	ND	958	<1.6	<1.6	7.59	NS
Average	<2	942	<1.6	<1.6	7.47	1.2

† Not used for compliance determination. The turbidity values here are from laboratory analysis of 24 hour composite sample after the turbidity was raised by the addition of sodium hypochlorite.

City of San Diego

Annual Report 2004 - North City Water Reclamation Plant - Reclaimed Water - Annual & Monthly Averages

Analyte:	Aluminum	Antimony	Arsenic	Barium	Beryllium	Boron
MDL and Units:	50 UG/L	23 UG/L	0.4 UG/L	10 UG/L	0.39 UG/L	15 UG/L
Limit:	1000	6	50	1000	4	700
=====	=====	=====	=====	=====	=====	=====
JANUARY -2004	205	ND	0.61	57	ND	447
FEBRUARY -2004	ND	ND	ND	48	ND	382
MARCH -2004	ND	ND	0.77	46	ND	359
APRIL -2004	ND	ND	0.86	51	ND	394
MAY -2004	ND	33	0.80	43	ND	420
JUNE -2004	43	ND	0.44	22	ND	371
JULY -2004	51	ND	0.54	24	ND	362
AUGUST -2004	ND	2	ND	20	ND	381
SEPTEMBER-2004	75	2	0.70	24	ND	367
OCTOBER -2004	97	ND	0.79	22	ND	368
NOVEMBER -2004	NS	NS	NS	NS	NS	NS
DECEMBER -2004	ND	ND	0.64	65	ND	251
=====	=====	=====	=====	=====	=====	=====
Annual Average:	43	3	0.56	38	ND	373

Analyte:	Cadmium	Chromium	Copper	Iron	Manganese	Mercury
MDL and Units:	1 UG/L	5 UG/L	4 UG/L	30 UG/L	4 UG/L	0.5 UG/L
Limit:	5	50		300	50	2
=====	=====	=====	=====	=====	=====	=====
JANUARY -2004	ND	ND	26	207	61	ND
FEBRUARY -2004	ND	5.6	25	117	21	ND
MARCH -2004	ND	ND	26	117	20	ND
APRIL -2004	ND	ND	49	241	49	ND
MAY -2004	ND	ND	82	75	72	ND
JUNE -2004	0.2	3.2	113	157	156	0.10
JULY -2004	0.2	1.9	66	232	130	ND
AUGUST -2004	0.4	5.8	47	175	114	ND
SEPTEMBER-2004	0.4	1.0	16	112	126	ND
OCTOBER -2004	0.2	1.5	10	124	152	ND
NOVEMBER -2004	NS	NS	NS	NS	NS	NS
DECEMBER -2004	ND	1.0	25	44	65	ND
=====	=====	=====	=====	=====	=====	=====
Annual Average:	0.1	1.8	44	146	88	0.01

Analyte:	Nickel	Selenium	Thallium	Chloride	Fluoride	Sulfate
MDL and Units:	14 UG/L	0.28 UG/L	40 UG/L	7 MG/L	.05 MG/L	0.5 MG/L
Limit:	100	50	2	300	1	300
=====	=====	=====	=====	=====	=====	=====
JANUARY -2004	ND	0.67	ND	237	0.4	228
FEBRUARY -2004	ND	0.65	ND	229	0.4	199
MARCH -2004	ND	0.70	ND	219	0.4	211
APRIL -2004	ND	0.76	ND	230	0.4	203
MAY -2004	ND	0.59	ND	215	0.4	189
JUNE -2004	7	0.60	ND	243	0.4	200
JULY -2004	5	0.55	ND	229	0.3	197
AUGUST -2004	11	0.52	ND	231	0.4	194
SEPTEMBER-2004	6	0.48	ND	221	0.4	195
OCTOBER -2004	8	0.81	ND	241	0.4	190
NOVEMBER -2004	NS	NS	NS	NS	NS	NS
DECEMBER -2004	6	0.88	ND	214	0.4	224
=====	=====	=====	=====	=====	=====	=====
Annual Average:	4	0.66	ND	228	0.4	203

ND= Not Detected

NR= Not Required

NS= No samples obtained for monthly parameters, plant down for reconfiguration.

City of San Diego

Annual Report 2004 - North City Water Reclamation Plant - Reclaimed Water - Annual & Monthly Averages

Analyte:	Total Cyanides	MBAS Surfactants	Total Organic Carbon	Percent Sodium	Adjusted Sodium Adsorption	Calcium
MDL and Units:	.002 MG/L	.03 MG/L	0.250 MG/L	Calculated	Calculated	.08 MG/L
Limit:	0.2				6	
JANUARY -2004	ND	0.11	8.1*	63	6.6	74.0
FEBRUARY -2004	0.0086	0.13	NA	60	5.2	66.0
MARCH -2004	ND	0.10	7.6	56	4.9	67.5
APRIL -2004	ND	0.14	9.4	58	4.8	64.0
MAY -2004	0.0044	0.18	8.1	59	4.9	57.0
JUNE -2004	0.0069	0.11	8.7	59	4.9	66.7
JULY -2004	0.0129	0.17	8.7	60	5.0	60.3
AUGUST -2004	0.0108	0.20	8.5	62	5.2	55.4
SEPTEMBER-2004	0.0098	0.15	9.0	60	4.9	59.2
OCTOBER -2004	0.0083	0.30	7.7	58	4.7	62.9
NOVEMBER -2004	NS	NS	NS	NS	NS	NS
DECEMBER -2004	0.0050	0.12	6.5	52	4.5	80.1
Annual Average:	0.0061	0.16	8.2	59	5.1	64.8

Analyte:	Magnesium	Potassium	Sodium	Calcium Hardness	Magnesium Hardness	Total Hardness
MDL and Units:	.02 MG/L	2 MG/L	.3 MG/L	0.2 MG/L	0.08 MG/L	0.08 MG/L
Limit:						
JANUARY -2004	31.1	14.6	262	185	128	313
FEBRUARY -2004	29.5	10.6	190	165	121	286
MARCH -2004	30.9	12.2	181	169	127	296
APRIL -2004	29.4	15.4	189	160	121	281
MAY -2004	27.3	12.6	177	143	112	255
JUNE -2004	30.8	14.5	193	167	126	293
JULY -2004	28.4	14.3	195	151	116	267
AUGUST -2004	26.2	13.9	198	139	107	246
SEPTEMBER-2004	27.5	14.2	190	148	113	261
OCTOBER -2004	26.8	13.2	183	157	110	267
NOVEMBER -2004	NS	NS	NS	NS	NS	NS
DECEMBER -2004	33.8	12.0	179	200	139	339
Annual Average:	29.2	13.4	194	162	120	282

Analyte:	Total Dissolved Solids	Lithium	Cobalt	Molybdenum	Vanadium
MDL and Units:	42 MG/L	.01 MG/L	4 UG/L	3 UG/L	7 UG/L
Limit:	1200				
JANUARY -2004	913	0.06	ND	NR	NR
FEBRUARY -2004	886	0.04	ND	ND	ND
MARCH -2004	901	0.02	ND	5.9	ND
APRIL -2004	917	0.04	ND	NR	ND
MAY -2004	906	0.05	ND	4.9	ND
JUNE -2004	967	0.05	ND	13.3	0.8
JULY -2004	940	0.03	ND	9.8	0.6
AUGUST -2004	970	0.03	ND	10.3	1.1
SEPTEMBER-2004	925	0.03	ND	10.6	0.9
OCTOBER -2004	978	0.03	ND	8.7	0.9
NOVEMBER -2004	1040	NS	NS	NS	NS
DECEMBER -2004	953	0.04	ND	7.9	0.6
Annual Average:	941.3	0.04	ND	7.93	0.490

ND= Not Detected

NR= Not Required

NS= No samples obtained for monthly parameters, plant down for reconfiguration.

* = Sample was analyzed out of holding time, is shown for review only, and is not included in averages.

Wastewater Chemistry Laboratory • Environmental Monitoring and Technical Services Division
Metropolitan Wastewater Department • Calif. ELAP Cert. No. 1609 and 2477