DEFERRED SUBMITTAL

DEFERRED SUBMITTAL(S) SHALL BE PROVIDED FOR THE FOLLOWING BUILDING COMPONENTS/ELEMENTS:

1. SUBMITTAL DOCUMENTS FOR DEFERRED SUBMITTAL ITEMS SHALL BE SUBMITTED TO THE BUILDING OFFICIAL FOR REVIEW AND APPROVAL BY THE PROJECT ARCHITECT, AND NOT BY THE INDIVIDUAL SUB-CONTRACTOR / CONSULTANT.
2. DEFERRED SUBMITTAL DOCUMENTS IN ADDITION TO THE SEAL OF THE RESPONSIBLE ENGINEER, SHALL BEAR THE SHOP DRAWING APPROVAL STAMPS OF THE PROJECT ARCHITECT, ENGINEER OF RECORD, AND THE GENERAL CONTRACTOR ON ALL SHEETS OF PLANS AND COVER OF THE CALCULATIONS.
3. SUBMITTAL DOCUMENTS FOR DEFERRED SUBMITTAL ITEMS SHALL BE SUBMITTED IN A TIMELY MANNER THAT ALLOWS A MINIMUM OF THIRTY CALENDAR DAYS FOR THE INITIAL PLAN REVIEW TURN-AROUND.
4. DEFERRED SUBMITTAL ITEMS SHALL NOT BE FABRICATED / INSTALLED UNTIL THEIR DESIGN AND SUBMITTAL DOCUMENTS HAVE BEEN APPROVED BY THE BUILDING OFFICIAL.
5. PROVIDE TWO COPIES OF DEFERRED SUBMITTAL DOCUMENTS FOR FINAL APPROVAL.

VICINITY MAP

HOLD ORDER MAP

ADDITIONAL INFORMATION

CHECK EACH APPLICABLE OVERLAY ZONE

- ☐ AIRPORT APPROACH
- ☐ AIRPORT ENVIRONS
- ☐ COASTAL
- ☐ COASTAL HEIGHT LIMIT
- ☐ SENSITIVE COASTAL
- ☐ MOBILE HOME PARK
- ☐ PARKING IMPACT
- ☐ RESIDENTIAL TANDEM PARKING
- ☐ TRANSIT AREA
- ☐ URBAN VILLAGE
- ☐ MISSION TRAILS DESIGN DISTRICT
- ☐ CLAIREMONT MESA HEIGHT LIMIT
- ☐ COMMUNITY PLAN IMPLEMENTATION

CHECK IF PROPOSED SITE IS ON OR ADJACENT TO ...

- ☐ SENSITIVE BIOLOGICAL RESOURCES
- ☐ STEEP HILLSIDES
- ☐ COASTAL BEACHES
- ☐ SENSITIVE COASTAL BLUFFS
- ☐ 100 YEAR FLOODPLAIN

BASIS FOR STRUCTURAL DESIGN

DESIGN LOADS:

SEISMIC CRITERIA:

DISTANCE TO SEISMIC SOURCE:
SOIL PROFILE TYPE:
DESIGN WIND:

FOUNDATIONS / SOILS CRITERIA:

☐ SOILS ENGINEER:
REPORT NO.:

☐ EXPANSION INDEX HAS BEEN DETERMINED TO BE GREATER THAN 20 AND THE RECOMMENDATIONS OF THE SOILS ENGINEER HAVE BEEN INCORPORATED INTO THESE PLANS.

☐ EXPANSION INDEX HAS BEEN DETERMINED TO BE 20 OR LESS AND NO SPECIAL DESIGN RECOMMENDATIONS ARE REQUIRED.

☐ AS A LICENSED ARCHITECT/ENGINEER, I HAVE CLASSIFIED THE UNDISTURBED NATIVE SOILS TO BE ________ AND PER TABLE 18-1-A OF THE 1998 CBC I HAVE ASSIGNED THE FOLLOWING SOILS PARAMETERS FOR THE DESIGN OF THE FOUNDATION RELATED ELEMENTS OF THIS PROJECT:

NAME (PRINT) SIGNATURE DATE ☐ LICENSED ARCHITECT ☐ LICENSED ENGINEER

☐ A FOUNDATION PRESSURE OF 1000 PSF HAS BEEN USED TO DESIGN FOUNDATIONS SUPPORTED ON UNCLASSIFIED, UNDISTURBED NATIVE SOILS. THE FOUNDATIONS WILL BE LOCATED ENTIRELY IN UNDISTURBED NATIVE SOILS.

NAME (PRINT) SIGNATURE DATE ☐ OWNER ☐ LICENSED ARCHITECT ☐ LICENSED ENGINEER

☐ IF THE BUILDING INSPECTOR SUSPECTS FILL, EXPANSIVE SOILS OR ANY GEOLOGIC INSTABILITY BASED UPON OBSERVATION OF THE FOUNDATION EXCAVATION, A SOILS OR GEOLOGICAL REPORT, AND RESUBMITTAL OF PLANS TO PLAN CHECK TO VERIFY THAT THE REPORT RECOMMENDATIONS HAVE BEEN INCORPORATED MAY BE REQUIRED.

SPECIAL INSPECTION & OFF-SITE FABRICATION

SPECIAL INSPECTION: ☐ YES ☐ NO

SPECIAL INSPECTION SHALL BE PROVIDED FOR THE FOLLOWING ITEMS:

REFER TO SHEET___ FOR "SPECIAL INSPECTION PROGRAM".

1. A CERTIFICATE OF SATISFACTORY COMPLETION OF WORK REQUIRING SPECIAL INSPECTION MUST BE COMPLETED AND SUBMITTED TO THE INSPECTION SERVICES DIVISION.

OFF-SITE FABRICATION ☐ YES ☐ NO

1. AN APPLICATION TO PERFORM OFF-SITE FABRICATION MUST BE SUBMITTED TO THE INSPECTION SERVICES DIVISION FOR APPROVAL PRIOR TO FABRICATION.
2. A CERTIFICATE OF COMPLIANCE FOR OFF-SITE FABRICATION MUST BE COMPLETED AND SUBMITTED TO THE INSPECTION SERVICES DIVISION PRIOR TO ERECTION OF PREFABRICATED COMPONENTS.

STRUCTURAL OBSERVATION

STRUCTURAL OBSERVATION ☐ YES ☐ NO

STRUCTURAL OBSERVATION SHALL BE PROVIDED FOR THE FOLLOWING ITEMS:

REFER TO SHEET___ FOR "STRUCTURAL OBSERVATION PROGRAM".

1. STRUCTURAL OBSERVATION MUST BE PROVIDED BY THE ENGINEER OR ARCHITECT OF RECORD RESPONSIBLE FOR THE STRUCTURAL DESIGN, OR ANOTHER ENGINEER OR ARCHITECT DESIGNATED BY THE ENGINEER OR ARCHITECT RESPONSIBLE FOR THE STRUCTURAL DESIGN, AS OUTLINED IN THE STRUCTURAL OBSERVATION PROGRAM. ALL OBSERVED DEFICIENCIES SHALL BE REPORTED IN WRITING TO THE OWNER'S REPRESENTATIVE, SPECIAL INSPECTOR, CONTRACTOR AND THE BUILDING OFFICIAL. THE STRUCTURAL OBSERVER SHALL SUBMIT TO THE BUILDING OFFICIAL A WRITTEN STATEMENT THAT THE SITE VISITS HAVE BEEN MADE AND IDENTIFYING ANY REPORTED DEFICIENCIES THAT, TO THE BEST OF THE STRUCTURAL OBSERVER'S KNOWLEDGE, HAVE NOT BEEN RESOLVED.

ACCESSIBILITY REQUIREMENTS

FOR EXISTING BUILDINGS / PORTIONS

1. I AM THE DESIGNER/OWNER IN RESPONSIBLE CHARGE OF THIS ADDITION/ALTERATION PROJECT; I HAVE INSPECTED THE SITE/PREMISES AND DETERMINED THAT EXISTING CONDITIONS,
   ☐ ARE
   ☐ AS IMPROVED PER THESE PLANS, WILL
   IN FULL COMPLIANCE WITH CURRENT SITE ACCESSIBILITY REQUIREMENTS TO THE EXTENT REQUIRED BY LAW.

   NAME (PRINT) SIGNATURE DATE ☐ DESIGNER ☐ OWNER

2. I AM THE DESIGNER/OWNER IN RESPONSIBLE CHARGE OF THIS ADDITION / ALTERATION PROJECT; I HAVE INSPECTED THE SITE/PREMISES AND DETERMINED THAT EXISTING RESTROOM(S) SERVING AREA(S) OF ALTERATION,
   ☐ ARE
   ☐ AS IMPROVED PER THESE PLANS, WILL BE
   FULLY ACCESSIBLE ACCORDING TO CURRENT REQUIREMENTS.

   NAME (PRINT) SIGNATURE DATE ☐ DESIGNER ☐ OWNER

3. IF THE BUILDING INSPECTOR DETERMINES NONCOMPLIANCE WITH ANY CURRENT ACCESSIBILITY PROVISIONS OF THE LAW, HE/SHE SHALL REQUIRE SUBMITTAL OF COMPLETE AND DETAILED PLANS TO THE BUILDING DEVELOPMENT REVIEW DIVISION OF THE DEVELOPMENT SERVICES DEPARTMENT FOR FURTHER REVIEW. PLANS MUST CLEARLY SHOW ALL EXISTING NON-COMPLYING CONDITIONS AFFECTED BY THE REMODEL (INCLUDING SITE PLAN, FLOOR PLAN, DETAILS, ETC.) AND PROPOSED MODIFICATIONS OF DEFICIENCIES TO MEET CURRENT ACCESSIBILITY PROVISIONS. THE PLANS MUST BE STAMPED BY THE FIELD INSPECTOR PRIOR TO SUBMITTAL FOR PLAN REVIEW.

PROJECT TEAM

ARCHITECT: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

CIVIL ENGINEER: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

STRUCTURAL ENGINEER: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

ELECTRICAL: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

MECHANICAL: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

SOILS ENGINEER: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

LANDSCAPING: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

ACOUSTICAL: NAME
ADDRESS
CITY, STATE ZIP
PHONE #:
FAX #:
CONTACT:

INFORMATION INDEX

ITEM

- SITE PLAN ________
- FLOOR PLAN(S) ________
- ROOF PLAN ________
- ARCHITECTURAL ELEVATIONS ________
- BUILDING SECTIONS ________
- DOOR, WINDOW, FINISH SCHEDULES ________
- ARCHITECTURAL DETAILS ________
- STRUCTURAL NOTES ________
- FOUNDATION PLAN ________
- FLOOR AND ROOF FRAMING PLANS ________
- STRUCTURAL DETAILS ________
- MECHANICAL PLAN(S) ________
- PLUMBING PLAN(S) ________
- ELECTRICAL PLAN(S) ________
- ENERGY CALCULATIONS ________
- TOPOGRAPHIC SURVEY ________
- GRADING & DRAINAGE PLANS ________
- LANDSCAPE PLAN(S) ________
- BRUSH MANAGEMENT PLAN(S) ________
- ACCESSIBLE PATH OF TRAVEL ________
- ACCESSIBLE PARKING ________
- MEANS OF EGRESS PLAN(S) ________
- LOCATION, SIZE & TYPE OF ALL EXISTING AND PROPOSED;
- WATER METERS, WATER SERVICES & MAINS ________
- CROSS CONNECTION CONTROL DEVICES ________
- SEWER LATERALS AND MAINS ________

STRUCTURAL NOTES

1. ALL REQUIRED APPROVALS MUST BE OBTAINED FROM THE FIRE AND HAZARD PREVENTION SERVICES BEFORE THE BUILDING IS OCCUPIED.
2. EXIT DOORS TO BE OPERABLE FROM THE INSIDE WITHOUT THE USE OF A KEY OR ANY SPECIAL KNOWLEDGE OR EFFORT.
3. FIRE AND/OR SMOKE DAMPER ASSEMBLIES, INCLUDING SLEEVES, AND INSTALLATION PROCEDURES SHALL BE APPROVED BY THE INSPECTION SERVICES DIVISION PRIOR TO INSTALLATION.
4. ELEVATOR DOORS MUST BE INSTALLED IN ACCORDANCE WITH THE APPROVAL ON THE AFFIXED FIRE RESISTANCE APPROVAL LABEL. WHERE ELEVATOR DOORS ARE NOT IDENTIFIED WITH APPROVED LABELS, THEY MUST BE INSTALLED IN THE SAME MANNER AS A ______ HOUR FIRE ASSEMBLY.
5. ELEVATOR LOBBIES SHALL HAVE ACCESS TO NOT LESS THAN ONE EXIT/EXIT ACCESS DOOR. SUCH DOOR(S) IN THE EXIT PATH FROM THE ELEVATOR LOBBY SHALL BE OPERABLE FROM THE INSIDE WITHOUT THE USE OF A KEY OR ANY SPECIAL KNOWLEDGE OR EFFORT PER CBC SEC. 1004.2.3.3
6. PROP "D" HEIGHT LIMIT AREA ☐ YES ☐ NO

   THE HIGHEST POINT OF THE ROOF, EQUIPMENT, OR ANY VENT, PIPE, ANTENNA, OR OTHER PROJECTION SHALL NOT EXCEED 30'-0" ABOVE GRADE. REFER TO SHEETS ________ FOR BUILDING HEIGHT DOCUMENTATION.

ELECTRICAL NOTES

1. ALL ELECTRICAL WORK SHALL COMPLY WITH THE 1998 CALIFORNIA ELECTRICAL CODE.
2. ALL OUTDOOR LIGHTING SHALL COMPLY WITH THE CITY OF SAN DIEGO LIGHTING POLLUTION ORDINANCE.
3. ALL INTERIOR LIGHTING SYSTEMS SHALL COMPLY WITH CALIFORNIA ENERGY COMMISSION STANDARDS.

MECHANICAL NOTES

1. LAVATORY FAUCETS IN RESTROOMS OF COMMERCIAL PROJECTS SHALL BE THE SELF-CLOSING TYPE.
2. SHOWERS AND TUB/SHOWER COMBINATIONS SHALL BE PROVIDED WITH MIXING VALVES PER CPC SEC. 420.0.
3. EACH FAUCET SHALL NOT EXCEED A WATER FLOW RATE OF 2.2 GPM.
4. EACH SHOWERHEAD SHALL NOT EXCEED A WATER FLOW RATE OF 2.5 GPM.
5. EACH TOILET SHALL BE THE ULTRA LOW FLUSH TYPE.
6. EACH URINAL SHALL HAVE A WATER CONSUMPTION OF NOT MORE THAN 1 GALLON PER FLUSH.
7. VACUUM BREAKERS SHALL BE PROVIDED AT ALL HOSE BIBBS.
8. FLOOR DRAINS OR SIMILAR TRAPS DIRECTLY CONNECTED TO THE DRAINAGE SYSTEM AND SUBJECT TO INFREQUENT USE SHALL BE PROVIDED WITH AN APPROVED AUTOMATIC MEANS OF MAINTAINING THEIR WATER SEALS .
9. INSULATION MATERIAL SHALL MEET THE CALIFORNIA QUALITY STANDARDS PER ENERGY EFFICIENCY STANDARDS SEC. 118.
10. DOORS AND WINDOWS SHALL MEET THE MINIMUM INFILTRATION REQUIREMENTS PER ENERGY EFFICIENCY STANDARDS SEC. 116.
11. ALL PIPING AND DUCTWORK SHALL BE INSULATED CONSISTENT WITH THE REQUIREMENTS OF ENERGY EFFICIENCY STANDARDS SEC. 118, 123, 124 AND CMC TABLE 6-D AS APPLICABLE.
12. ALL HVAC SYSTEMS SHALL MEET THE CONTROL REQUIREMENTS OF ENERGY EFFICIENCY STANDARDS SEC. 112, 122 AS APPLICABLE.
13. ALL HVAC EQUIPMENT AND APPLIANCES SHALL MEET THE REQUIREMENTS OF ENERGY EFFICIENCY STANDARDS SEC. 111, 115, 120-129 AS APPLICABLE.
14. SERVICE WATER HEATING SYSTEMS AND EQUIPMENT SHALL COMPLY WITH ENERGY EFFICIENCY STANDARDS SEC. 113.
15. SWIMMING POOL AND SPA HEATING SYSTEMS AND EQUIPMENT SHALL COMPLY WITH ENERGY EFFICIENCY STANDARDS SEC. 114.
16. SMOKE DETECTORS SHALL BE PROVIDED AT SUPPLY AIR DUCTS OF AIR MOVING SYSTEMS EXCEEDING 2000 CFM PER CMC SEC. 608.
17. PERMANENT LADDER/ACCESS TO ROOF MOUNTED EQUIPMENT SHALL COMPLY WITH CMC SEC. 307.
18. BUILDING DRAIN AND VENT PIPING MATERIALS SHALL COMPLY WITH CPC SEC. 701.0.
19. ALL SANITARY SYSTEM MATERIALS SHALL BE LISTED BY AN APPROVED LISTING AGENCY.
20. CHEMICAL WASTE PIPING SHALL COMPLY WITH CPC SEC. 811.0.
21. ALL STORAGE WATER HEATING EQUIPMENT SHALL BE PROVIDED WITH AN APPROVED, LISTED EXPANSION TANK OR OTHER DEVICE DESIGNED FOR INTERMITTENT OPERATION FOR THERMAL EXPANSION CONTROL PER CPC SEC. 608.3.
22. CROSS CONNECTION PROTECTION SHALL BE PROVIDED AT ALL POTABLE WATER SUPPLIED APPLIANCES AND EQUIPMENT EXCEPT THOSE SPECIFIC ITEMS LISTED IN INFORMATION BULLETIN 103.
23. WATER HEATERS SHALL BE ANCHORED OR STRAPPED TO RESIST HORIZONTAL DISPLACEMENTS DUE TO SEISMIC MOTION PER CPC SEC. 510.5.
24. MATERIALS EXPOSED WITHIN A DUCT OR PLENUM SHALL COMPLY WITH CMC SEC. 601.1.3.
25. CHLORINATED POLYVINYL CHLORIDE (CPVC) SHALL NOT BE USED FOR INTERIOR WATER SUPPLY PIPING PER STATE HEALTH & SAFETY CODE SEC. 17921.9.
26. HVAC EQUIPMENT AND WATER HEATERS SHALL COMPLY WITH CMC CHAP. 3.
27. MEDIUM PRESSURE GAS PIPING SHALL BE LABELED EVERY FIVE FEET.
28. MECHANICAL VENTILATION, WHEN REQUIRED IN RESIDENTIAL BATHROOMS AND LAUNDRY ROOMS AS APPLICABLE PER CBC SEC. 1203.3, SHALL PROVIDE A MINIMUM OF FIVE AIR CHANGES PER HOUR AND BE ROUTED TO THE EXTERIOR.

FIRE NOTES

1. BUILDINGS UNDERGOING CONSTRUCTION, ALTERATION OR DEMOLITION SHALL BE IN ACCORDANCE WITH CFC ARTICLE 87 (UFC/CFC SEC. 8701.
2. ADDRESS SHALL BE PROVIDED FOR ALL NEW AND EXISTING BUILDINGS IN A POSITION AS TO BE PLAINLY VISIBLE AND LEGIBLE FROM THE STREET OR ROAD FRONTING THE PROPERTY (UFC/CFC SEC. 901.4.4, FHPS POLICY P-00-6.
3. DECORATIVE MATERIALS SHALL BE MAINTAINED IN A FLAME RETARDANT CONDITION. (CAL CODE REGS., TIT. 19, SEC. 3.08, 3.21, UFC/CFC SEC. 2501.5.
4. AT LEAST ONE FIRE EXTINGUISHER WITH A MINIMUM RATING OF 2A10BC SHALL BE PROVIDED WITHIN 75' MAXIMUM TRAVEL DISTANCE FOR EACH 6000 SQ. FT. OR PORTION THEREOF ON EACH FLOOR. (UFC/CFC SEC. 1002, UFC STANDARD 10-1, CAL. CODE REGS., TIT. 19, 3.29.
5. COMPLETE PLANS AND SPECIFICATIONS FOR FIRE ALARM SYSTEMS; FIRE-EXTINGUISHING SYSTEMS, INCLUDING AUTOMATIC SPRINKLERS AND WET & DRY STANDPIPES; HALON SYSTEMS AND OTHER SPECIAL TYPES OF AUTOMATIC FIRE -EXTINGUISHING SYSTEMS; BASEMENT PIPE INLETS; AND OTHER FIRE-PROTECTION SYSTEMS AND APPURTENANCES THERETO SHALL BE SUBMITTED TO FIRE AND HAZARD PREVENTION SERVICES FOR REVIEW AND APPROVAL PRIOR TO INSTALLATION. (UFC/CFC SEC. 1001.3)
6. FIRE-EXTINGUISHING SYSTEMS SHALL BE INSTALLED IN ACCORDANCE WITH UBC/CBC SEC. 904 AND COMPLY WITH UBC STANDARDS 9-1 AND 9-2.
7. ALL VALVES CONTROLLING THE WATER SUPPLY FOR AUTOMATIC SPRINKLER SYSTEMS AND WATER FLOW SWITCHES ON ALL SPRINKLER SYSTEMS SHALL BE ELECTRONICALLY MONITORED WHERE THE NUMBER OF SPRINKLERS IS 100 OR MORE. (UBC/CBC SEC. 1003.3.1)
8. FIRE ALARM SYSTEMS SHALL BE IN ACCORDANCE WITH UFC/CFC SEC. 1007.
9. AT LEAST ONE FIRE EXTINGUISHER WITH A MINIMUM RATING OF 4-A-20BC SHALL BE PROVIDED OUTSIDE EACH MECHANICAL, ELECTRICAL, OR BOILER ROOM. (UFC/CFC SEC. 1002, UFC STANDARD 10-1, CAL. CODE REGS., TIT 19, SEC. 3.29)
10. FIRE PROTECTION, INCLUDING FIRE APPARATUS ACCESS ROADS AND WATER SUPPLIES FOR FIRE PROTECTION, SHALL BE INSTALLED AND MADE SERVICEABLE PRIOR TO AND DURING TIME OF CONSTRUCTION. (UFC/CFC SEC. 901.3, 8704.2, 8704.3)
11. FIRE HYDRANTS SHALL COMPLY WITH FHPS POLICY F-96-01 FOR ON-SITE FIRE HYDRANTS.
12. FIRE HYDRANT LOCATIONS SHALL BE IDENTIFIED BY THE INSTALLATION OF REFLECTIVE MARKERS. (UFC/CFC SEC. 901.4.3)
13. PROVIDE AN APPROVED ILLUMINATED DIRECTORY CONSTRUCTED IN ACCORDANCE WITH FHPS POLICY I-00-6. COMPLETE, FULLY DIMENSIONED PLANS SHOWING MATERIALS, METHOD OF CONSTRUCTION AND LOCATION OF INSTALLATION SHALL BE SUBMITTED TO FIRE AND HAZARD PREVENTION SERVICES FOR REVIEW AND APPROVAL. (UFC/CFC SEC. 901.4.4)

DETAILED SCOPE OF WORK

BUILDING CODE DATA

TYPE OF CONSTRUCTION: SPRINKLERED: ☐ YES ☐ NO
OCCUPANCY CLASSIFICATION(S):
NUMBER OF STORIES:
BUILDING HEIGHT:
GOVERNING CODES: 1998 CBC, CEC, CFC, CMC, CPC; 2001 EES; CCR TITLE 19

FLOOR AREA ANALYSIS

OPEN YARDS:___ SIDES, MIN.WIDTH ________ ft, ___% INCREASE
NOTE: OPEN YARDS USED FOR FLOOR AREA INCREASE SHALL BE MAINTAINED THROUGHOUT THE LIFE OF THE BUILDING.

OCCUPANCIES					
BASIC AREA, ft² PER TABLE 5-B (a)					
AREA INCREASE MULTIPLIER FOR OPEN YARDS PER SEC. 505.1 (b)					
AREA INCREASE MULTIPLIER FOR SPRINKLERS ONE-STORY PER SEC. 505.3 (c)	3	3	3	3	3
AREA INCREASE MULTIPLIER FOR SPRINKLERS MULTI-STORY PER SEC. 505.3 (d)	2	2	2	2	2
AREA INCREASE MULTIPLIER FOR MULTI-STORY BUILDINGS PER SEC. 504.2 (e)	2	2	2	2	2
ALLOWABLE AREA ONE-STORY, ft² (a)x(b)x(c)					
ALLOWABLE AREA MULTI-STORY, ft² (a)x(b)x(d)x(e)					

FLOOR AREAS PER OCCUPANCY:

OCCUPANCIES / FLOORS	ft²	ft²	ft²	ft²	SUM / FLOOR ft²
4th					
3rd					
2nd					
1st					
SUM / OCCUPANCY					
1st BASEMENT					
2nd BASEMENT					

CHECK OVERALL BUILDING;

CHECK EACH FLOOR AND BASEMENT;

PROJECT DATA

PROJECT NAME:
PROJECT ADDRESS: ADDRESS
SAN DIEGO, CALIFORNIA ZIP
HISTORIC: ☐ YES ☐ NO U.R.M.: ☐ YES ☐ NO
SUBMITTAL DATE: / /
ZONE:
OWNER: NAME(S)
ADDRESS
CITY, STATE -ZIP
PHONE NUMBER
MAP NUMBER:
BLOCK NUMBER:
LOT NUMBER:
A.P.N.:
F.A.R.:
LEGAL DESCRIPTION:

PLAN FILE NO.:
PERMIT NO(S).:

PROJECT:

DESIGNER:

REVISIONS:
△ ________
△ ________
△ ________
△ ________
△ ________
△ ________

CITY OF SAN DIEGO

DEVELOPMENT SERVICES DEPARTMENT

IN CASE OF CONFLICT, THE REQUIREMENTS OF THIS SHEET SHALL SUPERSEDE THOSE PROVIDED IN THE OTHER SHEETS OF PLANS

STAMP & SIGNATURE:

VERSION: 1.1
REVISED: 6/7/01

SHEET TITLE:

SHEET NUMBER: