


NOTES:

1. BACKFLOW PREVENTER ASSEMBLY SHALL BE TESTED UPON INSTALLATION BY A CERTIFIED BACKFLOW ASSEMBLY TESTER. CONTRACTOR SHALL FURNISH THE ENGINEER WITH WRITTEN TEST RESULTS COMPLETED BY A CERTIFIED BACK FLOW TESTER PRIOR TO BACKFLOW PREVENTER ASSEMBLY'S ACCEPTANCE.
2. ALL PIPE BELOW GRADE SHALL BE TRAPPED AS REQUIRED BY THE SPECIFICATIONS.
3. CONCRETE PAD SHALL BE 2" ABOVE GRADE UNLESS INSTALLED IN LAWN AREA WHERE IT WILL BE AT 1" ABOVE GRADE. SLOPE TO DRAIN.
4. VALVE SUPPORTS AS REQUIRED BY SPECIFICATIONS.
5. LOCATION SHALL BE APPROVED BY PUBLIC UTILITIES DEPARTMENT, WATER OPERATIONS DIVISION, METER/BACKFLOW GROUP AND SHOWN ON PLANS.

ITEMS CALL OUT:

- ① REDUCED PRESSURE PRINCIPLE DETECTION ASSEMBLY SHALL BE INCLUDED IN THE LATEST EDITION OF THE "APPROVED FOR SERVICE ISOLATION CALIFORNIA PUBLIC WATER SYSTEM" ISSUED BY THE STATE OF CALIFORNIA DEPARTMENT OF HEALTH SERVICES, OFFICE OF DRINKING WATER.
- ② 90° FLANGED CAST IRON OR DUCTILE IRON ELBOW (TYP).
- ③ FLANGED DUCTILE IRON SPOOL. BOTH ENDS SHALL BE FLANGED (UNI-FLANGE SHALL NOT BE USED).
- ④ 90° DUCTILE IRON FLANGED ELBOW.

LEGEND ON PLANS



REVISION	BY	APPROVED	DATE
ORIGINAL	LC	J. NAVARRO	6/00
UPDATED	KA	J. NAGELVOORT	01/12
UPDATED	HM	J. NAGELVOORT	02/16
DELETED	PUD	J. NAGELVOORT	10/16

CITY OF SAN DIEGO - STANDARD DRAWING

**BACKFLOW PREVENTER REDUCED PRESSURE PRINCIPLE DETECTOR ASSEMBLY FOR FIRE SERVICE 3" AND LARGER**

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

*CA Bungea 10/4/16*

COORDINATOR R.C.E. 56523 DATE

DRAWING NUMBER **SDW-120**