



NOTES:

1. DESIGN OF STORMWATER INFRASTRUCTURE SHALL CONFORM TO THE STORMWATER STANDARDS MANUAL AND DRAINAGE DESIGN MANUAL, AND SHALL BE SUBJECT TO REVIEW. USE OF THIS DETAIL DOES NOT PRECLUDE SUCH REQUIREMENTS.
2. RIP RAP SHALL BE PLACED IN IRREGULAR PATTERN USING NON-UNIFORM SIZES. THICKNESS OF MORTAR AND SIZE OF RIP RAP SHALL BE PER PLAN. RIP RAP SHALL HAVE A NON-EVEN TOP SURFACE AND MORTARED IN PLACE.
3. THIS DETAIL SHOULD NOT BE USED FOR OUTFALLS OR LARGER CHANNEL ENERGY DISSIPATION.
4. ENERGY DISSIPATION PAD SHALL EXTEND FROM THE CURB CUT INLET TO THE FULL WIDTH OF THE BIOFILTRATION AREA, PER SECTION A-A.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL	LT	R. AMEN	12/23		
				DRAWING NUMBER	SDSW-106