

FLOW LINE (FL)
ELEVATION PER PLAN

CURB AND GUTTER
PER SDG-151

DEPRESS FLOW LINE (FL) BY 1"

ENERGY DISSIPATION PAD
PER SDSW-106

6"

18"

6"

TAPERED
STREET
RELIEF

6" CURB

R = 3"

INLET TRANSITION
PER SDG-110
CURB & GUTTER
PER SDG-151

PLAN VIEW
NOT TO SCALE

CONCRETE LINER
PER SDSW-109, SDSW-110,
SDSW-111, SDSW-112,
SDSW-113

ENERGY DISSIPATION PAD
PER SDSW-106

1" MIN.

LIP OF GUTTER

EXISTING
FLOW LINE

SECTION A-A
NOT TO SCALE

LEGEND ON PLANS



6" 18" 6"

1" MIN

PROPOSED FLOW LINE

R=3"

SECTION B-B
NOT TO SCALE

NOTES

- DESIGN OF STORMWATER INFRASTRUCTURE SHALL CONFORM TO THE STORMWATER STANDARDS MANUAL AND DRAINAGE DESIGN MANUAL, AND SHALL BE SUBJECT TO REVIEW. USE OF THIS DETAIL DOES NOT PRECLUDE SUCH REQUIREMENTS.

REVISION	BY	APPROVED	DATE
ORIGINAL	LT	R. AMEN	12/23

CITY OF SAN DIEGO - STANDARD DRAWING

RECOMMENDED BY THE CITY
OF SAN DIEGO STANDARDS COMMITTEE

CURB CUT INLET

Alaine James 12/15/2023
COORDINATOR R.C.E. 81047 DATE

DRAWING
NUMBER

SDSW-107