



**Date of Notice:** March 26, 2024

# **NOTICE OF RIGHT TO APPEAL**

## **ENVIRONMENTAL DETERMINATION**

### **CITY PLANNING DEPARTMENT**

---

**PROJECT NAME/NUMBER:** Casa Del Prado Admin Building Piping Repair  
**COMMUNITY PLAN AREA:** Balboa Park  
**COUNCIL DISTRICT:** 3  
**LOCATION:** 1650 El Prado, San Diego CA 92101

**PROJECT DESCRIPTION:** Convert in-line backflow preventers to above ground double check-valve backflow preventers. The backflow preventer is part of the building's potable water system and is currently beyond repair. Work will include removing the failed system, installing the new system, and pressurizing the system to ensure that the building has water restored and is in compliance with City code. Work will not result in ground disturbance.

Replace approximately 80 ft. to 90 ft. of Heating Hot Water (HHW) riser piping and fittings between the boiler room and the rooftop penetration. Work will include the installation of necessary scaffolding, removal and disposal of approximately 80 ft. to 90 ft. of existing HHW riser piping and fittings between the boiler room and the roof top penetration, installation of approximately 80 ft. to 90 ft. of new HHW riser piping and fittings between the boiler room and the roof top penetration; installation of necessary piping insulation; and removal and replacement of a section of Outside Air (OSA) ducting to allow access to the piping.

**ENTITY CONSIDERING PROJECT APPROVAL:** City of San Diego

**ENVIRONMENTAL DETERMINATION:** Categorically exempt from CEQA pursuant to State CEQA Guidelines Section 15301 (Existing Facilities).

**ENTITY MAKING ENVIRONMENTAL DETERMINATION:** City of San Diego Mayor-Appointed Designee.

**STATEMENT SUPPORTING REASON FOR ENVIRONMENTAL DETERMINATION:**

The City of San Diego conducted an environmental review that determined the project would not have the potential for causing a significant effect on the environment pursuant to State CEQA Guidelines Section(s) 15301 (Existing Facilities) which consists of the operation, repair, maintenance, permitting, leasing, licensing, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of existing or former use. The exceptions listed in CEQA Guidelines Section 15300.2 would not apply in that no cumulative impacts were identified; no significant effects on the environment were identified; the project is not adjacent to a scenic highway; no historical resources would be affected by the action; and the project was not identified on a list of hazardous waste sites pursuant to Section 65962.5 of the Government Code.

**CITY CONTACT:** Amy Nonaka, Project Officer I, General Services  
**MAILING ADDRESS:** 1245 Caminito Centro, San Diego, CA 92102  
**PHONE NUMBER/E-MAIL:** (619) 525-8548 / [anonaka@sanidiego.gov](mailto:anonaka@sanidiego.gov)

---

On March 26, 2024, the City of San Diego made the above-referenced environmental determination pursuant to CEQA. This determination is appealable to the City Council. If you have any questions about this determination, contact the City Contact listed above.

Applications to appeal the CEQA determination to the City Council must be filed with the Office of the Clerk within five (5) business days from the date of the posting of this Notice (**April 03, 2024**). Appeals to the City Clerk must be filed via e-mail or in-person as follows:

1. Appeals filed via Email: The Environmental Determination Appeal Application Form [DS-3031](#) can be obtained at <https://www.sandiego.gov/sites/default/files/legacy/development-services/pdf/industry/forms/ds3031.pdf>. Send the completed appeal form (including grounds for appeal and supporting documentation in pdf format) by email to [Hearings1@sanidiego.gov](mailto:Hearings1@sanidiego.gov) by 5:00p.m. on the last day of the appeal period; your email appeal will be acknowledged within 24 business hours. You must separately mail the appeal fee by check payable to the City Treasurer to: City Clerk/Appeal, MS 2A, 202 C Street, San Diego, CA 92101. The appeal filing fee must be United States Postal Service (USPS) postmarked) before or on the final date of the appeal.
2. Appeals filed In-Person: The Environmental Determination Appeal Application Form [DS-3031](#) can be obtained at: <https://www.sandiego.gov/sites/default/files/legacy/development-services/pdf/industry/forms/ds3031.pdf>. Bring the fully completed appeal application [DS-3031](#) (including grounds for appeal and supporting documentation) to the City Administration Building— Public Information Counter (Open 8:00am to 5:00pm Monday through Friday excluding City approved holidays), 1st Floor Lobby, located at 202 C Street, San Diego, CA 92101, by 5:00pm on the last day of the appeal period. The completed appeal form shall include the required appeal fee, with a check payable to: City Treasurer.

The appeal application can also be obtained from the City Clerk, 202 'C' Street, Second Floor, San Diego, CA 92101.

This information will be made available in alternative formats upon request.

**POSTED ON THE CITY'S CEQA WEBSITE**

**POSTED: March 26, 2024**

**REMOVED:**

**POSTED: v. Sandoval**