

# WATER SUPPLY ASSESSMENT REPORT

# Clairemont Community Plan Update (IO # 21005493) March 2025

| PREPARED BY: | Sandra Carlson  | DATE: | 3/24/2025 |
|--------------|---|-------|-----------|
|              | Sandra Carlson, P.E., Associate Engineer                                  |       |           |
|              | $\Omega$  |       |           |
| REVIEWED BY: | a Ju  | DATE: | 3/24/2025 |
|              | Andrew Funk, Principal Water Resources Specialis                          | st    |           |
| APPROVED BY: | Toph Wh   | DATE: | 3/26/2025 |
|              | Keli Balo, Deputy Director<br>Engineering and Program Management Division |       |           |

# **Contents**

| Section 1. | Purpose  | 1-1 |
|------------|--|-----|
| Section 2. | Project Description  | 2-1 |
| Section 3. | WSA Findings   | 3-1 |
| Section 4. | City of San Diego Public Utilities Department                            | 4-1 |
| 4.1        | Overview of Potable System Facilities                                    | 4-1 |
| 4.2        | Overview of Recycled System Facilities                                   |     |
| 4.3        | Pure Water Program   | 4-3 |
| Section 5. | Existing and Projected Supply  | 5-1 |
| 5.1        | Metropolitan Water District of Southern California                       | 5-2 |
| 5.2        | San Diego County Water Authority   | 5-3 |
| 5.3        | Public Utilities Department  |     |
|            | 5.3.1 Demonstrating the Availability of Sufficient Supply                | 5-4 |
|            | 5.3.2 Plans for Acquiring Additional Supply                              |     |
|            | 5.3.3 Summary of Supply  |     |
| Section 6. | Projected Demand   | 6-1 |
| 6.1        | Water Sales to Other Agencies  | 6-3 |
|            | 6.1.1 Potable Water  | _   |
|            | 6.1.2 Recycled and Non-Revenue Water                                     | _   |
| 6.2        | Total Water Use  |     |
| 6.3        | Projected Single Dry Year Water Supply and Demand                        | -   |
| 6.4        | Projected Multiple Dry Year Water Supply and Demand                      |     |
| Section 7. | Conclusion   |     |
| -          | References   |     |
|            |  |     |
| Tables     |  |     |
| Section 2. | Project Description  | 2-1 |
| 2.1        | Clairemont CPU: Series 14 Housing Unit Projections                       |     |
| 2.2        | Existing and Proposed Residential Development for the Clairemont CPU     | 2-3 |
| 2.3        | Existing and Proposed Non-Residential Development for the Clairemont CPU | 2-3 |
| Section 3. | WSA Findings   | 3-1 |
| 3.1        | Planned Residential Water Demand for the Clairemont CPU                  | 3-2 |
| 3.2        | Planned Non-Residential Water Demand for the Clairemont CPU              | 3-2 |
| 3.3        | Water Demand for the Clairemont CPU                                      | 3-2 |
| 3.4        | Potential Water Supply for the Clairemont CPU                            | 3-3 |
| Section 4. | City of San Diego Public Utilities Department                            | 4-1 |
| 4.1        | City Reservoirs  |     |
| 4.2        | Water Treatment Plant Current Capacities                                 | 4-2 |

| Section 5. | Existing and Projected Supply   | 5-1  |
|------------|---|------|
| 5.1        | Current and Projected Local Service Water                                     | .5-5 |
| 5.2        | Historical Groundwater Supply to City from 2016-2020                          | .5-6 |
| 5.3        | Projected Ground Water Supply (AFY) to City                                   | .5-6 |
| 5.4        | PUD Historic Purchased, Local Surface, Groundwater, and Recycled Water Demand | d    |
|            | (AFY)   | .5-8 |
| Section 6. | Projected Demand  | 6-   |
| 6.1        | Past, Current, And Projected Water Deliveries                                 | .6-2 |
| 6.2        | Normal Year Demand vs. Supply for the City                                    | .6-3 |
| 6.3        | Sales to Other Agencies-Potable   | 6-2  |
| 6.4        | Additional Water Uses and Losses  | .6-2 |
| 6.5        | PUD's Projected Total Water Use   | .6-5 |
| 6.6        | Single Dry Year Demand vs. Supply for the City                                | .6-6 |
| 6.7        | Multiple Dry Year Demand vs. Supply for the City                              | .6-7 |
| Figures    |   |      |
| Section 2. | Project Description   | .2-1 |
|            | Project Site Map  |      |

### Section 1. PURPOSE

On January 1, 2002, Senate Bill 610 (SB 610) and Senate Bill 221 (SB 221) took effect. The intent of SB 610 and SB 221 was to improve the link between information on water supply availability and certain land-use decisions made by cities and counties. Under SB 610 (codified in the Water Code beginning at Section 10910), a water supply assessment (WSA) must be furnished to cities and counties for inclusion in any environmental documentation of projects (defined in the Water Code) that propose to construct 500 or more residential units, or that will use an amount of water equivalent to what would be used by 500 residential units and are subject to the California Environmental Quality Act (CEQA). Under SB 221, approval by a city or county of certain residential subdivisions requires an affirmative written verification of sufficient water supply or water supply verification (WSV).

Not every project that is subject to the requirements of SB 610 is also subject to the mandatory water verification of SB 221 (e.g., if subdivision map approval is not required). Conversely, not every project that is subject to the requirements of SB 221 must also obtain an SB 610 water supply assessment.

A foundational document for compliance for both SB 610 and SB 221 is the Urban Water Management Plan (UWMP) of the relevant water agency. Both statutes identify the UWMP as a planning document that can be used by a water supplier to meet the standards outlined in both statutes. Thorough and complete UWMPs will allow water suppliers to use UWMPs as a foundation to fulfill the specific requirements of the two statutes. Cities, counties, water districts, property owners and developers utilize this document when planning for and proposing new projects. It is crucial that cities, counties, and water suppliers work closely when developing and updating these planning documents. The City of San Diego's (City's) 2020 UWMP, which is used as the basis for this report (WSA), was adopted by the City Council in June 2021.

In developing forecast data for the 2020 UWMP, the City Public Utilities Department (PUD) utilized a hybrid approach that combined data including but not limited to current metered water use by billing code, projected variables based on the San Diego Association of Governments (SANDAG) Series 14 Growth Forecast, and geospatial analysis of developable and re-developable land areas. This new approach was a direct result of improvements in geospatial data matching metered water use to parcels, along with land use and demographic/socioeconomic data at the individual pressure zone level for the service area. This robust methodology provided the PUD with a water demand forecast to utilize for facility analysis and planning.

The City Planning Department requested the PUD prepare this WSA as part of the environmental review for the Clairemont Community Plan Update (IO # 21005493) (Project). A more detailed description of the Project is provided in Section 2. This WSA evaluates water supply that is or will be available during normal, single dry, and multiple dry water years over a 20-year period to meet the projected demand of the Project, in addition to identifying existing and planned future water demands for the City of San Diego service area. This WSA provides an assessment of the availability of sufficient water supply for the Project only and does not constitute approval of the Project.

This WSA also includes the identification of existing water supply entitlements, water rights, water service contracts, or agreements relevant to the identified water supply for the Project and quantities of water received in prior years pursuant to those entitlements, rights, contracts, and agreements.

This report has been prepared in compliance with the requirements under SB 610 by PUD in coordination the San Diego County Water Authority's (Water Authority's) 2020 UWMP.

# Section 2. PROJECT DESCRIPTION

The Clairemont Community Plan area encompasses approximately 8,500 acres within the City of San Diego and is generally bounded by State Route 52 (SR 52) on the north, Interstate 805 (I-805) on the east, Interstate 5 (I-5) on the west and the Linda Vista Community to the south. Clairemont is bordered by several other community planning areas, including Kearny Mesa to the east, Linda Vista to the south, and La Jolla, Pacific Beach, and Mission Beach to the west. Marine Corps Air Station (MCAS) is located north of the community planning area.

The Clairemont Community Plan area is 10 miles north of downtown San Diego. The community is an urbanized residential community with several shopping centers, parks, and recreational facilities and educational opportunities. The community has well-established single-family neighborhoods with streetscape parkways. The multifamily areas in Clairemont are traditionally located along major transportation corridors. The Clairemont Community Plan site map is shown on **Figure 2-1**.

The Project is an update to the Clairemont Community Plan. The proposed Clairemont Community Plan Update (Clairemont CPU) includes policies to create a network of parks and pedestrian and bicycle pathways that connect villages and destinations in the community, establish additional villages and neighborhood centers promoting a mix of employment and housing options, and provide housing and employment opportunities in proximity to transit. The proposed land uses will support mixed-use, transit-orientated, and pedestrian-friendly development. The proposed CPU provides long-range options and opportunities for new housing and employment. It does not require property owners to redevelop or mandate that development will happen.




Figure 2-1 Project Site Map

As discussed in Section 1, the City's 2020 UWMP incorporates the SANDAG Series 14 Growth Forecast and uses a hybrid approach to allocate the total water demand among the various pressure zones and community plans. As shown in **Table 2-1**, the SANDAG Series 14 Forecast indicates that the Clairemont Community could have 43,958 total housing units by 2045. The proposed Clairemont CPU could have 44,400 housing units in that same timeframe.

According to the Series 14 forecast, SANDAG estimated that the Clairemont Community had 33,045 existing homes in the year 2020, which leaves a capacity of 11,355 homes after the proposed update is completed. Therefore, due to the increased residential capacity proposed with the update to the Clairemont Community plan, approximately 454 homes are anticipated annually from 2020 to 2045.

A comparison of the existing and proposed residential development within the CPU boundary is tabulated in **Table 2-2**.

For non-residential development, there is expected to be an increase in acreage for industrial land use to provide opportunities for start-up and smaller base sector industries in the

technological, scientific, and professional services, and national security sectors. **Table 2-3** presents a comparison of the existing and proposed non-residential development within the CPU boundary.

Table 2-1 Clairemont CPU: Series 14 Housing Unit Projections

| Development   | SANDAG Series 14 Baseline Forecast<br>(Dwelling units (DUs)) |        | /S 111 |             |  | iremont CPU<br>Us |
|---------------|--|--------|--------|-------------|--|-------------------|
| Type          | 2020   | 2045   | 2045   | Beyond 2050 |  |                   |
| Multifamily   | 9,622  | 19,732 | 21,000 | 31,000      |  |                   |
| Single Family | 23,106   | 23,909 | 23,400 | 23,400      |  |                   |
| Mobile Home   | 317  | 317    | 0      | 0           |  |                   |
| Total Housing |  |        |        |             |  |                   |
| Units         | 33,045   | 43,958 | 44,400 | 54,400      |  |                   |

Source: City of San Diego 2020 UWMP, SANDAG Series 14 Growth Forecast, and City Planning Department, Request for the Preparation of a Water Supply Assessment for the Clairemont Community Plan Update (IO # 21005493), Updated December 13, 2024.

Table 2-2 Existing and Proposed Residential Development for the Clairemont CPU

|                     | Baseline 2045 <sup>1</sup> | Proposed CPU 2045 <sup>2</sup> | Proposed Difference |
|---------------------|----------------------------|--------------------------------|---------------------|
| Development Type    | DUs                        | DUs                            | DUs                 |
| Multifamily         | 19,732                     | 21,000                         | 1,268               |
| Single Family       | 23,909                     | 23,400                         | -509                |
| Mobile Home         | 317                        | 0                              | -317                |
| Total Housing Units | 43,958                     | 44,400                         | 442                 |

<sup>&</sup>lt;sup>1</sup> City of San Diego 2020 UWMP, SANDAG Series 14 Growth Forecast.

Table 2-3 Existing and Proposed Non-Residential Development for the Clairemont CPU

| Development Type | Secondary<br>Sector | Baseline 2045 <sup>1</sup><br>(SF) | Proposed CPU<br>2045 <sup>2</sup> (SF) | Proposed<br>Difference<br>(SF) |
|------------------|---------------------|------------------------------------|--|--------------------------------|
| Commercial       | Office              | 562,100                            | 562,100                                | 0                              |
| Commercial       | Retail              | 2,838,600                          | 2,838,600                              | 0                              |
| Commercial       | Mixed Use           | 91,400                             | 0                                      | -91,400                        |
| Institutional    | Universities        | 897,400                            | 897,400                                | 0                              |
| Institutional    | Schools             | 2,358,700                          | 2,358,700                              | 0                              |
| Industrial       | Regular             | 2,616,700                          | 2,982,100                              | 365,400                        |
|                  | Total Area          | 9,364,900                          | 9,638,900                              | 274,000                        |

<sup>&</sup>lt;sup>1</sup> City of San Diego 2020 UWMP, SANDAG Series 14 Growth Forecast.

<sup>&</sup>lt;sup>2</sup> City Planning Department, Request for the Preparation of a Water Supply Assessment for the Clairemont Community Plan Update (IO # 21005493), Updated December 13, 2024.

<sup>&</sup>lt;sup>2</sup> City Planning Department, Request for the Preparation of a Water Supply Assessment for the Clairemont Community Plan Update (IO # 21005493), Updated December 13, 2024.

### Section 3. WSA FINDINGS

As discussed further in this section and seen previously in **Table 2-2** and **Table 2-3**, the Project is proposing more residential dwelling units and non-residential square footage than previously forecasted for this area. The Project will increase the total water demand for the Project area, however there is additional water supply within the two partial pressure zones that are included in the community plan area, available to serve the Project. This WSA finds that the proposed water demand projections for the Project are included in the regional water resource planning documents of the City and the Water Authority. Current and future water supply, as well as actions necessary to develop future water supply, have been identified. This WSA demonstrates that there will be sufficient water supply available during normal, single dry, and multiple dry water years over a 20-year projection to meet the demand of the Project.

As demonstrated in **Table 3-1** and **Table 3-2** of this WSA, prepared by PUD in compliance with the requirements of SB 610, using the City's 2020 UWMP based upon SANDAG Series 14 Forecast land use, there is sufficient water planned to supply the Project's estimated annual average usage. The projected water demand of the Project is 72,880 gallons per day (GPD), or 81 acre-feet per year (AFY) (**Table 3-3**). Water demand for the Project assumes all mandatory water efficiency standards are met and results in more water efficient buildings and landscapes as compared to older developments.

As **Table 3-4** details, the 2020 UWMP establishes existing water demand and net capacity for future development. The Clairemont Community Plan has a planned net supply/capacity of 9,230 AFY, which includes adequate supply for the Project. Following the buildout of the Project, the Updated Clairemont Community Plan will have a remaining net capacity of 9,149 AFY to serve future development.

The City's 2020 UWMP demonstrates there will be sufficient water supply available to meet demand for existing and planned future developments that are projected to occur by 2045. Based on a normal water supply year, the estimated water supply projected in five-year increments for a 20-year projection will meet the City's projected water demand of 202,865 acre-feet (AF) in 2025 to 228,865 AF in 2045 (**Table 6-2**) for existing and planned future developments. Similarly, based on a single dry year forecast (**Table 6-6**), the estimated water supply will meet the projected water demand of 236,274 AF (2045). Based on a multiple dry year forecast (**Table 6-7**), the estimated water supply will meet the projected demand of 233,538 AF (Dry Year 5 for 2045). Therefore, based on the findings from the City's 2020 UWMP, this Project falls within an expected range of forecasted demand and, independently, will not result in unanticipated demand.

In summary, these findings substantiate that there is sufficient water supply planned to serve this Project's future water demand within the PUD service area in normal, single dry, and multiple dry water year forecasts.

Table 3-1 Planned Residential Water Demand for the Clairemont CPU

| Residential                 | Proposed Additonal DUs <sup>1</sup> | Water Demand<br>Factor <sup>2</sup> | Water Use,<br>gpd | Water Use,<br>AFY |
|-----------------------------|-------------------------------------|-------------------------------------|-------------------|-------------------|
| Multifamily                 | 1,268                               | 162                                 | 205,416           | 230               |
| Single Family               | -509                                | 162                                 | -82,458           | -92               |
| Mobile Home                 | -317                                | 162                                 | -51,354           | -58               |
| Total Residential<br>Demand | 442                                 | 162                                 | 71,604            | 80                |

<sup>&</sup>lt;sup>1</sup> Reference Table 2-2 of this WSA.

Table 3-2 Planned Non-Residential Water Demand for the Clairemont CPU

| Non-<br>Residential   | Secondary<br>Sector | Proposed<br>Additonal SF <sup>1</sup> | Water Demand<br>Factor <sup>2</sup> | Water Use,<br>gpd | Water Use,<br>AFY |
|-----------------------|---------------------|---------------------------------------|-------------------------------------|-------------------|-------------------|
| Commercial            | Office              | 0                                     | n/a                                 | 0                 | 0                 |
| Commercial            | Retail              | 0                                     | n/a                                 | 0                 | 0                 |
| Commercial            | Mixed Use           | -91,400                               | 0.054                               | -4,936            | -6                |
| Institutional         | Universities        | 0                                     | n/a                                 | 0                 | 0                 |
| Institutional         | Schools             | 0                                     | n/a                                 | 0                 | 0                 |
| Industrial            | Regular             | 365,400                               | 0.017                               | 6,212             | 7                 |
| Total Non-Residential |                     |                                       |                                     |                   |                   |
| Dema                  | nd                  | 365,400                               | n/a                                 | 1,276             | 1                 |

<sup>&</sup>lt;sup>1</sup> Reference Table 2-3 of this WSA.

Table 3-3 Water Demand for the Clairemont CPU

| Demand Type                 | Proposed Water Use, gpd | Proposed Water Use, AFY |
|-----------------------------|-------------------------|-------------------------|
| Residential                 | 71,604                  | 80                      |
| Non-Residential             | 1,276                   | 1                       |
| Net WSA Demand              | 72,880                  | 81                      |
| Source: Tables 3-1 and 3-2. |                         |                         |

 $<sup>^2</sup>$  For residential demands, PUD is using demands factors from the 2020 UWMP, which equal 60 gallons per capita per day times 2.7 persons per household = 162 gallons per day per DU. This is an average for residential demand. These demand factors include landscaping water demands.

<sup>&</sup>lt;sup>2</sup> For non-residential demands, PUD is using demands factors from the 2020 UWMP.

Table 3-4 Potential Water Supply for the Clairemont CPU

|  | Water Potentially Available |       |
|--|-----------------------------|-------|
|  | million gallons per day     |       |
| Community Plan   | (mgd)                       | AFY   |
| Existing Clairemont Community Plan Capacity <sup>1</sup> | 8.24                        | 9,230 |
| Previously Approved WSA Projects in Community Plan       |                             |       |
| Area (since 2020 UWMP approved)                          | 0.00                        | 0     |
| Proposed Clairemont Community Plan Update                | 0.07                        | 81    |
| Potential Remaining Supply/Capacity                      | 8.17                        | 9,149 |

<sup>&</sup>lt;sup>1</sup> The City of San Diego 2020 UWMP establishes existing water demand and potential net capacity for future development.

### Section 4. CITY OF SAN DIEGO PUBLIC UTILITIES DEPARTMENT

The City purchased its initial water system in 1901 from the privately-owned San Diego Water & Telephone Company. Since then, continual expansion of the water system has been required to meet the demand of the growing population of the City. To meet the demand, the PUD purchased several reservoirs between 1913 and 1935 to supplement local water supplies. Despite low annual precipitation in the area (approximately 10 inches per year), these reservoirs supplied the City's growing demand until the year of 1940.

The need to import water emerged with the increased demand generated by the presence of the United States Navy prior to and during World War II, and the ensuing population growth. As a result, the PUD and other local retail water distributors formed the Water Authority in 1944 for the purpose of purchasing Colorado River water from Metropolitan Water District of Southern California (MWD). The PUD and other local retail water distributors began receiving imported water from the Colorado River in 1947.

Purchased water from the Water Authority is the largest portion of the City's overall water supply. In 2015, a significant drought year, Water Authority water accounted for 97 percent of the City's total water supply as the availability of local surface water was lower than in normal hydrologic years. Imported water from the Water Authority accounted for about 89 percent on average from 2016 to 2020.

Today, the PUD treats and delivers a current average of 175,000 AFY of water to approximately 1.4 million residents. The water system extends over 400 square miles, including 340 square miles in the City. The PUD potable water system serves the City and certain surrounding areas, including both retail and wholesale customers. The Clairemont CPU WSA is located within the PUD's water service area of the Miramar Water Treatment Plant, discussed in the next section.

In addition to delivering potable water, the City has a recycled water program. Its objectives are to optimize the use of local water supplies, lessen reliance on imported water, and free up capacity in the potable water system. Recycled water provides the City a dependable, year-round, locally produced, and controlled water resource.

## 4.1 Overview of Potable System Facilities

The City's current and approved future water supplies consist of: (1) water purchased from the Water Authority, either directly delivered to treatment plants or stored in various reservoirs; (2) local supply including groundwater, capture of local runoff from rainfall primarily within its surface reservoirs, and Pure Water which is approved and in progress; and (3) recycled water for non-potable water use.

The City's water system is made up of nine raw water reservoirs that capture runoff from rainfall within local watersheds, three water treatment plants (WTPs), and a small portion from local groundwater. To offset potable (drinking) water demand, the City owns and operates two water reclamation plants and a recycled water distribution system that delivers recycled water for non-potable water uses.

The City's nine local surface water reservoirs have a combined capacity of 566,239 AF. The native water captured in these reservoirs provides approximately 11% of the City's total supply (based on average data from 2016 to 2020). These reservoirs not only capture local supply, but many of them store imported water and are connected to the regional Water Authority's system, providing the City with reliability and redundancy during seismic and other system emergencies. **Table 4-1** provides the storage capacity for the City's reservoirs and current storage levels (February 2025.)

**Table 4-1 City Reservoirs** 

| Reservoir      | Storage Capacity (AF) <sup>1</sup> | Current Storage (AF) <sup>2</sup> |
|----------------|------------------------------------|-----------------------------------|
| Barrett        | 34,806                             | 28,135                            |
| El Capitan     | 112,807 [50,732]                   | 28,678                            |
| Hodges         | 30,633 [5,996]                     | 3,601                             |
| Miramar        | 6,682                              | 5,645                             |
| Morena         | 50,694 [16,742]                    | 11,806                            |
| Murray         | 4,684 [3,884]                      | 3,541                             |
| Lower Otay     | 47,067                             | 39,075                            |
| San Vicente    | 249,358                            | 145,838                           |
| Sutherland     | 29,508                             | 8,914                             |
| Total Capacity | 566,239 [77,354]                   | 275,233                           |

<sup>&</sup>lt;sup>1</sup> Total potential capacity shown at dam spillway crest. El Capitan, Hodges, and Morena Reservoirs operating with water level restrictions per the California Division of Safety of Dams. [] = Capacity at level restriction. <sup>2</sup> Storage as of February 2025.

The Lower Otay, Barrett and Morena Reservoirs provide water to the Otay Water Treatment Plant (Otay WTP) in south San Diego; El Capitan, San Vicente, Sutherland, and Lake Murray Reservoirs provide water to the Alvarado Water Treatment Plant (Alvarado WTP) in central San Diego; and the Miramar Reservoir services the Miramar Water Treatment Plant (Miramar WTP) in north San Diego. Hodges Reservoir is connected to the Olivenhain Reservoir, which is owned by the Water Authority. Olivenhain Reservoir is connected to the Water Authority's second aqueduct, as detailed in Section 5.2. Through this connection, Hodges Reservoir water can be delivered to all City WTPs and can be delivered to San Vicente Reservoir for storage.

The City's three WTPs – Alvarado, Miramar and Otay – provide safe and reliable drinking water and have a combined permitted total rated capacity of 378 million gallons per day (mgd). **Table 4-2** summarizes the water treatment plant capacities in the City.

**Table 4-2 Water Treatment Plant Current Permitted Capacities** 

| Water Treatment Plant                | Original<br>Construction | Current Capacity<br>(mgd) | Geographic Area Served       |  |  |
|--------------------------------------|--------------------------|---------------------------|------------------------------|--|--|
| Miramar WTP                          | 1962                     | 144                       | North of the San Diego River |  |  |
| Alvarado WTP                         | 1951                     | 200                       | Central San Diego            |  |  |
| Otay WTP                             | 1914                     | 34                        | South San Diego              |  |  |
| Source: City of San Diego 2020 UWMP. |                          |                           |                              |  |  |

Source: City of San Diego - Public Utilities Department, Water Production Division (2025).

The three WTPs are located in such a way that there is flexibility in providing supply to the City's geographic areas; some areas of the City can be supplied by more than one of the treatment plants. To distribute potable water produced at these WTPs, the PUD maintains and operates numerous water pump stations within over 130 pressure zones (within the City's retail service area), and numerous treated water storage facilities with more than 200 million gallons of potable water capacity.

The PUD also maintains several emergency connections to and from neighboring water agencies, including the Santa Fe Irrigation District (connected to Miramar WTP), the City of Poway (connected to Miramar WTP), Olivenhain Municipal Water District (connected to Miramar WTP), the Cal-American Water Company (connected to Alvarado and Otay WTPs), Sweetwater Authority (connected to Otay WTP), and the Otay Water District (connected to Otay WTP).

### 4.2 Overview of Recycled System Facilities

Recycled water is produced at the City's North City Water Reclamation Plant (North City WRP) and South Bay Water Reclamation Plant (South Bay WRP) and is used for non-potable use, such as landscape irrigation.

The City's recycled water system has a combined total wastewater treatment capacity of 50,406 AFY (45.0 mgd), has three (3) recycled water storage facilities with over 12 million gallons of storage capacity, and includes approximately 100 miles of recycled water pipelines.

The North City WRP, with an ultimate capacity of 30.0 mgd, was the first large-scale water reclamation plant in San Diego; its operations commenced at the facility in 1997. The WRP, located in the Miramar area, serves the northern San Diego region, including the cities of Del Mar and Poway, as well as City neighborhoods of Mira Mesa, Rancho Peñasquitos, Scripps Ranch, Carmel Valley, Sorrento Valley, and southern Rancho Bernardo.

The South Bay WRP has an ultimate capacity of 15.0 mgd and began operation in 2002. Located at the end of Dairy Mart Road near the International Border with Mexico, the majority of the South Bay WRP recycled water is sold to the Otay Water District.

# 4.3 Pure Water Program

The Pure Water San Diego Program will provide a safe, secure and sustainable local drinking water supply for San Diego. It will use advanced water purification technology to produce potable water from recycled water. For more details on the Pure Water San Diego Program, see Section 5.

# Section 5. EXISTING AND PROJECTED SUPPLY

The PUD relies on purchased water from the Water Authority as a water supply source. The City is a Water Authority member agency, and the Water Authority is a member agency of the MWD. The statutory relationships between the Water Authority, the MWD and its member agencies, respectively, establish the scope of the City's entitlements to water from these two agencies. Due to the City's reliance on these two agencies, this WSA relies upon and includes information on the existing and projected supplies, supply programs, and related projects of the Water Authority and the MWD.

The City relies on the long-term water resources planning documents of the Water Authority and the MWD to support the work on this WSA. These documents are available at the following websites:

#### San Diego County Water Authority

 $\frac{https://www.sdcwa.org/wp-content/uploads/2021/08/2020-UWMP\_Final-Print-Version-July-2021-1.pdf$ 

#### **Metropolitan Water District of Southern California**

https://www.mwdh2o.com/media/21641/2020-urban-water-management-plan-june-2021.pdf

A brief overview of the Water Authority and the MWD, including the City's relationship to these agencies, is included below.

A description of local surface, local groundwater and local recycled water supplies available to the City can be found in Section 5.3.1 of this WSA.

This information is current at the time this document was prepared.

### 5.1 Metropolitan Water District of Southern California

The Metropolitan Water District (MWD) was created in 1928, under the authority of the Metropolitan Water District Act (California Statutes 1927, Chapter 429, as reenacted in 1969 as Chapter 209, as amended) (the "MWD Act"). The MWD's primary purpose is to provide a supplemental supply of wholesale water for domestic and municipal uses to its constituent agencies. The MWD service area comprises approximately 5,200 square miles and includes portions of the six counties of Los Angeles, Orange, Riverside, San Bernardino, San Diego, and Ventura.

There are 26 member agencies of the MWD, including 14 cities, 11 municipal water districts and the Water Authority. A Board of Directors, currently numbering 38 members, governs the MWD. Each constituent agency has at least one representative on the MWD Board.

The MWD's existing water supplies have been historically sufficient to meet demand within its service area during years of normal precipitation. Although the MWD plans and manages reserve supply to account for normal occurrences of drought conditions, regulatory actions, including but not limited to restrictions under the Federal and California Endangered Species Acts, have at times placed limitations on the MWD's ability to provide water to its member agencies. In the future, population growth, regulatory restrictions, increased competition for low-cost water supply, and other factors such as climate change could impact the MWD's ability to supply its member agencies.

The MWD's two major sources of water are the Colorado River and the State Water Project (SWP).

<u>Colorado River Water:</u> The Colorado River was the MWD's original source of water after its establishment in 1928. The MWD owns and operates the Colorado River Aqueduct (CRA), which is 242 miles long, starting at Lake Havasu and terminating at Lake Mathews in Riverside County.

In 2003, a Quantification Settlement Agreement (QSA) was completed to ensure that California stays within its 4.4 million acre-feet (MAF) annual apportionment of Colorado River water. The QSA provides the means to implement water transfers and supply programs between water agencies that use Colorado River water in California. Of the 4.4 MAF annual apportionment of Colorado River water, the MWD has a 550,000 AFY apportionment. Additionally, the MWD has developed several water transfers, irrigation conservation measures and storage programs with irrigation water districts that have more senior water rights to Colorado River water within California. Through these and other programs, MWD's goal is to keep its CRA nearly full at its capacity of 1.2 MAF.

The existing conditions of the Colorado River is that it has been in a decade-long, severe drought. Despite some recent improvements to snowpack in the Upper Colorado River Basin, the Lake Mead water surface elevation has only recently recovered from the long drought between 2014 and 2019. The Lower Basin States, including California, recognized that Lake Mead levels could quickly fall to 1,000 feet and trigger a formal shortage declaration. In April 2019, the U.S. Congress passed a finalized Drought Contingency Plan (DCP) agreed upon and produced by the U.S.'s three Lower Basin States (Arizona, California and Nevada) and Mexico. As defined in the DCP, California takes shortages beginning at a Lake Mead trigger elevation of 1045 feet; those shortages increase as the lake's water elevation decrease. Within California, Palo Verde Irrigation District and Coachella Valley Water District take 8 percent and 7 percent of the California DCP shortage, respectively.

In dry, below-normal conditions, the MWD has increased the supply received from the California Aqueduct by developing flexible Central Valley/SWP storage and transfer programs. Over the years, under the pumping restrictions of the SWP, the MWD has collaborated with the other contractors to develop numerous voluntary Central Valley/SWP storage and transfer programs. The goal of these storage/transfer programs is to develop additional dry-year supplies that can be conveyed through the California Aqueduct during dry hydrologic conditions and regulatory restrictions.

<u>State Water Project:</u> As the largest of 29 contractors for water from the SWP, the MWD holds a contract for a maximum of 1,911 thousand acre-feet (TAF) per year, or 46 percent of the total SWP contract. The maximum amount of the contract is rarely met because the California Department of Water Resources (DWR) determines annual allocations of SWP contract amounts based on hydrologic and regulatory conditions.

The SWP is owned by the State of California and operated by the DWR. The MWD receives water pumped from the Harvey O. Banks Pumping Plant in the southern portion of the Sacramento-San Joaquin River Delta, via the 444-mile-long California Aqueduct, to four delivery points near the northern and eastern boundaries of the MWD. Water supply from the SWP has also been significantly reduced because of the most recent California drought and environmental regulations protecting the Delta. Political and environmental concerns may also limit imported water supply from Northern California. In 2007, the SWP pumps were shut down to protect the Delta smelt population.

As discussed above, the quantity of SWP water available for delivery each year is controlled by hydrology, environmental and operational considerations. The original State Water Contract called for an ultimate delivery capacity of 4.2 MAF, with 1,911 TAF allocated to the MWD pursuant to its participation in the SWP. For decades, the Bay-Delta has experienced water quality and supply reliability challenges and conflicts due to variable hydrology and environmental standards that limit pumping operations. SWP deliveries in the most recent critically dry years lagged these projections and were 5 percent of contractual amounts in 2014 and 20 percent of contractual amounts in 2015. Dry conditions in 2020 also supported a supply allocation of only 20 percent. Consequently, MWD's key concern is the continual deterioration of water supply reliability.

To augment its imported water from the Colorado River and Delta, the MWD has developed water banking programs, agricultural efficiency and land fallowing programs, and water transfers. These supplemental supplies are used mainly during dry years and droughts, and are located in Riverside County, Imperial County, and the Central Valley region. Additionally, the MWD has developed groundwater storage programs with water agencies in its service area and provides financial incentives for local water agencies in its service area to implement projects for recycled water, groundwater recovery and seawater desalination.

# 5.2 San Diego County Water Authority

The Water Authority is the countywide water wholesaler comprised of 22 public member agencies and governed by a 35-member Board of Directors. It owns and operates five large-diameter pipelines to deliver imported water to its member agencies. The City, with a population of 1.4 million served, is the Water Authority's largest member agency and customer. The Water Authority's service area is a semi-arid region where the natural occurrence of water from rainfall and groundwater provides a firm water supply for only a small portion of the water demand of the current population. Since 1990, the Water Authority has provided an average of 85 percent of the

water supply within its service area. As a wholesaling entity, the Water Authority has no retail customers, and only serves its member agencies.

Historically, the principal source of supply for the Water Authority's service area has been water purchased from the MWD for sale to the Water Authority's member agencies. However, drought conditions and population growth in the Water Authority's service area have highlighted the need for diversification of the region's water supplies. The Water Authority has actively pursued a strategy of supply diversification that includes the acquisition and importation of additional water supplies, the development of additional local water supply projects and augmentation of its water supply via local and regional water storage capacity. In fiscal year 2020, total local water sources provided 28% of the water used in the Water Authority's service area.

The Water Authority receives most of its water supply from transfers with high-priority Colorado River contractors. In 2020, the Water Authority received 144,000 AF (31 percent of total water supply) from a conservation and transfer agreement with the Imperial Irrigation District (IID) and 86,000 AF (19 percent of its water supply) from the All-American Canal and Coachella Canal Lining Projects. By 2040, almost 8 percent of the Water Authority supply portfolio will be potable reuse, and 9 percent will be seawater desalination, which are drought-proof supplies.

### 5.3 Public Utilities Department

The City historically has purchased approximately 85 to 90 percent of its water from the Water Authority, which supplies the water (raw and treated) through two aqueducts consisting of five pipelines. While the City imports a majority of its water, it uses local supply sources to meet some of its demand. Additionally, non-potable recycled water is used to offset potable demand.

The availability of sufficient imported and regional water supply to serve existing and planned uses within the PUD service area is demonstrated in the prior discussion on the water supply reliability of the MWD and the Water Authority. The City has been receiving water from the Water Authority since 1947, and during the last 20 years purchased between 139,000 and 235,500 AFY. For FY2021, water purchases totaled approximately 144,708 AF. Depending upon demand, growth, and the success of local water supply initiatives, the imported supply demand will decrease with the construction of Pure Water San Diego Phases 1 and 2 and most likely be a maximum of 149,778 AFY in 2025 (as shown in **Table 6-2**) during normal years and decreases through 2035. Once both phases of the Pure Water Program are installed, from 2035 to 2045, the imported supply demand will increase again for the City.

For the purpose of this analysis the maximum is used.

#### 5.3.1 Demonstrating the Availability of Sufficient Supply

<u>Water Supply from Water Authority (Purchased Water):</u> Section 5, subdivision 11 of the County Water Authority Act states that the Water Authority "as far as practicable, shall provide each of its member agencies with adequate supplies of water to meet their expanding and increasing needs." Depending on local weather and supply conditions, the Water Authority provides between 75 to 95 percent of the total supplies used by its 22-member agencies. As mentioned in Section 4, the PUD and other local retail water distributors formed the Water Authority in 1944 for the purpose of purchasing Colorado River water from the MWD.

<u>Local Surface Water Supplies</u>: The City maintains and operates nine local surface raw water storage reservoirs which are connected directly or indirectly to water treatment operations. In the San Diego region, local precipitation produces surface runoff to streams that supply PUD reservoirs. A portion of this runoff is used for the municipal water supply, while the remainder is

stored in the reservoir. Average rainfall is needed to saturate the soil sufficiently for significant surface runoff to occur. Therefore, most of the runoff to reservoirs is produced in years with much greater than average rainfall. Some flooding may occur during average or below average rainfall years if the annual rainfall is concentrated in a few intense storms.

Seven of the City's nine reservoirs, as listed in **Table 5-1**, provide a local water supply to the City, while the other two reservoirs (Miramar and Murray) serve as the water treatment plant forebay and emergency storage. The median of historical reservoir supply from 1948 to 2020 was used as the projection for years 2025 to 2045 as shown in **Table 5-1** and is assumed to remain constant over the forecasted period.

Table 5-1 Current and Projected Local Surface Water

|                                      | Water Supply (AFY) |        |        |        |        |        |  |
|--------------------------------------|--------------------|--------|--------|--------|--------|--------|--|
| Reservoirs Providing Local Supply    | 2020               | 2025   | 2030   | 2035   | 2040   | 2045   |  |
| Barrett, El Capitan, Hodges, Lower   |                    |        |        |        |        |        |  |
| Otay, Morena, San Vicente,           |                    |        |        |        |        |        |  |
| Sutherland                           | 19,286             | 22,015 | 22,015 | 22,015 | 22,015 | 22,015 |  |
| City-Lake Cuyamaca Interagency       |                    |        |        |        |        |        |  |
| Agreement                            | 400.2              | 400    | 400    | 400    | 400    | 400    |  |
| Total Local Reservoir Supply         | 19,686             | 22,415 | 22,415 | 22,415 | 22,415 | 22,415 |  |
| Source: City of San Diego 2020 UWMP. |                    |        |        |        |        |        |  |

The use of local water is affected by availability and water resource management policies. The City's policy is to use local water first to reduce imported water purchases and costs. The City also operates emergency and seasonal storage programs in conjunction with its policy.

The purpose of emergency storage is to increase the reliability of the imported water aqueduct system. This is accomplished by maintaining an accessible amount of stored water that could provide an uninterrupted supply of water to the City's water treatment facilities, should an interruption to the supply of imported water occur. The management of reservoirs is guided by Council Policy 400–04, which outlines the City's Emergency Water Storage Program. The policy mandates that the Department store sufficient water in active, available storage to meet sixtenths of the normal annual (7.2 months) City water demand requirements (conservation is not included). Active, available storage is that portion of the water that is above the lowest usable outlet of each reservoir.

The monthly emergency storage requirement changes from month-to-month and is based on the upcoming seven months' water demand. This results in a seasonally fluctuating emergency storage requirement, generally peaking in April and reaching its minimum in October. This seasonally fluctuating requirement makes a portion of the required emergency storage capacity available for impounding or seasonal storage.

<u>Local Groundwater Supply:</u> The City has rights, jurisdiction, and municipal water supply development interests in four groundwater basins in the San Diego region: The San Pasqual Valley, Mission Valley, San Diego River Valley, and Coastal Plain of San Diego Groundwater Basins. None of the groundwater basins are adjudicated, meaning managed by the courts to ensure that water rights are protected, and safe yields are adhered to. The California Supreme Court decreed in 1930 that the City has Pueblo water rights to all the water (surface and underground) of the San Diego River. The City is committed to protecting its groundwater resources and preserving its established Pueblo water rights. This right includes the use of all

surface water and groundwater of the streams that flowed through the original pueblo, including their tributaries, from their source to the mouth.

The San Diego River Valley Basin (also known as the Santee/El Monte Basin) is primarily located outside the City's municipal boundary but within San Diego County. It is situated in the eastern portion of the San Diego River watershed near the cities of Santee, La Mesa, and El Cajon, and the unincorporated community of Lakeside. In accordance with requirements from the Sustainable Groundwater Management Act (SGMA), the basin is designated a very low priority basin and has an estimated capacity that ranges from 24,000 to 97,000 AF.

The City has two production wells in the San Diego River Valley Basin that deliver water to the potable supply. The first well is the San Vicente production well installed in 2004 with a maximum capacity estimated at 600 gallons per minute (gpm), or approximately 1,000 AFY. Due to issues with pump operations, the average annual production from this well is approximately 50 AFY. In March 2010, the City drilled the second production well, about a quarter mile downstream of its El Capitan Reservoir. Currently the groundwater available for beneficial use is approximately 50 AFY from the existing El Capitan production well. **Table 5-2** and **Table 5-3** detail historical and projected supply (respectively) from the San Diego River Valley (Santee/El Monte) Basin. The water produced from both of these wells is sent to the Alvarado WTP for distribution.

Table 5-2 Historical Groundwater Supply to City from 2016-2020

|                                      | Groundwater Supply (AFY) |      |      |      |      |  |  |
|--------------------------------------|--------------------------|------|------|------|------|--|--|
| Groundwater Well                     | 2016                     | 2017 | 2018 | 2019 | 2020 |  |  |
| Santee/El Monte: San Vicente GW      |                          |      |      |      |      |  |  |
| Production Well                      | 0.0                      | 0.0  | 0.0  | 0.0  | 0.0  |  |  |
| Santee/El Monte: El Capitan GW       |                          |      |      |      |      |  |  |
| Production Well                      | 0.0                      | 18.8 | 38.0 | 25.8 | 51.6 |  |  |
| Source: City of San Diego 2020 UWMP. |                          |      |      |      |      |  |  |

Table 5-3 Projected Groundwater Supply to City

|                                      | Groundwater Supply (AFY) |      |      |      |      |  |  |
|--------------------------------------|--------------------------|------|------|------|------|--|--|
| Groundwater Well                     | 2025                     | 2030 | 2035 | 2040 | 2045 |  |  |
| Santee/El Monte: San Vicente GW      |                          |      |      |      |      |  |  |
| Production Well                      | 50                       | 50   | 50   | 50   | 50   |  |  |
| Santee/El Monte: El Capitan GW       |                          |      |      |      |      |  |  |
| Production Well                      | 50                       | 50   | 50   | 50   | 50   |  |  |
| Source: City of San Diego 2020 UWMP. |                          |      |      |      |      |  |  |

The San Pasqual Valley, the Mission Valley, and the Coastal Plain of San Diego Groundwater Basins do not currently contribute to the City's potable water supply and the PUD has no current plans to pursue any groundwater from them for contribution to the potable water supply.

Recycled Water Supply: As detailed in the PUD's 2020 Recycled Water Master Plan Update, the City provides recycled water service to more than 700 recycled water retail customers and three wholesale customers, including the City of Poway, Olivenhain Municipal Water District and Otay Water District. The 2017 top ten retail customers included the City of San Diego Biosolids Center, the Torrey Pines Golf Course, Marine Corps Air Station – Miramar, the Santaluz Golf Course, El

Camino Memorial Park, Qualcomm, Village Nurseries, the Verrezzano HOA, and the San Diego Community College District.

The PUD, in cooperation with the Park & Recreation Department, has pursued the retrofitting of City parkland, street landscaping and open space to use recycled water for irrigation; sites fronting recycled water distribution pipelines were targeted. In 2007, 23 recycled water meters were serving City-owned sites and by December of 2014, the number of services increased to 96-meter connections.

<u>Conservation</u>: The City achieves year-round water savings through a water conservation ethic by adopting programs, policies and ordinances designed to promote water conservation practices and supporting public information and education campaigns. Examples of the programs and policies include turf replacement, water use efficient device rebates, commercial and residential water surveys and year-round permanent water use restrictions.

Over the past 30 years, the City has achieved substantial water savings by:

- Developing innovative, customer-oriented water conservation programs
- · Creating policies and ordinances designed to prevent water waste
- Implementing comprehensive public information and education campaigns that foster behavior change and a water conservation ethic.

#### 5.3.2 Plans for Acquiring Additional Supply

<u>Pure Water Program:</u> The Pure Water Program is the largest integrated infrastructure program the City of San Diego has ever undertaken. Phase 1 is comprised of several projects that will deliver an annual average of 30 mgd of purified water for San Diego. The purified water will be piped to the Miramar Reservoir for storage and then will be treated again at the Miramar Water Treatment Plant before it is distributed to the public.

Phase 1 is expected to be online in Calendar Year (CY) 2025. Production is expected to be a staged ramp-up in flow with 30 mgd produced by the end of CY 2027. This will allow the City to reduce the amount of water it purchases. Infrastructure components associated with the initial 30 mgd Phase 1 of the Pure Water Program are currently under construction.

Currently, Phase 2 of the Pure Water Program is planned to be online by 2035 and to expand advanced purified water production from 30 to 83 mgd on an annual average basis. The City has initiated early planning studies and plans to achieve this goal.

#### 5.3.3 Summary of Supply

Historic purchased water deliveries from the Water Authority to the PUD and local surface water, groundwater and recycled water deliveries are shown in **Table 5-4**.

Table 5-4 PUD Historic Purchased, Local Surface, Groundwater and Recycled Water Demand (AFY)

| Fiscal Year | Water Authority<br>Purchased Water | Local Surface<br>Water | Local<br>Groundwater | Recycled<br>Water <sup>1</sup> | Total                |
|-------------|------------------------------------|------------------------|----------------------|--------------------------------|----------------------|
| 2000        | 207,874                            | 39,098                 |                      | 3,250                          | 250,222              |
| 2005        | 204,144                            | 26,584                 |                      | 4,294                          | 235,022              |
| 2010        | 188,337                            | 13,117                 | 500                  | 7,951                          | 209,905              |
| 2015        | 173,754                            | 6,779                  | 500                  | 8,195                          | 199,527 <sup>2</sup> |
| 2020        | 150,577                            | 19,686                 | 52                   | 10,393                         | 180,708              |

<sup>&</sup>lt;sup>1</sup> Only includes "In-City" Recycled Water use and no sales to other agencies.

March 2025

 $<sup>^2</sup>$  Includes 10,229 AF of surface water deliveries to Cal Am that are not included in the Surface Water, or the Water Authority Purchased Water reported here.

Source: City of San Diego 2015 and 2020 UWMPs.

# Section 6. PROJECTED DEMAND

The City completes an updated UWMP and Water Demand Forecast for the PUD service area every five years. A computer model is used to forecast future water use based on SANDAG regional growth forecasts as well as per-capita demand factors and empirical water use trends. The result is a detailed demand forecast by water use sector (residential, commercial, industrial, irrigation, institutional, etc.) and by hydraulic pressure zone. The demand forecast is provided in five-year increments through the end of the UWMP horizon that can be applied by sector, by hydraulic pressure zone, or on a Citywide basis.

The City's 2020 UWMP compares future water demand and water supply under multiple hydrologic conditions. It is based on historical runoff in the State with data ranging from 1901 to 2020.

In addition to the PUD, the Water Authority and the MWD use regional growth forecasts to calculate projected water demand within their respective service areas. This provides for consistency between the retail and wholesale agencies' projected water demand, thereby ensuring that adequate supplies are being planned for the PUD's existing and future water users. The SANDAG forecasts are based on adopted community plan land use, but not citywide zoning. SANDAG forecasts the number of residents, dwelling units, and employees in an area, but not square footage, hotel rooms, or visitors (non-residents or non-employees). For urban areas, the smallest forecast geography is typically at the block level, but the forecast geography can be larger for suburban and less developed areas. SANDAG typically updates the regional growth forecast every three (3) to four (4) years.

The City's water demand projections, based on the SANDAG Series 14 Forecast land use, were incorporated in the City's 2020 UWMP. The 2020 UWMP was completed and adopted in June 2021.

The projections with the City's 2020 UWMP were forwarded to the Water Authority for use in the preparation of the Water Authority's UWMP, which is subsequently incorporated into the MWD's UWMP to calculate the ultimate water demand of the region.

The demand from the 2020 UWMP is used throughout this WSA. The historical and projected water demand for a normal year is shown in **Table 6-1**.

Future non-potable recycled water is assumed to remain constant, as the City shifts its recycled water strategy to the development of its Pure Water Program.

Table 6-1 Past, Current, And Projected Water Deliveries

|               |                  | Treatment        | 20      | 15        | 20      | 20        |
|---------------|------------------|------------------|---------|-----------|---------|-----------|
| Sector        | Type of Use      | Level            | Meters  | Use (AFY) | Meters  | Use (AFY) |
| Single Family | Indoor and       |                  |         |           |         |           |
| Residential   | outdoor uses     | Drinking Water   | 224,162 | 60,573    | 249,761 | 54,228    |
| Multifamily   | Indoor and       |                  |         |           |         |           |
| Residential   | outdoor uses     | Drinking Water   | 30,471  | 37,799    | 32,215  | 35,370    |
|               | Indoor and       |                  |         |           |         |           |
| CII           | outdoor uses     | Drinking Water   | 17,064  | 46,072    | 18,501  | 38,615    |
|               | Landscape        |                  |         |           |         |           |
| Irrigation    | irrigation       | Drinking Water   | 7,679   | 22,668    | 8,127   | 17,175    |
|               | Dust mitigation, |                  |         |           |         |           |
| Other         | cleaning         | Drinking Water   | 464     | 0         | 0       | 0         |
|               | Sub-Tot          | al (Retail Area) | 279,840 | 167,112   | 308,604 | 145,388   |

|                                      | Projected Water Use (AFY) |         |         |         |         |  |  |
|--------------------------------------|---------------------------|---------|---------|---------|---------|--|--|
| Sector                               | 2025                      | 2030    | 2035    | 2040    | 2045    |  |  |
| Single Family Residential            | 54,814                    | 54,360  | 53,794  | 54,197  | 55,159  |  |  |
| Multifamily Residential              | 40,623                    | 45,491  | 49,607  | 52,854  | 54,464  |  |  |
| CII                                  | 47,401                    | 50,089  | 52,784  | 55,239  | 56,873  |  |  |
| Large Irrigation                     | 17,718                    | 17,606  | 17,375  | 17,133  | 16,991  |  |  |
| Sub-Total (Retail Area)              | 160,556                   | 167,547 | 173,560 | 179,423 | 183,488 |  |  |
| Source: City of San Diego 2020 UWMP. |                           |         |         |         |         |  |  |

The analysis in **Table 6-2** compares the projected normal water supply and customer demand from 2025 to 2045, in five-year increments.

Table 6-2 Normal Year Demand vs. Supply for the City

|                                   | Demand and Supply (AFY) |         |         |         |         |
|-----------------------------------|-------------------------|---------|---------|---------|---------|
| Demand/Supply                     | 2025                    | 2030    | 2035    | 2040    | 2045    |
| Water Demand (with wholesale and  |                         |         |         |         |         |
| conservation) <sup>1</sup>        | 202,865                 | 210,547 | 217,156 | 223,598 | 228,065 |
|                                   | Local Water             | Supply  |         |         |         |
| Recycled Water (City service area |                         |         |         |         |         |
| only, non-potable)                | 13,773                  | 13,773  | 13,773  | 13,773  | 13,773  |
| Pure Water Phase 1                | 16,800 <sup>2</sup>     | 33,600  | 33,600  | 33,600  | 33,600  |
| Pure Water Phase 2                |                         |         | 59,360  | 59,360  | 59,360  |
| Local Surface Supply              | 22,015                  | 22,015  | 22,015  | 22,015  | 22,015  |
| City-Lake Cuyamaca Interagency    |                         |         |         |         |         |
| Agreement                         | 400                     | 400     | 400     | 400     | 400     |
| Groundwater                       | 100                     | 100     | 100     | 100     | 100     |
| Sub-total Local Supply            | 53,088                  | 69,888  | 129,248 | 129,248 | 129,248 |
| Water Supply from Water Authority |                         |         |         |         |         |
| (purchased water)                 | 149,778                 | 140,660 | 87,907  | 94,350  | 98,816  |
| Total City Water Supply           | 202,865                 | 210,547 | 217,156 | 223,598 | 228,065 |
| Estimated Water Shortages         | 0                       | 0       | 0       | 0       | 0       |

<sup>&</sup>lt;sup>1</sup> Includes consumptive use (retail and wholesale), non-revenue water, conservation, and non-potable recycled water demand.

# 6.1 Water Sales to Other Agencies

#### 6.1.1 Potable Water

The PUD, through past agreements, sells treated water to the California American Water Company (Cal-Am), which provides water service to the cities of Coronado, Imperial Beach, and the Naval Air Station North Island. The population of the Naval Air Station North Island is located within the City of Coronado, whereas the other military bases that the City serves are within the City.

Per the agreement between the City and Cal-Am, only local surface water is sold to Cal-Am to provide water to supply Cal-Am customers. A portion of City residents in the South Bay area are also served by Cal-Am and can be served by imported water as well. Per the agreement between the City and the City of Del Mar, the City takes deliveries of water which the City of Del Mar purchases from the Water Authority through the Second Aqueduct Connection at Miramar. This water is then treated at the City's Miramar WTP and transported to the City of Del Mar through several interconnections. **Table 6-3** presents the water sales to other agencies.

<sup>&</sup>lt;sup>2</sup> The exact amount of production expected to be available at the end of CY 2025 is only estimated at this time. The total 33,600 AFY (30 mgd) is expected to be online by the end of CY 2027. Source: City of San Diego 2020 UWMP.

The City has agreements to provide surplus treated water to Otay Water District and untreated exchange water to the Ramona Municipal Water District. These water deliveries occur infrequently and for short periods of time and are therefore not shown in **Table 6-3**.

Table 6-3 Sales to Other Agencies-Potable

|                               | Water Use (AFY)       |        |        |        |        |  |  |  |
|-------------------------------|-----------------------|--------|--------|--------|--------|--|--|--|
| Sector                        | 2025 2030 2035 2040 2 |        |        |        |        |  |  |  |
| Wholesale Water Sales         | 11,518                | 11,518 | 11,518 | 11,518 | 11,518 |  |  |  |
| Source: City of San Diego 202 | 20 UWMP.              |        |        |        |        |  |  |  |

#### 6.1.2 Recycled and Non-Revenue Water

The City has three (3) separate agreements to sell recycled water. The Olivenhain Municipal Water District and the City of Poway are provided recycled water from the City's North City WRP while Otay Water District receives recycled water from the City's South Bay WRP.

Non-Revenue Water (NRW) is the difference between the potable water supplied to the system (also known as potable water production) and the potable water sold to customers (also known as metered water deliveries). NRW typically includes legitimate uses that are not metered, such as street cleaning, line flushing and fire suppression as well as unaccounted for water. Unaccounted for water can be attributed to unauthorized consumption, meter inaccuracies, data errors, leakage on mains, leakage and overflow at storage and leakage at service connections. Typically, NRW is presented as a percentage of total potable water production. Beginning in 2013, the City has estimated non-revenue water utilizing the American Water Works Association's (AWWA) Water Audit software. An estimate of 9 percent is used in the Water Demand Forecast for 2020 and beyond. Using these values, the City's forecast of these additional water uses and losses to 2045 is presented in **Table 6-4**.

Table 6-4 Additional Water Uses and Losses

|                             | Water Use (AFY) |        |        |        |        |  |  |  |
|-----------------------------|-----------------|--------|--------|--------|--------|--|--|--|
| Use                         | 2025            | 2030   | 2035   | 2040   | 2045   |  |  |  |
| Non-Revenue Water           | 17,018          | 17,710 | 18,304 | 18,884 | 19,286 |  |  |  |
| Recycled Water <sup>1</sup> | 13,773          | 13,773 | 13,773 | 13,773 | 13,773 |  |  |  |

<sup>1</sup> Excludes wholesale recycled water that the City provides outside of its service area. Source: City of San Diego 2020 UWMP.

#### 6.2 Total Water Use

The City's total water demand forecast represents retail potable water consumption, wholesale water sales, non-revenue water, and non-potable recycled water. These demand categories, aggregated from the previous tables, are summarized in **Table 6-5**.

Table 6-5 PUD's Projected Total Water Use

|                                      | Water Demand (AFY) |         |         |         |         |  |
|--------------------------------------|--------------------|---------|---------|---------|---------|--|
| Use                                  | 2025               | 2030    | 2035    | 2040    | 2045    |  |
| Retail Potable Water Consumption     |                    |         |         |         |         |  |
| (Table 6-1)                          | 160,556            | 167,547 | 173,560 | 179,423 | 183,488 |  |
| Wholesale Potable Water Sales (Table |                    |         |         |         |         |  |
| 6-3)                                 | 11,518             | 11,518  | 11,518  | 11,518  | 11,518  |  |
| Non-Revenue Water (Table 6-4)        | 17,018             | 17,710  | 18,304  | 18,884  | 19,286  |  |
| Total Potable Water Production       | 189,092            | 196,774 | 203,383 | 209,825 | 214,292 |  |
| Non-Potable Recycled Water (Table 6- |                    |         |         |         |         |  |
| 4)                                   | 13,773             | 13,773  | 13,773  | 13,773  | 13,773  |  |
| Total Water Demand Forecast          | 202,865            | 210,547 | 217,156 | 223,598 | 228,065 |  |
| Source: City of San Diego 2020 UWMP. | ·                  |         |         | ·       |         |  |

### 6.3 Projected Single Dry Year Water Supply and Demand

As part of the requirement for complying with SB 610, **Table 6-6**, and **Table 6-7**, show the single dry year and consecutive multiple dry year demand. All tables in this section are based on data from the City's 2020 UWMP.

**Table 6-6** provides a comparison of a single dry year water supply with projected total water demand in five-year increments through 2045. The City's demand in single dry years is projected to be higher, similar in proportion to the increase in regional water demand projected in the Water Authority's 2020 UWMP. An increase in demand for landscape irrigation accounts for most of the increase in demand. It is assumed that recycled water demand would not increase in single dry years.

The wholesale water supplies from the Water Authority are assumed to decrease overall during this 20-year projection due to the completion of the City's Pure Water Phase 1 and 2 installations. This will offset the City's increased water demand and increase local water supply.

Table 6-6 Single Dry Year Demand vs. Supply for the City

|   | Demand and Supply (AFY) |         |         |         |         |  |
|---|-------------------------|---------|---------|---------|---------|--|
| Demand/Supply   | 2025                    | 2030    | 2035    | 2040    | 2045    |  |
| Water Demand (with wholesale and conservation) <sup>1</sup> | 210,169                 | 218,128 | 224,973 | 231,648 | 236,274 |  |
| Loc   | cal Water Su            | pply    |         |         |         |  |
| Recycled Water (City service area only, non-potable)        | 13,773                  | 13,773  | 13,773  | 13,773  | 13,773  |  |
| Pure Water Phase 1  | 16,800 <sup>2</sup>     | 33,600  | 33,600  | 33,600  | 33,600  |  |
| Pure Water Phase 2  |                         |         | 59,360  | 59,360  | 59,360  |  |
| Local Surface Supply  | 23,858                  | 23,858  | 23,858  | 23,858  | 23,858  |  |
| City-Lake Cuyamaca Interagency<br>Agreement                 | 400                     | 400     | 400     | 400     | 400     |  |
| Groundwater   | 100                     | 100     | 100     | 100     | 100     |  |
| Sub-total Local Supply                                      | 54,931                  | 71,731  | 131,091 | 131,091 | 131,091 |  |
| Water Supply from Water Authority (purchased water)         | 155,238                 | 146,397 | 93,882  | 100,557 | 105,183 |  |
| Total City Water Supply                                     | 210,169                 | 218,128 | 224,973 | 231,648 | 236,274 |  |
| Estimated Water Shortages                                   | 0                       | 0       | 0       | 0       | 0       |  |

<sup>&</sup>lt;sup>1</sup> Includes consumptive use (retail and wholesale), NRW, conservation, and non-potable recycled water demand.

## 6.4 Projected Multiple Dry Year Water Supply and Demand

**Table 6-7** presents the sequential five-year dry year hydrology comparison of demand and supply at five-year increments through 2045. The City's demand in multiple dry years is projected to be higher, similar in proportion to the increase in regional water demand projected in the Water Authority's 2020 UWMP. It is presumed that recycled water demand would not increase in multiple dry years.

Unlike the single dry year water supply discussed in Section 6.3, the wholesale water supply from the Water Authority is assumed to decrease overall during this 20-year projection due to the completion of the City's Pure Water Phase 1 and 2 installations. This will offset the City's increased water demand and increase local water supply.

<sup>&</sup>lt;sup>2</sup> The exact amount of production expected to be available at the end of CY 2025 is only estimated at this time. The total 33,600 AFY (30 mgd) is expected to be online by the end of CY 2027. Source: City of San Diego 2020 UWMP.

Table 6-7 Multiple Dry Year Demand vs Supply for City

| Dry Year 1 (2013)                 |                     | Deman      | d and Supply  | (AFY)    |         |
|-----------------------------------|---------------------|------------|---------------|----------|---------|
| Demand/Supply                     | 2025                | 2030       | 2035          | 2040     | 2045    |
| Water Demand (with wholesale and  |                     |            |               |          |         |
| conservation) <sup>1</sup>        | 202,865             | 210,547    | 217,156       | 223,598  | 228,065 |
|                                   | Local Wate          | r Supply   |               |          | 1       |
| Recycled Water (City service area |                     |            |               |          |         |
| only, non-potable)                | 13,773              | 13,773     | 13,773        | 13,773   | 13,773  |
| Pure Water Phase 1                | 16,800 <sup>2</sup> | 33,600     | 33,600        | 33,600   | 33,600  |
| Pure Water Phase 2                |                     |            | 59,360        | 59,360   | 59,360  |
| Local Surface Supply              | 20,963              | 20,963     | 20,963        | 20,963   | 20,963  |
| City-Lake Cuyamaca Interagency    |                     |            |               |          |         |
| Agreement                         | 400                 | 400        | 400           | 400      | 400     |
| Groundwater                       | 100                 | 100        | 100           | 100      | 100     |
| Sub-Total Local Supply            | 52,036              | 68,836     | 128,196       | 128,196  | 128,196 |
| Water Supply from Water Authority |                     |            |               |          |         |
| (purchased water)                 | 150,830             | 141,712    | 88,959        | 95,402   | 99,868  |
| Total City Water Supply           | 202,865             | 210,547    | 217,156       | 223,598  | 228,065 |
| Estimated Water Shortages         | 0                   | 0          | 0             | 0        | 0       |
| Dry Year 2 (2014)                 |                     | Deman      | d and Supply  | (AFY)    |         |
| Demand/Supply                     | 2025                | 2030       | 2035          | 2040     | 2045    |
| Water Demand (with wholesale and  |                     |            |               |          |         |
| conservation) <sup>1</sup>        | 210,169             | 218,128    | 224,973       | 231,648  | 236,274 |
|                                   | Local Wate          | r Supply   |               |          |         |
| Recycled Water (City service area |                     |            |               |          |         |
| only, non-potable)                | 13,773              | 13,773     | 13,773        | 13,773   | 13,773  |
| Pure Water Phase 1                | 16,800 <sup>2</sup> | 33,600     | 33,600        | 33,600   | 33,600  |
| Pure Water Phase 2                |                     |            | 59,360        | 59,360   | 59,360  |
| Local Surface Supply              | 23,858              | 23,858     | 23,858        | 23,858   | 23,858  |
| City-Lake Cuyamaca Interagency    |                     |            |               |          |         |
| Agreement                         | 400                 | 400        | 400           | 400      | 400     |
| Groundwater                       | 100                 | 100        | 100           | 100      | 100     |
| Sub-Total Local Supply            | 54,931              | 71,731     | 131,091       | 131,091  | 131,091 |
| Water Supply from Water Authority | 455.000             | 44605=     | 00.001        | 400 ==== | 405.455 |
| (purchased water)                 | 155,238             | 146,397    | 93,881        | 100,556  | 105,183 |
| Total City Water Supply           | 210,169             | 218,128    | 224,973       | 231,648  | 236,274 |
| Estimated Water Shortages         | 0                   | 0          | 0             | 0        | 0       |
| Dry Year 3 (2015)                 |                     | Demand and | d Supply (AFY | )        |         |

Table 6-7 Multiple Dry Year Demand vs Supply for City

| Demand/Supply                     | 2025                | 2030        | 2035    | 2040    | 2045    |  |  |  |
|-----------------------------------|---------------------|-------------|---------|---------|---------|--|--|--|
| Water Demand (with wholesale and  |                     |             |         |         |         |  |  |  |
| conservation) <sup>1</sup>        | 210,169             | 218,128     | 224,973 | 231,648 | 236,274 |  |  |  |
| Local Water Supply                |                     |             |         |         |         |  |  |  |
| Recycled Water (City service area |                     |             |         |         |         |  |  |  |
| only, non-potable)                | 13,773              | 13,773      | 13,773  | 13,773  | 13,773  |  |  |  |
| Pure Water Phase 1                | 16,800 <sup>2</sup> | 33,600      | 33,600  | 33,600  | 33,600  |  |  |  |
| Pure Water Phase 2                |                     |             | 59,360  | 59,360  | 59,360  |  |  |  |
| Local Surface Supply              | 6,280               | 6,280       | 6,280   | 6,280   | 6,280   |  |  |  |
| City-Lake Cuyamaca Interagency    |                     |             |         |         |         |  |  |  |
| Agreement                         | 400                 | 400         | 400     | 400     | 400     |  |  |  |
| Groundwater                       | 100                 | 100         | 100     | 100     | 100     |  |  |  |
| Sub-Total Local Supply            | 37,353              | 54,153      | 113,513 | 113,513 | 113,513 |  |  |  |
| Water Supply from Water Authority |                     |             |         |         |         |  |  |  |
| (purchased water)                 | 172,817             | 163,975     | 111,460 | 118,135 | 122,762 |  |  |  |
| Total City Water Supply           | 210,169             | 218,128     | 224,973 | 231,648 | 236,274 |  |  |  |
| Estimated Water Shortages         | 0                   | 0           | 0       | 0       | 0       |  |  |  |
| Dry Year 4 (2016)                 | Deman               | id and Supp |         |         |         |  |  |  |
| Demand/Supply                     | 2025                | 2030        | 2035    | 2040    | 2045    |  |  |  |
| Water Demand (with wholesale and  |                     |             |         |         |         |  |  |  |
| conservation) <sup>1</sup>        | 207,735             | 215,601     | 222,367 | 228,964 | 233,538 |  |  |  |
| Local Water Supply                |                     |             |         |         |         |  |  |  |
| Recycled Water (City service area |                     |             |         |         |         |  |  |  |
| only, non-potable)                | 13,773              | 13,773      | 13,773  | 13,773  | 13,773  |  |  |  |
| Pure Water Phase 1                | 16,800 <sup>2</sup> | 33,600      | 33,600  | 33,600  | 33,600  |  |  |  |
| Pure Water Phase 2                |                     |             | 59,360  | 59,360  | 59,360  |  |  |  |
| Local Surface Supply              | 16,464              | 16,464      | 16,464  | 16,464  | 16,464  |  |  |  |
| City-Lake Cuyamaca Interagency    |                     |             |         |         |         |  |  |  |
| Agreement                         | 400                 | 400         | 400     | 400     | 400     |  |  |  |
| Groundwater                       | 100                 | 100         | 100     | 100     | 100     |  |  |  |
| Sub-Total Local Supply            | 47,537              | 64,337      | 123,697 | 123,697 | 123,697 |  |  |  |
| Water Supply from Water Authority |                     |             |         |         |         |  |  |  |
| (purchased water)                 | 160,198             | 151,264     | 98,670  | 105,267 | 109,840 |  |  |  |
| Total City Water Supply           | 207,735             | 215,601     | 222,367 | 228,964 | 233,538 |  |  |  |
| Estimated Water Shortages         | 0                   | 0           | 0       | 0       | 0       |  |  |  |

Table 6-7 Multiple Dry Year Demand vs Supply for City

| Dry Year 5 (2017)                 | Demand and Supply (AFY) |         |         |         |         |  |  |  |
|-----------------------------------|-------------------------|---------|---------|---------|---------|--|--|--|
| Demand/Supply                     | 2025                    | 2030    | 2035    | 2040    | 2045    |  |  |  |
| Water Demand (with wholesale and  |                         |         |         |         |         |  |  |  |
| conservation) <sup>1</sup>        | 207,735                 | 215,601 | 222,367 | 228,964 | 233,538 |  |  |  |
| Local Water Supply                |                         |         |         |         |         |  |  |  |
| Recycled Water (City service area |                         |         |         |         |         |  |  |  |
| only, non-potable)                | 13,773                  | 13,773  | 13,773  | 13,773  | 13,773  |  |  |  |
| Pure Water Phase 1                | 16,800 <sup>2</sup>     | 33,600  | 33,600  | 33,600  | 33,600  |  |  |  |
| Pure Water Phase 2                |                         |         | 59,360  | 59,360  | 59,360  |  |  |  |
| Local Surface Supply              | 18,547                  | 18,547  | 18,547  | 18,547  | 18,547  |  |  |  |
| City-Lake Cuyamaca Interagency    |                         |         |         |         |         |  |  |  |
| Agreement                         | 400                     | 400     | 400     | 400     | 400     |  |  |  |
| Groundwater                       | 100                     | 100     | 100     | 100     | 100     |  |  |  |
| Sub-Total Local Supply            | 49,620                  | 66,420  | 125,780 | 125,780 | 125,780 |  |  |  |
| Water Supply from Water Authority |                         |         |         |         |         |  |  |  |
| (purchased water)                 | 158,114                 | 149,181 | 96,586  | 103,184 | 107,757 |  |  |  |
| Total City Water Supply           | 207,735                 | 215,601 | 222,367 | 228,964 | 233,538 |  |  |  |
| Estimated Water Shortages         | 0                       | 0       | 0       | 0       | 0       |  |  |  |

<sup>&</sup>lt;sup>1</sup> Includes consumptive use (retail and wholesale), NRW, conservation, and non-potable water demand.

Source: City of San Diego 2020 UWMP

6-9

 $<sup>^2</sup>$  The exact amount of production expected to be available at the end of CY 2025 is only estimated at this time. The total 33,600 AFY is expected to be online by the end of CY 2027.

### Section 7. CONCLUSION

The Clairemont CPU WSA includes water demand assumptions that are covered in the regional water resource planning documents of the City, the Water Authority, and the MWD. The MWD's 2020 UWMP and the Water Authority's 2020 UWMP include projects that meet long-term supply needs through securing water from the State Water Project, Colorado River, local water supply development, conservation, and water reuse.

In summary, this WSA demonstrates there is sufficient water supply over a 20-year planning horizon to meet the projected demand of the Project, as well as the existing and other planned development projects within the PUD service area in normal, dry and multiple dry year forecasts.

### Section 8. REFERENCES

California Department of Water Resources, Guidebook for Implementation of Senate Bill 1610 and Senate Bill 221 of 2001 to assist water suppliers, cities, and counties in integrating water and land use planning (2003). California Agencies. Paper 95.

City of San Diego, 2020 Recycled Water Master Plan Update, June 2020.

City of San Diego, 2022, Grid Tile: 18 Official Zoning Map, December 12, 2023.

City of San Diego Planning Department, Clairemont Mesa Community Plan, 1989.

City of San Diego Planning Department, Draft Proposed Clairemont Community Plan, May 2021.

City of San Diego Planning Department, Request for the Preparation of a Water Supply Assessment for the Clairemont Community Plan Update (IO # 21005493), Updated December 13th, 2024.

City of San Diego Public Utilities Department, 2015 Urban Water Management Plan, June 2016.

City of San Diego Public Utilities Department, 2020 Water Demand Forecast Report, January 2021.

City of San Diego Public Utilities Department, 2020 Urban Water Management Plan, June 2021.

City of San Diego Pure Water San Diego, 2021 Annual Report: A Year in Review, 2022.

Metropolitan Water District of Southern California, 2020 Regional Urban Water Management Plan, June 2021.

San Diego Association of Governments (SANDAG), 2022. Series 14 Growth Forecasts Housing Units by Community Planning Area. October 6, 2022.

San Diego County Water Authority, 2020 Urban Water Management Plan, May 2021.