

E R R A T A

Intensive Care Unit and Emergency Services Pavilion Addendum No. 697308 May 17, 2023

Subsequent to finalization of the Addendum to Mitigated Negative Declaration (MND) No. 84791, dated February 16, 2023, a minor revision to the environmental document has been made. Specifically, additional text has been added to describing the existing sewer. The revision made is reflected in a ~~striketrough~~ and/or underline format.

1. Project Description, page 8: An existing 15-inch reinforced concrete public sanitary sewer line that serves both RCHSD and the Sharp Memorial Hospital Campus runs from west to east across the RCHSD campus. This sewer line drains to the Kearny Mesa Trunk Line east of the campus. Sanitary sewer connections for proposed buildings would connect to the existing City sewer lines on the RCHSD campus and a new connection on Children's Way. Several buried tanks would be installed to provide 72 hours of emergency sanitary sewage storage to be able to maintain hospital operations in the event of City sewer system disruption in accordance with the requirements for hospital facilities contained in SB 1953. These would include a 45,000- gallon tank to support the ICU and a 24,000-gallon tank at the CUP. The existing sewer line is anticipated to be replaced-in-place prior to any construction occurring over the easement.

The revision made to the Addendum does not affect the environmental analysis or conclusions of the environmental document. The addition of the new information only clarifies and does not result in no new impacts or new mitigation beyond those previously disclosed.