

Appendix 5.17 - Summary of Miramar Reservoir Source Water Constituents 2016 - 2020

CSD

			Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
Group/Constituents	Units	CSD MDL	DLR	Primary MCL	Secondary SMCL	Criteria	Objectives	No. of Samples	Min	Max	Mean
General Physical											
Alkalinity, (Total) (as CaCO3 equivalents)	MG/L	20						20	83.6	133	109
Calcium Hardness (CaCO3)	MG/L	10						18	94.5	179	137
Color, Apparent (Unfiltered)	COLOR	1			15	20	20	19	ND	8	3.21
Corrosivity ³	-							18	-0.45	0.63	0.191
Hydroxide Alkalinity	MG/L							19	ND	ND	ND
MBAS (Foaming Agents)	MG/L	0.05		0.5		0.5	0.5	5	ND	ND	ND
Odor Threshold @ 60 C (TON)	ODOR	1	1		3		none	2	4	17	10.5
pH	PH					6.5-8.5 ⁶		19	7.41	8.25	7.86
Specific Conductance (E.C.)	UMHO/CM				1600			20	554	1070	790
Total Filterable Residue @ 180 C (TDS)	MG/L	10			1000	300	500	20	340	661	489
Total Hardness (CaCO3)	MG/L	10						19	162	299	229
Turbidity, Laboratory	NTU	0.07	0.1		5	20	20	20	0.2	3.79	0.551
Microbiological											
Enterococcus	/100 ML	1				60 ⁷		252	< 1	730	15
Escherichia Coli	/100 ML	1		Present		190 ⁷		252	< 10	170	32
Total Coliform	/100 ML	1		Present				252	10	24000	757
Total Crypto Oocyst Count	/ L	0.1		1				10	ND	ND	ND
Total Giardia Cyst Count	/ L	0.1		1				10	ND	ND	ND
Radiologicals											
Gross Alpha	PCI/L		3	15				2	ND	ND	ND
Gross Beta	PCI/L		4	50 ⁸				2	ND	4.30	2.15
Uranium	PCI/L		1	20				1	1.3	1.3	1.3

			Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
Group/Constituents	Units	CSD MDL	DLR	Primary	Secondary	Criteria	Objectives	No. of Samples	Min	Max	Mean
				MCL	SMCL						
Metals ⁴											
Aluminum (Al)	UG/L	5	50	1000	200			19	ND	ND	ND
Antimony	UG/L	1	6	6				19	ND	ND	ND
Arsenic	UG/L	1	2	10				20	ND	ND	ND
Barium (Ba)	UG/L	2	100	1000				20	59.6	129	88.3
Beryllium	UG/L	0.5	1	4				20	ND	ND	ND
Boron	UG/L	5	100			500	750	20	106	184	139
Cadmium (Cd)	UG/L	0.5	1	5				20	ND	ND	ND
Calcium (Ca)	MG/L	5						20	37.8	71.6	54.8
Chromium (Total Cr)	UG/L	1	10	50				20	ND	ND	ND
Chromium, Hexavalent	UG/L	1						5	ND	ND	ND
Copper (Cu) ⁵	UG/L	1	50	1300	1000			20	ND	8.87	ND
Iron (Fe)	UG/L	100	100		300	300	300	19	ND	60.7	ND
Lead (Pb) ⁵	UG/L	0.5	5	15				20	ND	ND	ND
Magnesium (Mg)	MG/L	3						40	14.8	32.1	21.6
Manganese (Mn)	UG/L	0.5	20		50	50	50	20	4.34	42.8	10.4
Mercury (Hg)	UG/L	0.2	1	2				20	ND	ND	ND
Nickel	UG/L	1	10	100				20	ND	2.15	ND
Potassium (K)	MG/L	0.5						16	3.59	5.2	4.26
Selenium (Se)	UG/L	2	5	50				20	ND	ND	ND
Silver	UG/L	1	10	50				20	ND	ND	ND
Sodium (Na)	MG/L	20				60%	60%	20	55.5	98.8	77.5
Thallium	UG/L	0.5	1	2				20	ND	ND	ND
Vanadium	UG/L	1	3					20	ND	ND	ND
Zinc (Zn)	UG/L	5	50		5000			18	ND	ND	ND

			Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
Group/Constituents	Units	CSD MDL	DLR	Primary MCL	Secondary SMCL	Criteria	Objectives	No. of Samples	Min	Max	Mean
Inorganic Constituents											
Ammonia-N	MG/L	0.031				0.025		38	ND	0.171	ND
Asbestos Chrysotile Fibers >10 microns	MFL	0.2	0.2	7				1	ND	ND	ND
Bicarbonate (as HCO3)	MG/L							20	101	162	132
Bromide	MG/L	0.1						20	ND	0.135	ND
Carbonate (as CO3)	MG/L							20	ND	3.47	0.243
Chloride	MG/L	0.5			500	250	250	20	67	123	91
Cyanide	UG/L		100	150				5	ND	ND	ND
Fluoride	MG/L	0.02	0.1	2		1	1	20	0.152	0.826	0.272
Nitrate (as NO3)	MG/L		2	45		5		65	ND	0.852	0.251
Nitrite (NO2)	MG/L	0.0156	0.131	0.328				42	ND	0.034	ND
Perchlorate	UG/L	4	4	6				40	ND	ND	ND
Phosphate, Ortho (as PO4)	MG/L	0.2						19	ND	ND	ND
Phosphorus	MG/L	0.078				0.025 ⁹	0.025 ⁹	46	ND	0.211	ND
Silica	MG/L	0.625						20	5.35	9.15	7.59
Sulfate (SO4)	MG/L	0.5	0.5		500	65	250	20	90.3	273	158
Total Nitrogen	MG/L	0.156					0.25 ⁹	49	ND	1.08	0.278

			Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
Group/Constituents	Units	CSD MDL	DLR	Primary	Secondary	Criteria	Objectives	No. of Samples	Min	Max	Mean
				MCL	SMCL						
Organic Constituents, Regulated											
1,1,1-Trichloroethane (1,1,1-TCA)	UG/L	0.4	0.5	200		200		20	ND	ND	ND
1,1,2,2-Tetrachloroethane	UG/L	0.4	0.5	1		1		20	ND	ND	ND
1,1,2-Trichloroethane (1,1,2-TCA)	UG/L	0.4	0.5	5		32		20	ND	ND	ND
1,1-Dichloroethane (1,1-DCA)	UG/L	0.4	0.5	5		5		20	ND	ND	ND
1,1-Dichloroethylene (1,1-DCE)	UG/L	0.4	0.5	6		6		20	ND	ND	ND
1,2,4-Trichlorobenzene	UG/L	0.4	0.5	5				20	ND	ND	ND
1,2-Dichlorobenzene (o-DCB)	UG/L	0.4	0.5	600				20	ND	ND	ND
1,2-Dichloroethane (1,2-DCA)	UG/L	0.4	0.5	0.5		0.5		20	ND	ND	ND
1,2-Dichloropropane	UG/L	0.4	0.5	5		5		20	ND	ND	ND
1,4-Dichlorobenzene (p-DCB)	UG/L	0.4	0.5	5		5		20	ND	ND	ND
2,3,7,8-tetra CDD	UG/L		5E-06	0.00003				2	ND	ND	ND
2,4,5-TP (SILVEX)	UG/L	1	1	50		10		20	ND	ND	ND
2,4-D	UG/L	3	10	70		100		20	ND	ND	ND
Alachlor (ALANEX)	UG/L	0.5	1	2				9	ND	ND	ND
Atrazine (AATREX)	UG/L	0.4	0.5	1		3		9	ND	ND	ND
Bentazon (BASAGRAN)	UG/L	2	2	18		18		20	ND	ND	ND
Benzene	UG/L	0.4	0.5	1		1		20	ND	ND	ND
Benzo(a)pyrene	UG/L	0.1	0.1	0.2				8	ND	ND	ND
Bromodichloromethane	UG/L	0.4	1			100		20	0.99	2.83	1.62
Bromoform	UG/L	0.4	1			100		20	ND	0.74	0.456
Carbofuran (FURADAN)	UG/L	0.4	5	18		18		20	ND	ND	ND
Carbon Tetrachloride	UG/L	0.4	0.5	0.5		0.5		20	ND	ND	ND
Chlordane	UG/L	0.1	0.1	0.1		0.1		3	ND	ND	ND
Chlorodibromomethane	UG/L	0.4	1					20	1.16	2.7	1.8
Chloroform (Trichloromethane)	UG/L	1	1			100		20	ND	4.75	1.34
cis-1,2-Dichloroethylene (c-1,2-DCE)	UG/L	0.4	0.5	6		6		20	ND	ND	ND
Dalapon	UG/L	2	10	200				2	ND	ND	ND
Di(2-ethylhexyl) Adipate	UG/L	2	5	400				9	ND	ND	ND
Di(2-ethylhexyl)phthalate (DEHP)	UG/L	3	3	4		4		9	ND	ND	ND
Dibromoacetic Acid (DBAA)	UG/L	1	1					2	ND	ND	ND
Dibromochloropropane (DBCP)	UG/L	0.01	0.01	0.2		0.2		20	ND	ND	ND
Dichloroacetic Acid (DCAA)	UG/L	1	1					2	ND	ND	ND
Dichloromethane (Methylene Chloride)	UG/L	0.4	0.5	5				20	ND	ND	ND
Dinoseb (DNBP)	UG/L	2	2	7				20	ND	ND	ND
Diquat	UG/L	3	4	20				2	ND	ND	ND
Endothall	UG/L	15	45	100				2	ND	ND	ND

Group/Constituents	Units	CSD MDL	Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
			DLR	Primary MCL	Secondary SMCL	Criteria	Objectives	No. of Samples	Min	Max	Mean
Endrin	UG/L	0.1	0.1	2		0.2		12	ND	ND	ND
Ethyl Benzene	UG/L	0.4	0.5	300		680		20	ND	ND	ND
Ethylene Dibromide (EDB)	UG/L	0.02	0.02	0.05		0.02		22	ND	ND	ND
Glyphosate	UG/L	10	25	700		700		19	ND	13.7	ND
Haloacetic Acids (five) (HAA5) ¹⁰	UG/L	1		60				2	ND	1.18	ND
Heptachlor	UG/L	0.01	0.01	0.01		0.01		3	ND	ND	ND
Heptachlor Epoxide	UG/L	0.01	0.01	0.01		0.01		3	ND	ND	ND
Hexachlorobenzene	UG/L	0.5	0.5	1				12	ND	ND	ND
Hexachlorocyclopentadiene	UG/L	0.211	1	50				11	ND	ND	ND
Lindane (gamma-BHC)	UG/L	0.2	0.2	0.2		4		3	ND	ND	ND
meta,para xylenes	UG/L	0.4	0.5			1750		20	ND	ND	ND
Methoxychlor	UG/L	0.5	10	30		100		12	ND	ND	ND
Methyl tert-Butyl Ether (MTBE)	UG/L	0.4	3	13	5			20	ND	ND	ND
Molinate (ORDRAM)	UG/L	0.5	2	20		20		7	ND	ND	ND
Monobromoacetic Acid (MBAA)	UG/L	1	1					2	ND	ND	ND
Monochloroacetic Acid (MCAA)	UG/L	2	2					2	ND	ND	ND
Monochlorobenzene (Chlorobenzene)	UG/L	0.4	0.5	70				20	ND	ND	ND
Oxamyl (Vydate)	UG/L	0.4	20	50				20	ND	ND	ND
o-Xylene	UG/L	0.4	0.5					20	ND	ND	ND
Pentachlorophenol (PCP)	UG/L	0.2	0.2	1		1		20	ND	ND	ND
Picloram	UG/L	1	1	500				20	ND	ND	ND
Polychlorinated Biphenyls, Total, as DCB	UG/L	0.5		0.5				8	ND	ND	ND
Simazine (PRINCEP)	UG/L	0.5	1	4		10		9	ND	ND	ND
Styrene	UG/L	0.4	0.5	100				20	ND	ND	ND
Tetrachloroethylene (PCE)	UG/L	0.4	0.5	5		5		20	ND	ND	ND
Thiobencarb (BOLERO)	UG/L	0.5	1	70	1	70		8	ND	ND	ND
Toluene	UG/L	0.4	0.5	150				20	ND	ND	ND
Total Organic Carbon (TOC)	MG/L	0.3						59	2.68	5.01	3.08
Total Toxaphene	UG/L	1	1	3		5		3	ND	ND	ND
Total Trihalomethanes (TTHMs) ¹⁰	UG/L	0.4		80				20	ND	4.75	ND
trans-1,2-Dichloroethylene (t-1,2-DCE)	UG/L	0.4	0.5	10		10		20	ND	ND	ND
Trichloroacetic Acid (TCAA)	UG/L	1	1					2	ND	1.18	ND
Trichloroethylene (TCE)	UG/L	0.4	0.5	5		5		20	ND	ND	ND
Trichlorofluoromethane (FREON 11)	UG/L	0.4	5	150		150		20	ND	ND	ND
Trichlorotrifluoroethane (FREON 113)	UG/L	0.4	10	1200				20	ND	ND	ND
Vinyl Chloride (VC)	UG/L	0.4	0.5	0.5		0.5		20	ND	ND	ND

			Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
Group/Constituents	Units	CSD MDL	DLR	Primary MCL	Secondary SMCL	Criteria	Objectives	No. of Samples	Min	Max	Mean
Organic Constituents, Unregulated											
1,1,1,2-Tetrachloroethane	UG/L	0.4	0.5					20	ND	ND	ND
1,1-Dichloropropene	UG/L	0.4	0.5					20	ND	ND	ND
1,2,3-Trichlorobenzene	UG/L	0.4	0.5					20	ND	ND	ND
1,2,3-Trichloropropane	NG/L	5	5					13	ND	ND	ND
1,2,4-Trimethylbenzene	UG/L	0.4	0.5					20	ND	ND	ND
1,3,5-Trimethylbenzene	UG/L	0.4	0.5					20	ND	ND	ND
1,3-Dichlorobenzene (m-DCB)	UG/L	0.4	0.5					20	ND	ND	ND
1,3-Dichloropropane	UG/L	0.4	0.5			0.5		20	ND	ND	ND
2,2-Dichloropropane	UG/L	0.4	0.5					20	ND	ND	ND
2,4,5-T	UG/L	3						20	ND	ND	ND
2,4-DB	UG/L	3						20	ND	ND	ND
2-Chlorotoluene	UG/L	0.4	0.5					20	ND	ND	ND
2-Methylisoborneol	NG/L	5						245	ND	17.5	ND
3,5-Dichlorobenzoic Acid	UG/L	3						20	ND	ND	ND
3-Hydroxycarbofuran	UG/L	0.4	3					20	ND	ND	ND
4-Chlorotoluene	UG/L	0.4	0.5					20	ND	ND	ND
4-Nitrophenol	UG/L	3	5			1		20	ND	ND	ND
Acenaphthylene	UG/L	0.5						8	ND	ND	ND
Acifluorfen	UG/L	3						20	ND	ND	ND
Aldicarb (TEMIK)	UG/L	0.4	3					20	ND	0.537	ND
Aldicarb Sulfone	UG/L	0.4	4					20	ND	ND	ND
Aldicarb Sulfoxide	UG/L	0.4	3					19	ND	ND	ND
Aldrin	UG/L	0.1	0.075					3	ND	ND	ND
Anthracene	UG/L	0.5						8	ND	ND	ND
Baygon	UG/L	0.4						20	ND	ND	ND
Benzo (a) Anthracene	UG/L	0.5						8	ND	ND	ND
Benzo (b) Fluoranthene	UG/L	0.5						8	ND	ND	ND
Benzo (ghi) Perylene	UG/L	0.5						7	ND	ND	ND
Benzo (k) Fluoranthene	UG/L	0.5						8	ND	ND	ND
Benzyl Butyl Phthalate	UG/L	0.5						8	ND	ND	ND
Bromobenzene	UG/L	0.4	0.5					20	ND	ND	ND
Bromochloromethane	UG/L	0.4	0.5					20	ND	ND	ND
Bromomethane (Methyl Bromide)	UG/L	0.4	0.5					20	ND	ND	ND
Carbaryl (Sevin)	UG/L	0.4	5					20	ND	ND	ND
Chloramben	UG/L	3						20	ND	ND	ND
Chloroethane	UG/L	0.4	0.5					20	ND	ND	ND

Group/Constituents	Units	CSD MDL	Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
			DLR	Primary MCL	Secondary SMCL	Criteria	Objectives	No. of Samples	Min	Max	Mean
Chloromethane (Methyl Chloride)	UG/L	0.4	0.5					21	ND	ND	ND
Chrysene	UG/L	0.5						8	ND	ND	ND
cis-1,3-dichloropropene	UG/L	0.4	0.5					20	ND	ND	ND
Dibenzo (a,h) anthracene	UG/L	0.5						7	ND	ND	ND
Dibromomethane	UG/L	0.4	0.5					19	ND	ND	ND
Dicamba (BANVEL)	UG/L	1.5	1.5					20	ND	ND	ND
Dichlorodifluoromethane (Freon 12)	UG/L	0.4	0.5					20	ND	ND	ND
Dichlorprop	UG/L	3						20	ND	ND	ND
Dieldrin	UG/L	0.02	0.02					3	ND	ND	ND
Diethylphthalate	UG/L	0.5						8	ND	ND	ND
Diisopropyl Ether (DIPE)	UG/L	0.4	3					20	ND	ND	ND
Dimethyl phthalate	UG/L	0.5						8	ND	ND	ND
di-n-Butylphthalate	UG/L	2						20	ND	ND	ND
Ethyl-tert-Butyl Ether (ETBE)	UG/L	0.4	3					20	ND	ND	ND
Fluorene	UG/L	0.5						8	ND	ND	ND
Geosmin	NG/L	5						245	ND	> 55	ND
Hexachlorobutadiene	UG/L	0.4	0.5					20	ND	ND	ND
Indeno (1,2,3-cd) Pyrene	UG/L	0.5						7	ND	ND	ND
Isopropylbenzene (Cumene)	UG/L	0.4	0.5					20	ND	ND	ND
MCPA	UG/L	3						20	ND	ND	ND
MCPP	UG/L	3						20	ND	ND	ND
Methiocarb	UG/L	0.4						20	ND	ND	ND
Methomyl	UG/L	0.4	2					20	ND	ND	ND
Naphthalene	UG/L	0.4	0.5					20	ND	ND	ND
n-Butylbenzene	UG/L	0.4	0.5					20	ND	ND	ND
n-Propylbenzene	UG/L	0.4	0.5					20	ND	ND	ND
Paraquat	UG/L	4	20					2	ND	ND	ND
PCB-1016 (as DCB)	UG/L	0.26	0.5	0.5				8	ND	ND	ND
PCB-1221 (as DCB)	UG/L	0.19	0.5	0.5				8	ND	ND	ND
PCB-1232 (as DCB)	UG/L	0.23	0.5	0.5				8	ND	ND	ND
PCB-1242 (as DCB)	UG/L	0.26	0.5	0.5				8	ND	ND	ND
PCB-1248 (as DCB)	UG/L	0.3	0.5	0.5				8	ND	ND	ND
PCB-1254 (as DCB)	UG/L	0.33	0.5	0.5				8	ND	ND	ND
PCB-1260 (as DCB)	UG/L	0.36	0.5	0.5				8	ND	ND	ND
Phenanthrene	UG/L	0.5				1		8	ND	ND	ND
p-Isopropyltoluene	UG/L	0.4						20	ND	ND	ND
Propachlor	UG/L	0.5	0.5					11	ND	ND	ND
Pyrene	UG/L	0.5						8	ND	ND	ND

Group/Constituents	Units	CSD MDL	Federal/California Drinking Water Standards ¹			Basin Plan Inland Surface Waters Quality ²		2016 - 2020 Source Water Quality at Surface			
			DLR	Primary MCL	Secondary SMCL	Criteria	Objectives	No. of Samples	Min	Max	Mean
sec-Butylbenzene	UG/L	0.4	0.5					20	ND	ND	ND
tert-Amyl Methyl Ether (TAME)	UG/L	0.4	3					20	ND	ND	ND
tert-Butyl Alcohol (TBA)	UG/L	1	2					20	ND	ND	ND
tert-Butylbenzene	UG/L	0.4	0.5					20	ND	ND	ND
trans-1,3-dichloropropene	UG/L	0.4	0.5	0.5				20	ND	ND	ND
Trifluralin	UG/L	0.5						8	ND	ND	ND

End Notes:

CSD MDL: City of San Diego Water Quality Laboratory minimum detection level, DLR: detection level for reporting, MCL: maximum contaminant level, SMCL: Secondary MCL, ND: not detected. Calculated mean below CSD MDL reported as ND.

¹ DLR, MCL, SMCL are obtained from California OEHHA and SWRCB and apply to drinking water and are for reference only. California MCL and SMCL values may be more stringent than federal standards for drinking water.

² Water Quality Control Plan for the San Diego Basin (9) with amendments effective on or before May 17, 2016. Water Quality Objectives concentrations not to be exceeded more than 10% of the time during any one year period.

³ Based on the Langelier index. A positive value indicates non-corrosive tendencies. A negative value indicates corrosive tendencies.

⁴ Trace metal values were from filtered and unfiltered samples. Differences in values were negligible.

⁵ Values referred to as MCLs for Lead and Copper are actually called Action Levels under the Lead and Copper Rule.

⁶ Waters designated Fresh or Warm changes in normal ambient pH levels shall not exceed 0.5 units

⁷ Beach Action Values (BAV): Amendment to the Domestic Water Permit issued by SWRCB to CSD, August 27, 2018

⁸ DDW considers 50 pCi/L to be the level of concern for beta particles.

⁹ P= 0.025 mg/L in any standing body of water. Nitrogen threshold determined by monitoring or if data are lacking, ratio of N:P = 10:1 is used. These values not to be exceeded more than 10% of the time.

¹⁰ Total Trihalomethane and HAA5 compliance is based on quarterly Locational Running Annual Averages (LRAA)