

I-4 and E Day Care
(Day care for more than six adults/children for less than 24 hours)

EXTERIOR

Access and Fire Lanes

- Address numbers are visible from street **505.1**
- Knox box is required where access to or within a structure and/or area is restricted **506.1**
- Keys in the Knox box are maintain current/updated **506.2**
- Fire lane markings are maintained in a clear and legible condition at all times **503.3**
- An additional fire access road is provided, when required **503.1.2**
- A minimum width of 20 feet in width is provided for the fire lane **503.2.1**
- Fire lane road surface is maintained to support imposed loads of fire apparatus with all-weather capabilities **503.2.3**
- Fire department approval is required when security gates across fire access roads **503.6**

Fire Hydrants

- Caps on, outlets toward street, shut off valve location noted, corrosion, leaking, **507.5.2**
- Private hydrants fire service mains and water tanks: annual visual, five year test and maintained with records kept on site **507.5.3**
- Unobstructed access is maintained at all times **507.5.4**
- A 3 ft circumference of clearance of clear space is maintained at all times **507.5.5**
- Provide physical protection when subject to damage **507.5.6**
- Blue dot hydrant markers are provided **SDMC §55.0507(a)**

Fire Sprinkler Systems

- Back-flow preventer: Inspect for access, lock, chain, sign w/building address, cover for tamper and flow switches and wiring intact, FDC with caps and freely swivel, no corrosion, no leaks **901.6**
- PIV: Clearly visible and accessible, site glass readable and in place, break-away lock, shutoff wrench, sign w/building address listing area covered, tamper switch cover in place and wiring intact **901.6**
- Butterfly, OS&Y: Valves open, not damaged, no parts missing **901.6**
- Tamper switch: Conduit broken, exposed wires, cover missing **901.6**
- FDC: Clearly visible and accessible, caps on, connections swivel freely, gasket inside, signage indicating the FDC and areas served **901.6**
- Signs are in place for all FDCs and multiple risers showing areas covered **509.1**
- Standpipes: signage indicating what each valve controls, caps in place, no damage, no corrosion, no obstructions **901.6**
- Sprinkler heads are not painted, corroded or damaged, inadequate coverage **901.6**
- Sprinkler piping, braces: Damage, leaking, corrosion, any non-sprinkler attachments present **901.6**
- Access to fire protection equipment is provided **509.2**
- Sprinkler bell, if present: Inspect for sign, damage, corrosion, obstructions **901.6**

Storage (outside)

- Combustible waste material is removed from the structure and premises **304.1**
- Dumpsters over 1.5 cu yards (40 cu ft) are a minimum of 5 feet from combustible walls, openings, roof eaves **304.3.3**
- There is 10 feet of clearance between combustible material and the property line **315.4**

INTERIOR

General

- Occupant load sign is conspicuously posted near entrances of public assembly spaces **1004.3**
- A change of use/change of occupancy is obtained when required **102.3**

Compressed Gases

- Compressed gas cylinders are properly secured **5303.5.3**
- Caps are on when cylinders are not in use **5303.6.2**
- Physical protection is provided when cylinders are exposed to physical damage **5303.5.2**

Electrical

- Abatement of electrical hazards (general electrical hazard) **605.1**
- Cover plates are present for electrical boxes, conduit bodies, on/off switches **605.6**
- Electrical splices are done inside electrical boxes or conduit bodies **605.6**
- Extension cords are not used in lieu of permanent wiring **605.5**
- Extension cords are not affixed to structures; extended through walls, ceilings or floors **605.5**
- Extension cords are only used with portable appliances **605.5**
- Extension cords are not subject to environmental damage or physical impact **605.5**
- Clear space is provided in front of electrical service equipment a minimum of 36 inches deep, 78 inches in height and a minimum of 30 inches wide or the length of the equipment, whichever is greater **605.3**
- Signs are provided for electrical control panel rooms **605.3.1**
- Service disconnects and individual circuit breakers are permanently marked/identified **605.3.1**

Exit Doors

- Operable at all times without a key, special knowledge or effort **1010.1.9**
- Unlatching, of any door or leaf does not require more than one action **1010.1.9.5**
- Minimum dimensions are not less than 32" wide and 80" high **1010.1.1**
- Open in the direction of emergency travel when occupant load exceeds 49 **1010.1.2.1**
- Not concealed with decorations, furnishings, mirrors or drapes **1010.1**
- Manually operated flush bolts, surface bolts are removed from exit doors **1010.1.9.4**
- A landing is provided and maintained outside exit door that is the same width as door **1010.1.6**
- A sign is provided on the door above and within 12" of delayed egress locks **1010.1.9.7**
- Time delay devices may only be used with an automatic sprinkler system and automatic smoke detection system (exterior gates surrounding the property are excluded) **1010.1.9.7**

Exit Signs

- Internally or externally illuminated **1013.3**
- Readily visible from any direction of egress **1013.1**
- Additional exit signs are provided when the exit path is not easily identified **1013.1**
- Illuminated when two or more exits are required **1013.1**
- Back-up power is provided **1013.6.3**

Fire Alarm System

- Panel: Green light – system ok
- Panel: Any other color light – TROUBLE or SUPERVISORY signal **901.6**
- Fire alarm components/system are maintained in an operable condition at all times **901.6**
- Panel: The date of installation is noted on the back-up batteries and replaced every five years **901.6**
- The location of the circuit breaker is noted inside the fire alarm panel **901.6**
- A lock-out is provided on the electrical panel for fire alarm circuit breaker and fire alarm bell **901.6**
- Maintenance, inspection and test documentation is provided **901.6.2**
- A sign is provided on the door if the fire alarm panel is enclosed **509.1**
- Operating, testing and maintenance instructions are provided **901.6.2.1**
- Fire watch is required or evacuate building when system is not working **901.7**
- Construction permit is needed for installation and/or modification of system **105.7.6**

Fire Extinguishers

- Minimum 2A:10BC extinguisher is present **906.1**
- Mounted so that the top is no more than 5 feet above floor **906.9.1**
- Mounted with hangers and brackets supplied with the extinguisher **906.7**
- Travel distance to any extinguisher is no more than 75 feet **906.3.1**
- California State Fire Marshal tag is attached showing annual certification (monthly visual inspection by owner) **906.2**

Fire Resistive Assemblies and Construction

- Maintain fire resistive construction (fire rated walls, ceilings, fire rated columns) **703.1**
- Hanging/display of salable goods and other decorative materials from fire resistive ceiling system prohibited **703.3**
- Fire assemblies are maintained operable and free of obstructions (doors, fire dampers, etc.) **703.2**
- Replace fused and/or damaged fusible links **703.2**
- Modification of fire door assemblies is prohibited **703.2**
- Maintain magnetic hold open devices and automatic door closers **703.2.2**
- Fire doors are kept closed when hold open devices are not in service **703.2.2**
- Fire doors self-close and latch automatically in place **703.2.3**
- Repair damaged fire rated doors, trash chute doors, fire dampers **703.2**
- Sign in place for roll down or sliding fire doors:
 - Fire doors designed to be kept normally open - "FIRE DOOR - DO NOT BLOCK" **703.2.1**
 - Fire doors designed to be kept normally closed - "FIRE DOOR- KEEP CLOSED" **703.2.1**
- Maintenance, inspection and annual testing required for all fire rated doors and assemblies **703.4**

Fire Sprinkler Systems

- Signage is present on the door of enclosed fire sprinkler risers **509.1**
- The 5 year cert tag is affixed to the sprinkler riser **901.6.1**
- Sprinkler heads: Painted, corroded, damaged, obstructed, improperly installed, incorrect sprinkler installed, adequate coverage **901.6**
- Spare sprinkler box: Wrench is present, sprinkler heads are representing those that are currently installed are present **901.6**
- Standpipes: 5 year cert tag is affixed, caps present, no damage, no corrosion **901.6**
- The system is tested and maintained at all times in operative condition **901.6.1**
- Riser: Accessible, calc card present, gauges broken/unreadable, bracing detached/corroded, flow and tamper switch covers in place and wiring intact, J box covers missing **901.6**
- Sprinkler piping, braces: damage, leaking, corrosion, any non-sprinkler attachments **901.6**
- Provide access to fire protection equipment **509.2**
- Sprinkler piping is free from attachments **901.6**
- Coverage is required in every room **901.4**
- Fire watch is required or evacuate the building when system is not in working order **901.7**
- Documentation of five year certification and regular maintenance reports shall be kept on-site **901.6.2**

Kitchen

- K Class extinguisher is within 30 feet of kitchens with fire suppression hood systems **904.12.5.2**
- K Class extinguisher has California State Fire Marshal tag is attached showing annual certification (monthly visual inspection by owner) **906.2**
- Pull station: Accessible and visible (not required for sprinkler systems) **904.12.1**
- Inspect for excess grease: Discharge nozzles, discharge nozzle covers, general hood area, filters within hood, fusible link, sprinkler heads **609.3.3.2**
- Fusible link and sprinkler heads are replaced annually (except frangible bulbs) **904.12.6.3**
- Nitrogen expellant bottle and hoses connected properly to Agent tanks **901.6**
- Hood suppression system is serviced and tagged every 6 months and after each activation **904.12.6.2**
- Documentation of inspection, testing and maintenance and other service records are kept on-site **901.6.2**

Means of Egress

- Protruding objects shall not reduce the clear width of accessible routes **1003.3.4**
- Floor surface shall have a slip resistant surface and be securely attached **1003.4**
- Remove obstructions from path of egress **1003.6**
- No combustible material storage in exits or in exit enclosures (stairwells) **315.3.2**
- Provide emergency exit lighting **1008.2**
- Means of egress shall be illuminated when building is occupied **1008.2**

Mechanical/HVAC Rooms

- Provide signage for mechanical HVAC, fan and elevator rooms **509.1.1**
- Fire extinguisher required **906.3**
- Patch holes in walls and ceilings **703.1.3**
- No combustible material storage **315.3.3**

Smoke Detectors & Sprinkler Systems

- Smoke detectors must be on every floor and in every room except kitchens and bathrooms **F907.2.11.2**
- Automatic sprinkler system required for more than one bedridden client and non-ambulatory above the first floor **F903.2.8**

Storage (inside)

- Reduce storage to 2 feet from the ceiling in unsprinklered buildings **315.3.1**
- Reduce storage to 18 inches below the bottom of sprinkler heads in sprinklered buildings **315.3.1**
- Storage of combustible materials inside shall be orderly with stable stacks and separated from ignition sources **315.3**
- No storage under stairs, exits or exit enclosures **315.3.2**
- Combustible material shall not be stored in boiler rooms, mechanical rooms, electrical equipment rooms or in fire command centers **315.3.3**