

Chapter 1. General Introduction

INTRODUCTION

Treated effluent from the City of San Diego E.W. Blom Point Loma Wastewater Treatment Plant (PLWTP) is discharged to the Pacific Ocean through the Point Loma Ocean Outfall (PLOO) according to requirements set forth in Order No. R9-2002-0025, National Pollutant Discharge Elimination System (NPDES) Permit No. CA0107409. The above Order and associated Monitoring and Reporting Program (MRP No. R9-2002-0025) were adopted by the San Diego Regional Water Quality Control Board (RWQCB) on April 10, 2002. During 2003, the monitoring and reporting requirements for the Point Loma region were further modified with the adoption of Addendum No. 1 to the above Order and NPDES Permit (see City of San Diego 2004). The provisions established in Addendum No. 1 became effective August 1, 2003, thus superceding and replacing all prior receiving waters monitoring requirements for the PLWTP.

The MRP for Point Loma defines the requirements for monitoring the receiving water environment around the PLOO, including the sampling plan, compliance criteria, laboratory analyses, statistical analyses and reporting guidelines. The main objectives of the ocean monitoring program are to provide data that satisfy the requirements of the NPDES permit, demonstrate compliance with the 2001 California Ocean Plan (COP), detect movement and dispersion of the wastewater field, and identify any biological or chemical changes that may be associated with wastewater discharge.

BACKGROUND

The City of San Diego began operation of the PLWTP and original ocean outfall off Point Loma in 1963, at which time treated effluent was discharged approximately 3.9 km offshore at a depth of about 60 m (200 ft). From 1963 to 1985, the plant operated as a primary treatment

facility, removing approximately 60% of the total suspended solids (TSS) by gravity separation. Since then, considerable improvements have been made to the treatment process. For example, the City began upgrading the process to advanced primary treatment (APT) in mid-1985, with full APT status being achieved by July of 1986. This improvement involved the addition of chemical coagulation to the treatment process, and resulted in an increased TSS removal of about 75%. Since 1986, treatment has been further enhanced with the addition of several more sedimentation basins, expanded aerated grit removal, and refinements in chemical treatment. These enhancements have resulted in lower mass emissions from the plant, with TSS removals consistently greater than the 80% permit requirement. In addition, the PLOO was extended 3.3 km further offshore in the early 1990s in order to prevent intrusion of the wastewater plume into nearshore waters and thus comply with standards set forth in the COP for water contact sports areas. Construction of the outfall extension was completed in November 1993, at which time discharge was terminated at the original 60-m site. The outfall presently extends approximately 7.2 km offshore to a depth of 94 m (310 ft), where the pipeline splits into a Y-shaped multiport diffuser system. The two diffuser legs extend an additional 762 m to the north and south, each terminating at a depth of about 98 m (320 ft) near the edge of the continental shelf.

The average daily flow of effluent through the PLOO in 2005 was 183 mgd, ranging from 169 mgd in December to 217 mgd in February. This is higher than the average flow of 174 mgd during 2004. TSS removal averaged about 85% during 2005, with a total mass emissions of approximately 10,400 mt/yr (see City of San Diego 2006a).

RECEIVING WATERS MONITORING

Prior to 1994, the City conducted an extensive ocean monitoring program off Point Loma centered around

the original 60-m discharge site. This program was subsequently modified and expanded with the construction and operation of the deeper outfall. Data from the last year of regular monitoring near the original inshore site are presented in City of San Diego (1995b), while the results of a 3-year recovery study for that area are summarized in City of San Diego (1998). From 1991 through 1993, the City also conducted a voluntary “predischarge” study in the vicinity of the new site in order to collect baseline data prior to the discharge of effluent in these deeper waters (City of San Diego 1995a, 1995b). Results of NPDES mandated monitoring for the extended PLOO from 1994 through 2003 are available in previous annual receiving waters monitoring reports (e.g., City of San Diego 2004). Additionally, the City has participated in a number of regional and other monitoring efforts off San Diego and throughout the Southern California Bight that have provided useful background information for the entire region (e.g., SCBPP 1998, Bight’98 Steering Committee 2003, City of San Diego 1999, 2006c).

The current sampling area off Point Loma extends from La Jolla southward to Point Loma, and from the shoreline seaward to a depth of about 116 m (380 ft) (**Figure 1.1**). Fixed sites are generally arranged in a grid surrounding the outfall and are monitored in accordance with a prescribed sampling schedule. The monitoring program may be divided into the following major components, each comprising a separate chapter in this report: (1) Oceanographic Conditions; (2) Microbiology; (3) Sediment Characteristics; (4) Macrobenthic Communities; (5) Demersal Fishes and Megabenthic Invertebrates; (6) Bioaccumulation of Contaminants in Fish Tissues. Detailed information concerning station locations, sampling equipment, analytical techniques, and quality assurance procedures are included in the Environmental Monitoring and Technical Services Division Laboratory Quality Assurance Project Plan for the City’s Ocean Monitoring Program (City of San Diego in prep). Results of the Laboratory’s quality assurance procedures are included in the EMTS Division Laboratory Quality Assurance Report (City of San Diego 2006b). In addition, data files, detailed methodologies, completed




Figure 1.1
Receiving waters monitoring stations for the Point Loma Ocean Outfall Monitoring Program.

reports, and other pertinent information submitted to the USEPA and the RWQCB throughout the year are available online at the City’s Metropolitan Wastewater Department website (<http://www.sandiego.gov/mwwd>).

This report summarizes the results from the receiving waters monitoring conducted off Point Loma from January through December 2005. The data are compared to the results from previous years in order to examine long-term patterns of change in the region. In addition, results from the continuing coastal remote sensing study of the San Diego/Tijuana Region that is funded by the City and the International Boundary and Water Commission have been incorporated into the water quality sections of this report (Chapters 2 and 3). A glossary of technical terms is included.

LITERATURE CITED

Bight’98 Steering Committee. (2003). Southern California Bight 1998 Regional Monitoring

- Program: Executive Summary. Southern California Coastal Water Research Project, Westminster, CA.
- City of San Diego. (1995a). Outfall Extension Pre-Construction Monitoring Report (July 1991–October 1992). City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (1995b). Receiving Waters Monitoring Report for the Point Loma Ocean Outfall, 1994. City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (1998). Recovery Stations Monitoring Report for the Original Point Loma Ocean Outfall (1991–1996). City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (1999). San Diego Regional Monitoring Report for 1994–1997. City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (2004). Annual Receiving Waters Monitoring Report for the Point Loma Ocean Outfall, 2003. City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (2006a). 2005 Annual Reports and Summary: Point Loma Wastewater Treatment Plant and Point Loma Ocean Outfall. City of San Diego, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (2006b). EMTS Division Laboratory Quality Assurance Report, 2005. City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (2006c). Annual Receiving Waters Monitoring Report for the South Bay Ocean Outfall (South Bay Water Reclamation Plant), 2005. City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- City of San Diego. (in prep). EMTS Division Laboratory Quality Assurance Project Plan. City of San Diego Ocean Monitoring Program, Metropolitan Wastewater Department, Environmental Monitoring and Technical Services Division, San Diego, CA.
- SCBPP (Southern California Bight Pilot Project). (1998). Southern California Bight Pilot Project Reports: Volume I. Executive Summary; Volume II. Water Quality; Volume III. Sediment Chemistry; Volume IV. Benthic Infauna; Volume V. Demersal Fishes and Megabenthic Invertebrates; Volume VI. Sediment Toxicity. Southern California Coastal Water Research Project, Westminster, CA.

This page intentionally left blank