


SECTION C-C

SECTION A-A

NOTES

1. TYPES ARE DESIGNATED AS FOLLOWS: (NO WING) C, (ONE WING) C-1, (TWO WINGS) C-2.
2. EXPOSED EDGES OF CONCRETE SHALL BE ROUNDED WITH A RADIUS OF 1/2".
3. WHEN V EXCEEDS 4', STEPS SHALL BE INSTALLED.
4. CONCRETE GUTTER TO MATCH ADJACENT GUTTERS.
5. AN EXPANSION JOINT SHALL BE PLACE AT THE ENDS OF THE INLET WHERE THE CURB IS TO ADJOIN PER G-10.
6. PROVIDE 1/4" TOOLED GROOVE IN TOP SLAB IN LINE WITH BACK OF ADJACENT CURB.
7. SURFACE OF TOP SLAB SHALL BE SIDEWALK FINISHED TO DRAIN TOWARD STREET AT A SLOPE OF 1/4" PER FOOT.
8. WHERE INLET IS TO BE CONSTRUCTED ON GRADE AND D-3B CONCRETE APRON IS REQUIRED, LIFT DOWN-GRADE END OF GRATE.
9. INSTALL INLET MARKER.
10. ELEVATION SHALL BE SHOWN ON PLANS WHERE INDICATED BY "O" SYMBOL.
11. DIAMETER D SHALL BE 24" MAXIMUM. FOR LARGER DIAMETER PIPES THIS DRAWING MUST BE MODIFIED.

LEGEND ON PLANS



REVISION	BY	APPROVED	DATE
ORIGINAL*	KA	J. NAGELVOORT	01/12
UPDATED	RB	J. NAGELVOORT	10/15

CITY OF SAN DIEGO - STANDARD DRAWING

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

CA Dungea 10/5/15
COORDINATOR R.C.E. 56523 DATE

CURB INLET - TYPE C

DRAWING NUMBER **SDD-117**