



NOTES

1. DIMENSION SHOWN BECOMES 2'-0" WHEN OPENING ON BOTH SIDES. ADJUST MANHOLE AS REQUIRED.
2. EXPOSED EDGES OF CONCRETE SHALL BE ROUNDED WITH A RADIUS OF 12"
3. WHEN V EXCEEDS 4', STEPS SHALL BE INSTALLED.
4. CONCRETE GUTTER TO MATCH ADJACENT GUTTERS.
5. AN EXPANSION JOINT SHALL BE PLACED AT THE ENDS OF THE INLET WHERE THE CURB IS TO ADJOIN PER G-10.
6. PROVIDE 1/4" TOOLED GROOVE IN TOP SLAB IN LINE WITH BACK OF ADJACENT CURB.
7. MAINTAIN 1 1/2" CLEAR SPACING BETWEEN REINFORCING AND SURFACE UNLESS OTHERWISE NOTED.
8. INSTALL INLET MARKER.

LEGEND ON PLANS



REVISION	BY	APPROVED	DATE
ORIGINAL*	BB	J. NAGELVOORT	01/12
UPDATED	RB	J. NAGELVOORT	10/15

CITY OF SAN DIEGO - STANDARD DRAWING

MEDIAN CURB INLET - TYPE J

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

CRDunger 10/15/15
 COORDINATOR R.C.E. 56523 DATE

DRAWING NUMBER **SDD-118**