



NOTES:

1. CEMENT SLURRY BACKFILL SHALL BE THOROUGHLY CONSOLIDATED, HAVE A MAXIMUM SLUMP OF 4 INCHES, AND MAY CONTAIN 30% MAXIMUM 3/8" ROCK.
2. CONCRETE SHALL BE PLACED AND FINISHED IN ACCORDANCE WITH 306-6. CONCRETE MAY BE PLACED IMMEDIATELY FOLLOWING SLURRY BACKFILL.
3. CONCRETE TRENCH COVER SHALL BE A MINIMUM OF 5 1/2" THICK IN ALLEY OR LOCAL RESIDENTIAL STREETS AND 7" THICK IN ALL OTHER STREETS. SEE NOTE #5 IN SDG-108 FOR CONCRETE CLASS OPTIONS AND CURING REQUIREMENTS.
4. EXISTING PORTLAND CEMENT CONCRETE PAVEMENT WILL REQUIRE SAWCUTTING.
5. FOR ELECTRICAL SUPPLY CABLES, SEE CALIFORNIA PUBLIC UTILITY COMMISSION GENERAL ORDER NO. 128, RULE 33.4 CLEARANCES AND DEPTHS.
6. FOR DRY UTILITIES (ELECTRICAL, COMMUNICATION, GAS, ETC.) SEE SDG-119.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL		BAHMANIAN	04/86		<i>CR Dominga 10/5/15</i>
TITLE BLOCK		A. OSKOUI	12/06	NARROW TRENCH RESURFACING FOR PCC SURFACED STREETS	COORDINATOR R.C.E. 56523 DATE
UPDATED	KA	J. NAGELVOORT	01/12		
UPDATED	KA	J. NAGELVOORT	08/13		
UPDATED	AB	J. NAGELVOORT	10/15		
					DRAWING NUMBER SDG-118