



**NOTES:**

1. BEDDING MATERIAL SHALL BE SE 50 PLASTER OR MORTAR SAND.
2. WIRES WHICH RUN UNDER PAVED AREAS SHALL BE INSTALLED IN PVC PIPE SLEEVES TWICE THE DIAMETER OF THE WIRE BUNDLE (2" MINIMUM SIZE), EXTENDING 12" MINIMUM BEYOND EDGE OF PAVEMENT. INSTALL ELECTRICAL PULL BOX AT EACH END OF PIPE SLEEVES PER SDI-115.
3. THE LETTER E SHALL BE STAMPED OR CHISELED ON THE IMPROVEMENT(CURB-SIDEWALK) DIRECTLY ABOVE THE CONTROL WIRE /CABLE.
4. WHEN CONTROL WIRING CANNOT BE INSTALLED IN A PIPE TRENCH, IT SHALL BE INSTALLED A MINIMUM 18" BELOW FINISH GRADE BUNDLED WITH PLASTIC TAPE.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL*	RH	J. NAGELVOORT	01/12		<i>CA Bungca</i> 10/5/15
UPDATED	JW	J. NAGELVOORT	08/15	<b>CONTROL WIRE INSTALLATION</b>	COORDINATOR R.C.E. 56523 DATE
UPDATED	AR	J. NAGELVOORT	10/15		DRAWING NUMBER <b>SDI-119</b>