



SIDE VIEW

NOTE:

STABILIZERS SHALL BE PLACED NO GREATER THAN 10' APART, AT EACH RISER AND AT ALL FITTINGS.

REVISION	BY	APPROVED	DATE
ORIGINAL*	RH	J. NAGELVOORT	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

**ON-GRADE PIPE STABILIZATION  
TEMPORARY INSTALLATION**

RECOMMENDED BY THE CITY OF SAN DIEGO  
STANDARDS COMMITTEE

*H. Hadli*

1/31/2012

COORDINATOR R.C.E. 65271 DATE

DRAWING  
NUMBER

**SDI-120**