



NOTES:

1. AT CATCH BASIN LOCATIONS, JOINT TRENCH SHALL BE 7' MINIMUM FROM BACK OF CURB TO INSIDE WALL OF TRENCH.
2. SEWER AND RECLAIMED WATER MAINS AND LATERALS SHALL BE DESIGNED TO CROSS UNDER POTABLE WATER MAINS WITH A MINIMUM VERTICAL SEPARATION OF 12".
3. SEWER AND RECLAIMED WATER MAINS SHALL MAINTAIN A 10' MINIMUM HORIZONTAL SEPARATION FROM ANY POTABLE WATER.

REVISION	BY	APPROVED	DATE
ORIGINAL		J. CASEY	09/86
UPDATE	KA	J. NAGELVOORT	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

UTILITY LOCATIONS IN LOCAL AND MAJOR STREETS, PRIME ARTERIALS AND EXPRESSWAYS

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

H. Hadli 1/31/2012
COORDINATOR R.C.E. 65271 DATE

DRAWING NUMBER **SDM-111**