



NOTE:

ALL RECYCLED METERS, AIRVACUUM RELIEF VALVES, VALVES, PRESSURE REDUCING VALVES, PUMPS, PUMP CONTROL VALVES, ETC., SHALL BE TAGGED OR LABELED INDICATING THAT THE DEVICES ARE ON RECYCLED WATER SYSTEM AND COLOR CODED PANTONE #522. 12" MINIMUM CLEARANCE BETWEEN GROUND AND WATER CONTROL DEVICES.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE	
ORIGINAL	KA	J. NAGELVOORT	01/12		<i>J. Nagelvoort</i>	1/31/2012
				SIGN / TAG FOR IDENTIFICATION OF RECYCLED WATER CONTROL DEVICES	COORDINATOR R.C.E. 65271 DATE	
					DRAWING NUMBER	SDRW-111