



NOTES:

- ①- TEE SIZE TO MATCH EXISTING PIPE
- ②- REDUCER TO 2" DIAMETER PIPE, IF TEE IS LARGER THAN 2" DIAMETER
INCREASER TO 2" DIAMETER PIPE, IF TEE IS SMALLER THAN 2" DIAMETER
- ③- 2" BRASS BALL VALVE
- ④- 1 1/2" FIRE HOSE CONNECTION, MIN. 4" HORIZ.
CLEARANCE 6" TO 14" ABOVE EXISTING GROUND
- ⑤- 1 1/2" CAP
- ⑥- MISCELLANEOUS NIPPLES AS REQUIRED
- ⑦- INSTALL BRASS BALL VALVE SIZE TO MATCH EXIST PIPE
- ⑧- INSTALL UNION SIZE TO MATCH EXISTING PIPE

REVISION	BY	APPROVED	DATE
ORIGINAL	KA	A. OSKOUI	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

**THRESHOLD
BYPASS PIPING**

RECOMMENDED BY THE CITY OF SAN DIEGO
STANDARDS COMMITTEE

H. Hadli 1/31/2012
COORDINATOR R.C.E. 65271 DATE

DRAWING
NUMBER **SDRW-120**