



NOTES

1. IN NO CASE SHALL A LATERAL CONNECT TO THE SEWER MAIN DIRECTLY ON TOP OF THE PIPE.
2. ALL JOINTS ON SEWER LATERAL PIPE SHALL BE COMPRESSION TYPE OR APPROVED SOLVENT WELD.
3. LATERAL SHALL EXTEND TO PROPERTY LINE UNLESS SHOWN OTHERWISE ON PLANS
4. DO NOT TAP HOLE AND INSERT LATERAL PIPE DIRECTLY INTO MAIN. ALL CONNECTIONS SHALL BE MADE USING A SADDLE OR WYE CUT IN.
5. SEWER LATERAL SHALL HAVE 6" METAL TAPE WITH GREEN LETTERING INDICATING "SEWER" INSTALLED ABOVE THE ALIGNMENT OF THE NON-METALLIC PIPE FROM SEWER MAIN TO PROPERTY LINE.

DETAIL SHOWING THE MANNER OF CONNECTING OPPOSITE LATERALS TO A SEWER MAIN. TWO CONNECTIONS SHALL NOT BE MADE IN THE SAME LENGTH OF PIPE.

LEGENDS ON PLANS



REVISION	BY	APPROVED	DATE
DETAIL	JP	A. OSKOUI	12/03
UPDATED	KA	J. NAGELVOORT	01/12

CITY OF SAN DIEGO – STANDARD DRAWING

**HOUSE CONNECTION
(SEWER LATERAL)**

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

CA Bringer

COORDINATOR R.C.E. 12/9/13 DATE

DRAWING NUMBER

SDS-105