


NOTES:

1. MANHOLE FRAME AND ALL JOINTS SHALL BE SET IN CLASS "C" MORTAR.
2. ALL PRECAST COMPONENTS SHALL BE MANUFACTURED IN ACCORDANCE WITH ASTM C478.
3. VERTICAL WALL OF CONE SHALL BE ON THE UPSTREAM SIDE OF THE MANHOLE.
4. CONCRETE BASE SHALL BE 560-C-3250.
5. APPROVED WATER STOP REQUIRED FOR PLASTIC PIPE CONNECTORS.
6. PRECAST SECTIONS SHALL BE USED WITHIN DIMENSION "A" AS REQUIRED, IN ORDER OF PREFERENCE LISTED:
 - A) CONE (NOTCHED FOR PIPE IF DIMENSION "A" IS LESS THAN 3'.)
 - B) 6" TO 18" OF 3' DIAMETER GRADE RINGS AND/OR RISERS.
 - C) 5' DIAMETER SHAFT VARIABLE HEIGHT.
7. FLEXIBLE PIPE JOINTS SHALL BE REQUIRED WITHIN 12" OF INSIDE FACE OF MANHOLE, EXCEPT FOR PLASTIC PIPE.
8. ALL PATCHING WITHIN MANHOLE BASE SHALL BE EPOXY MORTAR.
9. PRIOR APPROVAL OF PRECAST BASE IS REQUIRED BY THE ENGINEER.
10. MANHOLES SERVING 18" DIAMETER PIPE AND LARGER SHALL USE PRECAST RISERS LINED WITH WHITE PVC SHEETS IMBEDDED WITH LOCKING EXTENSIONS TO THE CONCRETE WALL. THE BASE AND ALL REMAINING EXPOSED CONCRETE SHALL BE COATED WITH AN APPROVED POLYURETHANE COATING.

LEGEND ON PLANS



REVISION	BY	APPROVED	DATE
DETAIL	SS	A. OSKOU	12/03
UPDATE	KA	J. NAGELVOORT	01/12
UPDATE	GB	J. NAGELVOORT	07/15

CITY OF SAN DIEGO – STANDARD DRAWING

MANHOLE 5' X 3' DIAMETER

RECOMMENDED BY THE CITY OF SAN DIEGO
STANDARDS COMMITTEE

CA Dzunga 7/21/15
COORDINATOR R.C.E. 56523 DATE

DRAWING NUMBER **SDS-106**