



NOTES:

1. FOR TRENCH RESURFACING IN IMPROVED STREETS SEE OTHER STANDARD DRAWINGS.
2. (*) INDICATES MINIMUM RELATIVE COMPACTION.
3. MINIMUM DEPTH OF COVER FROM THE TOP OF PIPE TO FINISH GRADE FOR PVC SDR 35 SEWER MAIN SHALL BE 5'. FOR SHALLOWER DEPTH, SPECIAL DESIGN IS REQUIRED.
4. INSTALL WARNING/IDENTIFICATION TAPE PER SDM-105.
5. 1' SAND CUSHION OR A 6" MIN SAND CUSHION WITH 1" NEOPRENE PAD SHALL BE PLACED FOR ALL CROSSING UTILITIES WHEN VERTICAL CLEARANCE IS 1' OR LESS. THE NEOPRENE PAD SHALL BE PLACED ON THE MOST FRAGILE UTILITY.

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL	KA	J. NAGELVOORT	01/12		PIPE BEDDING AND TRENCH BACKFILL FOR SEWERS IN GROUNDWATER
UPDATED	AR	J. NAGELVOORT	10/15	COORDINATOR R.C.E. 56523 DATE	
				DRAWING NUMBER	
				SDS-119	