



SCHEDULE			
ITEM		SIZE AND DESCRIPTION	
1	WATER MAIN	3" - 8" INCL.	10" - 20" INCL.
2	CAST IRON PLUG OR CAP	MAIN SIZE X 2"	MAIN SIZE X 3"
3	BRASS NIPPLE	2" X 8"	3" X 8"
4	BRONZE GATE VALVE WITH BRONZE WHEEL-SCREW ENDS	2"	3"
5	BRASS NIPPLE	AS NEEDED	AS NEEDED
6	BRASS 90° EL	2"	3"
7	BRASS RISER	2" X VARIABLE TO GRADE MINUS 4"	3" X VARIABLE TO GRADE MINUS 4"
8	BRASS COUPLING THREAD	2"	3"
9	BRASS PLUG	2"	3"
10	STEEL CASING FOR GATE VALVE AND RISER	8" X VARIABLE TO GRADE MINUS 3/4"	8" X VARIABLE TO GRADE MINUS 3/4"
11	GATE WELL CAP AND CAN SEE SDW-153	8"	8"

REVISION	BY	APPROVED	DATE
ORIGINAL		J. MUELLER	3-3-83
NOTES	AO	F. BELOCK	04-96
NOTES	SM	A. OSKOU	12-03
NOTES	JS	A. OSKOU	12-06
UPDATED	KA	J. NAGELVOORT	12/12
UPDATED	RB	J. NAGELVOORT	10/15

CITY OF SAN DIEGO - STANDARD DRAWING

**BLOW-OFF ASSEMBLIES  
AT THE END OF  
PVC AND CAST IRON MAINS**

RECOMMENDED BY THE CITY OF SAN DIEGO  
STANDARDS COMMITTEE

*C. Abungca* 10/15/15

COORDINATOR R.C.E. 56523 DATE

DRAWING NUMBER **SDW-106**