




WELD TOP OF CAP TO PIPE




WELD PLATE RING TO UNDERSIDE OF COVER




WELD CHAIN TO INSIDE OF CAP'S PIPE AND TO UNDERSIDE OF COVER



1/4" FLOOR PLATE




3/16" STEEL PIPE




1/8" STEEL PLATE RING

HOT DIPPED GALVANIZED STEEL CHAIN



1/4" X 9" CHAIN



COVER (TYP)

NOTES:

1. 8 1/4" FLOOR PLATE SHALL BE CUT OUT OF THE COVER AND THE OPENING SHALL BE FINISHED FOR TIGHT FIT.
2. READ HOLE IN COVER SHALL BE CENTERED OVER EACH METER REGISTER.

REVISION	BY	APPROVED	DATE
ORIGINAL	XX	T. MUELLER	2-4-86
		J. CASEY	8-22-86
UPDATED	KA	J. NAGELVOORT	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

**READ HOLE
CAP & CHAIN DETAIL
(FOR METAL METER VAULT COVERS)**

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

H. Hadli 1/31/2012
COORDINATOR R.C.E. 65271 DATE

DRAWING NUMBER **SDW-115**