



NOTES:

1. PLACE TWO DECALS, ONE FACING ROADWAY.
2. FILL THE PIPE WITH 50 SIEVE SAND FROM BOTTOM OF CONCRETE FOOTING TO 12" ABOVE GRADE.
3. THIS POST-MOUNTED STATION IS FOR USE ONLY IN AREAS WITH NO VEHICULAR TRFFIC.

ITEM CALL OUT:

1. CABLE: AWG #8 COPPER ASTM B3 STRANDED ASTM B8 INSULATION ASTM D 1248 TYPE 1, CLASS C, GR. 5.
2. FOOTING: CONCRETE 12" DIA., SSPWC 295-C-17.
3. PIPE: 4" DIAMETER, SCH 40, ASTM A 53 GALVANIZED.
4. DECAL: SEE SDW-132.
5. CAP: THREADED 4" DIAMETER GALVANIZED.

POST-MOUNTED TEST STATION

REVISION	BY	APPROVED	DATE
ORIGINAL	BM	A. OSKOUI	1203
NOTES	BM	A. OSKOUI	1206
UPDATED	KA	J. NAGELVOORT	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

**ABOVE GRADE CATHODIC PROTECTION
TEST STATION INSTALLATION
FOR UNDEVELOPED AREAS**

RECOMMENDED BY THE CITY OF SAN DIEGO
STANDARDS COMMITTEE

H. Hadli

1/31/2012

COORDINATOR R.C.E. 65271 DATE

DRAWING
NUMBER

SDW-127