



NOTES:

- 1) 6" WARNING / IDENTIFICATION TAPE SHALL BE INSTALLED ABOVE THE PIPE AS SPECIFIED AND RUN CONTINUOUSLY ALONG THE ENTIRE LENGTH OF THE PIPE AND ALL RELATED APPURTENANCES.
- 2) ELECTRICALLY BOND SERVICE TAPE AND MAIN TAPE TOGETHER. TAPE SHALL EXTEND WITHIN METER BOX ITSELF TO ALLOW MARKOUT BY CONTINUITY TESTER.

REVISION	BY	APPROVED	DATE
ORIGINAL*	KA	J. NAGELVOORT	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

WARNING / IDENTIFICATION TAPE INSTALLATION

RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE

H. Hadli 1/31/2012
 COORDINATOR R.C.E. 65271 DATE

DRAWING NUMBER **SDW-148**