



- ① GROOVED 2"x2"x1" TEE W/SNAP-JOINT COUPLING (2-GROOVE)
- ② 1" 90° ELBOW W/THREADED JOINT FITTINGS
- ③ 1" SHUTOFF VALVE W/THREADED JOINT FITTINGS
- ④ 1" PIPE TO HOSE ADAPTER
- ⑤ 1" CONNECTION HOSE

- ⑥ 1" 90° ELBOW TO METER THREADS (ADAPTERS MAY BE REQUIRED)
- ⑦ EXISTING WATER METER
- ⑧ EXISTING WATER METER BOX
- ⑨ EXISTING SERVICE CONNECTION FROM WATER MAIN
- ⑩ EXISTING ROADWAY
- ⑪ EXISTING CURB & GUTTER

REVISION	BY	APPROVED	DATE
ORIGINAL	KA	J. NAGELVOORT	01/12

CITY OF SAN DIEGO - STANDARD DRAWING

**RESIDENTIAL USER
HIGHLINING CONNECTION**

RECOMMENDED BY THE CITY OF SAN DIEGO
STANDARDS COMMITTEE

H. Hadli 1/31/2012
COORDINATOR R.C.E. 65271 DATE

DRAWING
NUMBER **SDW-172**