



NOTES:

- 1) REFER TO AGENCY SPECIFICATIONS WHERE APPLICABLE
- 2) SET TOP OF METER BOX 2" ABOVE FINISH GRADE
- 3) BLOW-OFF ASSEMBLIES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN AGENCY'S SPECIFICATIONS
- 4) THE CONSTRUCTION OF A TEMPORARY BLOW-OFF FOR THE USE OF TESTING AND FLUSHING OF NEW MAINS ONLY
- 5) CAM & GROOVE ADAPTER SHALL BE DRILLED AND TAPPED AS REQUIRED FOR THE PRESSURE PET COCK
- 6) MATERIALS SHALL BE SELECTED FROM THE AGENCY'S APPROVED MATERIALS LIST

TEMP 2"

 LEGEND ON PLANS

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
①	POLYMER METER BOX WITH LID 17" x 30"	⑥	2" 90° BRONZE IRON PIPE THREAD BY COMPRESSION ELL
②	2" CAM & GROOVE ADAPTER x MIPT WITH LOCKING DUST CAP, SEE NOTE 5	⑦	2" CLOSE NIPPLE IPT
③	1/4" PRESSURE PET COCK	⑧	2" COMPRESSION x FIPT BALL VALVE WITH HANDLE
④	2" x REQUIRED LENGTH COPPER PIPE TYPE "K" RIGID OR SOFT	⑨	3/8" ROCK 6" DEEP
⑤	CONCRETE THRUST BLOCK SEE WT-01	⑩	DI END CAP WITH 2.5" FIPT OUTLET
		⑪	WATER MAIN
		⑫	NYLON DIELECTRIC BUSHING (2.5" x 2")

Revision	By	Approved	Date	SAN DIEGO REGIONAL STANDARD DRAWING TEMPORARY 2" BLOW-OFF INSTALLATION	RECOMMENDED BY THE SAN DIEGO REGIONAL STANDARDS COMMITTEE  7/26/2012 Chairperson R.C.E. 19246 Date
ORIGINAL		Kercheval	12/75		
Add Metric		T. Stanton	03/03		
Replaced W-07		J. Tomasulo	10/04		
Delete Metric	MR	B. KNOLL	03/11		
DRAWING NUMBER WB-05					

FOR DRAWING WT-01 SEE DRAWING SDW-151