



NOTES:

1. REFER TO AGENCY SPECIFICATIONS WHERE APPLICABLE.
2. CLEANOUTS TO BE INSTALLED AT THE END OF MAINS WHERE INDICATED ON THE PLANS.
3. CLEANOUT PIPE TO BE SAME SIZE AND MATERIAL AS SEWER (MAX DIA. 8")
4. BACKFILL TO TOP OF 45° BEND WITH 3/8" CRUSHED ROCK.
5. LATERIALS SHALL BE SELECTED FROM THE AGENCY'S APPROVED MATERIALS LIST.



LEGEND ON PLANS

| REVISION | BY | APPROVED | DATE | CITY OF SAN DIEGO - STANDARD DRAWING | RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE | |
|----------|----|---------------|-------|--------------------------------------|---|--------------------------|
| ORIGINAL | BB | J. NAGELVOORT | 05/15 | | SEWER MAIN CLEANOUT | <i>CA Arungga</i> |
| UPDATED | BB | J. NAGELVOORT | 07/15 | | | COORDINATOR R.C.E. 56523 |
| | | | | 7/21/15 DATE | | |
| | | | | | DRAWING NUMBER SDS-121 | |