


NOTES:

- 1) SET TOP OF METER BOX FLUSH WITH SIDEWALK, CURB OR FINISH GRADE
- 2) LOCATE METER BOX
- 3) INSTALL WARNING / IDENTIFICATION TAPE
- 4) FOR BLOW-OFF INSTALLATION AT END OF MAIN SEE OTHER STANDARD DRAWINGS
- 5) BLOW-OFF ASSEMBLIES INSTALLED FOR THE USE OF RECYCLED WATER SHALL BE IDENTIFIED AS DESCRIBED IN SPECIFICATIONS
- 6) 45° BEND SHALL BE USED FOR MAINS UP TO 30°. 90° BEND SHALL BE USED FOR MAINS IN EXCESS OF 30° AS DIRECTED BY THE ENGINEER
- 7) CAM & GROOVE ADAPTER SHALL BE DRILLED AND TAPPED AS REQUIRED FOR THE PRESSURE PET COCK



LEGEND ON PLANS

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	POLYMER METER BOX WITH LID 17" x 30", SEE NOTE 2	8	4" OR 6" FLG x MJPO 90° BEND
2	4" OR 6" CAM & GROOVE ADAPTER x MIPT WITH LOCKING DUST CAP, SEE NOTE 7	9	USE DUCTILE IRON OR PVC C900
3	1/4" PRESSURE PET COCK	10	VALVE WELL FRAME AND COVER (SEE SDW-153, SDW-154)
4	4" OR 6" FLANGED COMPANION x FIPT	11	4" OR 6" FLG x MJPO/FLG RWGV
5	3/8" ROCK 4" TO 6" DEEP	12	4" OR 6" FLG x MJPO ADAPTER (IF REQUIRED)
6	4" OR 6" FLG DI PIPE x REQUIRED LENGTH (MAXIMUM OF 2 SPOOLS)	13	WATER MAIN
7	CONCRETE THRUST BLOCK SEE SDW-151	14	SIZE x 4" OR 6" MJPO/FLG x FLG TEE
		15	4" OR 6" FLANGED 45° BEND
		16	4" OR 6" x 24" FLG DISPOOL

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL*	KA	J. NAGELVOORT	01/12		
UPDATED	KA	J. NAGELVOORT	12/12		
				4" & 6" BLOW-OFF INSTALLATION TYPE A	 COORDINATOR R.C.E. 65271 DATE 12/17/2012
					DRAWING NUMBER SDW-144