



THE CITY OF SAN DIEGO

MITIGATED NEGATIVE DECLARATION

Project No. 525677

SCH No. N/A

SUBJECT: **3060 Broadway:** A SITE DEVELOPMENT PERMIT to demolish an existing church and two-story residential building, and construct a three-story 28-unit multi-family dwelling development over basement that is partially below grade with underground and surface parking on multiple lots totaling 26,887-square-feet. The project would also construct various site improvements, including associated hardscape and landscaping. Development incentives for affordable housing density bonus projects, in the form of deviations from development regulations, for minimum yards, yard and setback requirements, minimum average unit floor area, and height limits are also being requested. The project would conform to the criteria of the Affordable/In-Fill Housing and Sustainable Buildings Expedite Program by providing affordable housing. The 0.32 acre project site is located at 3060 Broadway. The project site is designated for High Density (44 - 73 dwelling units per acre) per the Greater Golden Hill Community Plan Area and is located in the GHPD-GH-600 zone. The project site is also within the Airport Land Use Compatibility Plan Noise Contours (San Diego International Airport 65 - 70 CNEL), the Airport Influence Overlay Zone - Review Area 1 (San Diego International Airport), the Federal Aviation Administration (FAA) Part 77 Noticing Area (San Diego International Airport - Lindbergh Field), the Residential Tandem Parking Overlay Zone, and the Transit Area Overlay Zone. (LEGAL DESCRIPTION: Lots 39, 40, 41, and 42, Block 94 of E.W. Morse's Subdivision of Pueblo Lot 1150 according to Map No. 547.) Applicant: Jay Wexler, Discovery Group Jerry Rudick, Littlepoint LLC

UPDATE: **September 26, 2017.** Revisions and/or minor corrections have been made to this document when compared to the draft Mitigated Negative Declaration. More specifically, typographical errors and clarifications were made to the final environmental document. In accordance with the California Environmental Quality Act, Section 15073.5(c)(4), the addition of new information that clarifies, amplifies, or makes insignificant modifications does not require recirculation as there are no new impacts and no new mitigation identified. An environmental document need only be recirculated when there is the identification of new significant environmental impacts or the addition of a new mitigation measure required to avoid a significant environmental

impact. The modifications within the environmental document do not affect the environmental analysis or conclusions of the Mitigated Negative Declaration. All revisions are shown in a strikethrough and/or underline format.

- I. PROJECT DESCRIPTION: See attached Initial Study.
- II. ENVIRONMENTAL SETTING: See attached Initial Study.
- III. DETERMINATION: The City of San Diego conducted an Initial Study which determined that the proposed project could have a significant environmental effect in the following areas(s): **Noise**. Subsequent revisions in the project proposal create the specific mitigation identified in Section V of this Mitigated Negative Declaration. The project as revised now avoids or mitigates the potentially significant environmental effects previously identified, and the preparation of an Environmental Impact Report will not be required.
- IV. DOCUMENTATION: The attached Initial Study documents the reasons to support the above Determination.
- V. MITIGATION, MONITORING AND REPORTING PROGRAM:

A. GENERAL REQUIREMENTS – PART I
Plan Check Phase (prior to permit issuance)

1. Prior to the issuance of a Notice To Proceed (NTP) for a subdivision, or any construction permits, such as Demolition, Grading or Building, or beginning any construction related activity on-site, the Development Services Department (DSD) Director's Environmental Designee (ED) shall review and approve all Construction Documents (CD), (plans, specification, details, etc.) to ensure the MMRP requirements are incorporated into the design.

2. In addition, the ED shall verify that the MMRP Conditions/Notes that apply **ONLY** to the construction phases of this project are included VERBATIM, under the heading, **"ENVIRONMENTAL/MITIGATION REQUIREMENTS."**

3. These notes must be shown within the first three (3) sheets of the construction documents in the format specified for engineering construction document templates as shown on the City website:

<http://www.sandiego.gov/development-services/industry/information/standtemp.shtml>

4. The **TITLE INDEX SHEET** must also show on which pages the "Environmental/Mitigation Requirements" notes are provided.

5. **SURETY AND COST RECOVERY** – The Development Services Director or City Manager may require appropriate surety instruments or bonds from private Permit Holders to ensure the long term performance or implementation of required mitigation measures or programs. The City is authorized to recover its cost to offset the salary, overhead, and expenses for City personnel and programs to monitor qualifying projects.

B. GENERAL REQUIREMENTS – PART II

Post Plan Check (After permit issuance/Prior to start of construction)

1. PRE CONSTRUCTION MEETING IS REQUIRED TEN (10) WORKING DAYS PRIOR TO BEGINNING ANY WORK ON THIS PROJECT. The PERMIT HOLDER/OWNER is responsible to arrange and perform this meeting by contacting the CITY RESIDENT ENGINEER (RE) of the Field Engineering Division and City staff from MITIGATION MONITORING COORDINATION (MMC). Attendees must also include the Permit holder's Representative(s), Job Site Superintendent and the following consultants:

Qualified Acoustical Monitor

Note:

Failure of all responsible Permit Holder's representatives and consultants to attend shall require an additional meeting with all parties present.

CONTACT INFORMATION:

- a) The PRIMARY POINT OF CONTACT is the **RE** at the **Field Engineering Division – 858-627-3200**
- b) For Clarification of ENVIRONMENTAL REQUIREMENTS, it is also required to call **RE and MMC at 858-627-3360**

2. MMRP COMPLIANCE: This Project, Project Tracking System (PTS) No. 525677 and /or Environmental Document No. 525677, shall conform to the mitigation requirements contained in the associated Environmental Document and implemented to the satisfaction of the DSD's Environmental Designee (MMC) and the City Engineer (RE). The requirements may not be reduced or changed but may be annotated (i.e. to explain when and how compliance is being met and location of verifying proof, etc.). Additional clarifying information may also be added to other relevant plan sheets and/or specifications as appropriate (i.e., specific locations, times of monitoring, methodology, etc.).

Note:

Permit Holder's Representatives must alert RE and MMC if there are any discrepancies in the plans or notes, or any changes due to field conditions. All conflicts must be approved by RE and MMC BEFORE the work is performed.

3. OTHER AGENCY REQUIREMENTS: Evidence of compliance with all other agency requirements or permits shall be submitted to the RE and MMC for review and acceptance prior to the beginning of work or within one week of the Permit Holder obtaining documentation of those permits or requirements. Evidence shall include copies of permits, letters of resolution or other documentation issued by the responsible agency.

Not Applicable

4. MONITORING EXHIBITS

All consultants are required to submit , to RE and MMC, a monitoring exhibit on a 11x17 reduction of the appropriate construction plan, such as site plan, grading, landscape, etc., marked to clearly show the specific areas including the **LIMIT OF WORK**, scope of that discipline's work, and notes indicating

when in the construction schedule that work will be performed. When necessary for clarification, a detailed methodology of how the work will be performed shall be included.

NOTE:

Surety and Cost Recovery – When deemed necessary by the Development Services Director or City Manager, additional surety instruments or bonds from the private Permit Holder may be required to ensure the long term performance or implementation of required mitigation measures or programs. The City is authorized to recover its cost to offset the salary, overhead, and expenses for City personnel and programs to monitor qualifying projects.

5. OTHER SUBMITTALS AND INSPECTIONS:

The Permit Holder/Owner's representative shall submit all required documentation, verification letters, and requests for all associated inspections to the RE and MMC for approval per the following schedule:

DOCUMENT SUBMITTAL/INSPECTION CHECKLIST		
Issue Area	Document Submittal	Associated Inspection/Approvals/Notes
General	Consultant Qualification Letters	Prior to Preconstruction Meeting
General	Consultant Construction Monitoring Exhibits	Prior to or at Preconstruction Meeting
Noise	Acoustical Reports	Noise Mitigation Features Inspection
Bond Release	Request for Bond Release Letter	Final MMRP Inspections Prior to Bond Release Letter

C. SPECIFIC MMRP ISSUE AREA CONDITIONS/REQUIREMENTS

NOISE

- I. Construction Noise Mitigation:** Prior to issuance of any construction permits, including but not limited to, the first Grading Permit, Demolition Plans/Permits and Building Plans/Permits or a Notice to Proceed for Subdivisions, but prior to the first preconstruction meeting, whichever is applicable, the Owner/Permitee shall ensure the following to the satisfaction of the City of San Diego Development Service Department as discussed in the Noise Study (July 10, 2017) prepared by Veneklasen Associates, Inc.:
 - A. The project shall restrict grading and construction activities in accordance with Section 59.5.0404 of the San Diego Municipal Code.
 - B. Schedule highest noise-generating activity and construction activity away from noise-sensitive land uses.

- C. Equip internal combustion engine-driven equipment with original factory (or equivalent) intake and exhaust mufflers, which are maintained in good condition.
- D. Prohibit, and post signs prohibiting, unnecessary idling of internal combustion engines.
- E. Locate all stationary noise-generating equipment, such as air compressors and portable generators, as far as practicable from noise-sensitive land uses.
- F. Utilize "quiet" air compressors and other stationary equipment where feasible and available.
- G. Designate a noise disturbance coordinator who would respond to neighborhood complaints about construction noise by determining the cause of the noise complaints and require implementation of reasonable measures to correct the problem. Conspicuously post a telephone number for the disturbance coordinator at the construction site.
- H. Install a temporary noise barrier that breaks the line of sight between the nearest noise-sensitive land uses and the project's construction activities at the northern, western and eastern property lines of the project site to reduce the noise impacts to residential uses. The noise barrier shall be solid with no gaps and have a minimum density of two pounds per square foot.

VI. PUBLIC REVIEW DISTRIBUTION: Draft copies or notice of this Mitigated Negative Declaration were distributed to:

CITY OF SAN DIEGO

Mayor's Office
 Councilmember Ward - District 3
 City Attorney's Office (93C)
 Development Services
 Fire – Plan Review
 LDR – Engineering Review
 LDR – EAS
 LDR – Geology
 LDR – Landscaping
 LDR – Planning Review
 LDR – Transportation Development
 PUD – Water & Sewer Development
 Planning Department
 Park & Rec.
 Plan – Airport
 Plan – Historic
 Facilities Financing (93B)
 Water Review (86A)

San Diego Central Library (81A)
Logan Heights Branch Library (81N)

OTHER ORGANIZATIONS AND INTERESTED PARTIES

Mel Shapiro (258)
Greater Golden Hill Planning Committee (259)
Friends of Switzer Canyon (260)
Ruchell Alvarez
Valerie Hodge
Jay Wexler, Applicant Discovery Group

VII. RESULTS OF PUBLIC REVIEW:

- (X) No comments were received during the public input period.
- () Comments were received but did not address the accuracy or completeness of the draft environmental document. No response is necessary and the letters are incorporated herein.
- () Comments addressing the accuracy or completeness of the draft environmental document were received during the public input period. The letters and responses are incorporated herein.

Copies of the draft Mitigated Negative Declaration, the Mitigation, Monitoring and Reporting Program and any Initial Study material are available in the office of the Entitlements Division for review, or for purchase at the cost of reproduction.



E. Shearer-Nguyen
Senior Planner
Development Services Department

September 1, 2017
Date of Draft Report

September 26, 2017
Date of Final Report

Analyst: L. Sebastian

Attachments: Initial Study Checklist
Figure 1 – Location Map
Figure 2 – Site Plan

INITIAL STUDY CHECKLIST

1. Project title/Project number: 3060 Broadway / 525677
2. Lead agency name and address: City of San Diego, 1222 First Avenue, MS-501, San Diego, California 92101
3. Contact person and phone number: L. Sebastian / (619) 236-5993
4. Project location: 3060 Broadway, San Diego, California 92102
5. Project Applicant/Sponsor's name and address: Jerry Rudick, Littlepoint LLC/Jay Wexler, Discovery Group, PO Box 1492, La Jolla, California 92038
6. General/Community Plan designation: General Plan: Residential / Community Plan: Greater Golden Hill Community Plan: High Density (44 – 73 dwelling units per acre)
7. Zoning: GHPD-GH-600
8. Description of project (Describe the whole action involved, including but not limited to, later phases of the project, and any secondary, support, or off-site features necessary for its implementation.):

A SITE DEVELOPMENT PERMIT to demolish an existing church and two-story residential building, and construct a three-story 28-unit multi-family dwelling development over basement that is partially below grade with underground and surface parking on multiple lots totaling 26,887-square-feet.

The project would also construct various site improvements, including associated hardscape and landscaping. The project would conform to the criteria of the Affordable/In-Fill Housing and Sustainable Buildings Expedite Program by providing affordable housing.

The project landscaping has been reviewed by City Landscape staff and would comply with all applicable City of San Diego Landscape ordinances and standards. Drainage would be directed into appropriate storm drain systems designated to carry surface runoff, which has been reviewed and accepted by City Engineering staff. Pedestrian ingress ~~Ingress~~ to the

project site would be via Broadway. Vehicle access to the project site would be via the alley entry to parking. All parking would be provided on-site.

Grading operations for the project would require 1,400 cubic yards of cut with a maximum cut depth of 19.50 feet, and 200 cubic yards of fill with a maximum fill depth of five feet. 1,200 cubic yards of import is also proposed. Approximately two retaining/crib walls totaling 312 feet with a maximum height of six feet are also proposed.

The Land Development Code (LDC), Section 143.0740 allows development incentives for affordable housing density bonus projects. Four affordable housing incentives, in the form of deviations from developmental regulations, are being requested in accordance with LDC Section 143.0740, and are as follows:

1. Minimum Yards – A deviation from San Diego Municipal Code (SDMC) Section 158.0301(b)(2)(B), Table 158-03C, Footnote 2, 3, and 5 for no third story step back setback.
2. Yard and Setback Requirements – A deviation from SDMC 158.0301(b)(2)(A) for no minimum street yard size.
3. Minimum Average Unit Floor Area – A deviation from SDMC 158.0301(b)(5)(B) to allow a 603-square-foot minimum unit size, where 700-square-feet is required.
4. Height Limits – A deviation from SDMC 158.0301(b)(3) to allow 50 feet in height, where 40 feet is the maximum.

9. Surrounding land uses and setting: Briefly describe the project's surroundings:

The 0.32 acre project site is located at 3060 Broadway. The project site is designated for High Density (44 - 73 dwelling units per acre) per the Greater Golden Hill Community Plan Area and is located in the GHPD-GH-600 zone. The project site is also within the Airport Land Use Compatibility Plan Noise Contours (San Diego International Airport 65 - 70 CNEL), the Airport Influence Overlay Zone - Review Area 1 (San Diego International Airport), the Federal Aviation Administration (FAA) Part 77 Noticing Area (San Diego International Airport – Lindbergh Field), the Residential Tandem Parking Overlay Zone, and the Transit Area Overlay Zone.

The project site is a rectangular-shaped property situated on the north side of Broadway about 370 feet east of 30th Street. The project site is bounded to the south by Broadway, to the east and west by existing residential structures, and to the north by an alley. The project site is currently occupied by a church and apartment building in the western half of the site and pavement in the eastern half. Vegetation on-site is varied and consists of non-native landscaping flora, including shrubs, trees, and lawn areas. Additionally, the project site is situated in a developed area currently served by existing public services and utilities.

10. Other public agencies whose approval is required (e.g., permits, financing approval, or participation agreement.):

None required.

11. Have California Native American tribes traditionally and culturally affiliated with the project area requested consultation pursuant to Public Resources Code section 21080.3.1? If so, has consultation begun?

Note: Conducting consultation early in the CEQA process allows tribal governments, lead agencies, and project proponents to discuss the level of environmental review, identify and address potential adverse impacts to tribal cultural resources, and reduce the potential for delay and conflict in the environmental review process. (See Public Resources Code section 21083.3.2.) Information may also be available from the California Native American Heritage Commission's Sacred Lands File per Public Resources Code section 5097.96 and the California Historical Resources Information System administered by the California Office of Historic Preservation. Please also note that Public Resources Code section 21082.3(c) contains provisions specific to confidentiality.

In accordance with the requirements of Assembly Bill (AB) 52, the City of San Diego sent notification to two Native American Tribes traditionally and culturally affiliated with the project area on June 20, 2017. Both the Iipay Nation of Santa Ysabel and the Jamul Indian Village responded within the 30-day period requesting consultation and additional information. Consultation took place on June 22, 2017 with Iipay Nation of Santa Ysabel and on June 23, 2017 with Jamul Indian Village.

ENVIRONMENTAL FACTORS POTENTIALLY AFFECTED:

The environmental factors checked below would be potentially affected by this project, involving at least one impact that is a "Potentially Significant Impact" as indicated by the checklist on the following pages.

- | | | |
|---|--|---|
| <input type="checkbox"/> Aesthetics | <input type="checkbox"/> Greenhouse Gas Emissions | <input type="checkbox"/> Population/Housing |
| <input type="checkbox"/> Agriculture and Forestry Resources | <input type="checkbox"/> Hazards & Hazardous Materials | <input type="checkbox"/> Public Services |
| <input type="checkbox"/> Air Quality | <input type="checkbox"/> Hydrology/Water Quality | <input type="checkbox"/> Recreation |
| <input type="checkbox"/> Biological Resources | <input type="checkbox"/> Land Use/Planning | <input type="checkbox"/> Transportation/Traffic |
| <input type="checkbox"/> Cultural Resources | <input type="checkbox"/> Mineral Resources | <input type="checkbox"/> Tribal Cultural Resources |
| <input type="checkbox"/> Geology/Soils | <input checked="" type="checkbox"/> Noise | <input type="checkbox"/> Utilities/Service System |
| | | <input checked="" type="checkbox"/> Mandatory Findings Significance |

DETERMINATION: (To be completed by Lead Agency)

On the basis of this initial evaluation:

- ☐ The proposed project COULD NOT have a significant effect on the environment, and a NEGATIVE DECLARATION will be prepared.
- ☒ Although the proposed project could have a significant effect on the environment, there will not be a significant effect in this case because revisions in the project have been made by or agreed to by the project proponent. A MITIGATED NEGATIVE DECLARATION will be prepared.
- ☐ The proposed project MAY have a significant effect on the environment, and an ENVIRONMENTAL IMPACT REPORT is required.
- ☐ The proposed project MAY have a "potentially significant impact" or "potentially significant unless mitigated" impact on the environment, but at least one effect (a) has been adequately analyzed in an earlier document pursuant to applicable legal standards, and (b) has been addressed by mitigation measures based on the earlier analysis as described on attached sheets. An ENVIRONMENTAL IMPACT REPORT is required.
- ☐ Although the proposed project could have a significant effect on the environment, because all potentially significant effects (a) have been analyzed adequately in an earlier EIR or (MITIGATED) NEGATIVE DECLARATION pursuant to applicable standards, and (b) have been avoided or mitigated pursuant to that earlier EIR or (MITIGATED) NEGATIVE DECLARATION, including revisions or mitigation measures that are imposed upon the proposed project, nothing further is required.

EVALUATION OF ENVIRONMENTAL IMPACTS:

- 1) A brief explanation is required for all answers except "No Impact" answers that are adequately supported by the information sources a lead agency cites in the parentheses following each question. A "No Impact" answer is adequately supported if the referenced information sources show that the impact simply does not apply to projects like the one involved (e.g., the project falls outside a fault rupture zone). A "No Impact" answer should be explained where it is based on project specific factors as well as general standards (e.g., the project will not expose sensitive receptors to pollutants, based on a project-specific screening analysis.)
- 2) All answers must take account of the whole action involved, including off-site as well as on-site, cumulative as well as project-level, indirect as well as direct, and construction as well as operational impacts.

- 3) Once the lead agency has determined that a particular physical impact may occur, then the checklist answers must indicate whether the impact is potentially significant, less than significant with mitigation, or less than significant. "Potentially Significant Impact" is appropriate if there is substantial evidence that an effect may be significant. If there are one or more "Potentially Significant Impact" entries when the determination is made, an EIR is required.
- 4) "Negative Declaration: Less Than Significant With Mitigation Incorporated" applies where the incorporation of mitigation measures has reduced an effect from "Potentially Significant Impact" to a "Less Than Significant Impact." The lead agency must describe the mitigation measures, and briefly explain how they reduce the effect to a less than significant level (mitigation measures from "Earlier Analyses", as described in (5) below, may be cross-referenced).
- 5) Earlier analyses may be used where, pursuant to the tiering, program EIR, or other CEQA process, an effect has been adequately analyzed in an earlier EIR or (mitigated) negative declaration. *Section 15063(c)(3)(D)*. In this case, a brief discussion should identify the following:
 - a. Earlier Analysis Used. Identify and state where they are available for review.
 - b. Impacts Adequately Addressed. Identify which effects from the above checklist were within the scope of and adequately analyzed in an earlier document pursuant to applicable legal standards, and state whether such effects were addressed by mitigation measures based on the earlier analysis.
 - c. Mitigation Measures. For effects that are "Less Than Significant With Mitigation Measures Incorporated", describe the mitigation measures that were incorporated or refined from the earlier document and the extent to which they address site-specific conditions for the project.
- 6) Lead agencies are encouraged to incorporate into the checklist references to information sources for potential impacts (e.g., general plans, zoning ordinances). Reference to a previously prepared or outside document should, where appropriate, include a reference to the page or pages where the statement is substantiated.
- 7) Supporting Information Sources: A source list should be attached, and other sources used or individuals contacted should be cited in the discussion.
- 8) This is only a suggested form, and lead agencies are free to use different formats; however, lead agencies should normally address the questions from this checklist that are relevant to a project's environmental effects in whatever format is selected.
- 9) The explanation of each issue should identify:
 - a. The significance criteria or threshold, if any, used to evaluate each question; and
 - b. The mitigation measure identified, if any, to reduce the impact to less than significant.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

I) AESTHETICS – Would the project:

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| a) Have a substantial adverse effect on a scenic vista? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

No scenic vista or view corridor designated within the community plan exists on the project site. Therefore, the project would not have a substantial adverse effect on a scenic vista. No impacts would result.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| b) Substantially damage scenic resources, including but not limited to, trees, rock outcroppings, and historic buildings within a state scenic highway? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project is situated within a developed residential neighborhood. No such scenic resources or state scenic highways are located on, near, or adjacent to the project site. Therefore, no impacts would result.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| c) Substantially degrade the existing visual character or quality of the site and its surroundings? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is within a developed residential neighborhood. The project would construct a three-story 28-unit multi-family dwelling development. The project is compatible with the surrounding development, and permitted by the community plan and zoning designation. The project would not substantially degrade the existing visual character or quality of the site or the surrounding area. Also see response I(a) above. No impacts are anticipated.

- | | | | | |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|
| d) Create a new source of substantial light or glare that would adversely affect day or nighttime views in the area? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project would not be expected to create new and/or cause substantial light or glare. No substantial sources of light would be generated during project construction, as construction activities would occur during daylight hours. All permanent exterior lighting is required to comply with City regulations to reduce potential adverse effects on neighborhood properties. No impacts are anticipated.

II. AGRICULTURAL AND FOREST RESOURCES: In determining whether impacts to agricultural resources are significant environmental effects, lead agencies may refer to the California Agricultural Land Evaluation and Site Assessment Model (1997) prepared by the California Department of Conservation as an optional model to use in assessing impacts on agriculture and farmland. In determining whether impacts to forest resources, including timberland, are significant environmental effects, lead agencies may refer to information compiled by the California Department of Forestry and Fire Protection regarding the state's inventory of forest land, including the Forest and Range Assessment Project and the Forest Legacy Assessment project; and forest carbon measurement methodology provided in Forest Protocols adopted by the California Air Resources Board. – Would the project:

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

- a) Converts Prime Farmland, Unique Farmland, or Farmland of Statewide Importance (Farmland), as shown on the maps prepared pursuant to the Farmland Mapping and Monitoring Program of the California Resources Agency, to non-agricultural use?

☐
☐
☐
☒

The project is consistent with the community plan's land use designation, and is located within a developed residential neighborhood. As such, the project site does not contain, and is not adjacent to, any lands identified as Farmland, Unique Farmland, or Farmland of Statewide Importance (Farmland), as show on maps prepared pursuant to the Farmland Mapping and Monitoring Program of the California Resource Agency. Therefore, the project would not result in the conversion of such lands to non-agricultural use. No significant impacts would occur, and no mitigation measures are required.

- b) Conflict with existing zoning for agricultural use, or a Williamson Act Contract?

☐
☐
☐
☒

Refer to response to II(a) above. There are no Williamson Act Contract lands on or within the vicinity of the project site. The project is consistent with the existing land use and the underlying zone. The project does not conflict with any agricultural use. No impacts would result.

- c) Conflict with existing zoning for, or cause rezoning of, forest land (as defined in Public Resources Code section 1220(g)), timberland (as defined by Public Resources Code section 4526), or timberland zoned Timberland Production (as defined by Government Code section 51104(g))?

☐
☐
☐
☒

The project would not conflict with existing zoning for, or cause rezoning of, forest land, timberland, or timberland zoned Timberland Production. No designated forest land or timberland occur onsite as the project is consistent with the community plan, and the underlying zone. No impacts would result.

- d) Result in the loss of forest land or conversion of forest land to non-forest use?

☐
☐
☐
☒

Refer to response II(c) above. Additionally, the project would not contribute to the conversion of any forested land to non-forest use, as surrounding land uses are built out. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
e) Involve other changes in the existing environment, which, due to their location or nature, could result in conversion of Farmland to non-agricultural use or conversion of forest land to non-forest use?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Refer to responses II(a) and (c) above. No impacts would result.

III. AIR QUALITY – Where available, the significance criteria established by the applicable air quality management or air pollution control district may be relied on to make the following determinations – Would the project:

a) Conflict with or obstruct implementation of the applicable air quality plan?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
---	--------------------------	--------------------------	--------------------------	-------------------------------------

The San Diego Air Pollution Control District (SDAPCD) and San Diego Association of Governments (SANDAG) are responsible for developing and implementing the clean air plan for attainment and maintenance of the ambient air quality standards in the San Diego Air Basin (SDAB). The County Regional Air Quality Strategy (RAQS) was initially adopted in 1991, and is updated on a triennial basis (most recently in 2009). The RAQS outlines the SDAPCD's plans and control measures designed to attain the state air quality standards for ozone (O3). The RAQS relies on information from the California Air Resources Board (CARB) and SANDAG, including mobile and area source emissions, as well as information regarding projected growth in San Diego County and the cities in the county, to project future emissions and then determine the strategies necessary for the reduction of emissions through regulatory controls. CARB mobile source emission projections and SANDAG growth projections are based on population, vehicle trends, and land use plans developed by San Diego County and the cities in the county as part of the development of their general plans.

The RAQS relies on SANDAG growth projections based on population, vehicle trends, and land use plans developed by the cities and by the county as part of the development of their general plans. As such, projects that propose development that is consistent with the growth anticipated by local plans would be consistent with the RAQS. However, if a project proposes development that is greater than that anticipated in the local plan and SANDAG's growth projections, the project might be in conflict with the RAQS and may contribute to a potentially significant cumulative impact on air quality.

The project would construct a three-story 28-unit multi-family dwelling development within a developed neighborhood of similar residential uses. The project is consistent with the General Plan, community plan, and the underlying zoning for residential development. Therefore, the project would be consistent at a sub-regional level with the underlying growth forecasts in the RAQS, and would not obstruct implementation of the RAQS. As such, no impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
b) Violate any air quality standard or contribute substantially to an existing or projected air quality violation?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

Short-term Emissions (Construction)

Project construction activities would potentially generate combustion emissions from on-site heavy-duty construction vehicles and motor vehicles transporting the construction crew and necessary construction materials. Exhaust emissions generated by construction activities would generally result from the use of typical construction equipment that may include excavation equipment, forklift, skip loader, and/or dump truck. Variables that factor into the total construction emissions potentially generated include the level of activity, length of construction period, number of pieces and types of equipment in use, site characteristics, weather conditions, number of construction personnel, and the amount of materials to be transported on or off-site. It is anticipated that construction equipment would be used on-site for four to eight hours a day; however, construction would be short-term and impacts to neighboring uses would be minimal and temporary.

Fugitive dust emissions are generally associated with land clearing and grading operations. Due to the nature and location of the project, construction activities are expected to create minimal fugitive dust, as a result of the disturbance associated with grading. The project would construct a three-story 28-unit multi-family dwelling development. Construction operations would include standard measures as required by the City of San Diego grading permit to reduce potential air quality impacts to less than significant. Therefore, impacts associated with fugitive dust are considered less than significant, and would not violate an air quality standard or contribute substantially to an existing or projected air quality violation. Impacts related to short-term emissions would be less than significant.

Long-term Emissions (Operational)

Long-term air emission impacts are those associated with stationary sources and mobile sources related to any change caused by a project. The project would produce minimal stationary source emissions. Once construction of the project is complete, long-term air emissions would potentially result from such sources as fireplaces, heating, ventilation, and cooling (HVAC) systems, and other motorized equipment typically associated with residential uses. The project is compatible with the surrounding development and is permitted by the community plan and zone designation. Based on the residential land use, project emissions over the long-term are not anticipated to violate any air quality standard or contribute substantially to an existing or projected air quality violation. Impacts would be less than significant.

Overall, the project is not expected to generate substantial emissions that would violate any air quality standard or contribute to an existing or projected air quality violation; therefore, impacts would be less than significant.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
c) Result in a cumulatively considerable net increase of any criteria pollutant for which the project region is non-attainment under an applicable federal or state ambient air quality standard (including releasing emissions which exceed quantitative thresholds for ozone precursors)?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>

As described above in response III(b), construction operations temporarily increase the emissions of dust and other pollutants. However, construction emissions would be temporary and short-term in duration. Implementation of Best Management Practices (BMP's) would reduce potential impacts related to construction activities to a less than significant level. Therefore, the project would not result in a cumulatively considerable net increase of any criteria pollutant for which the project region is non-attainment under applicable federal or state ambient air quality standards. Impacts would be less than significant.

d) Create objectionable odors affecting a substantial number of people?	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
---	--------------------------	--------------------------	-------------------------------------	--------------------------

Short-term (Construction)

Odors would be generated from vehicles and/or equipment exhaust emissions during construction of the project. Odors produced during construction would be attributable to concentrations of unburned hydrocarbons from tailpipes of construction equipment and architectural coatings. Such odors are temporary and generally occur at magnitudes that would not affect a substantial number of people. Therefore, impacts would be less than significant.

Long-term (Operational)

Typical long-term operational characteristics of the project are not associated with the creation of such odors nor anticipated to generate odors affecting a substantial number of people. The project would construct a three-story 28-unit multi-family dwelling development. Residential dwelling units, in the long-term operation, are not typically associated with the creation of such odors nor are they anticipated to generate odors affecting a substantial number or people. Therefore, project operations would result in less than significant impacts.

IV. BIOLOGICAL RESOURCES – Would the project:

a) Have substantial adverse effects, either directly or through habitat modifications, on any species identified as a candidate, sensitive, or special status species in local or regional plans, policies, or regulations, or by the California Department of Fish and Game or U.S. Fish and Wildlife Service?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
---	--------------------------	--------------------------	--------------------------	-------------------------------------

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

On-site landscaping is non-native. The project site does not contain any sensitive biological resources, nor does it contain any candidate, sensitive or special status species. No impacts would occur, and no mitigation measures are required.

- b) Have a substantial adverse effect on any riparian habitat or other community identified in local or regional plans, policies, and regulations or by the California Department of Fish and Game or U.S. Fish and Wildlife Service?

☐
☐
☐
☒

Refer to response IV(a) above. The project site is urban developed and currently supports non-native landscaping. Additionally, the project site is developed with an existing church and two-story residential building, and is located within a residential neighborhood. The project site does not contain any riparian habitat or other identified community. No impacts would result.

- c) Have a substantial adverse effect on federally protected wetlands as defined by Section 404 of the Clean Water Act (including but not limited to marsh, vernal pool, coastal, etc.) through direct removal, filling, hydrological interruption, or other means?

☐
☐
☐
☒

The project site does not contain any federally protected wetlands as defined by Section 404 of the Clean Water Act. The project site is located within a developed residential neighborhood. No impacts would result. Also refer to response IV(a) above.

- d) Interfere substantially with the movement of any native resident or migratory fish or wildlife species or with established native resident or migratory wildlife corridors, or impede the use of native wildlife nursery sites?

☐
☐
☐
☒

No formal and/or informal wildlife corridors are on or near the project site, as the project site is located within a developed residential neighborhood. Therefore, no impacts would result. Also refer to response IV(a) above.

- e) Conflict with any local policies or ordinances protecting biological resources, such as a tree preservation policy or ordinance?

☐
☐
☐
☒

The project would not conflict with any local policies and/or ordinances protecting biological resources, such as a tree preservation policy or ordinance. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
f) Conflict with the provisions of an adopted Habitat Conservation Plan, Natural Community Conservation Plan, or other approved local, regional, or state habitat conservation plan?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Refer to response IV(e) above. The project site is located within a developed urban neighborhood and is not within, nor adjacent to, the City's Multi-Habitat Planning Area (MHPA). Therefore, no impacts would result.

V. CULTURAL RESOURCES – Would the project:

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| a) Cause a substantial adverse change in the significance of an historical resource as defined in §15064.5? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The purpose and intent of the Historical Resources Regulations of the Land Development Code (Chapter 14, Division 3, and Article 2) is to protect, preserve and, where damaged, restore the historical resources of San Diego. The regulations apply to all proposed development within the City of San Diego when historical resources are present on the premises. Before approving discretionary projects, CEQA requires the Lead Agency to identify and examine the significant adverse environmental effects which may result from that project. A project that may cause a substantial adverse change in the significance of a historical resource may have a significant effect on the environment (Sections 15064.5(b) and 21084.1). A substantial adverse change is defined as demolition, destruction, relocation, or alteration activities, which would impair historical significance (Sections 15064.5(b)(1)). Any historical resource listed in, or eligible to be listed in the California Register of Historical Resources, including archaeological resources, is considered to be historically or culturally significant.

Archaeological Resources

A record search of the California Historic Resources Information System (CHRIS) digital database was reviewed by qualified archaeological City staff to determine the presence or absence of potential resources within the project site. The CHRIS search did not identify any archaeological sites recorded within the project site. No additional archaeological evaluation was recommended by qualified archaeological City staff based on the CHRIS search, site photographs, location of the project site in an urbanized area surrounded by existing development, and disturbed nature of the project site as documented in the geotechnical study. In addition, the project is not mapped within the City's Historical Sensitivity Map. Therefore, there is no potential to impact any unique or non-unique historical resources. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

Built Environment

The City of San Diego reviews projects requiring the demolition of structures 45 years or older for historic significance in compliance with the California Environmental Quality Act (CEQA). CEQA Section 21084.1 states that “A project that may cause a substantial adverse change in the significance of an historical resource is a project that may cause a significant effect on the environment.” Historic property (built environment) surveys are required for properties which are 45 years of age or older and which have integrity of setting, location, design, materials, workmanship, feeling, and association.

The existing property on the project site is over 45 years old. Therefore, Historical Resources staff conducted a historic review of the property on January 11, 2017. Historical Resources staff determined that the property does not meet local designation criteria as an individually significant resource under any adopted Historical Resources Board Criteria. Therefore, no impacts would result.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| b) Cause a substantial adverse change in the significance of an archaeological resource pursuant to §15064.5? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

Refer to response V(a) above.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| c) Directly or indirectly destroy a unique paleontological resource or site or unique geologic feature? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

According to the submitted Anticipated Infiltration Characteristics prepared by Geotechnical Explorations, Inc. dated November 29, 2016, the project site is underlain by Lindavista Formation (Qvop8). Lindavista Formation is assigned a moderate sensitivity rating for paleontological resources.

Paleontological monitoring during grading activities may be required if it is determined that the project's earth movement quantity exceeds the Paleontological threshold (if greater than 1,000 cubic yards and ten feet deep for formations with a high sensitivity rating, and if greater than 2,000 cubic yards and ten feet deep for formations with a moderate sensitivity rating).

Per the submitted plans (Preliminary Grading Plan, Sheet C.110), the project would require 1,400 cubic yards of cut with a maximum cut depth of 19.5 feet, and 200 cubic yards of fill with a maximum fill depth of five feet. The amount of export would be 1,200 cubic yards.

Consequently, the project does not have the potential to disturb or destroy paleontological resources. Therefore, the project does not exceed the threshold for paleontological monitoring. No impacts would occur.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
d) Disturb and human remains, including those interred outside of dedicated cemeteries?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

Refer to response V(a) above. No cemeteries, formal or informal, have been identified on the project site; therefore, no impacts would result.

VI. GEOLOGY AND SOILS – Would the project:

- a) Expose people or structures to potential substantial adverse effects, including the risk of loss, injury, or death involving:
- i) Rupture of a known earthquake fault, as delineated on the most recent Alquist-Priolo Earthquake Fault Zoning Map issued by the State Geologist for the area or based on other substantial evidence of a known fault? Refer to Division of Mines and Geology Special Publication 42.

☐ ☐ ☒ ☐

The project is not located within an Alquist-Priolo Fault Zone. The project is required to comply with the seismic requirements of the California Building Code. Implementation of proper engineering design and utilization of standard construction practices, to be verified at the building permit stage, would ensure that the potential for impacts from regional geologic hazards would remain less than significant.

- ii) Strong seismic ground shaking? ☐ ☐ ☒ ☐

The project site is located within a seismically active southern California region, and is potentially subject to moderate to strong seismic ground shaking along major earthquake faults. Seismic shaking at the site could be generated by any number of known active and potentially active faults in the region. Implementation of proper engineering design and utilization of standard construction practices, to be verified at the building permit stage, would ensure that the potential for impacts from regional geologic hazards would remain less than significant.

- iii) Seismic-related ground failure, including liquefaction? ☐ ☐ ☒ ☐

Refer to response VI(a)(ii) above. The site could be affected by seismic activity as a result of earthquakes and major active faults located throughout the Southern California area. Liquefaction occurs when loose, unconsolidated, water-laden soils are subject to shaking, causing the soils to lose cohesion. Implementation of proper engineering design and utilization of standard construction practices, to be verified at the building permit stage, would ensure that the potential for impacts from regional geologic hazards would remain less than significant.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

iv) Landslides?

☐
☐
☒
☐

According to the City of San Diego Seismic Safety Study 2008, the project site is located in Geologic Hazard Category 52. Hazard Category 52 is characterized as "Other Terrain – other level areas, gently sloping to steep terrain, favorable geologic structure, low risk." Implementation of proper engineering design and utilization of standard construction practices, to be verified at the building permit stage, would ensure that the potential for impacts from regional geologic hazards would remain less than significant.

b) Result in substantial soil erosion or the loss of topsoil?

☐
☐
☒
☐

Construction of the project would temporarily disturb on-site soils during grading activities, thereby increasing the potential for soil erosion to occur. However, the use of standard erosion control measures and implementation of storm water BMP requirements during construction would reduce potential impacts to a less than a significant level. Additionally, the project site would be landscaped in accordance with City requirements, which would also preclude erosion or topsoil loss, and all storm water requirements would be met. Therefore, impacts would be less than significant, and no mitigation measures are required.

c) Be located on a geologic unit or soil that is unstable, or that would become unstable as a result of the project, and potentially result in on- or off-site landslide, lateral spreading, subsidence, liquefaction or collapse?

☐
☐
☒
☐

Refer to response VI(a) above. As previously discussed, the project site is located in Geologic Hazard Category 52. Geologic Hazard Category 52 is defined as "Other Terrain – other level areas, gently sloping to steep terrain, favorable geologic structure, low risk." Implementation of proper engineering design and utilization of standard construction practices, to be verified at the building permit stage, would ensure that the potential for impacts from regional geologic hazards would remain less than significant.

d) Be located on expansive soil, as defined in Table 18-1-B of the Uniform Building Code (1994), creating substantial risks to life or property?

☐
☐
☒
☐

Refer to response VI(a) above. The project would be constructed in accordance with the California Building Code and appropriate engineering design. Utilization of appropriate engineering design measures and standard construction practices, to be verified at the building permit stage, would ensure that the potential for impacts from geologic hazards would be less than significant.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

Therefore, impacts related to unstable soils are considered less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|
| e) Have soils incapable of adequately supporting the use of septic tanks or alternative waste water disposal systems where sewers are not available for the disposal of waste water? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|

No septic system or alternative wastewater systems are proposed. The project site is located within an area that is already developed with existing infrastructure (i.e., water and sewer lines). No impacts would result.

VII. GREENHOUSE GAS EMISSIONS – Would the project:

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| a) Generate greenhouse gas emissions, either directly or indirectly, that may have a significant impact on the environment? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

The City's Climate Action Plan (CAP) outlines the actions that the City will undertake to achieve its proportional share of State greenhouse gas (GHG) emission reductions. A CAP Consistency Checklist (Checklist) is part of the CAP and contains measures that are required to be implemented on a project-by-project basis to ensure that the specified emission targets identified in the CAP are achieved.

The project is consistent with the existing General Plan and Community Plan land use and zoning designations. Further based upon review and evaluation of the completed CAP Consistency Checklist for the project, the project is consistent with the applicable strategies and actions of the CAP. Therefore, the project is consistent with the assumptions for relevant CAP strategies toward achieving the identified GHG reduction targets, and impacts from greenhouse gas emissions are considered less than significant. No mitigation is required.

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| b) Conflict with the City's CAP or an applicable plan, policy, or regulation adopted for the purpose of reducing the emissions of greenhouse gases? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

The project would not conflict with an applicable plan, policy, or regulation adopted for the purposes of reducing the emissions of greenhouse gases. The project is consistent with the existing General Plan and Community Plan land use and zoning designations. Further based upon review and evaluation of the completed CAP Consistency Checklist for the project, the project is consistent with the applicable strategies and actions of the CAP. Therefore, the project is consistent with the assumptions for relevant CAP strategies toward achieving the identified GHG reduction targets. Impacts are considered less than significant. No mitigation is required.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

VIII. HAZARDS AND HAZARDOUS MATERIALS – Would the project:

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| a) Create a significant hazard to the public or the environment through routine transport, use, or disposal of hazardous materials? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

The project would demolish an existing church and two-story residential building, and construct a three-story 28-unit multi-family dwelling. Construction of the project may require the use of hazardous material (fuel, lubricants, solvents, etc.) that would require proper storage, handling, use and disposal. Although minimal amounts of such substances may be present during construction, they are not anticipated to create a significant public hazard. Once constructed, the routine transport, use, or disposal of hazardous materials on or through the project site is not anticipated. Therefore, impacts would be less than significant, and no mitigation is required.

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| b) Create a significant hazard to the public or the environment through reasonably foreseeable upset and accident conditions involving the release of hazardous materials into the environment? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

Refer to response VIII(a) above. Demolition of an existing church and two-story residential building, and construction of a three-story 28-unit multi-family dwelling within a neighborhood of similar uses would not be associated with such impacts. Therefore, no significant impacts related to this issue were identified, and no mitigation measures are required.

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| c) Emit hazardous emissions or handle hazardous or acutely hazardous materials, substances, or waste within one-quarter mile of an existing or proposed school? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

Refer to responses VIII(a) and VIII (b) above. The project site is not within one-quarter mile of an existing school. Future risk of releases of hazardous substances would not occur as a result of project operations because it is anticipated that future on-site operations would not require the routine use or transport of acutely hazardous materials.

Construction of the project may require the use of hazardous materials (fuels, lubricants, solvents, etc.), which would require proper storage, handling, use and disposal. Further, the project would be required to comply with all federal, state and local requirements associated with hazardous materials; therefore, impacts would be less than significant.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| d) Be located on a site which is included on a list of hazardous materials sites compiled pursuant to Government Code | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

Section 65962.5 and, as a result, would it create a significant hazard to the public or the environment?

The project site is not listed as a hazardous materials site in public records databases (i.e., Envirostor, Geotracker). No impacts would result.

- e) For a project located within an airport land use plan or, where such a plan has not been adopted, within two mile of a public airport or public use airport, would the project result in a safety hazard for people residing or working in the project area?

☐
☐
☐
☒

The project site is located within the Federal Aviation Administration Part 77 Notification Area (San Diego International Airport – Lindbergh Field), and the Airport Influence Area Review Area 1 as identified in the Airport Land Use Compatibility Plan (ALUCP) for San Diego International Airport. The basic function of the ALUCP (2014) is to promote compatibility between airports and the land uses that surround them to the extent that these areas are not already devoted to incompatible land uses. The ALUCP safeguards the general welfare of the inhabitants within the vicinity of San Diego International Airport and the public in general. The ALUCP provides policies and criteria for the City of San Diego to implement and for the Airport Land Use Commission (ALUC) to use when reviewing development proposals.

Although the project site is located within an airport land use plan, the project would not result in a safety hazard residing in the project area. Per the San Diego International Airport ALUCP, Review Area 2 is defined by the combination of the airspace protection and overflight boundaries beyond Review Area 1. Only airspace protection and overflight policies and standards apply within Review Area 2. No impacts would result.

- f) For a project within the vicinity of a private airstrip, would the project result in a safety hazard for people residing or working in the project area?

☐
☐
☐
☒

Refer to response VIII(e) above. The project site is not in proximity to any private airstrip. Therefore, no significant impacts would occur, and no mitigation measures are required.

- g) Impair implementation of or physically interfere with an adopted emergency response plan or emergency evacuation plan?

☐
☐
☐
☒

The project would not impair the implementation of, or physically interfere with, an adopted emergency response plan or evacuation plan. No roadway improvements are proposed that would

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

interfere with circulation or access, and all construction would take place on-site. No impacts would occur, and no mitigation measures are required.

- h) Expose people or structures to a significant risk of loss, injury or death involving wildland fires, including where wildlands are adjacent to urbanized areas or where residences are intermixed with wildlands?

☐
☐
☐
☒

The project site is located within a developed residential neighborhood. There are no wildlands or other areas prone to wildfire within the vicinity of the project site. Therefore, the project would not expose people or structures to wildland fires. No impacts would occur, and no mitigation measures are required.

IX. HYDROLOGY AND WATER QUALITY - Would the project:

- a) Violate any water quality standards or waste discharge requirements?

☐
☐
☒
☐

The project would comply with all storm water quality standards during and after construction, and appropriate Best Management Practices (BMP's) must be utilized. Implementation of these BMP's would preclude any violations of existing standards and discharge regulations. Impacts would be less than significant, and no mitigation measures are required.

- b) Substantially deplete groundwater supplies or interfere substantially with groundwater recharge such that there would be a net deficit in aquifer volume or a lowering of the local groundwater table level (e.g., the production rate of pre-existing nearby wells would drop to a level which would not support existing land uses or planned uses for which permits have been granted)?

☐
☐
☐
☒

The project does not require the construction of wells. The project is located within a developed residential neighborhood with existing public water supply infrastructure. No impacts would result.

- c) Substantially alter the existing drainage pattern of the site or area, including through the alteration of the course of a stream or river, in a manner, which would result in substantial erosion or siltation on- or off-site?

☐
☐
☒
☐

The project would not substantially alter the existing drainage pattern of the site or the area. There are no streams or rivers located on-site and thus, no such resources would be impacted through the

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

proposed grading activities. Although grading would be required for the project, the project would implement BMPs to ensure that substantial erosion or siltation on or off-site would not occur. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| d) Substantially alter the existing drainage pattern of the site or area, including through the alteration of the course of a stream or river, or substantially increase the rate or amount of surface runoff in a manner, which would result in flooding on- or off-site? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

The project would implement low impact development principles ensuring that a substantial increase in the rate or amount of surface runoff resulting in flooding on or off-site, or a substantial alteration to the existing drainage pattern would not occur. Streams or rivers do not occur on or adjacent to the project site. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| e) Create or contribute runoff water, which would exceed the capacity of existing or planned stormwater drainage systems or provide substantial additional sources of polluted runoff? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

The project would comply with all City storm water quality standards during and after construction. Appropriate BMP's would be implemented to ensure that water quality is not degraded; therefore, ensuring that the project runoff is directed to appropriate drainage systems. Due to the nature of the project, any runoff from the site is not anticipated to exceed the capacity of existing storm water systems or provide substantial additional sources of polluted runoff that would require new or expanded facilities. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| f) Otherwise substantially degrade water quality? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

The project would comply with all City storm water quality standards during and after construction. Appropriate BMP's would be implemented to ensure that water quality is not degraded. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|
| g) Place housing within a 100-year flood hazard area as mapped on a federal Flood Hazard Boundary or Flood Insurance Rate Map or other flood hazard delineation map? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is not located within a 100-year flood hazard area. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| h) Place within a 100-year flood hazard area, structures that would impede or redirect flood flows? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is not located within a 100-year flood hazard area or any other known flood area. No impacts would result.

X. LAND USE AND PLANNING – Would the project:

- | | | | | |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|
| a) Physically divide an established community? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project is consistent with the General Plan's and Community Plan's land use designation. The project site is located within a developed residential neighborhood and surrounded by similar residential development. Construction of the project would not affect adjacent properties and is consistent with surrounding land uses. Therefore, the project would not physically divide an established community. No impacts would result.

- | | | | | |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|
| b) Conflict with any applicable land use plan, policy, or regulation of an agency with jurisdiction over the project (including but not limited to the general plan, specific plan, local coastal program, or zoning ordinance) adopted for the purpose of avoiding or mitigating an environmental effect? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|

The Land Development Code (LDC), Section 143.0740 allows development incentives for affordable housing density bonus projects. Four affordable housing incentives, in the form of deviations from developmental regulations, are being requested in accordance with LDC Section 143.0740, and are as follows:

1. Minimum Yards – A deviation from San Diego Municipal Code (SDMC) Section 158.0301(b)(2)(B), Table 158-03C, Footnote 2, 3, and 5 for no third story step back setback.
2. Yard and Setback Requirements – A deviation from SDMC 158.0301(b)(2)(A) for no minimum street yard size.
3. Minimum Average Unit Floor Area – A deviation from SDMC 158.0301(b)(5)(B) to allow a 603-square-foot minimum unit size, where 700-square-feet is required.
4. Height Limits – A deviation from SDMC 158.0301(b)(3) to allow 50 feet in height, where 40 feet is the maximum.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

See response X(a) above. The project is compatible with the area designated for residential development by the General Plan and Community Plan, and is consistent with the existing underlying zone and surrounding land uses. Construction of the project would occur within an urbanized neighborhood with similar development. Furthermore, the project would not conflict with any applicable land use plan, policy, or regulation of an agency with jurisdiction over the project (including but not limited to the general plan, community plan, or zoning ordinance) adopted for the purpose of avoiding or mitigating an environmental effect. No conflict would occur and thus, no impacts would result.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| c) Conflict with any applicable habitat conservation plan or natural community conservation plan? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project is located within a developed residential neighborhood and would not conflict with any applicable habitat conservation plan or natural community conservation plan. The project would not conflict with the City's Multiple Species Conservation Plan (MSCP), in that the site is not located within or adjacent to the MHPA. No significant impacts would occur, and no mitigation measures are required.

XI. MINERAL RESOURCES – Would the project?

- | | | | | |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|
| a) Result in the loss of availability of a known mineral resource that would be of value to the region and the residents of the state? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--|--------------------------|--------------------------|--------------------------|-------------------------------------|

There are no known mineral resources located on the project site. The urbanized and developed nature of the project site and vicinity would preclude the extraction of any such resources. No impacts would result.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| b) Result in the loss of availability of a locally important mineral resource recovery site delineated on a local general plan, specific plan or other land use plan? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

See response XI(a) above. The project site has not been delineated on a local general plan, specific plan, or other land use plan as a locally important mineral resource recovery site, and no such resources would be affected with project implementation. Therefore, no significant impacts were identified, and no mitigation measures are required.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
XII. NOISE – Would the project result in:				
a) Generation of, noise levels in excess of standards established in the local general plan or noise ordinance, or applicable standards of other agencies?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Veneklasen Associates, Inc. prepared a Noise Report (July 10, 2017) to analyze the existing and future noise environments. Vehicular traffic on Broadway Street and the 94 Freeway, and Aircraft overflight associated with the San Diego Airport are the primary noise sources around the project site. The land uses surrounding the project are mainly multi-family residential. The technical report is summarized below.

Traffic Noise

According to the technical study, the existing traffic volume on Broadway is 17,700 ADT. It was determined that the project would generate approximately 168 ADT, using the rate of 6 ADT/dwelling unit, with 13 morning peak hour trips and 15 evening peak hour trips. The increase of traffic due to the project is less than 1 percent. This increase would result in a sound level increase of less than 1 CNEL, which is below the 3 CNEL threshold that defines a significant impact. Therefore, the impact with regard to traffic noise is less than significant.

Operational Noise

The project would include mechanical equipment, including split-system outdoor condensing units. Calculations based on published sound power data for units of typical residential size were utilized and the resulting sound pressure levels at the closest property line were calculated. Calculations were completed with the assumption that half of the units would be operating simultaneously, with the result of approximately 51 dBA Leq. Since the units cycle on and off during the day, it was determined that the existing CNEL would not increase and therefore, the project would not significantly increase noise levels in the vicinity. The impact is less than significant.

For the long-term, typical noise levels associated with residential uses are anticipated, and the project would not result in an increase in the existing ambient noise level. The project would not result in noise levels in excess of standards established in the City of San Diego General Plan or Noise Ordinance. No significant long-term impacts would occur, and no mitigation measures are required.

Construction Noise (Short Term)

Short-term noise impacts would be associated with onsite demolition, grading, and construction activities of the project. Construction-related short-term noise levels would be higher than existing ambient noise levels in the project area, but would no longer occur once construction is completed. Sensitive receptors (e.g. residential uses) occur in the immediate area and may be temporarily affected by construction noise; however, construction activities would be required to comply with

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

the construction hours specified in the City's Municipal Code (Section 59.5.0404, Construction Noise), which are intended to reduce potential adverse effects resulting from construction noise. The technical report determined that during some construction phases, noise levels could exceed the 75 dBA construction noise level limit set forth by the City's Municipal Code.

In addition to compliance with the City's construction noise requirements under the City's Municipal Code Section 59.5.0404, project construction noise levels would be reduced to less than significant with mitigation measures. Therefore, mitigation measures related to noise are required.

A Mitigation Monitoring and Reporting Program, as detailed within Section V of the Mitigated Negative Declaration, would be implemented to reduce impacts related to noise below a level of significance.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| b) Generation of, excessive ground borne vibration or ground borne noise levels? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

See response XII(a) above. According to the technical study, construction equipment would be the only vibration-generating sources introduced by the project. Potential effects from construction noise would be reduced through compliance with City restrictions. The technical study determined that adjacent sensitive receptors would not experience significant impacts due to vibration generated by construction equipment. The impact would be less than significant and no mitigation is required.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| c) A substantial permanent increase in ambient noise levels in the project vicinity above levels existing without the project? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

See response XII(a) above. The project would not significantly increase long-term noise levels. The project would not introduce a new land use or significantly increase the intensity of the allowed land use. Post-construction noise levels and traffic would be generally unchanged as compared to noise with the existing use. Therefore, no substantial permanent increase in ambient noise levels is anticipated. A less than significant impact would result.

- | | | | | |
|---|--------------------------|-------------------------------------|--------------------------|--------------------------|
| d) A substantial temporary or periodic increase in ambient noise levels in the project vicinity above existing without the project? | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|-------------------------------------|--------------------------|--------------------------|

See response XII(a) above. The project has the potential to expose people to a substantial increase in temporary or periodic ambient noise levels. Construction noise would result during grading, demolition, and construction activities, but would be temporary in nature. Construction-related noise impacts from the project would generally be higher than existing ambient noise levels in the project area, but would no longer occur once construction is completed. In addition to compliance

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

with the San Diego Municipal Code, Article 9.5, Noise Abatement and Control, project construction noise levels would be reduced to less than significant with mitigation measures. Therefore, implementation of these standard measures, as well as mitigation measures, would reduce potential impacts from an increase in ambient noise levels during construction to a less than significant level. A Mitigation Monitoring and Reporting Program, as detailed within Section V of the Mitigated Negative Declaration, would be implemented to reduce impacts related to noise to ~~below~~ below a level of significance.

- e) For a project located within an airport land use plan, or, where such a plan has not been adopted, within two miles of a public airport or public use airport would the project expose people residing or working in the area to excessive noise levels?

☐
☐
☒
☐

The project site is approximately three miles east of the San Diego International Airport. Although the project site is located within the Airport Land Use Compatibility Plan (ALUCP), the project site is within the Conditionally Compatible Zone (65-70 Community Noise Equivalent Level (CNEL)) as depicted in the 2014 ALUCP, meaning use is permitted subject to the condition that the building is capable of attenuating exterior noise to 45 CNEL. To reduce interior noise levels to below 45 CNEL, the project would be required to incorporate project features, such as sound-rated dual-glazed windows, as well as mechanical, or other means, of ventilation, as a condition of project approval. Therefore, the impact would be less than significant.

- f) For a project within the vicinity of a private airstrip, would the project expose people residing or working in the project area to excessive noise levels?

☐
☐
☐
☒

The project site is not located within the vicinity of a private airstrip. No impacts would result, and no mitigation measures are required.

XIII. POPULATION AND HOUSING – Would the project:

- a) Induce substantial population growth in an area, either directly (for example, by proposing new homes and businesses) or indirectly (for example, through extension of roads or other infrastructure)?

☐
☐
☐
☒

The project site is located in a developed residential neighborhood. The project site currently receives water and sewer service from the City, and no extension of infrastructure to new areas is required. As such, the project would not substantially increase housing or population growth in the area. No roadway improvements are proposed as part of the project. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| b) Displace substantial numbers of existing housing, necessitating the construction of replacement housing elsewhere? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is located in a developed residential neighborhood, and no such displacement would occur in that the project would construct a three-story 28-unit multi-family dwelling development. No impacts would result.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| c) Displace substantial numbers of people, necessitating the construction of replacement housing elsewhere? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

See response XIII(b) above. No impacts would result.

XIV. PUBLIC SERVICES

- a) Would the project result in substantial adverse physical impacts associated with the provisions of new or physically altered governmental facilities, need for new or physically altered governmental facilities, the construction of which could cause significant environmental impacts, in order to maintain acceptable service rations, response times or other performance objectives for any of the public services:

- | | | | | |
|--------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|
| i) Fire Protection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is located in an urbanized and developed area where fire protection services are already provided. The project site is located within a developed residential neighborhood. Construction of the project would not adversely affect existing levels of fire protection services to the area, and would not require the construction of new, or expansion of, existing governmental facilities. No impacts would result.

- | | | | | |
|-----------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|
| ii) Police Protection | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|-----------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is located in an urbanized and developed area within the City of San Diego where police protection services are already provided. Construction of the project would not adversely affect existing levels of police protection services to the area or create significant new demand for such services. Additionally, the project would not require the construction of new, or expansion of, existing governmental facilities. No impacts would result.

- | | | | | |
|--------------|--------------------------|--------------------------|--------------------------|-------------------------------------|
| iii) Schools | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|--------------|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project site is located in an urbanized and developed area where public school services are available. The project would not significantly increase the demand on public schools over that which currently exists. Construction of the project is not anticipated to result in a significant increase in demand for public educational services. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
v) Parks	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>

The project site is located in an urbanized and developed area where City-operated parks are available. The project would not significantly increase the demand on existing neighborhood or regional parks, or other recreational facilities, over that which presently exists. Construction of the project is not anticipated to result in a significant increase in demand for parks or other offsite recreational facilities. No impacts would result.

vi) Other public facilities	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
-----------------------------	--------------------------	--------------------------	--------------------------	-------------------------------------

The project site is located in an urbanized and developed area where City services are already available. Construction of the project would not require the construction of new, or expansion of, existing governmental facilities. No impacts would result.

XV. RECREATION

a) Would the project increase the use of existing neighborhood and regional parks or other recreational facilities such that substantial physical deterioration of the facility would occur or be accelerated?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
--	--------------------------	--------------------------	--------------------------	-------------------------------------

The project would construct a three-story 28-unit multi-family dwelling development and therefore, not adversely affect the availability of and/or need for new or expanded recreational resources. The project would not adversely affect existing levels of public services, and would not require the construction or expansion of an existing governmental facility. The project would not significantly increase the use of existing neighborhood or regional parks or other recreational facilities. Therefore, the project is not anticipated to result in the use of available parks or facilities such that substantial deterioration occurs, or that would require the construction or expansion of recreational facilities to satisfy demand. As such, no significant impacts related to recreational facilities have been identified, and no mitigation measures are required.

b) Does the project include recreational facilities or require the construction or expansion of recreational facilities, which might have an adverse physical effect on the environment?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
--	--------------------------	--------------------------	--------------------------	-------------------------------------

See response to XIV(a) above. The project does not propose recreation facilities, nor does it require the construction or expansion of any such facilities. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

XVI. TRANSPORTATION/TRAFFIC – Would the project?

- a) Conflict with an applicable plan, ordinance or policy establishing measures of effectiveness for the performance of the circulation system, taking into account all modes of transportation including mass transit and non-motorized travel and relevant components of the circulation system, including but not limited to intersections, streets, highways and freeways, pedestrian and bicycle paths, and mass transit?

☐
☐
☒
☐

Construction of the project would not change existing circulation patterns on area roadways; however, a temporary minor increase in traffic may occur during construction. The project would not conflict with any applicable plan, ordinance, or policy establishing measures of effectiveness for the performance of the circulation system. The project is not expected to cause a significant short-term or long-term increase in traffic volumes, and thus, would not adversely affect existing levels of service along area roadways. Therefore, impacts are considered less than significant, and no mitigation measures are required.

- b) Conflict with an applicable congestion management program, including, but not limited to level of service standards and travel demand measures, or other standards established by the county congestion management agency for designated roads or highways?

☐
☐
☒
☐

Refer to response XVI(a) above. Construction of the project would not generate additional vehicular traffic nor would it adversely affect any mode of transportation in the area. Therefore, the project would not conflict with any applicable plan, ordinance, or policy establishing measures of effectiveness for the performance of the circulation system. Impacts are considered less than significant, and no mitigation measures are required.

- c) Result in a change in air traffic patterns, including either an increase in traffic levels or a change in location that results in substantial safety risks?

☐
☐
☐
☒

Implementation of the project would not result in a change to air traffic patterns. As stated in Section VIII(e), the project site is located within the Federal Aviation Administration Part 77 Notification Area (San Diego International Airport – Lindbergh Field), and the Airport Influence Area Review Area 1 as identified in the Airport Land Use Compatibility Plan (ALUCP) for San Diego International Airport. The basic function of the ALUCP (2014) is to promote compatibility between airports and the land uses that surround them to the extent that these areas are not already

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

devoted to incompatible land uses. The ALUCP safeguards the general welfare of the inhabitants within the vicinity of San Diego International Airport and the public in general. The ALUCP provides policies and criteria for the City of San Diego to implement and for the Airport Land Use Commission (ALUC) to use when reviewing development proposals.

Although the project site is located within an airport land use plan, the project would not result in a safety hazard residing in the project area. Per the San Diego International Airport ALUCP, Review Area 2 is defined by the combination of the airspace protection and overflight boundaries beyond Review Area 1. Only airspace protection and overflight policies and standards apply within Review Area 2. No impacts would result.

- d) Substantially increase hazards due to a design feature (e.g., sharp curves or dangerous intersections) or incompatible uses (e.g., farm equipment)?

☐
☐
☐
☒

The project would not alter existing circulation patterns on Broadway. No design features or incompatible uses that would increase potential hazards are proposed. The project would not affect emergency access to the project site or adjacent properties. Pedestrian access ~~Access~~ would be provided to the project site via Broadway. Vehicle access would be provided to the project site via the alley entry to parking. Driveway design for the project is consistent with City design requirements to ensure safe ingress/egress from the properties. Additionally, the project site is located within an existing residential neighborhood and is not an incompatible use that would create hazardous conditions. No impacts would result.

- e) Result in inadequate emergency access?

☐
☐
☐
☒

The project is consistent with the underlying zone and would not result in inadequate emergency access. The project design would be subject to City review and approval for consistency with all design requirements to ensure that no impediments to emergency access occur. No impacts would result.

- f) Conflict with adopted policies, plans, or programs regarding public transit, bicycle, or pedestrian facilities, or otherwise decrease the performance or safety of such facilities?

☐
☐
☐
☒

The project would not alter the existing conditions of the project site or adjacent facilities with regard to alternative transportation. Construction of the project would not result in design measures or circulation features that would conflict with existing policies, plan, or programs supporting alternative transportation. No impacts would result.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

XVII. TRIBAL CULTURAL RESOURCES- Would the project cause a substantial adverse change in the significance of a tribal cultural resource, defined in Public Resources Code section 21074 as either a site, feature, place, cultural landscape that is geographically defined in terms of the size and scope of the landscape, sacred place, or object with cultural value to a California Native American tribe, and that is:

- a) Listed or eligible for listing in the California Register of Historical Resources, or in a local register of historical resources as defined in Public Resources Code section 5020.1(k), or

☐
☐
☐
☒

No recorded sites within the project area are listed or eligible for listing on the California Register of Historical Resources or in a local register of historical resources as defined in Public Resources Code section 5020.1 (k). Additionally as previously identified in Section V(a), qualified archaeological City staff determined that no further evaluation was required based on the negative California Historic Resources System (CHRIS) search, site photographs, location of the project site in an urbanized area surrounded by existing development, and disturbed nature of the project site as documented in the geotechnical study. Further, the project is not mapped within the City's Historical Sensitivity Map. No impacts would result.

- b) A resource determined by the lead agency, in its discretion and supported by substantial evidence, to be significant pursuant to criteria set forth in subdivision (c) of Public Resources Code Section 5024.1. In applying the criteria set forth in subdivision (c) of Public Resource Code Section 5024.1, the lead agency shall consider the significance of the resource to a California Native American tribe.

☐
☐
☐
☒

There is potential for Tribal Cultural Resources pursuant to subdivision (c) of Public Resources Code Section 5024.1 (c) to exist on the project site; however, it was determined through the consultation process that Tribal Cultural Resources would not be adversely impacted by the proposed project. Additionally, as previously identified in Section V(a), qualified archaeological City staff determined that no further evaluation was required based on the negative CHRIS search, site photographs, location of the project site in an urbanized area surrounded by existing development, and disturbed nature of the project site as documented in the geotechnical study.

In accordance with the requirements of Assembly Bill (AB) 52, the City of San Diego sent notification to two Native American Tribes traditionally and culturally affiliated with the project area on June 20, 2017. Both the Iipay Nation of Santa Ysabel and the Jamul Indian Village responded within the 30-day period requesting consultation and additional information. Consultation took place on June 22, 2017 with Iipay Nation of Santa Ysabel and on June 23, 2017 with Jamul Indian Village. Iipay Nation of Santa Ysabel and Jamul Indian Village identified that no significant Tribal Cultural

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

Resources are present. No further evaluation was required and consultation under AB 52 was concluded. Therefore, no impacts would result.

XVIII. UTILITIES AND SERVICE SYSTEMS – Would the project:

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| a) Exceed wastewater treatment requirements of the applicable Regional Water Quality Control Board? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

Implementation of the project would not interrupt existing sewer service to the project site or other surrounding uses. No increase in demand for wastewater disposal or treatment would be created by the project, as compared to current conditions. The project is not anticipated to generate significant amounts of wastewater. Wastewater facilities used by the project would be operated in accordance with the applicable wastewater treatment requirements of the Regional Water Quality Control Board (RWQCB). Additionally, the project site is located in an urbanized and developed area. Adequate services are already available to serve the project. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| b) Require or result in the construction of new water or wastewater treatment facilities or expansion of existing facilities, the construction of which could cause significant environmental effects? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

See response XVII(a) above. Adequate services are available to serve the project site. Additionally, the project would not significantly increase the demand for water or wastewater treatment services and thus, would not trigger the need for new treatment facilities. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|
| c) Require or result in the construction of new storm water drainage facilities or expansion of existing facilities, the construction of which could cause significant environmental effects? | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
|---|--------------------------|--------------------------|--------------------------|-------------------------------------|

The project would not exceed the capacity of the existing storm water drainage systems and therefore, would not require construction of new or expansion of existing storm water drainage facilities of which could cause significant environmental effects. The project was reviewed by qualified City staff who determined that the existing facilities are adequately sized to accommodate the proposed development. No impacts would result.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| d) Have sufficient water supplies available to serve the project from existing entitlements and resources, or are new or expanded entitlements needed? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

The project does not meet the CEQA significance threshold requiring the need for the project to prepare a water supply assessment. The existing project site currently receives water service from the City, and adequate services are available to serve the proposed residential dwelling units without requiring new or expanded entitlements. Impacts would be less than significant.

- | | | | | |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|
| e) Result in a determination by the wastewater treatment provider which serves or may serve the project that it has adequate capacity to serve the project's projected demand in addition to the provider's existing commitments? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|---|--------------------------|--------------------------|-------------------------------------|--------------------------|

Construction of the project would not adversely affect existing wastewater treatment services. Adequate services are available to serve the project site without requiring new or expanded entitlements. Impacts would be less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| f) Be served by a landfill with sufficient permitted capacity to accommodate the project's solid waste disposal needs? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

Construction debris and waste would be generated from the construction of the project. All construction waste from the project site would be transported to an appropriate facility, which would have adequate capacity to accept the limited amount of waste that would be generated by the project. Long-term operation of the project is anticipated to generate typical amounts of solid waste associated with residential use. Furthermore, the project would be required to comply with the City's Municipal Code for diversion of both construction waste during the demolition phase and solid waste during the long-term, operational phase. Impacts are considered to be less than significant, and no mitigation measures are required.

- | | | | | |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|
| g) Comply with federal, state, and local statutes and regulation related to solid waste? | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
|--|--------------------------|--------------------------|-------------------------------------|--------------------------|

The project would comply with all Federal, State, and local statutes and regulations related to solid waste. The project would not result in the generation of large amounts of solid waste, nor generate or require the transport of hazardous waste materials, other than minimal amounts generated during the construction phase. All demolition activities would comply with any City of San Diego requirements for diversion of both construction waste during the demolition phase and solid waste during the long-term, operational phase. Impacts would be less than significant, and no mitigation measures are required.

Issue	Potentially Significant Impact	Less Than Significant with Mitigation Incorporated	Less Than Significant Impact	No Impact
-------	--------------------------------	--	------------------------------	-----------

XIX. MANDATORY FINDINGS OF SIGNIFICANCE –

- a) Does the project have the potential to degrade the quality of the environment, substantially reduce the habitat of a fish or wildlife species, cause a fish or wildlife population to drop below self-sustaining levels, threaten to eliminate a plant or animal community, reduce the number or restrict the range of a rare or endangered plant or animal or eliminate important examples of the major periods of California history or prehistory?

☐
☒
☐
☐

As documented in this Initial Study, the project may have the potential to degrade the quality of the environment, notably with respect to noise. As such, mitigation measures have been incorporated to reduce impacts to less than significant.

- b) Does the project have impacts that are individually limited, but cumulatively considerable? ("Cumulatively considerable" means that the incremental effects of a project are considerable when viewed in connection with the effects of past projects, the effects of other current projects, and the effects of probable futures projects)?

☐
☒
☐
☐

As documented in this Initial Study, the project may have the potential to degrade the quality of the environment, notably with respect to noise, which may have cumulatively considerable impacts. As such, mitigation measures have been incorporated to reduce impacts to less than significant. Other future projects within the surrounding neighborhood or community would be required to comply with applicable local, State, and Federal regulations to reduce the potential impacts to less than significant, or to the extent possible. As such, the project is not anticipated to contribute potentially significant cumulative environmental impacts.

- c) Does the project have environmental effects, which will cause substantial adverse effects on human beings, either directly or indirectly?

☐
☐
☒
☐

The construction of a three-story 28-unit multi-family dwelling development is consistent with the setting and with the use anticipated by the City. It is not anticipated that demolition or construction activities would create conditions that would significantly directly or indirectly impact human beings. Impacts would be less than significant.

INITIAL STUDY CHECKLIST

REFERENCES

I. Aesthetics / Neighborhood Character

- ☒ City of San Diego General Plan.
- ☒ Community Plans: Greater Golden Hill Community Plan

II. Agricultural Resources & Forest Resources

- ☐ City of San Diego General Plan
- ☐ U.S. Department of Agriculture, Soil Survey - San Diego Area, California, Part I and II, 1973
- ☐ California Agricultural Land Evaluation and Site Assessment Model (1997)
- ☐ Site Specific Report:

III. Air Quality

- ☐ California Clean Air Act Guidelines (Indirect Source Control Programs) 1990
- ☐ Regional Air Quality Strategies (RAQS) - APCD
- ☐ Site Specific Report:

IV. Biology

- ☒ City of San Diego, Multiple Species Conservation Program (MSCP), Subarea Plan, 1997
- ☒ City of San Diego, MSCP, "Vegetation Communities with Sensitive Species and Vernal Pools" Maps, 1996
- ☒ City of San Diego, MSCP, "Multiple Habitat Planning Area" maps, 1997
- ☐ Community Plan - Resource Element
- ☐ California Department of Fish and Game, California Natural Diversity Database, "State and Federally-listed Endangered, Threatened, and Rare Plants of California," January 2001
- ☐ California Department of Fish & Game, California Natural Diversity Database, "State and Federally-listed Endangered and Threatened Animals of California," January 2001
- ☐ City of San Diego Land Development Code Biology Guidelines
- ☐ Site Specific Report:

V. Cultural Resources (includes Historical Resources)

- ☒ City of San Diego Historical Resources Guidelines
- ☐ City of San Diego Archaeology Library
- ☐ Historical Resources Board List
- ☐ Community Historical Survey:
- ☐ Site Specific Report:

VI. Geology/Soils

- ☒ City of San Diego Seismic Safety Study
- ☐ U.S. Department of Agriculture Soil Survey - San Diego Area, California, Part I and II, December 1973 and Part III, 1975
- ☒ Site Specific Report: Report of Preliminary Geotechnical Investigation and Infiltration Testing prepared by Geotechnical Exploration, Inc. dated March 17, 2017
- ☒ Site Specific Report: Response to City Geology Reviewer prepared by Geotechnical Exploration, Inc. dated April 20, 2017
- ☒ Site Specific Report: Anticipated Infiltration Characteristics prepared by Geotechnical Exploration, Inc. dated November 29, 2016

VII. Greenhouse Gas Emissions

- ☒ Site Specific Report: Climate Action Plan Consistency Checklist

VIII. Hazards and Hazardous Materials

- ☒ San Diego County Hazardous Materials Environmental Assessment Listing
- ☐ San Diego County Hazardous Materials Management Division
- ☐ FAA Determination
- ☐ State Assessment and Mitigation, Unauthorized Release Listing, Public Use Authorized
- ☐ Airport Land Use Compatibility Plan
- ☐ Site Specific Report:

IX. Hydrology/Water Quality

- ☐ Flood Insurance Rate Map (FIRM)
- ☒ Federal Emergency Management Agency (FEMA), National Flood Insurance Program-Flood Boundary and Floodway Map
- ☐ Clean Water Act Section 303(b) list, http://www.swrcb.ca.gov/tmdl/303d_lists.html
- ☒ Site Specific Report: Storm Water Quality Management Plan prepared by Pasco Laret Suiter & Associates dated May 19, 2017
- ☒ Site Specific Report: Drainage Study prepared by prepared by Pasco Laret Suiter & Associates dated May 19, 2017

X. Land Use and Planning

- ☒ City of San Diego General Plan
- ☒ Community Plan
- ☐ Airport Land Use Compatibility Plan
- ☒ City of San Diego Zoning Maps
- ☐ FAA Determination
- ☐ Other Plans:

XI. Mineral Resources

- ☐ California Department of Conservation - Division of Mines and Geology, Mineral Land Classification
- ☐ Division of Mines and Geology, Special Report 153 - Significant Resources Maps
- ☐ Site Specific Report:

XII. Noise

- ☒ City of San Diego General Plan
- ☐ Community Plan
- ☐ San Diego International Airport - Lindbergh Field CNEL Maps
- ☐ Brown Field Airport Master Plan CNEL Maps

- ___ Montgomery Field CNEL Maps
- ___ San Diego Association of Governments - San Diego Regional Average Weekday Traffic Volumes
- ___ San Diego Metropolitan Area Average Weekday Traffic Volume Maps, SANDAG
- X Site Specific Report: Noise Report prepared by Veneklasen Associates, Inc. dated July 10, 2017

XIII. Paleontological Resources

- X City of San Diego Paleontological Guidelines
- ___ Deméré, Thomas A., and Stephen L. Walsh, "Paleontological Resources City of San Diego," Department of Paleontology San Diego Natural History Museum, 1996
- ___ Kennedy, Michael P., and Gary L. Peterson, "Geology of the San Diego Metropolitan Area, California. Del Mar, La Jolla, Point Loma, La Mesa, Poway, and SW 1/4 Escondido 7 1/2 Minute Quadrangles," California Division of Mines and Geology Bulletin 200, Sacramento, 1975
- X Kennedy, Michael P., and Siang S. Tan, "Geologic Map of the San Diego 30' x 60' Quadrangle, California" (2005)
- ___ Site Specific Report:

XIV. Population / Housing

- ___ City of San Diego General Plan
- ___ Community Plan
- ___ Series 11/Series 12 Population Forecasts, SANDAG
- ___ Other:

XV. Public Services

- ___ City of San Diego General Plan
- ___ Community Plan

XVI. Recreational Resources

- ___ City of San Diego General Plan
- ___ Community Plan
- ___ Department of Park and Recreation
- ___ City of San Diego - San Diego Regional Bicycling Map
- ___ Additional Resources:

XVII. Transportation / Circulation

- ___ City of San Diego General Plan
- ___ Community Plan
- ___ San Diego Metropolitan Area Average Weekday Traffic Volume Maps, SANDAG
- ___ San Diego Region Weekday Traffic Volumes, SANDAG
- ___ Site Specific Report:


XVIII. Utilities

- ___ Site Specific Report:

XIX. Water Conservation

- ___ Sunset Magazine, New Western Garden Book, Rev. ed. Menlo Park, CA: Sunset Magazine

Created: REVISED - October 11, 2013




Vicinity Map

3060 Broadway / Project No. 525677

City of San Diego – Development Services Department

FIGURE

No. 1



Site Plan

3060 Broadway / Project No. 525677

City of San Diego - Development Services Department

FIGURE
No. 2