

**Water Quality Chemistry Services  
 2022 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	PHG (MCLG)	DDW DLR	PARAMETER	UNITS	MCL	PHG (MCLG)	DDW DLR
1,1,1,2-Tetrachloroethane	ppb	n/a	n/a	0.5	Diquat*	ppb	20	6	4
1,1,1-Trichloroethane (1,1,1-TCA)*	ppb	200	1000	0.5	Endothall*	ppb	100	94	45
1,1,2,2-Tetrachloroethane*	ppb	1	0.1	0.5	Endrin*	ppb	2	0.3	0.1
1,1,2-Trichloroethane (1,1,2-TCA)*	ppb	5	0.3	0.5	Ethoprop#	ppb	n/a	n/a	0.03
1,1-Dichloroethane (1,1-DCA)*	ppb	5	3	0.5	Ethyl Benzene*	ppb	300	300	0.5
1,1-Dichloroethylene (1,1-DCE)*	ppb	6	10	0.5	Ethylene Dibromide (EDB)*	ppt	50	10	20
1,1-Dichloropropene	ppb	n/a	n/a	0.5	Ethyl-tert-Butyl Ether (ETBE)	ppb	n/a	n/a	3
1,2,3-Trichlorobenzene	ppb	n/a	n/a	0.5	Foaming Agents (MBAS)	ppb	500	n/a	n/a
1,2,3-Trichloropropene (TCP)	ppb	0.005	0.0007	0.005	Germanium#	ppb	n/a	n/a	0
1,2,4-Trichlorobenzene*	ppb	5	5	0.5	Geosmin	ppt	n/a	n/a	n/a
1,2,4-Trimethylbenzene	ppb	n/a	n/a	0.5	Glyphosate*	ppb	700	900	25
1,2-Dichlorobenzene (o-DCB)*	ppb	600	600	0.5	Heptachlor*	ppt	10	8	10
1,2-Dichloroethane (1,2-DCA)*	ppt	500	400	500	Heptachlor Epoxide*	ppt	10	6	10
1,2-Dichloropropane*	ppb	5	0.5	0.5	Hexachlorobenzene*	ppb	1	0.03	0.5
1,3,5-Trimethylbenzene	ppb	n/a	n/a	0.5	Hexachlorobutadiene	ppb	n/a	n/a	0.5
1,3-Dichlorobenzene (m-DCB)	ppb	n/a	n/a	0.5	Hexachlorocyclopentadiene*	ppb	50	2	1
1,3-Dichloropropane	ppb	n/a	n/a	0.5	Iron (Fe)	ppb	n/a	n/a	100
1,4-Dichlorobenzene (p-DCB)*	ppb	5	6	0.5	Isopropylbenzene (Cumene)	ppb	n/a	n/a	0.5
1-Butanol#	ppb	n/a	n/a	2	Lead(Pb)*	ppb	15^	0.2	5
2,2-Dichloropropane	ppb	n/a	n/a	0.5	Lindane (gamma-BHC)*	ppt	200	32	200
2,4,5-T	ppb	n/a	n/a	n/a	Manganese	ppb	50	n/a	20
2,4,5-TP (SILVEX)*	ppb	50	3	1	MCPA	ppb	n/a	n/a	n/a
2,4-D*	ppb	70	20	10	MCPPP	ppb	n/a	n/a	n/a
2,4-DB	ppb	n/a	n/a	n/a	Mercury*	ppb	2	1.2	1
2-Chlorotoluene	ppb	n/a	n/a	0.5	meta,para xylenes	ppb	n/a	n/a	0.5
2-Methoxyethanol#	ppb	n/a	n/a	0.4	Methiocarb	ppb	n/a	n/a	n/a
2-Methylisoborneol	ppt	n/a	n/a	n/a	2-Methylisoborneol (MIB)	ppb	n/a	n/a	n/a
2-propen-1-ol#	ppb	n/a	n/a	0.5	Methomyl	ppb	n/a	n/a	2
3,5-Dichlorobenzoic Acid	ppb	n/a	n/a	n/a	Methoxychlor*	ppb	30	0.09	10
3-Hydroxycarbofuran	ppb	n/a	n/a	3	Methyl tert-Butyl Ether (MTBE)*+	ppb	13	13	3
4-Chlorotoluene	ppb	n/a	n/a	0.5	Molinate (ORDRAM)*	ppb	20	1	2
4-Nitrophenol	ppb	n/a	n/a	5	Monochlorobenzene (Chlorobenzene)*	ppb	70	70	0.5
Acifluorfen	ppb	n/a	n/a	n/a	Naphthalene	ppb	n/a	n/a	0.5

**Water Quality Chemistry Services  
 2022 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	PHG (MCLG)	DDW DLR	PARAMETER	UNITS	MCL	PHG (MCLG)	DDW DLR
Alachlor (ALANEX)*	ppb	2	4	1	n-Butylbenzene	ppb	n/a	n/a	0.5
Aldicarb (TEMIK)	ppb	n/a	n/a	3	Nickel	ppt	100	12	10
Aldicarb Sulfone	ppb	n/a	n/a	4	Nitrite (as N)	ppm	1	1	0.4
Aldicarb Sulfoxide	ppb	n/a	n/a	3	n-Propylbenzene	ppb	n/a	n/a	0.5
Aldrin	ppb	n/a	n/a	0.075	Oxamyl (Vydate)*	ppb	50	26	20
Alpha-hexachlorocyclohexane#	ppb	n/a	n/a	0.01	Oxyfluorfen#	ppb	n/a	n/a	0.05
Anatoxin-a#	ppb	n/a	n/a	0.03	o-Xylene	ppb	n/a	n/a	0.5
Antimony*	ppb	6	1	6	o-toluidine#	ppb	n/a	n/a	0.007
Asbestos	mfL	7	7	0.2	Paraquat	ppb	n/a	n/a	20
Atrazine (AATREX)*	ppb	1	0.15	0.5	Pentachlorophenol (PCP)*	ppb	1	0.3	0.2
Baygon	ppb	n/a	n/a	n/a	Perfluorohexanesulfonic acid (PFHxS)	ppt			NL = 3.0
Bentazon (BASAGRAN)*	ppb	18	200	2	Perfluorooctanoic acid (PFOA)	ppt			NL = 5.1
Benzene*	ppb	1	0.15	0.5	Perfluorooctane sulfonic acid (PFOS)	ppt			NL = 6.5
Benzo(a)pyrene*	ppt	200	7	100	Picloram*	ppb	500	166	1
Beryllium*	ppb	4	1	1	p-Isopropyltoluene	ppb	n/a	n/a	n/a
Bromobenzene	ppb	n/a	n/a	0.5	Phosphate, Ortho (as PO4)	ppm	n/a	n/a	n/a
Bromochloromethane	ppb	n/a	n/a	0.5	Polychlorinated Biphenyls (PCBs)	ppt	500	90	n/a
Bromomethane (Methyl Bromide)	ppb	n/a	n/a	0.5	Profenofos#	ppb	n/a	n/a	0.3
Butylated Hydroxyanisole#	ppb	n/a	n/a	0.03	Propachlor	ppb	n/a	n/a	0.5
Cadmium*	ppb	5	0.04	1	Quinoline#	ppb	n/a	n/a	0.02
Carbaryl (Sevin)	ppb	n/a	n/a	5	Radium 226	pCi/L	n/a	0.05	1
Carbofuran (FURADAN)*	ppb	18	0.7	5	sec-Butylbenzene	ppb	n/a	n/a	0.5
Carbon Tetrachloride*	ppt	500	100	500	Selenium	ppb	50	30	5
Chloramben	ppb	n/a	n/a	n/a	Silver+	ppb	100	n/a	10
Chlordane*	ppt	100	30	100	Simazine (PRINCEP)*	ppb	4	4	1
Chloroethane	ppb	n/a	n/a	0.5	Styrene*	ppb	100	0.5	0.5
Chloromethane	ppb	n/a	n/a	0.5	Tebuconazole#	ppb	n/a	n/a	0.2
Chromium [Total]	ppb	50	n/a	10	tert-Amyl Methyl Ether (TAME)	ppb	n/a	n/a	3
Chlorpyrifos#	ppb	n/a	n/a	0.03	tert-Butyl Alcohol (TBA)	ppb	n/a	n/a	2
Copper (Cu)^	ppm	1.3	0.3	0.05	tert-Butylbenzene	ppb	n/a	n/a	0.5
cis-1,2-Dichloroethylene (c-1,2-DCE)*	ppb	6	13	0.5	Tetrachloroethylene (PCE)*	ppb	5	0.06	0.5
cis-1,3-dichloropropene	ppb	n/a	n/a	0.5	Thallium*	ppb	2	0.1	1

**Water Quality Chemistry Services  
 2022 NON-DETECTED PARAMETERS IN THE DRINKING WATER**

PARAMETER	UNITS	MCL	PHG (MCLG)	DDW DLR	PARAMETER	UNITS	MCL	PHG (MCLG)	DDW DLR
Cryptosporidium (untreated water)	Cysts/L	n/a	n/a	n/a	Thiobencarb (BOLERO)*+	ppb	70	42	1
Cylindrospermopsin#	ppb	n/a	n/a	0.09	Toluene*	ppb	150	150	0.5
Cyanide*	ppb	150	150	100.0	Total Microcystins#	ppb	n/a	n/a	0.3
Dalapon	ppb	200	790	10	Total Permethrin(cis&trans)#	ppb	n/a	n/a	0.04
Di(2-ethylhexyl) Adipate*	ppb	400	200	5	Toxaphene	ppb	3	0.03	1
Di(2-ethylhexyl)phthalate (DEHP)*	ppb	4	12	3	Total Suspended Solids	ppm	n/a	n/a	n/a
1,2-Dibromo-3-chloropropane (DBCP)*	ppt	200	3	10	trans-1,2-Dichloroethylene (t-1,2-DCE)*	ppb	10	50	0.5
Dibromomethane	ppb	n/a	n/a	0.5	trans-1,3-Dichloropropene	ppb	n/a	n/a	0.5
Dicamba (BANVEL)	ppb	n/a	n/a	1.5	Tribufos#	ppb	n/a	n/a	0.07
Dichlorodifluoromethane (Freon 12)	ppb	n/a	n/a	0.5	Trichloroethylene (TCE)*	ppb	5	1.7	0.5
Dichloromethane (Methylene Chloride)	ppb	5	4	0.5	Trichlorofluoromethane (FREON 11)*	ppb	150	1300	5
Dichlorprop	ppb	n/a	n/a	n/a	Trichlorotrifluoroethane (FREON 113)*	ppb	1200	4000	10
Dieldrin	ppb	n/a	n/a	0.02	Vanadium	ppb	n/a	n/a	3
Diisopropyl Ether (DIPE)	ppb	n/a	n/a	3	Vinyl Chloride (VC)*	ppt	500	50	500
Dimethipin#	ppb	n/a	n/a	0.2	Zinc+	ppm	5	n/a	0.05
Dinoseb (DNBP)*	ppb	7	14	2					

Note: All of the contaminants listed in this table were analyzed for, but not detected, in the drinking water in 2022

(\*) Primary or (+) Secondary Contaminants

(^) Regulatory Action Level

(#) Unregulated Contaminant Monitoring Rule (UCMR4) analytes are not currently regulated and have not been assigned a DLR.

The UCMR MRL (Minimum Reporting Level) is listed in the DLR column. UCMR4 samples were collected in 2018.