

# POOLS, SPAS & FOUNTAINS

## **Storm Water Regulations**

It is illegal to discharge swimming pool, spa, fountain, reflective pool, and pond water; filter backwash; or their construction materials such as plaster, gunite, and cement into the Municipal Separate Storm Sewer System (MS4) (San Diego Municipal Code §43.0304 and §43.035(e)(3)). Penalties associated with these violations can be up to \$10,000 per day per incident.

### <u> Pools, Spas & Fountains</u>

Draining a swimming pool, spa or fountain can be a source of pollutants into the storm drain system. Algae, chlorine, salt, and other chemicals in the water can be hazardous to San Diego residents and toxic to our environment and must be removed before draining to the storm drain system. Never let pool construction materials enter the storm drain system.

## **Draining Requirements**

When draining a swimming pool, spa or fountain, follow these rules:

- Monitor the chlorine levels over a period of 3 to 5 days to reach an acceptable pH level of 7-8.
- Pool, spa or fountain water <u>cannot</u> contain:
  - Chlorine or saline (salt)
  - Chemicals to counteract the chlorine
  - Hydrogen peroxide based products
  - Algae (green color to water) or algaecides
  - Debris, vegetation or other suspended solids
- Water must be at ambient temperature.
- Water should be used to gradually irrigate lawns or landscape over several days provided the water can be absorbed by the soil without runoff or erosion. Check for yard drains to avoid discharge to the storm drain system.
- Water may also be drained into the sanitary sewer system through an onsite sink or lateral cleanout. Contact the Public Utilities Department at (858) 654-4100 for approval.









SAN DIEGO

STORM WATER FACT SHEET A CHANGE FOR THE BETTER BEGINS WITH YOU

# **Restrictions for Draining**

Draining a swimming pool, spa or fountain directly to the storm drain system is only permissible if the surface flow path is cleared of trash, debris and sediment; the water is dechlorinated; has a pH in the 7-8 range; is within ambient temperature; has no algae, algaecide or suspended solids; and is not saline. The path to the storm drain inlet must be swept, even if it is a few blocks away. You must be able to prove this has been completed.

Discharge of saline swimming pool water to City storm drains, curb gutters, or any other part of the City's storm drain system is prohibited unless the saline water is prepared as above and can be discharged through a pipe or concrete channel directly to a naturally saline water body (e.g., the Pacific Ocean).

## **Cleaning a Pool or Spa**

Back washing or acid cleaning is <u>not</u> allowed to enter the storm drain system. Clean pool filters over a lawn, planter box, vegetated hillside or an area that will absorb the discharge. Collect materials on filter cloth, and throw the filter cloth away. All filter backwash fluids must have a pH of 7-8 before discharging into the sanitary sewer via a legal sewer connection. See manufacturer's specifications for information on how to check pH.

## **Pool Construction Preparation**

All construction materials must be contained and disposed of properly (see *Construction Waste* fact sheet for more information). These materials include, but are not limited to, plaster, cement, sediment, and other pool construction materials. These materials are not allowed to enter the storm drain system.

### **Keep Pollutants Out of Storm Drains**

Many people think that when water flows into a storm drain it is treated, but the storm drain system and the sanitary sewer system are not connected. Everything that enters storm drains flows <u>untreated</u> directly into our creeks, rivers, bays, beaches and ultimately the ocean. Storm water often contains pollutants, including chemicals, trash, and automobile fluids, all of which pollute our beaches and harm fish and wildlife.

Whether at home or work, you can help reduce pollution and improve water quality by using the above Best Management Practices (BMP's) as part of your daily clean up and maintenance routine.













