



**NOTES:**

1. ALL PIPES, NIPPLES, AND FITTINGS AFTER MALE ADAPTER SHALL BE RED BRASS.
2. VALVE AND CONTROLLER IDENTIFICATION SHALL BE LABELED OUTSIDE ON THE VALVE BOX LID AND TAGGED INSIDE THE BOX ON THE VALVE.
3. TEFLON TAPE SHALL BE USED ON THREADED CONNECTIONS.
4. BRASS COUPLING, GLOBE VALVE AND FITTINGS SHALL BE THE SAME SIZE AS THE LARGEST VALVE ON THE MANIFOLD. USE REDUCERS AS REQUIRED WHEN DOWNLINE VALVES ARE SMALLER.

REVISION	BY	APPROVED	DATE
ORIGINAL*	RH	J. NAGELVOORT	01/12
REDRAFTED	CD	J. NAGELVOORT	09/18
UPDATED	AJ	J. NAGELVOORT	09/21

CITY OF SAN DIEGO – STANDARD DRAWING

**REMOTE CONTROL VALVE  
MANIFOLD ASSEMBLY WITH BRASS PIPE**

RECOMMENDED BY THE CITY  
OF SAN DIEGO STANDARDS COMMITTEE

*Alaine L. James* 09/30/21  
COORDINATOR R.C.E. 81047 DATE

DRAWING NUMBER **SDI-126**