


SECTION

NOTES:

1. ENCASE PIPE TO THE NEAREST FLEXIBLE JOINT.
2. FOR TRENCH RESURFACING IN IMPROVED STREETS, SEE SDG-107 AND SDG-108.
3. CONCRETE ENCASEMENT SHALL BE USED FOR RIGID PIPE ONLY.
4. 6" METAL TAPE SHALL BE INSTALLED ABOVE PIPE 4" BELOW PAVEMENT SECTION, PER SDM-105.
5. (*) INDICATES MINIMUM RELATIVE COMPACTION.

LEGEND ON PLANS



REVISION	BY	APPROVED	DATE
ORIGINAL	RA	A. OSKOUJ	1206
UPDATED	KA	J. NAGELVOORT	01/12
UPDATED	CD	J. NAGELVOORT	09/17

CITY OF SAN DIEGO - STANDARD DRAWING

CONCRETE ENCASEMENT

RECOMMENDED BY THE CITY OF SAN DIEGO
STANDARDS COMMITTEE

C. Pungco 9/6/2017
COORDINATOR R.C.E. 56523 DATE

DRAWING NUMBER **SDS-112**