



NOTES:

1. REFER TO AGENCY SPECIFICATIONS WHERE APPLICABLE.
2. CLEANOUTS TO BE INSTALLED AT THE END OF MAINS WHERE INDICATED ON THE PLANS.
3. CLEANOUT PIPE TO BE SAME SIZE AND MATERIAL AS SEWER (MAX DIA. 8").
4. BACKFILL TO TOP OF 45° BEND WITH 3/8" OR 1/2" CRUSHED ROCK.
5. LATERIALS SHALL BE SELECTED FROM THE AGENCY'S APPROVED MATERIALS LIST.
6. INSTALL WARNING/ IDENTIFICATION TAPE PER SDM-105.
7. CLEANOUT COVERS IN THE ROADWAY OR OTHER AREAS SUBJECT TO VEHICULAR LOADING SHALL BE CAST IRON. CLEANOUT COVERS IN ALL OTHER AREAS NOT SUBJECT TO VEHICULAR LOADING SHALL BE CONCRETE.
8. FOR CLEANOUT INSTALLED OUTSIDE OF TRAVEL WAY, USE SAND SE 30.

—○—
LEGEND ON PLANS

REVISION	BY	APPROVED	DATE			
ORIGINAL	BB	J. NAGELVOORT	05/15	CITY OF SAN DIEGO – STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE	
UPDATED	BB	J. NAGELVOORT	07/15		SEWER MAIN CLEANOUT	<i>CA Dungee</i> 9/22/20 COORDINATOR R.C.E. 56523 DATE
UPDATED	JN	J. NAGELVOORT	11/17			
REDRAFTED	CD	J. NAGELVOORT	09/18			
UPDATED	TP	J. NAGELVOORT	09/20			
				DRAWING NUMBER	SDS-121	