



NOTES:

1. REFER TO AGENCY SPECIFICATIONS WHERE APPLICABLE.
2. CLEANOUTS TO BE INSTALLED AT THE END OF MAINS WHERE INDICATED ON THE PLANS.
3. CLEANOUT PIPE TO BE SAME SIZE AND MATERIAL AS SEWER (MAX DIA. 8")
4. BACKFILL TO TOP OF 45° BEND WITH 3/8" OR 1/2" CRUSHED ROCK.
5. MATERIALS SHALL BE SELECTED FROM THE AGENCY'S APPROVED MATERIALS LIST.
6. INSTALL WARNING/IDENTIFICATION TAPE PER **SDM-105**.



LEGEND ON PLANS

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO – STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE	
ORIGINAL	BB	J. NAGELVOORT	05/15		SEWER MAIN CLEANOUT	<i>Chungee</i> 11/20/2017 COORDINATOR R.C.E. 56523 DATE
UPDATED	BB	J. NAGELVOORT	07/15			
UPDATED	JN	J. NAGELVOORT	11/17			
					DRAWING NUMBER SDS-121	