



NOTES:

1. ANY BACKFLOW PROTECTING A SERVICE USED FOR HUMAN CONSUMPTION SHALL BE LEAD FREE
2. ALL METER/BACKFLOW INSTALLATIONS SHALL BE APPROVED BY PUBLIC UTILITIES DEPARTMENT
3. SERVICE CONNECTIONS ON WATER MAIN SHALL BE 30" APART
4. INSTALL A CASING INCASED IN CONCRETE WHEN THE DISTANCE BETWEEN THE METER BOX AND THE RISER TO THE BFD EXCEEDS 18". NO MANIFOLD OR CONNECTIONS OF ANY KIND PERMITTED IN THIS AREA.
5. **SEE SDW-155** FOR ADDITIONAL BACKFLOW INFORMATION

2-2" METER AND 2" BACKFLOW INSTALLATION WITH SERVICE AND METER BOXES

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING		RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL	KA	J. NAGELVOORT	03/13	2" METER, BACKFLOW AND METER BOXES		 COORDINATOR R.C.E. 81047 DATE 9/12/22
REDRAFTED	CD	J. NAGELVOORT	09/18			
UPDATED	RC	R. AMEN	09/22			
				DRAWING NUMBER		SDW-114