

- 1. NO DIPS OR LOW SPOTS WILL BE ALLOWED IN INSTALLATION.
- 2. INSTALL ENCLOSURE PER SDW-117.
- 3. INSTALL WARNING/IDENTIFICATION TAPE PER SDM-105.
- 4. AIR & VACUUM VALVE INSTALLED FOR THE USE OF POTABLE/ RECYCLED WATER SHALL BE SHOWN ON THE PLANS.
- 5. ON STEEL MAINS USE WELD ON COUPLINGS, ON DUCTILE IRON MAINS USE DUCTILE IRON SERVICE SADDLES.
- 6. FOR STEEL AND DI MAINS, INSTALL DIELECTRIC UNION AFTER CORPORATION STOP.
- 7. INSTALL WAX TAPE FROM MAIN TO 3" PAST DIELECTRIC UNION, INCLUDING SADDLE.

ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION		
1	1" OR 2" PVC SCH 80 CLOSE NIPPLE & 2-SCH 80 STREET ELLS & INSECT SCREEN.	10	1" OR 2" BRONZE COMPRESSION COUPLING COPPER TO COPPER (IF REQUIRED).		
2	APPROVED VALVE ENCLOSURE PER SDW-117.	11	1" OR 2" COMP BALL VALVE THREADED ON BOTH SIDES. 1" OR 2" 90 DEGREE BRONZE FIPT X COMP ELL. 1" OR 2" BRONZE MIPT X MIPT CORPORATION STOP. SIZE X 1" OR 2" SERVICE SADDLE. WATER MAIN. VALVE STEM EXTENSION. 1" OR 2" COPPER DIELECTRIC UNION. REQUIRED FOR STEEL OR DI MAINS.		
3	1" OR 2" AUTOMATIC COMBINATION AIR RELEASE & AIR/ VACUUM VALVE.	(12)			
4	8", OD STEEL GATE CASING WELL WITH CAP PER SDW-153.	13			
5	COLD JOINT STRIP.	(14)			
6	3'-6" X 3'-6" X 6" THICK CONCRETE SLAB. CONCRETE SHALL BE 520-C-2500.	15)			
(7)	1" OR 2" X 1/2" BLACK FOAM SLEEVE.	16			
8	BRASS TUBING.	17			
9	90 DEGREE BRASS ELL (NO SWEAT, NO GLUED JOINTS ALLOWED).	18)	COPPER TUBING.		
REVISION BY APPROVED DATE				RECOMMENDED BY THE CITY	

REVISION	BY	APPROVED	DATE
ORIGINAL	KA	J. NAGELVOORT	01/12
UPDATED	вв	J. NAGELVOORT	09/14
UPDATED	AR	J. NAGELVOORT	11/15
UPDATED	НМ	J. NAGELVOORT	02/16
UPDATED	TP	J. NAGELVOORT	08/18

CITY OF SAN DIEGO - STANDARD DRAWING

1" OR 2" AUTOMATIC COMBINATION AIR RELEASE & AIR/ VACUUM VALVE INSTALLATIONS RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE



DRAWING SDW-159