



NOTE:

1. THE ALUMINUM HOUSING AND LID SHALL BE 6063 ALUMINUM WITH A THICKNESS OF 0.065 INCH (16 GAUGE).
2. SAMPLING STATIONS MUST MAINTAIN A 4'-0" MIN CLEARANCE (PLUS CURB) IF INSTALLED ON A SIDEWALK OR A 4'-0" MIN CLEARANCE IF INSTALLED ON A WALKWAY.
3. THE METER BOX SHALL BE COMPLETELY FLUSHED WITH THE SIDEWALK SURFACE WHEN INSTALLED ON WALKWAYS OR SIDEWALKS.

LEGEND ON PLANS



ITEM NO	SIZE AND DESCRIPTION	ITEM NO	SIZE AND DESCRIPTION
1	ALUMINUM LID	4	1/2" X 3/8" STAINLESS STEEL BALL VALVE
2	ALUMINUM HOUSING - 6" DIAMETER (O. D.)	5	STAINLESS STEEL GOOSENECK
3	PAD LOCK HASP		

REVISION	BY	APPROVED	DATE	CITY OF SAN DIEGO - STANDARD DRAWING	RECOMMENDED BY THE CITY OF SAN DIEGO STANDARDS COMMITTEE
ORIGINAL	TP	J. NAGELVOORT	06/01/20		
DRAWING NUMBER				SDW-163	